

DCS MS-016

MAR 3 1982

Docket No. 50-339


Mr. R. H. Leasburg  
Vice President - Nuclear Operations  
Virginia Electric and Power Company  
Post Office Box 26666  
Richmond, Virginia 23261

Dear Mr. Leasburg:

Distribution:

- Docket File
- NRC PDR
- L PDR
- ORB #3 Rdg
- D. Eisenhut
- P. Kreutzer
- L. Engle
- OELD
- SECY
- OI&E (2)
- T. Barnhart
- L. Schneider
- D. Brinkman

- ACRS (10)
- OPA
- R. Diggs
- NSIC
- ASLAB



This confirms our telephone authorization given today, March 3, 1982, for a change to the Technical Specifications for the North Anna Power Station, Unit No. 2 as requested in your telecopy dated March 2, 1982. Facility Operating License No. NPF-7 is amended on this date, March 3, 1982 by making the following technical specification change.

Add footnote to Specification 3.4.1.2 on page 3/4 4-2 to read:

The requirement to have one coolant loop in operation is exempted during the performance of the boron mixing tests as stipulated in License Conditions 2.C(15)(f) and 2.C(20)(b).

Copies of the license amendment, our evaluation and Federal Register Notice for this technical specification change will be sent to you when completed.

Sincerely,

Original signed by:

Thomas M. Novak, Assistant Director  
for Operating Reactors  
Division of Licensing

CP  
3

cc: See next page

8203160043 820303  
PDR ADDCK 05000339  
P PDR

OFFICE	DL:ORB#3	DL:ORB#3	DL:ORB#3	DL:OR			
SURNAME	PKreutzer	LEngle:ms	RA Clark	TNovak			
DATE	3/3/82	3/3/82	3/3/82	3/3/82			



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

MAR 3 1982

Docket No. 50-339

Mr. R. H. Leasburg  
Vice President - Nuclear Operations  
Virginia Electric and Power Company  
Post Office Box 26666  
Richmond, Virginia 23261

Dear Mr. Leasburg:

This confirms our telephone authorization given today, March 3, 1982, for a change to the Technical Specifications for the North Anna Power Station, Unit No. 2 as requested in your teletype dated March 2, 1982. Facility Operating License No. NPF-7 is amended on this date, March 3, 1982 by making the following technical specification change.

Add footnote to Specification 3.4.1.2 on page 3/4 4-2 to read:

The requirement to have one coolant loop in operation is exempted during the performance of the boron mixing tests as stipulated in License Conditions 2.C(15)(f) and 2.C(20)(b).

Copies of the license amendment, our evaluation and Federal Register Notice for this technical specification change will be sent to you when completed.

Sincerely,

A handwritten signature in dark ink, appearing to read "Tom Novak".

Thomas M. Novak, Assistant Director  
for Operating Reactors  
Division of Licensing

cc: See next page

Virginia Electric and Power Company

cc:

Richard M. Foster, Esquire  
Musick, Williamson, Schwartz,  
Leavenworth & Cope, P.C.  
P. O. Box 4579  
Boulder, Colorado 80306

Michael W. Maupin, Esquire  
Hunton, Williams, Gay and Gibson  
P. O. Box 1535  
Richmond, Virginia 23212

Alderman Library  
Manuscripts Department  
University of Virginia  
Charlottesville, Virginia 22901

Mr. Edward Kube  
Board of Supervisors  
Louisa County Courthouse  
P. O. Box 27  
Louisa, Virginia 23093

Ellyn R. Weiss, Esquire  
Sheldon, Harman, Roisman and Weiss  
1725 I Street, N.W. Suite 506  
Washington, D. C. 20006

Mr. W. R. Cartwright, Station Manager  
P. O. Box 402  
Mineral, Virginia 23117

Mr. Anthony Gambardella  
Office of the Attorney General  
11 South 12th Street - Room 308  
Richmond, Virginia 23219

Resident Inspector/North Anna  
c/o U.S.N.R.C.  
Route 2, Box 78A  
Mineral, Virginia 23117

Mr. J. H. Ferguson  
Executive Vice President - Power  
Virginia Electric and Power Company  
Post Office Box 26666  
Richmond, Virginia 23261

Mr. James Torson  
501 Leroy  
Socorro, New Mexico 87891

Mrs. Margaret Dietrich  
Route 2, Box 568  
Gordonsville, Virginia 22042

Mr. James C. Dunstance  
State Corporation Commission  
Commonwealth of Virginia  
Blandon Building  
Richmond, Virginia 23209

Mrs. June Allen  
North Anna Environmental Coalition  
8720 Lockmoor Circle  
Wichita, Kansas 67207

U.S. Environmental Protection Agency  
Region III Office  
ATTN: Regional Radiation Representative  
Curtis Building  
6th and Walnut Streets  
Philadelphia, Pennsylvania 19106

Mr. Paul W. Purdom  
Environmental Studies Institute  
Drexel University  
32nd and Chestnut Streets  
Philadelphia, Pennsylvania 19104

Atomic Safety and Licensing  
Appeal Board Panel  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Regional Administrator  
Nuclear Regulatory Commission, Region II  
Office of Executive Director for Operations  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303.