

MAY 12 1976

Distribution

Docket File ✓

Local PDR

NRC PDR

TIC

LWR #3

OELD

Docket No. 50-335

IE (3)

NDube w/o encl

BJones w/encl (4)

RCDeYoung

JMcGough w/encl

Chebron W/oI only

DFoster w/oI

JSaltzman, OAI

w/o Tech Specs

HRood

WMiller w/o Tech Specs

ODLynch, EP

EGoulbourne (2)

MDuncan, EP

ACRS (16)

DMuller

BScharf (15) fr orig

LWR Tech Coordinators

KGoller

DSkovholt

DSilver

BCC: JRBuchanan, ORNL

TBAbernathy, DTIE

ASLAB

ASLAP

Florida Power and Light Company

ATTN: Dr. Robert E. Uhrig, Vice President

Nuclear and General Engineering

P. O. Box 3100

Miami, Florida 33101

Gentlemen:

This confirms our telephoned authorization given March 5, 1976 for a change in Technical Specifications for St. Lucie Plant Unit 1 as requested by your submittal dated March 11, 1976. Facility Operating License No. DPR-67 is amended effective March 5, 1976 by making the following technical specification change:

"The requirements of Technical Specification 4.9.7 relating to the operability of the Spent Fuel Storage Pool crane interlocks which limit crane loads to a maximum of 2000 pounds are suspended from applicability until midnight March 19, 1976, subject to the following provisions:

1. The Spent Fuel Storage Pool shall not contain water, and
2. The crane loads shall be limited to either a single fuel assembly or a single Control Element Assembly."

Copies of the license amendment, Federal Register Notice, and Safety Evaluation for this technical specification change are enclosed.

Sincerely,

Original Signed by

Olan D. Parr, Chief
Light Water Reactors
Branch No. 3

Division of Project Management

Enclosures:

1. Amendment No. 1 to Facility Operating License No. DPR-67
2. Federal Register Notice
3. Safety Evaluation

OFFICE >	2. Federal Register Notice	DPM:LWR #3	DPM:LWR #3	OELD	DPM:LWR #3
SURNAME >	3. Safety Evaluation	EGoulbourne:	HRood	Retchen	ODParr
DATE >	cc: See page 2	3/12/76 mjt	3/12/76	5/11/76	5/11/76

Florida Power and Light
Company

- 2 -

cc: Jack R. Newman, Esq.
Lowenstein, Newman, Reis & Axelrad
1025 Connecticut Avenue, N. W.
Washington, D. C. 20036

Norman A. Coll, Esq.
McCarthy, Steel, Hector & Davis
14th Floor, First National Bank Building
Miami, Florida 33131

Mr. John L. McQuigg
P. O. Box 1408
Stuart, Florida 33494

Mr. Ed Maroney
Bureau of Intergovernmental Relations
725 South Bronough Street
Tallahassee, Florida 32304

Mr. Weldon B. Lewis
County Administrator
St. Lucie County
P. O. Box 700
Ft. Pierce, Florida 33450

Mr. Shepard N. Moore, Region IV
Environmental Protection Agency
1421 Peachtree Street, N. E., Suite 300
Atlanta, Georgia 30390

Mr. Bruce Blanchard
Environmental Projects Review
Department of the Interior
Room 5321
18th and C Streets, N. W.
Washington, D. C. 20240

Chief-TIRB (2)
Technology Assessment Division
Office of Radiation Programs
EPA, Room 647A, East Tower
Waterside Mall
401 M Street, S. W.
Washington, D. C. 20460

OFFICE ➤						
SURNAME ➤						
DATE ➤						



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FLORIDA POWER AND LIGHT COMPANY

DOCKET NO. 50-335

ST. LUCIE PLANT UNIT NO. 1

FACILITY OPERATING LICENSE

Amendment No. 1
License No. DPR-67

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power and Light Company (the licensee) dated March 11, 1976, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations; and
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.
2. Accordingly, the license is amended by a change to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C(2) of Facility License No. DPR-67 is hereby amended to read as follows:

"(2) Technical Specifications

The Technical Specifications contained in Appendices A and E, as revised, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications, as revised by issued changes thereto through Amendment No. 1.

3. This license amendment is effective as of March 5, 1976.

FOR THE NUCLEAR REGULATORY COMMISSION:

Olan D. Parr
Olan D. Parr, Chief
Light Water Reactors
Branch No. 3
Division of Project Management

Attachment:
Amendment No. 1 to the
Technical Specifications

Date of Issuance **MAY 12 1976**

AMENDMENT NO. 1 TO

FACILITY OPERATING LICENSE

The requirements of Technical Specification 4.9.7 relating to the operability of the Spent Fuel Storage Pool crane interlocks which limit crane loads to a maximum of 2000 pounds are suspended from applicability until midnight March 19, 1976, subject to the following provisions:

1. The Spent Fuel Storage Pool shall not contain water, and:
2. The crane loads shall be limited to either a single fuel assembly or a single Control Element Assembly.

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-335

FLORIDA POWER AND LIGHT COMPANY

ST. LUCIE PLANT UNIT NO. 1

NOTICE OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE

Notice is hereby given that the U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 1 to the Facility Operating License No. DPR-67 issued to Florida Power and Light Company. The amendment revises the Technical Specifications for operation of the St. Lucie Plant Unit No. 1 located in St. Lucie County, Florida, and is effective as of March 5, 1976.

The amendment change suspended for two weeks until March 19, 1976, the Technical Specification which requires the operability of the Spent Fuel Storage Pool crane interlocks, in order to allow fuel loading to be continued while the interlocks were being repaired.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter 1. These findings are set forth in the license amendment. Prior public notice of this amendment was not required because the amendment did not involve a significant hazards consideration.

For further details with respect to this action, see (1) the application for amendment dated March 11, 1976, (2) Amendment No. 1 to license

No. DPR-67, and (3) the Commission's related safety evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C., and at the Indian River College Library, 3209 Virginia Avenue, Ft. Pierce, Florida 33450. A copy of items (2) and (3) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Project Management.

Dated at Bethesda, Maryland this **12** day of May 1976.

FOR THE NUCLEAR REGULATORY COMMISSION

Original Signed by

Olan D. Parr, Chief
Light Water Reactors
Branch No. 3
Division of Project Management

SAFETY EVALUATION BY OFFICE OF NUCLEAR REACTOR REGULATION

SUPPORTING AMENDMENT NO. 1 TO DPR-67

FLORIDA POWER AND LIGHT COMPANY

ST. LUCIE PLANT UNIT NO. 1

DOCKET NO. 59-335

Introduction

By telephone conversation on March 5, 1976, the licensee requested a change to Technical Specification 4.9.7 for St. Lucie 1. This specification requires that the spent fuel storage pool crane interlocks which prevent crane travel with loads in excess of 2000 pounds over fuel assemblies shall be demonstrated operable within 7 days prior to crane use and at least once per 7 days thereafter during crane operation.

Discussion

The licensee stated that during the currently-in-progress initial loadings of new fuel into the reactor vessel, the crane interlock was malfunctioning; such that the interlock would on occasion prevent the 1750 pound fuel assemblies from being lifted. Conversely, when tested, the interlock would on occasion permit loads in excess of 2000 pounds to be lifted. This indicates an intermittent condition.

The licensee proposed that the requirement for the interlock be temporarily suspended to allow fuel loading to continue. The licensee proposed to administratively limit the crane from lifting more than 2000 pounds by limiting the objects lifted to a fuel element assembly or a control element assembly, neither of which weighs in excess of 2000 pounds, and to maintain a dry spent fuel storage pool.

The purpose of the spent fuel storage pool crane is to move fuel assemblies and other objects that are already in the spent fuel storage pool. The interlock on the crane is set at 2000 pounds to permit lifting of a fuel element assembly and its control element assembly. The restriction on movement of loads in excess of 2000 pounds over irradiated fuel assemblies ensures that no more than the contents of one fuel assembly will be ruptured in the event of a fuel handling accident. This assumption is consistent with the activity release assumed in the accident analysis.

The new fuel stored in the spent fuel storage pool has not been irradiated and contains no fission products. Therefore, a dropped fuel element assembly or control element assembly would not produce consequences that would exceed the activity release assumed in the accident analysis. Moreover, the spent fuel storage racks are designed to preclude a critical configuration of fresh fuel element assemblies and water, even in the event that a fuel element assembly is dropped onto the racks. The removal of the water from the spent fuel storage pool is a further precaution against accidental criticality.

Thus, the consequences of a fuel handling accident are not increased with the water removed from the pool (required as a limiting condition in that circumstances) and with an administrative limit that permits the spent fuel storage pool crane to lift only a single fuel element assembly or a single control element assembly.

Based on the above analysis, we have reasonable assurance that the health and safety of the public will not be endangered by operation in the manner proposed by the licensee. In addition, the safety margins will not be reduced by the proposed operation. Therefore, we find that the licensee's proposed operation is acceptable provided that the licensee meet the following requirements: (1) the crane loads are limited to either a single fuel assembly or a single control element assembly, and (2) the water is removed from the spent fuel storage pool. The suspension of the portion of Technical Specification 4.9.7 pertaining to the crane interlocks will terminate at midnight March 19, 1976.

Conclusions

We have reviewed the information verbally provided by the applicant and we have concluded, based on the considerations discussed above, that (1) because the changes do not involve a significant increase in the probability or consequences of accidents previously considered and do not involve a significant decrease in a safety margin, the changes do not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-335

FLORIDA POWER AND LIGHT COMPANY

ST. LUCIE PLANT UNIT NO. 1

NOTICE OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE

Notice is hereby given that the U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 1 to the Facility Operating License No. DPR-67 issued to Florida Power and Light Company. The amendment revises the Technical Specifications for operation of the St. Lucie Plant Unit No. 1 located in St. Lucie County, Florida, and is effective as of March 5, 1976.

The amendment change suspended for two weeks until March 19, 1976, the Technical Specification which requires the operability of the Spent Fuel Storage Pool crane interlocks, in order to allow fuel loading to be continued while the interlocks were being repaired.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter 1. These findings are set forth in the license amendment. Prior public notice of this amendment was not required because the amendment did not involve a significant hazards consideration.

For further details with respect to this action, see (1) the application for amendment dated March 11, 1976, (2) Amendment No. 1 to license

No. DPR-67, and (3) the Commission's related safety evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C., and at the Indian River College Library, 3209 Virginia Avenue, Ft. Pierce, Florida 33450. A copy of items (2) and (3) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Project Management.

Dated at Bethesda, Maryland this **12** day of May 1976.

FOR THE NUCLEAR REGULATORY COMMISSION

Original Signed by

Olan D. Parr, Chief
Light Water Reactors
Branch No. 3
Division of Project Management

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-335

FLORIDA POWER AND LIGHT COMPANY

ST. LUCIE PLANT UNIT NO. 1

NOTICE OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE

Notice is hereby given that the U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 1 to the Facility Operating License No. DPR-67 issued to Florida Power and Light Company. The amendment revises the Technical Specifications for operation of the St. Lucie Plant Unit No. 1 located in St. Lucie County, Florida, and is effective as of March 5, 1976.

The amendment change suspended for two weeks until March 19, 1976, the Technical Specification which requires the operability of the Spent Fuel Storage Pool crane interlocks, in order to allow fuel loading to be continued while the interlocks were being repaired.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter 1. These findings are set forth in the license amendment. Prior public notice of this amendment was not required because the amendment did not involve a significant hazards consideration.

For further details with respect to this action, see (1) the application for amendment dated March 11, 1976, (2) Amendment No. 1 to license

No. DPR-67, and (3) the Commission's related safety evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C., and at the Indian River College Library, 3209 Virginia Avenue, Ft. Pierce, Florida 33450. A copy of items (2) and (3) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Project Management.

Dated at Bethesda, Maryland this **12** day of May 1976.

FOR THE NUCLEAR REGULATORY COMMISSION

Olan D. Parr
Olan D. Parr, Chief
Light Water Reactors
Branch No. 3
Division of Project Management

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-335

FLORIDA POWER AND LIGHT COMPANY

ST. LUCIE PLANT UNIT NO. 1

NOTICE OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE

Notice is hereby given that the U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 1 to the Facility Operating License No. DPR-67 issued to Florida Power and Light Company. The amendment revises the Technical Specifications for operation of the St. Lucie Plant Unit No. 1 located in St. Lucie County, Florida, and is effective as of March 5, 1976.

The amendment change suspended for two weeks until March 19, 1976, the Technical Specification which requires the operability of the Spent Fuel Storage Pool crane interlocks, in order to allow fuel loading to be continued while the interlocks were being repaired.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter 1. These findings are set forth in the license amendment. Prior public notice of this amendment was not required because the amendment did not involve a significant hazards consideration.

For further details with respect to this action, see (1) the application for amendment dated March 11, 1976, (2) Amendment No. 1 to license

No. DPR-67, and (3) the Commission's related safety evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C., and at the Indian River College Library, 3209 Virginia Avenue, Ft. Pierce, Florida 33450. A copy of items (2) and (3) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Project Management.

Dated at Bethesda, Maryland this **12** day of May 1976.

FOR THE NUCLEAR REGULATORY COMMISSION

Olan D. Parr
Olan D. Parr, Chief
Light Water Reactors
Branch No. 3
Division of Project Management

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-335

FLORIDA POWER AND LIGHT COMPANY

ST. LUCIE PLANT UNIT NO. 1

NOTICE OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE

Notice is hereby given that the U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 1 to the Facility Operating License No. DPR-67 issued to Florida Power and Light Company. The amendment revises the Technical Specifications for operation of the St. Lucie Plant Unit No. 1 located in St. Lucie County, Florida, and is effective as of March 5, 1976.

The amendment change suspended for two weeks until March 19, 1976, the Technical Specification which requires the operability of the Spent Fuel Storage Pool crane interlocks, in order to allow fuel loading to be continued while the interlocks were being repaired.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter 1. These findings are set forth in the license amendment. Prior public notice of this amendment was not required because the amendment did not involve a significant hazards consideration.

For further details with respect to this action, see (1) the application for amendment dated March 11, 1976, (2) Amendment No. 1 to license

No. DPR-67, and (3) the Commission's related safety evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C., and at the Indian River College Library, 3209 Virginia Avenue, Ft. Pierce, Florida 33450. A copy of items (2) and (3) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Project Management.

Dated at Bethesda, Maryland this **12** day of May 1976.

FOR THE NUCLEAR REGULATORY COMMISSION

Olan D. Parr
Olan D. Parr, Chief
Light Water Reactors
Branch No. 3
Division of Project Management

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-335

FLORIDA POWER AND LIGHT COMPANY

ST. LUCIE PLANT UNIT NO. 1

NOTICE OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE

Notice is hereby given that the U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 1 to the Facility Operating License No. DPR-67 issued to Florida Power and Light Company. The amendment revises the Technical Specifications for operation of the St. Lucie Plant Unit No. 1 located in St. Lucie County, Florida, and is effective as of March 5, 1976.

The amendment change suspended for two weeks until March 19, 1976, the Technical Specification which requires the operability of the Spent Fuel Storage Pool crane interlocks, in order to allow fuel loading to be continued while the interlocks ^{were} ~~are~~ being repaired.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter 1. These findings are set forth in the license amendment. Prior public notice of this amendment ^{was} ~~is~~ not required because the amendment ^{did} ~~does~~ not involve a significant hazards consideration.

For further details with respect to this action, see (1) the appli-

ication for amendment dated March 11, 1976, (2) Amendment No. 1 to license

SURNAME >

DATE >

No. DPR-67, and (3) the Commission's related safety evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C., and at the Indian River College Library, 3209 Virginia Avenue, Ft. Pierce, Florida 33450. A copy of items (2) and (3) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Project Management.

Dated at Bethesda, Maryland this _____ day of May 1976.

FOR THE NUCLEAR REGULATORY COMMISSION

Original Signed by
 O. D. Parr
 Olan D. Parr, Chief
 Light Water Reactors
 Branch No. 3
 Division of Project Management

OFFICE >	DPM:LWR	DPM:LWR #3	<i>Boeld</i> BOELD	DPM:LWR #3		
SURNAME >	EIGodbourne	HRood	<i>Ketchen</i> KETCHEN	ODParr		
DATE >	5/5/76	5/ /76	5/10/76	5/11/76		

No. DPR-67, and (3) the Commission's related safety evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, NW, Washington, D. C., and at the Indian River Collage Library, 3209 Virginia Avenue, Ft. Pierce, Florida 33450. A copy of items (2) and (3) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Project Management.

Dated at Bethesda, Maryland this day of April 1976.

FOR THE NUCLEAR REGULATORY COMMISSION

Olan D. Parr, Chief
 Light Water Reactors
 Branch No. 3
 Division of Project Management

OFFICE >	DPM:LWR #3	DPM:LWR #3	OELD	DPM:LWR #3		
SURNAME >	EIG ⁰⁴⁸ bourne: MJF	HRood		ODParr		
DATE >	4/15/76	4/ /75	4/ /76	4/ /76		

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-335

FLORIDA POWER AND LIGHT COMPANY

ST. LUCIE PLANT UNIT NO. 1

NOTICE OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE

Notice is hereby given that the U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 1 to Facility Operating License No. DPR-67 issued to Florida Power and Light Company. The amendment revises the Technical Specifications for operating of the St. Lucie Plant Unit No. 1 located in St. Lucie County, Florida, and is effective as of March 5, 1976.

The amendment change suspends for two weeks the Technical Specification which requires the operability of the Spent Fuel Storage Pool crane interlocks, in order to allow fuel loading to be continued while the interlocks are being repaired.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings required by the Act and the Commission's rules and regulations in 10 CFR Chapter I. These findings are set forth in the license amendment. Prior public notice of this amendment is not required because the amendment does not involve a significant hazards consideration.

For further details with respect to this action, see (1) the application for amendment dated March 11, 1976, (2) Amendment No. 1 to license

OF

SURNAME >

DATE >

No. DPR-67, and (3) the Commission's related safety evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, NW, Washington, D. C., and at the Indian River College Library, 3209 Virginia Avenue, Ft. Pierce, Florida 33450. A copy of items (2) and (3) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Project Management.

Dated at Bethesda, Maryland this day of March 1976.

FOR THE NUCLEAR REGULATORY COMMISSION:

Olan D. Parr, Chief
Light Water Reactors
Branch No. 3
Division of Project Management

OFFICE ▶	DPM:LWR #3	DPM:LWR #3	OELD	DPM:LWR #3		
SURNAME ▶	EGo <i>116</i> Bourne:mj	f Hrood		ODParr		
DATE ▶	3/9/76	3/ /76	3/ /76	3/ /76		

FLORIDA POWER AND LIGHT COMPANY

DOCKET NO. 50-335

ST. LUCIE PLANT UNIT NO. 1

FACILITY OPERATING LICENSE

Amendment No. 1
License No. DPR-67

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power and Light Company (the licensee) dated March 11, 1976, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations; and
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.
2. Accordingly, the license is amended by a change to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C(2) of Facility License No. DPR-67 is hereby amended to read as follows:

OFFICE ▶						
SURNAME ▶						
DATE ▶						

"(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications, as revised by issued changes thereto through Amendment No. 1.

3. This license amendment is effective as of March 5, 1976.

FOR THE NUCLEAR REGULATORY COMMISSION:

Original Signed by,
O. D. Parr

Olan D. Parr, Chief
Light Water Reactors
Branch No. 3
Division of Project Management

Attachment:
Amendment No. 1 to the
Technical Specifications

Date of Issuance MAY 12 1976

OFFICE	DPM:LWR #3	DPM:LWR #3	BOELD	DPM:LWR #3	
SURNAME	EGoullbourne: mjf	HRood	Ketcher	ODParr	
DATE	3/9/76	3/10/76	5/10/76	5/11/76	

AMENDMENT NO. 1 TO
FACILITY OPERATING LICENSE

The requirements of Technical Specification 4.9.7 relating to the operability of the Spent Fuel Storage Pool crane interlocks which limit crane loads to a maximum of 2000 pounds are suspended from applicability until midnight March 19, 1976, subject to the following provisions:

1. The Spent Fuel Storage Pool shall not contain water, and
2. The crane loads shall be limited to either a single fuel assembly or a single Control Element Assembly.

OFFICE >						
SURNAME >						
DATE >						