

DISTRIBUTION:

SEP 19 1980

Docket No. 50-335

✓ Docket File  
 NRC PDR  
 L PDR  
 TERA  
 NSIC  
 ORB#3 Rdg  
 NRR Rdg  
 HRDenton  
 EGCASE  
 RHartfield, MPA  
 GBennington, MPA  
 DEisenhut  
 RPurple  
 TNovak  
 RTedesco  
 GLainas  
 JRoe  
 RAClark  
 Project Manager  
 PKreutzer  
 SNorris  
 OELD  
 I&E (3)  
 BJones (4)  
 ACRS (16)  
 CMiles, OPA  
 SECY  
 RDiggs  
 JHeltemes  
 Gray File + 4

Dr. Robert E. Uhrig  
 Vice President  
 Florida Power & Light Company  
 Advanced Systems & Technology  
 P. O. Box 529100  
 Miami, Florida 33152

Dear Dr. Uhrig:

The Order for Modification of License dated August 29, 1980,  
 contained incorrect references. We have accordingly revised the  
 Order. In view of this revision, the date for which a hearing may  
 be requested is also accordingly revised.

Sincerely,

Original signed by:

*R Purple*

Darrell G. Eisenhut, Director  
 Division of Licensing

Enclosure:  
 Revised Order

cc: See next page

8010080352

G

CP  
3

GO

OFFICE	ORB#3:DL	ORB#3:DL	ORB#3:DL	OELD	D:DL
SURNAME	PKreutzer/JL	CHatson	RAClark	MWilliams	DEisenhut
DATE	9/17/80	9/17/80	9/17/80	9/17/80	9/19/80



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555  
September 19, 1980


Docket No. 50-335

Dr. Robert E. Uhrig  
Vice President  
Florida Power & Light Company  
Advanced Systems & Technology  
P. O. Box 529100  
Miami, Florida 33152

Dear Dr. Uhrig:

The Order for Modification of License dated August 29, 1980, contained incorrect references. We have accordingly revised the Order. In view of this revision, the date for which a hearing may be requested is also accordingly revised.

Sincerely,

  
for Darrell G. Eisenhut, Director  
Division of Licensing

Enclosure:  
Revised Order

cc: See next page

Florida Power & Light Company

cc:

Robert Lowenstein, Esquire  
Lowenstein, Newman, Reis & Axelrad  
1025 Connecticut Avenue, N.W.  
Washington, D.C. 20036

Norman A. Coll, Esquire  
McCarthy, Steel, Hector & Davis  
14th Floor, First National Bank Building  
Miami, Florida 33131

Indian River Junior College Library  
3209 Virginia Avenue  
Fort Pierce, Florida 33450

Administrator  
Department of Environmental Regulation  
Power Plant Siting Section  
State of Florida  
2600 Blair Stone Road  
Tallahassee, Florida 32301

Mr. Weldon B. Lewis  
County Administrator  
St. Lucie County  
2300 Virginia Avenue, Room 104  
Fort Pierce, Florida 33450

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection Agency  
Crystal Mall #2  
Arlington, Virginia 20460

U.S. Environmental Protection Agency  
Region IV Office  
ATTN: EIS COORDINATOR  
345 Courtland Street, N.E.  
Atlanta, Georgia 30308

Mr. Charles B. Brinkman  
Manager - Washington Nuclear Operations  
C-E Power Systems  
Combustion Engineering, Inc.  
4853 Cordell Avenue, Suite A-1  
Bethesda, Maryland 20014

Mr. Jack Shreve  
Office of the Public Counsel  
Room 4, Holland Bldg.  
Tallahassee, Florida 32304

Bureau of Intergovernmental  
Relations  
660 Apalachee Parkway  
Tallahassee, Florida 32304

Resident Inspector/St. Lucie  
Nuclear Power Station  
c/o U.S.N.R.C  
P.O. Box 400  
Jensen Beach, Florida 33457

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of

FLORIDA POWER AND LIGHT COMPANY  
(St. Lucie Nuclear Power Plant,  
Unit No. 1)

)  
)  
)  
)  
)

Docket No. 50-335

REVISED ORDER FOR MODIFICATION OF LICENSE

I.

Florida Power and Light Company (licensee) is the holder of License No. DPR-67, which authorizes the operation of the St. Lucie Nuclear Power Plant Unit 1 at steady state reactor power levels not in excess of 2560 megawatts thermal (rated power). The facility consists of a Pressurized Water Reactor located at the licensee's site in St. Lucie County, Florida.

II.

On November 4, 1977, the Union of Concerned Scientists (UCS) filed with the Commission a "Petition for Emergency and Remedial Relief." The petition sought action in two areas: fire protection for electrical cables, and environmental qualification of electrical components. By Memorandum and Order dated April 13, 1978 (7 NRC 400), the Commission denied certain aspects of the petition and, with respect to other aspects, ordered the NRC staff to take several related actions. UCS filed a Petition for Reconsideration on May 2, 1978. By Memorandum and Order, dated May 23, 1980, the Commission reaffirmed its April 13, 1978 decision

8010080359

regarding the possible shutdown of operating reactors. However, the Commission's May 23, 1980 decision directed licensees and the NRC staff to undertake certain actions.

With respect to environmental qualification of safety-related electrical equipment, the Commission determined that the provisions of the two staff documents - the Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class 1E Electrical Equipment in Operating Reactors" (DOR Guidelines) and NUREG-0588, "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment," December 1979 "form the requirements which licensees and applicants must meet in order to satisfy those aspects of 10 CFR Part 50, Appendix A General Design Criterion (GDC-4), which relate to environmental qualification of safety-related electrical equipment." The Commission directed, for replacement parts in operating plants, "unless there are sound reasons to the contrary, the 1974 standard in NUREG-0588 will apply." The Commission also directed the staff to complete its review of the information sought from licensees by Bulletin 79-01B<sup>1</sup> and to complete its review of environmental qualification of safety-related electrical equipment in all operating plants, including the publication of Safety Evaluation Reports, by February 1, 1981. The Commission

---

<sup>1</sup> Bulletin 79-01B was not sent to licensees for plants under review as part of the staff's Systematic Evaluation Program. The information sought by Bulletin 79-01B was requested from these licensees by a series of letters and meetings during the months of February and March, 1980.

imposed a deadline that, "by no later than June 30, 1982 all safety-related electrical equipment in all operating plants shall be qualified to the DOR Guidelines or NUREG-0588." The Commission requested the staff to, "keep the Commission and the public apprised of any further findings of incomplete environmental qualification of safety-related electrical equipment, along with corrective actions taken or planned," and requested the staff to provide bi-monthly progress reports to the Commission.

The Commission further directed the staff to add certain documentation requirements to each license after the specific requirements were approved by the Commission. The Commission also pointed out that the various deadlines imposed in its Order, "do not excuse a licensee from the obligation to modify or replace inadequate equipment promptly."

### III.

The information developed during this proceeding emphasizes the importance of adequate documentation, the prompt completion of the review of environmental qualification of safety-related electrical equipment, and the prompt completion of any plant modification needed to assure conformance with the DOR Guidelines or NUREG-0588. A significant aspect of this review is the timely submittal of environmental qualification information by the operating plant licensees to enable the staff to complete its review in accordance with the Commission's Order. The staff has a program presently underway to reevaluate, using the DOR Guidelines and NUREG-0588, the qualifications of safety-related electrical equipment exposed

to environments that may exist following postulated accidents. These accidents are Loss of Coolant Accident and Main Steam Line Break inside containment, and High Energy Line Breaks inside and outside containment.

In this connection the licensee was requested by I&E Bulletin 79-01B dated January 14, 1980 to provide a detailed review of the environmental qualification of Class 1E electrical equipment. This review was to include all equipment required to function under postulated accident conditions, both inside and outside the primary containment, and recognize all conditions specified in the bulletin. Evidence of qualification together with methods and justification, was requested.

Clarification was provided by supplemental information, briefings, and in some cases, meetings with the licensee. Timely completion of the staff's review of environmental qualification of electrical equipment and timely completion of needed modifications by the licensee is required to provide continuing reasonable assurance of public health and safety. Such completion is dependent on the prompt receipt of a complete response by the licensee to the staff's requests for information. However, the licensee's response, to date, is incomplete.

Therefore, I have concluded that the public health, safety, and interest require that a firm schedule for the timely submission of all the information previously requested by the staff should be established by Order effective immediately.

IV.

Accordingly, pursuant to the Atomic Energy Act of 1954, as amended, and the Commission's regulations in 10 CFR Parts 2 and 50, IT IS ORDERED THAT EFFECTIVE IMMEDIATELY Facility Operating License No. DPR-67 is hereby amended to add the following provisions:

"Information which fully and completely responds to the staff's request as specified in I&E Bulletin 79-01B, shall be submitted to the Director, Region II, Office of Inspection and Enforcement, by the licensee not later than November 1, 1980."

An earlier response is encouraged to facilitate staff review and issuance of the safety evaluation report. The licensee or any person whose interest may be affected by this Order may request a hearing within 20 days of the date of publication of this Revised Order in the Federal Register.


Any request for a hearing will not stay the effective date of this Order. Any request for a hearing shall be addressed to the Director, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, D. C. 20555. A copy of the request should also be sent to the Executive Legal Director, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, and to Robert Lowenstein, Esq., Lowenstein, Newman, Reis and Alexrad, 1025 Connecticut Avenue, N. W., Washington, D. C., attorney for the licensee.

If a hearing is held concerning this Order, the issue to be considered at the hearing shall be whether the license should be modified to require submission of information as set forth in Section IV. of the Order.



Operating of the facility on terms consistent with this Order is not stayed by the pendency of any proceedings on the Order. This Order revises, in its entirety, the Order issued August 29, 1980, and published in the Federal Register September 11, 1980 (45 FR 60081).

FOR THE NUCLEAR REGULATORY COMMISSION

  
Darrell G. Eisenhut, Director  
Division of Licensing

Effective Date: September 19, 1980  
Bethesda, Maryland