Docket No. 50-335

JAN 1 9 1981

<u>.</u>

Dr. Robert E. Uhrig Vice President Advanced Systems & Technology Florida Power & Light Company P. O. Box 529100 Miami, Florida 33152



Dear Dr. Uhrig:

The Commission has issued the enclosed Amendment No. 37 to Facility Operating License No. DPR-67 for the St. Lucie Plant, Unit 1. This amendment consists of changes to the Technical Specifications in response to your applications dated January 22, and October 31, 1980.

The amendment changes the Technical Specifications to add requirements associated with actions you have taken to satisfy the NRC's "Category A" Lessons Learned Recommendations.

Since your October 31, 1980 proposal included the subject matter of your January 22, 1980 proposal, that is, adding the Safety Injection Actuation Signal as an initiating event for the Containment Isolation Signal, both proposed changes are addressed by this amendment.

Certain modifications to your proposed changes were necessary to meet our criteria. These modifications have been discussed with and agreed to by your staff. We find that your proposals, as modified, are consistent with the NRC's July 2, 1980 guidance letter and are therefore acceptable.

We have evaluated the potential for environmental impact of plant operation in accordance with the enclosed amendment, and have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level, and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and pursuant to 10 CFR § 51.5(d)(4) that an environmental impact statement, negative declaration or environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

	8102()60313 F)				÷ .
OFFICE							T
SURNAME		-				•	• • • • • • • • • • • • • • • • • • • •
DATE							•
NRC FORM	 318 (10/80) NRCM	0240	OFFICIAL	RECORD C	OPY	.1	

Dr. Robert E. Uhrig Florida Power & Light Company

Since the amendment applies only to NRC requested additions resulting from TMI-2 "Category A" Lessons Learned Implementation, it does not involve significant new safety information of a type not considered by a previous Commission safety review of the facility. It does not involve a significant increase in the probability or consequences of an accident, does not involve a significant decrease in a safety margin, and therefore does not involve a significant hazards consideration. We have also concluded that there is reasonable assurance that the health and safety of the public will not be endangered by this action.

-2-

A copy of the Notice of Issuance is also enclosed.

Sincerely,



Robert A. Clark, Chief Operating Reactors Branch # Division of Licensing

Enclesures:

1. Amendment No. 37

2. Notice

cc w/enclosures: See next page





UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555 January 19, 1981 DISTRIBUTION:

Docket File PMKreutzer ORB#3 Rdg

Docket No. 50-335

Docketing and Service Section Office of the Secretary of the Commission

SUBJECT: ST. LUCIE PLANT, UNIT 1

Two signed originals of the <u>Federal Register</u> Notice identified below are enclosed for your transmittal to the Office of the Federal Register for publication. Additional conformed copies (12) of the Notice are enclosed for your use.

- □ Notice of Receipt of Application for Construction Permit(s) and Operating License(s).
- □ Notice of Receipt of Partial Application for Construction Permit(s) and Facility License(s): Time for Submission of Views on Antitrust Matters.
- □ Notice of Availability of Applicant's Environmental Report.
- □ Notice of Proposed Issuance of Amendment to Facility Operating License.
- Notice of Receipt of Application for Facility License(s); Notice of Availability of Applicant's Environmental Report; and Notice of Consideration of Issuance of Facility License(s) and Notice of Opportunity for Hearing.
- □ Notice of Availability of NRC Draft/Final Environmental Statement.
- □ Notice of Limited Work Authorization.
- □ Notice of Availability of Safety Evaluation Report.
- □ Notice of Issuance of Construction Permit(s).
- □ Notice of Issuance of Facility Operating License(s) or Amendment(s).
- Amendment No. 37

Referenced documents have been provided PDR

Division of Licensing, ORB#3 Office of Nuclear Reactor Regulation

As Stated OFFICE DL:ORB#3 PMKreutzer/J DATE 1/2z/81

NRC FORM 102 (1-76)

Enclosure:



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555 January 19, 1981

Docket No. 50-335

Dr. Robert E. Uhrig Vice President Advanced Systems & Technology Florida Power & Light Company P. O. Box 529100 Miami, Florida 33152

Dear Dr. Uhrig:

The Commission has issued the enclosed Amendment No. 37 to Facility Operating License No. DPR-67 for the St. Lucie Plant, Unit 1. This amendment consists of changes to the Technical Specifications in response to your applications dated January 22, and October 31, 1980.

The amendment changes the Technical Specifications to add requirements associated with actions you have taken to satisfy the NRC's "Category A" Lessons Learned Recommendations.

Since your October 31, 1980 proposal included the subject matter of your January 22, 1980 proposal, that is, adding the Safety Injection Actuation Signal as an initiating event for the Containment Isolation Signal, both proposed changes are addressed by this amendment.

Certain modifications to your proposed changes were necessary to meet our criteria. These modifications have been discussed with and agreed to by your staff. We find that your proposals, as modified, are consistent with the NRC's July 2, 1980 guidance letter and are therefore acceptable.

We have evaluated the potential for environmental impact of plant operation in accordance with the enclosed amendment, and have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level, and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and pursuant to 10 CFR § 51.5(d)(4) that an environmental impact statement, negative declaration or environmental impact appraisal need not be prepared in connection with the issuance of this amendment. Dr. Robert E. Uhrig Florida Power & Light Company

Since the amendment applies only to NRC requested additions resulting from TMI-2 "Category A" Lessons Learned Implementation, it does not involve significant new safety information of a type not considered by a previous Commission safety review of the facility. It does not involve a significant increase in the probability or consequences of an accident, does not involve a significant decrease in a safety margin, and therefore does not involve a significant hazards consideration. We have also concluded that there is reasonable assurance that the health and safety of the public will not be endangered by this action.

-2-

A copy of the Notice of Issuance is also enclosed.

Sincerely,

Robert A. Clark, Chief Operating Reactors Branch #3 Division of Licensing

Enclosures:

- 1. Amendment No. 37
- 2. Notice

cc w/enclosures: See next page

Florida Power & Light Company

CC:

Robert Lowenstein, Esquire Lowenstein, Newman, Reis & Axelrad 1025 Connecticut Avenue, N.W. Washington, D.C. 20036

Norman A. Coll, Esquire McCarthy, Steel, Hector & Davis 14th Floor, First National Bank Building Miami, Florida 33131

Indian River Junior College Library 3209 Virginia Avenue Fort Pierce, Florida 33450

Administrator Department of Environmental Regulation Power Plant Siting Section State of Florida 2500 Blair Stone Road Tallahassee, Florida 32301

Mr. Weldon B. Lewis County Administrator St. Lucie County 2300 Virginia Avenue, Room 104 Fort Pierce, Florida 33450

Director, Criteria and Standards Division Office of Radiation Programs (ANR-460) U.S. Environmental Protection Agency Washington, D.C. 20460

U.S. Environmental Protection Agency Region IV Office ATTN: EIS COORDINATOR 345 Courtland Street, N.E. Atlanta, Georgia 30308

Mr. Charles B. Brinkman Manager - Washington Nuclear Operations C-E Power Systems Combustion Engineering, Inc. 4853 Cordell Avenue, Suite A-1 Bethesda, Maryland 20014 Mr. Jack Shreve Office of the Public Counsel Room 4, Holland Bldg. Tallahassee, Florida 32304

cc w/enclosure(s) and incoming dtd: 1/22/80, 10/31/80 Bureau of Intergovernmental Relations 660 Apalachee Parkway Tallahassee, Florida 32304

Resident Inspector/St. Lucie Nuclear Power Station c/o U.S.N.R.C P.O. Box 400 Jensen Beach, Florida 33457



810206032

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

FLORIDA POWER & LIGHT COMPANY

DOCKET NO. 50-335

ST. LUCIE PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 37 License No. DPR-67

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The applications for amendment by Florida Power and Light Company (the licensee) dated January 22 and October 31, 1980, comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the applications the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-67 is hereby amended to read as follows:
 - (2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 37, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

ł

Robert A. Clark, Chief Operating Reactors Branch #3 Division of Licensing

Attachment: Changes to the Technical Specifications

Date of Issuance: January 19, 1981

ATTACHMENT TO LICENSE AMENDMENT NO. 37

FACILITY OPERATING LICENSE NO. DPR-67

DOCKET NO. 50-335

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Pages I۷ X۷

3/4 3-10 3/4 3-11 3/4 3-13 3/4 3-14 3/4 3-15 3/4 3-16 3/4 3-17 3/4 3-18 3/4 3-19 3/4 3-41 (new) 3/4 3-42 (new) 3/4 3-43 (new) 3/4 3-44 (new) 3/4 4-4 3/4 4-58 (new) 3/4 7-5 B 3/4 3-1 B 3/4 3-3 B 3/4 4-2 B 3/4 4-14 (new) B 3/4 6-3 6-4 6-5 (new) 6-21 6-22

INDEX

SECTION		<u>P/</u>	AGE
3/4.0 AP	PLICABILITY	3/4	0-1
8/4.1 RE	ACTIVITY CONTROL SYSTEMS		
3/4.1.1	BORATION CONTROL	3/4	1-1
	Shutdown Margin - $T_{avg} > 200^{\circ}F$	3/4	1-1
	Shutdown Margin - $T_{2VG} < 200^{\circ}F$	3/4	1-3
	Boron Dilution	3/4	1-
	Moderator Temperature Coefficient	3/4]-:
	Minimum Temperature for Criticality	3/4	1-
3/4.1.2	BORATION SYSTEMS	3/4	1-
	Flow Paths - Shutdown	3/4	1-
	Flow Paths - Operating	3/4	1-
	Charging Pump - Shutdown	3/4	1-
	Charging Pumps - Operating	3/4	1-
	Boric Acid Pumps - Shutdown	3/4	1-
	Boric Acid Pumps - Operating	3/4	1-
	Borated Water Sources - Shutdown	3/4	1-
	Borated Water Sources - Operating	3/4	1-
3/4.1.3	MOVABLE CONTROL ASSEMBLIES	3/4	1-
	Full Length CEA Position	3/4	1-
	Position Indicator Channels	3/4	1-
	CEA Drop Time	3/4	1-
	Shutdown CEA Insertion Limit	3/4	1-
	Regulating CEA Insertion Limits	3/4	1-

III

Amendment No.27

INDEX

¥,

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

SECTION

PAGE

3/4.2 POWER DISTRIBUTION LIMITS

3/4.2.1	LINEAR HEAT RATE	3/4	2-1
3/4.2.2	TOTAL PLANAR RADIAL PEAKING FACTOR - F	3/4	2-6
3/4.2.3	TOTAL INTEGRATED RADIAL PEAKING FACTOR - F.	3/4	2-9
3/4.2.4	AZIMUTHAL POWER TILT Ta	3/4	2-11
3/4.2.5	DNB PARAMETERS	3/4	2-13
3/4.3 IN	ISTRUMENTATION		
3/4.3.1	REACTOR PROTECTIVE INSTRUMENTATION	3/4	3-1
3/4.3.2	ENGINEERED SAFETY FEATURE ACTUATION SYSTEM		
	INSTRUMENTATION	3/4	3-9
3/4.3.3	MONITORING INSTRUMENTATION	3/4	3-21

-			
	Radiation Monitoring	3/4	3-21
	Incore Detectors	3/4	3-25
	Seismic Instrumentation	3/4	3-27
	Meteorological Instrumentation	3/4	3-30
	Remote Shutdown Instrumentation	3/4	3-33
	Chlorine Detection Systems	3/4	3-36
	Fire Detection Instrumentation	3/4	3-37
	Accident Monitoring Instrumentation	3/4	3-41

3/4.4 REACTOR COOLANT SYSTEM

3/4.4.1	REACTOR COOLANT	LOOPS	3/4	4-1
3/4.4.2	SAFETY VALVES -	SHUTDOWN	3/4	4-2
3/4.4.3	SAFETY VALVES -	OPERATING	3/4	4-3

ST. LUCIE - UNIT 1

I۷

INDEX

ADMINISTRATIVE CONTROLS	<u></u>
<u>SECTION</u>	AGE
6.6 REPORTABLE OCCURRENCE ACTION	-12
6.7 SAFETY LIMIT VIOLATION 6-	-13
6.8 PROCEDURES	-13
6.9 REPORTING REQUIREMENTS 6.9.1 ROUTINE REPORTS AND REPORTABLE OCCURRENCES	-14 -18 -19 -20 -20
6.13 ENVIRONMENTAL QUALIFICATION 6- 6.14 SYSTEMS INTEGRITY 6-	-21 -21
6.15 IODINE MONITORING 6-	-21
6.16 BACKUP METHOD FOR DETERMINING SUBCOOLING MARGIN 6-	-22

Amendment No.23, 37

INSTRUMENTATION

3/4.3.2 ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.2.1 The Engineered Safety Feature Actuation System (ESFAS) instrumentation channels and bypasses shown in Table 3.3-3 shall be OPERABLE with their trip setpoints set consistent with the values shown in the Trip Setpoint column of Table 3.3-4 and with RESPONSE TIMES as shown in Table 3.3-5.

APPLICABILITY: As shown in Table 3.3-3.

ACTION:

- a. With an ESFAS instrumentation channel trip setpoint less conservative than the value shown in the Allowable Values column of Table 3.3-4, declare the channel inoperable and apply the applicable ACTION requirement of Table 3.3-3 until the channel is restored to OPERABLE status with the trip setpoint adjusted consistent with the Trip Setpoint value.
- b. With an ESFAS instrumentation channel inoperable, take the ACTION shown in Table 3.3-3.

SURVEILLANCE REQUIREMENTS

4.3.2.1.1 Each ESFAS instrumentation channel shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL CALIBRATION and CHANNEL FUNCTIONAL TEST operations during the modes and at the frequencies shown in Table 4.3-2.

4.3.2.1.2 The logic for the bypasses shall be demonstrated OPERABLE during the at power CHANNEL FUNCTIONAL TEST of channels affected by bypass operation. The total bypass function shall be demonstrated OPERABLE at least once per 18 months during CHANNEL CALIBRATION testing of each channel affected by bypass operation.

4.3.2.1.3 The ENGINEERED SAFETY FEATURES RESPONSE TIME of each ESFAS function shall be demonstrated to be within the limit at least once per 18 months. Each test shall include at least one channel per function such that all channels are tested at least once every N times 18 months where N is the total number of redundant channels in a specific ESF function as shown in the "Total No. of Channels" Column of Table 3.3-3.

ST. LUCIE - UNIT 1

3/4 3-9

TABLE 3.3-3

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>F(</u>	UNCTIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
1	. SAFETY INJECTION (SIAS) a. Manual (Trip Buttons)	2	1	2	1, 2, 3, 4	8
	b. Containment Pressure - High	4	2	3	1, 2, 3	9#
	c. Pressurizer Pressure - Low	4	2	3	1, 2, 3(a)	9#
2.	. CONTAINMENT SPRAY (CSAS) a. Manual (Trip Buttons)	2	1	2	1, 2, 3, 4	8
	b. Containment Pressure High - High	- 4	2(b)	3	1, 2, 3	10
3.	. CONTAINMENT ISOLATION (CIS) a. Manual (Trip Buttons)	2	1	2	1, 2, 3, 4	8
	b. Containment Pressure - High	4	2	3	1, 2, 3	 9#
	c. Containment Radiation - High	- 4	2	3	1, 2, 3, 4	9#
	d. SIAS		(See Functior	nal Unit 1 above)	
4.	MAIN STEAM LINE ISOLATION (MSIS)					
	a. Manual (Trip Buttons)	2/steam generator	l/steam generator	2/operating steam generator	1, 2, 3, 4	8
	b. Steam Generator Pressure - Low	4/steam generator	2/steam generator	3/steam generator	1, 2, 3(c)	9#

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FUN	CTIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
5.	CONTAINMENT SUMP RECIRCULATION (RAS) a. Manual RAS (Trip	_				
	Buttons)	2	1	2	1, 2, 3, 4	8
	b. Refueling Water Tank - Low	4	2	3	1, 2, 3	9#
6.	LOSS OF POWER 4.16 kv Emergency Bus Undervoltage (Under- voltage relays)	1/Bus	1/Bus	1/Bus	1, 2, 3	9#
7.	AUXILIARY FEEDWATER AUTOMATIC START Steam Generator (SG)					
	Level Instruments	4/SG	2/SG ^{1/}	2/SG	1,2,3	11

 $\underline{1}$ / 2/SG for either steam generator will start one train of AFW.

_

Amendment No. 15, 37

TABLE 3.3-3 (Continued)

TABLE NOTATION

- (a) Trip function may be bypassed in this MODE when pressurizer pressure is < 1725 psia; bypass shall be automatically removed when pressurizer pressure is \geq 1725 psia.
- (b) An SIAS signal is first necessary to enable CSAS logic.
- (c) Trip function may be bypassed in this MODE below 585 psig; bypass shall be automatically removed at or above 585 psig.
- # The provisions of Specification 3.0.4 are not applicable.

ACTION STATEMENTS

- ACTION 8 With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- ACTION 9 With the number of OPERABLE channels one less than the Total Number of Channels, operation may proceed provided the following conditions are satisfied:
 - a. The inoperable channel is placed in either the bypassed or tripped condition within 1 hour. For the purposes of testing and maintenance, the inoperable channel may be bypassed for up to 48 hours from time of initial loss of OPERABILITY; however, the inoperable channel shall then be either restored to OPERABLE status or placed in the tripped condition.
 - b. Within one hour, all functional units receiving an input from the inoperable channel are also placed in the same condition (either bypassed or tripped, as applicable) as that required by a. above for the inoperable channel.
 - c. The Minimum Channels OPERABLE requirement is met; however, one additional channel may be bypassed for up to 48 hours while performing tests and maintenance on that channel provided the other inoperable channel is placed in the tripped condition.

ST. LUCIE - UNIT 1

Amendment No. 15

TABLE 3.3-3 (Continued)

TABLE NOTATION

- ACTION 10 With the number of OPERABLE channels one less than the Total Number of Channels, operation may proceed provided the inoperable channel is placed in the bypassed condition and the Minimum Channels OPERABLE requirement is demonstrated within 1 hour; one additional channel may be bypassed for up to 2 hours for surveillance testing per Sepcification 4.3.2.1.1.
- ACTION 11 Instrument operability requirements are contained in the Reactor Protection System requirements for Reactor Trip on Steam Generator Level. If an Automatic Start channel is inoperable, operation may continue provided that the affected pump is verified to be OPERABLE per Specification 4.7.1.2.a within 8 hours and at least once per 7 days thereafter; and the Automatic Start channel shall be restored to OPERABLE status within 30 days or the reactor shall be in at least HOT SHUTDOWN within the next 12 hours.

TABLE 3.3-4

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP VALUES

FUNC	TIONAL UNIT	TRIP SETPOINT	ALLOWABLE VALUES
1.	SAFETY INJECTION (SIAS) a. Manual (Trip Buttons)	Not Applicable	Not Applicable
	b. Containment Pressure - High	<pre>< 5 psig</pre>	<u><</u> 5 psig
	c. Pressurizer Pressure - Low	<u>></u> 1600 psia	<u>></u> 1600 psia
2.	CONTAINMENT SPRAY (CSAS) a. Manual (Trip Buttons)	Not Applicable	Not Applicable
	b. Containment Pressure High-High	<u><</u> 10 psig	<u><</u> 10 psig
3.	CONTAINMENT ISOLATION (CIS) a. Manual (Trip Buttons)	Not Applicable	Not Applicable
	b. Containment Pressure - High	<u><</u> 5 psig	<u><</u> 5 psig
	c. Containment Radiation - High	<u><</u> 10 R/hr	<u><</u> 10 R/hr
	d. SIAS	(See FUNCTIONAL UNIT 1	above)
4.	MAIN STEAM LINE ISOLATION (MSIS) a. Manual (Trip Buttons)	Not Applicable	Not Applicable
	b. Steam Generator Pressure - Low	<u>></u> 485 psig	> 485 psig
5.	CONTAINMENT SUMP RECIRCULATION (RAS) a. Manual RAS (Trip Buttons)	Not Applicable	Not Applicable
	b. Refueling Water Tank - Low	48 inches above tank bottom	48 inches ab ov e tank bottom

4.

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP VALUES

FUN	CTIONAL UNIT	TRIP VALUE	VALUES
6.	LOSS OF POWER		
	4.16 kv Emergency Bus Undervoltage (Undervoltage relays)	<u>></u> 3307 volts	<u>></u> 3307 volts
7.	AUXILIARY FEEDWATER	<u>></u> 30% level	<u>></u> 30% level

ST. LUCIE - UNIT 1

TABLE 3.3-5

ENGINEERED SAFETY FEATURES RESPONSE TIMES

INIT	IATIN	NG SIGNAL AND FUNCTION	RESPONSE TIME IN SECONDS
1.	Manu	Jal	
	a.	SIAS	
		Safety Injection (ECCS)	Not Applicable
		Containment Fan Coolers	Not Applicable
		Feedwater Isolation	Not Applicable
		Containment Isolation	Not Applicable
	Ь.	CSAS	
		Containment Spray	Not Applicable
	c.	CIS	
		Containment Isolation	Not Applicable
		Shield Building Ventilation System	Not Applicable
	d.	RAS	
		Containment Sump Recirculation	Not Applicable
•	e.	MSIS	
		Main Steam Isolation Feedwater Isolation	Not Applicable Not Applicable
2.	Pres	ssurizer Pressure-Low	
	a.	Safety Injection (ECCS)	<u><</u> 30.0*/19.5**
	b.	Containment Isolation	< 30.5*/20.5**
	c.	Containment Fan Coolers	<u><</u> 30.0*/17.0**
	d.	Feedwater Isolation	<u><</u> 60.0

_

 ST. LUCIE - UNIT 1
 3/4 3-16
 Amendment No. 77, 37

TABLE 3.3-5 (Continued),

ENGINEERED SAFETY FEATURES RESPONSE TIMES

INIT	IATIN	IG SIGNAL AND FUNCTION	RESPONSE TIME IN SECONDS
3.	Cont	ainment Pressure-High	
2	a.	Safety Injection (ECCS)	<u><</u> 30.0*/19.5**
	b.	Containment Isolation	<u><</u> 30.5*/20.5**
	c.	Shield Building Ventilation System	<u><</u> 30.0*/14.0**
	d.	Containment Fan Coolers	<u><</u> 30.0*/17.0**
	e.	Feedwater Isolation	<u><</u> 60.0
4.	Cont	tainment PressureHigh-High	
	a.	Containment Spray	<u><</u> 30.0*/18.5**
5.	Cont	tainment Radiation-High	
	a.	Containment Isolation	<u><</u> 30.5*/20.5**
	b.	Shield Building Ventilation System	<u><</u> 30.0*/14.0**
6.	Stea	am Generator Pressure-Low	
	a.	Main Steam Isolation	<u><</u> 6.9
	b.	Feedwater Isolation	<u><</u> 60.0
7.	Ref	ueling Water Storage Tank-Low	
	a.	Containment Sump Recirculation	<u><</u> 91.5
8.	Ste	am Generator Level	
	a.	Auxiliary Feedwater	<u>></u> 180, ≤ 600

TABLE NOTATION

^{*}Diesel generator starting and sequence loading delays included. ^{**}Diesel generator starting and sequence loading delays <u>not</u> included. Offsite power available.

Amendment No. 17: 37

TABLE 4.3-2

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

FUN	CTIONAL UNIT	CHANNEL CHECK	CHANNEL CALIBRATION	CHANNEL FUNCTIONAL TEST	MODES IN WHICH SURVEILLANCE REQUIRED
1.	SAFETY INJECTION (SIAS) a. Manual (Trip Buttons) b. Containment Pressure - High c. Pressurizer Pressure - Low d. Automatic Actuation Logic	N.A. S S N.A.	N.A. R R N.A.	R M M(1)	N.A. 1, 2, 3 1, 2, 3 1, 2, 3
2.	CONTAINMENT SPRAY (CSAS) a. Manual (Trip Buttons) b. Containment Pressure High - High c, Automatic Actuation Logic	N.A. S N.A.	N.A. R N.A.	R M M(1)	N.A. 1, 2, 3 1, 2, 3
3.	CONTAINMENT ISOLATION (CIS) a. Manual (Trip Buttons) b. Containment Pressure - High c. Containment Radiation - Hig d. Automatic Actuation Logic e. SIAS	N.A. S N.A. N.A.	N.A. R R N.A. N.A.	R M M(1) R	N.A. 1, 2, 3 1, 2, 3, 4 1, 2, 3 N.A.
4.	MAIN STEAM LINE ISOLATION (MSIS) a. Manual (Trip Buttons) b. Steam Generator Pressure - L c. Automatic Actuation Logic	N.A. Low S N.A.	N.A. R N.A.	R M M(1)	N.A. 1, 2, 3 1, 2, 3
5.	CONTAINMENT SUMP RECIRCULATION (RAS) a. Manual RAS (Trip Buttons) b. Refueling Water Storage Tank - Low c. Automatic Actuation Logic	N.A. S N.A.	N.A. R N.A.	R M M(1)	N.A. 1, 2, 3 1, 2, 3

ST. LUCIE - UNIT 1

3/4 3-18

Amendment No. 17, 37

ST			TABLE 4.3-2	(Continued)		
		ENGINEERED SAFETY FEATURE AC	TUATION SYSTEM	INSTRUMENTATION S	URVEILLANCE REQU	JIREMENTS
TE - UNI	FUN	CTIONAL UNIT	CHANNEL CHECK	CHANNEL CALIBRATION	CHANNEL FUNCTIONAL TEST	MODES IN WHICH SURVEILLANCE REQUIRED
-4	6.	LOSS OF POWER 4.16 kv Emergency Bus Undervoltage (Undervoltage relays)	S	R	М	1, 2, 3
	7.	AUXILIARY FEEDWATER a. Auto Start b. Steam Generator		(See Su	urveillance 4.7. ee RPS Table 4.3	1.2.b) -1)

TABLE 4.3-2 (Continued)

TABLE NOTATION

 The logic circuits shall be tested manually at least once per 31 days.

ST. LUCIE - UNIT 1

3/4 3-20

INSTRUMENTATION

ACCIDENT MONITORING INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.3.8 The accident monitoring instrumentation channels shown in Table 3.3-11 shall be OPERABLE

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

a. Actions per Table 3.3-11.

b. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.3.3.8 Each accident monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK and CHANNEL CALIBRATION operations at the frequencies shown in Table 4.3-7.

TABLE 3.3-11

ACCIDENT MONITORING INSTRUMENTATION

~*

INS	TRUMENT	TOTAL NO. OF_CHANNELS	MINIMUM CHANNELS OPERABLE	ACTION
1.	Pressurizer Water Level	3	1	1
2.	Auxiliary Feedwater Flow Rate	1/pump	1/pump	1
3.	RCS Subcooling Margin Monitor	1	1	1
4.	PORV Position Indicator Acoustic Flow Monitor	l/valve	l/valve	2
5.	PORV Block Valve Position Indicator	l/valve	1/valve	2
6.	Safety Valve Position Indicator	l/valve	l/valve	3

TABLE 3.3-11 (Continued)

ACTION STATEMENTS

- ACTION 1 With the number of OPERABLE channels less than required by Table 3.3-11, either restore the inoperable channel(s) to OPERABLE status within 30 days or be in HOT STANDBY within the next 12 hours.
- ACTION 2 With position indication inoperable, restore the inoperable indicator to OPERABLE status or close the associated PORV block valve and remove power from its operator within 48 hours or be in HOT STANDBY within the next 6 hours.
- ACTION 3 With any individual valve position indicator inoperable, obtain quench tank temperature, level and pressure information once per shift to determine valve position.

Amendment No. 37

TABLE 4.3-7

ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

INSTRUMENT	CHANNEL CHECK	CHANNEL CALIBRATION
1. Pressurizer Water Level	М	R
2. Auxiliary Feedwater Flow Rate	M	R
3. Reactor Coolant System Subcooling Margin Monitor	м	R
4. PORV Position Indicator	м	R
5. PORV Block Valve Position Indicator	М	R
6. Safety Valve Postition Indicator	м	R

ST. LUCIE - UNIT 1

SAFETY VALVES - OPERATING

LIMITING CONDITION FOR OPERATION

3.4.3 All pressurizer code safety values shall be OPERABLE with a lift setting of 2500 PSIA \pm 1%.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

With one pressurizer code safety valve inoperable, either restore the inoperable valve to OPERABLE status within 15 minutes or be in HOT SHUTDOWN within 12 hours.

SURVEILLANCE REQUIREMENTS

4.4.3 Each pressurizer code safety value shall be demonstrated OPERABLE with a lift setting of 2500 PSIA \pm 1%, in accordance with Section XI of the ASME Boiler and Pressure Vessel Code, 1974 Edition.

PRESSURIZER

LIMITING CONDITION FOR OPERATION

3.4.4 The pressurizer shall be OPERABLE with a steam bubble, and with at least 150 kw of pressurizer heaters capable of being supplied by emergency power.

N

APPLICABILITY: MODES 1 and 2.

ACTION:

With the pressurizer inoperable, be in at least HOT STANDBY with the reactor trip breakers open within 6 hours.

SURVEILLANCE REQUIREMENTS

4.4.4 In accordance with 4.8.1.1.

ST LUCIE - UNIT 1

PORV BLOCK VALVES

LIMITING CONDITION FOR OPERATION

3.4.12 Each Power Operator Relief Valve (PORV) Block Valve shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

With one or more block valve(s) inoperable, within 1 hour either restore the block valve(s) to OPERABLE status or close the block valve(s) and remove power from the block valve(s); otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.4.12 Each block valve shall be demonstrated OPERABLE at least once per 92 days by operating the valve through one complete cycle of full travel.

ST LUCIE - UNIT 1

Amendment No. 37

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued) 3. Verifying that each pump operates for at least 15 minutes. Cycling each testable power operated or automatic valve 4. in the flow path through at least one complete cycle of full travel. 5. Verifying that each valve (manual, power operated or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position. At least once per 18 months during shutdown by cycling each b. power operated valve in the flow path that is not testable during plant operation, through at least one complete cycle of full travel, and 1. Verifying that each automatic valve in the flowpath actuates to its correct position upon receipt of the Auto Start actuation signal. Verifying that each auxiliary feedwater pump starts 2. automatically as designed upon receipt of the Auto Start actuation signal.

PLANT SYSTEMS

CONDENSATE STORAGE TANK

LIMITING CONDITION FOR OPERATION

3.7.1.3 The condensate storage tank shall be OPERABLE with a minimum contained volume of 116,000 gallons.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

With the condensate storage tank inoperable, restore the condensate storage tank to OPERABLE status within 4 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.7.1.3 The condensate storage tank shall be demonstrated OPERABLE at least once per 12 hours by verifying the water level.

3/4.3 INSTRUMENATION

BASES

3/4.3.1 and 3/4.3.2 PROTECTIVE AND ENGINEERED SAFETY FEATURES (ESF) INSTRUMENTATION

The OPERABILITY of the protective and ESF instrumentation systems and bypasses ensure that 1) the associated ESF action and/or reactor trip will be initiated when the parameter monitored by each channel or combination thereof reaches its setpoint, 2) the specified coincidence logic is maintained, 3) sufficient redundancy is maintained to permit a channel to be out of service for testing or maintenance, and 4) sufficient system functional capability is available for protective and ESF purposes from diverse parameters.

The OPERABILITY of these systems is required to provide the overall reliability, redundancy and diversity assumed available in the facility design for the protection and mitigation of accident and transient conditions. The integrated operation of each of these systems is consistent with the assumptions used in the accident analyses.

The surveillance requirements specified for these systems ensure that the overall system functional capability is maintained comparable to the original design standards. The periodic surveillance tests performed at the minimum frequencies are sufficient to demonstrate this capability.

The measurement of response time at the specified frequencies provides assurance that the protective and ESF action function associated with each channel is completed within the time limit assumed in the accident analyses. No credit was taken in the analyses for those channels with response times indicated as not applicable.

Response time may be demonstrated by any series of sequential, overlapping or total channel test measurements provided that such tests demonstrate the total channel response time as defined. Sensor response time verification may be demonstrated by either 1) in place, onsite or offsite test measurements or 2) utilizing replacement sensors with certified response times.

The Safety Injection Actuation Signal (SIAS) provides direct actuation of the Containment Isolation Signal (CIS) to ensure containment isolation in the event of a small break LOCA.

3/4.3.3 MONITORING INSTRUMENTATION

3/4.3.3.1 RADIATION MONITORING INSTRUMENTATION

The OPERABILITY of the radiation monitoring channels ensures that 1) the radiation levels are continually measured in the areas served

ST. LUCIE - UNIT 1

Amendment No. 27, 37

1

INSTRUMENTATION

BASES

RADIATION MONITORING INSTRUMENTATION (Continued)

by the individual channels and 2) an alarm is initiated when the radiation level alarm setpoint is exceeded.

N.

3/4.3.3.2 INCORE DETECTORS

The OPERABILITY of the incore detectors with the specified minimum complement of equipment ensures that the measurements obtained from use of this system accurately represent the spatial neutron flux distribution of the reactor core.

3/4.3.3.3 SEISMIC INSTRUMENTATION

The OPERABILITY of the seismic instrumentation ensures that sufficient capbility is available to promptly determine the magnitude of a seismic event and evaluate the response of those features important to safety. This capability is required to permit comparison of the measured response to that used in the design basis for the facility.

3/4.3.3.4. METEOROLOGICAL INSTRUMENTATION

The OPERABILITY of the meteorological instrumentation ensures that sufficient meteorological data is available for estimating potential radiation doses to the public as a result of routine or accidental release of radioactive materials to the atmosphere. This capability is required to evaluate the need for initiating protective measures to protect the health and safety of the public and is consistent with the recommendations of Regulatory Guide 1.23 "Onsite Meteorological Programs", February 1972.

3/4.3.3.5 REMOTE SHUTDOWN INSTRUMENTATION

The OPERABILITY of the remote shutdown instrumentation ensures that sufficient capability is available to permit shutdown and maintenance of HOT SHUTDOWN of the facility from locations outside of the control room. This capability is required in the event control room habitability is lost and is consistent with General Design Criteria 19 of 10 CFR 50.

ST. LUCIE - UNIT 1

INSTRUMENTATION

BASES

3/4.3.3.6 CHLORINE DETECTION SYSTEMS

The operability of the chlorine detection systems ensures that an accidental chlorine release will be detected promptly and the necessary protective actions will be automatically initiated to provide protection for control room personnel. Upon detection of a high concentration of chlorine, the control room emergency ventilation system will automatically isolate the control room and initiate its operation in the recirculation mode of operation to provide the required protection. The chlorine detection systems required by this specification are consistent with the recommendations of Regulatory Guide 1.95, "Protection of Nuclear Power Plant Control Room Operators Against an Accidental Chlorine Release", February 1975.

÷

3/4.3.3.7 FIRE DETECTION INSTRUMENTATION

OPERABILITY of the fire detection instrumentation ensures that adequate warning capability is available for the prompt detection of fires. This capability is required in order to detect and locate fires in their early stages. Prompt detection of fires will reduce the potential for damage to safety related equipment and is an integral element in the overall facility fire protection program.

In the event that a portion of the fire detection instrumentation is inoperable, the establishment of frequent fire patrols in the affected areas is required to provide detection capability until the inoperable instrumentation is restored to OPERABILITY.

3/4.3.3.8 ACCIDENT MONITORING INSTRUMENTATION

The OPERABILITY of the accident monitoring instrumentation ensures that sufficient information is available on selected plant parameters to monitor and assess these variables during and following an accident. This capability is consistent with the recommendations of NUREG-0578, "TMI-2 Lessons Learned Task Force Status Report and Short-Term Recommendations."

3/4.4 REACTOR COOLANT SYSTEM

BASES

3/4.4.1 REACTOR COOLANT LOOPS

The plant is designed to operate with both reactor coolant loops and associated reactor coolant pumps in operation, and maintain DNBR above 1.30 during all normal operations and anticipated transients. STARTUP and POWER OPERATION may be initiated and may proceed with one or two reactor coolant pumps not in operation after the setpoints for the Power Level-High, Reactor Coolant Flow-Low, and Thermal Margin/Low Pressure trips have been reduced to their specified values. Reducing these trip setpoints ensures that the DNBR will be maintained above 1.30 during three pump operation and that during two pump operation the core void fraction will be limited to ensure parallel channel flow stability within the core and thereby prevent premature DNB.

١.

A single reactor coolant loop with its steam generator filled above the low level trip setpoint provides sufficient heat removal capability for core cooling while in MODES 2 and 3; however, single failure considerations require plant cooldown if component repairs and/or corrective actions cannot be made within the allowable out-of-service time.

3/4.4.2 and 3/4.4.3 SAFETY VALVES

The pressurizer code safety values operate to prevent the RCS from being pressurized above its Safety Limit of 2750 psia. Each safety value is designed to relieve 2 x 10^5 lbs per hour of saturated steam at the value setpoint. The relief capacity of a single safety value is adequate to relieve any overpressure condition which could occur during shutdown. In the event that no safety values are OPERABLE, an operating shutdown cooling loop, connected to the RCS, provides overpressure relief capability and will prevent RCS overpressurization.

During operation, all pressurizer code safety valves must be OPERABLE to prevent the RCS from being pressurized above its safety limit of 2750 psia. The combined relief capacity of these valves is sufficient to limit the Reactor Coolant System pressure to within its Safety Limit of 2750 psia following a complete loss of turbine generator load while operating at RATED THERMAL POWER and assuming no reactor trip until the first Reactor Protective System trip setpoint (Pressurizer Pressure-High) is reached (i.e., no credit is taken for a direct reactor trip on the loss of turbine) and also assuming no operation of the pressurizer power operated relief valve or steam dump valves.

ST. LUCIE - UNIT 1

B 3/4 4-1

BASES

SAFETY VALVES (Continued)

Demonstration of the safety values' lift settings will occur only during shutdown and will be performed in accordance with the provisions of Section XI of the ASME Boiler and Pressure Vessel Code, 1974 Edition.

١.

3/4.4.4 PRESSURIZER

A steam bubble in the pressurizer ensures that the RCS is not a hydraulically solid system and is capable of accommodating pressure surges during operation. The steam bubble also protects the pressurizer code safety valves and power operated relief valve against water relief. The power operated relief valve and steam bubble function to relieve RCS pressure during all design transients. Operation of the power operated relief valve in conjunction with a reactor trip on a Pressurizer--Pressure-High signal, minimizes the undesirable opening of the springloaded pressurizer code safety valves. The required pressurizer heater capacity if capable of maintaining natural circulation subcooling. Operability of the heaters, which are powered by a diesel generator bus, ensures ability to maintain pressure control even with loss of offsite power.

3/4.4.5 STEAM GENERATORS

One OPERABLE steam generator provides sufficient heat removal capability to remove decay heat after a reactor shutdown. The requirement for two steam generators capable of removing decay heat, combined with the requirements of Specifications 3.7.1.1, 3.7.1.2 and 3.7.1.3 ensures adequate decay heat removal capabilities for RCS temperatures greater than 325°F if one steam generator becomes inoperable due to single failure considerations. Below 325°F, decay heat is removed by the shutdown cooling system.

The Surveillance Requirements for inspection of the steam generator tubes ensure that the structural integrity of this portion of the RCS will be maintained. The program for inservice inspection of steam generator tubes is based on a modification of Regulatory Guide 1.83, Revision 1. Inservice inspection of steam generator tubing is essential in order to maintain surveillance of the conditions of the tubes in the event that there is evidence of mechanical damage or progressive degradation due to design, manufacturing errors, or inservice conditions that lead to corrosion. Inservice inspection of steam generator tubing also provides a means of characterizing the nature and cause of any tube degradation so that corrective measures can be taken.

ST. LUCIE - UNIT 1

BASES

The nondestructive testing for repairs on components greater than 2 inches diameter gives a high degree of confidence in the integrity of the system, and will detect any significant defects in and near the new welds. Repairs on components 2 inches in diameter or smaller receive a surface examination which assures a similar standard of integrity. In each case, the leak test will ensure leak tightness during normal operation.

For normal opening and reclosing, the structural integrity of the Reactor Coolant System is unchanged. Therefore, satisfactory performance of a system leak test at 2235 psia following each opening and subsequent reclosing is acceptable demonstration of the system's structural interity. These leak tests will be conducted within the pressure-temperature limitations for Inservice Leak and Hydrostatic Testing and Figure 3.4-2.

The Safety Class 2 and 3 components will be pressure tested at least once toward the end of each inspection interval (10 years). The Safety Class 2 components having a design temperature above 400°F will be pressure tested at not less than 125 percent of the system design pressure while those components having a design temperature of 400°F and below will be pressure tested at 110 percent of design pressure. The Safety Class 3 components will be pressure tested at the levels indicated in Specification 4.4.10.3b.

3/4.4.11 CORE BARREL MOVEMENT

This specification is provided to ensure early detection of excessive core barrel movement if it should occur. Core barrel movement will be detected by using four excore neutron detectors to obtain Amplitude Probability Distribution (APD) and Special Analysis (SA). Baseline core barrel movement Alert Levels and Action Levels at nominal THERMAL POWER levels of 20%, 50%, 80% and 100% of RATED THERMAL POWER will be determined during the reactor startup test program.

A modification to the required monitoring program may be justified by an analysis of the data obtained and by an examination of the affected parts during the plant shutdown at the end of the first fuel cycle.

B 3/4 4-13

BASES

3/4.4.12 PORV BLOCK VALVES

The opening of the Power Operated Relief Valves fulfills no safety related function. The electronic controls of the PORVs must be maintained OPERABLE to ensure satisfaction of Specifications 4.5.1.d.1 and 4.5.2.d.1. Since it is impractical and undesirable to actually open the PORVs to demonstrate reclosing, it becomes necessary to verify operability of the PORV Block Valves to ensure the capability to isolate a malfunctioning PORV.

Υ,

ST LUCIE - UNIT 1

B 3/4 4-14

Amendment No. 37

CONTAINMENT SYSTEMS

BASES

3/4.6.2.2 SPRAY ADDITIVE SYSTEM

The OPERABILITY of the spray additive system ensures that sufficient NaOH is added to the containment spray in the event of a LOCA. The limits on NaOH volume and concentration ensure a pH value of between 8.5 and 11.0 for the solution recirculated within containment after a LOCA. This pH band minimizes the evolution of iodine and minimizes the effect of chloride and caustic stress corrosion on mechanical systems and components. The contained water volume limit includes an allowance for water not usable because of tank discharge line location or other physical characteristics. These assumptions are consistent with the iodine removal efficiency assumed in the accident analyses.

3/4.6.2.3 CONTAINMENT COOLING SYSTEM

The OPERABILITY of the containment cooling system ensures that 1) the containment air temperature will be maintained within limits during normal operation, and 2) adequate heat removal capacity is available when operated in conjunction with the containment spray systems during post-LOCA conditions.

3/4.6.3 CONTAINMENT ISOLATION VALVES

The OPERABILITY of the containment isolation valves ensures that the containment atmosphere will be isolated from the outside environment in the event of a release of radioactive material to the containment atmosphere or pressurization of the containment. Containment isolation within the time limits specified ensures that the release of radioactive material to the environment will be consistent with the assumptions used in the analyses for a LOCA. This includes the containment purge inlet and outlet valves.

3/4.6.4 COMBUSTIBLE GAS CONTROL

The OPERABILITY of the equipment and systems required for the detection and control of hydrogen gas ensures that this equipment will be available to maintain the hydrogen concentration within containment below its flammable limit during post-LOCA conditions. Either recombiner unit is capable of controlling the expected hydrogen generation associated with 1) zirconium-water reactions, 2) radiolytic decomposition of water and 3) corrosion of metals within containment.

The containment fan coolers are used in a secondary function to ensure adequate mixing of the containment atmosphere following a LOCA. This mixing action will prevent localized accumulations of hydrogen from exceeding the flammable limit.

ST. LUCIE - UNIT 1

TABLE 6.2-1

٠,

	· · · · · · · · · · · · · · · · · · ·	
LICENSE	APPLICABLE MODES	
CATEGORY	1, 2, 3, & 4	2 & 0
SOL	1	אן *
OL	2	1
Non-Licensed	2	1
Shift Technical Advisor	1	0

MINIMUM SHIFT CREW COMPOSITION

*Does not include the licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling, supervising CORE ALTERATIONS after the initial fuel loading.

#Shift crew composition may be less than the minimum requirements for a period of time not to exceed 2 hours in order to accomodate unexpected absence of on duty shift crew members provided immediate action is taken to restore the shift crew composition to within the minimum requirements of Table 6.2-1.

ST. LUCIE - UNIT 1

1

ADMINISTRATIVE CONTROLS

6.3 FACILITY STAFF QUALIFICATIONS

6.3.1 Each member of the facility staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions, except for (1) the Radiation Protection Manager who shall meet or exceed the qualifications of Regulatory Guide 1.8., September 1975, and (2) the Shift Technical Advisor who shall have a bachelor's degree or equivalent in a scientific or engineering discipline with specific training in plant design and in the response and analysis of the plant for transients and accidents.

۰.

6.4 TRAINING

6.4.1 A retraining and replacement training program for the facility staff shall be maintained under the direction of the Training Supervisor and shall meet or exceed the requirements and recommendations of Section 5.5 of ANSI N18.1-1971 and Appendix "A" of 10 CFR Part 55.

6.4.2 A training program for the Fire Brigade shall be maintained under the direction of the Fire Protection Administrator and shall meet or exceed the requirements of Section 27 of the NFPA Code-1975, except for Fire Brigade training sessions which shall be held at least quarterly.

6.5 REVIEW AND AUDIT

6.5.1 FACILITY REVIEW GROUP (FRG)

FUNCTION

6.5.1.1 The Facility Review Group shall function to advise the Plant Manager on all matters related to nuclear safety.

COMPOSITION

6.5.1.2 The Facility Review Group shall be composed of the:

Member:	Plant Manager
Member:	Operations Superintendent
Member:	Operations Supervisor
Member:	Maintenance Superintendent
Member:	Instrument & Control Supervisor
Member:	Reactor Supervisor
Member:	Health Physics Supervisor
Member:	Technical Supervisor
Member:	Chemistry Supervisor
Member:	Quality Control Supervisor
Member:	Assistant Plant Supt. Mechanical
Member:	Assistant Plant Supt. Electrical

The FRG Chairman shall be designated in writing.

ST. LUCIE - UNIT 1

Amendment No. 28,37

ADMINISTRATIVE CONTROLS

6.13 ENVIRONMENTAL QUALIFICATION

6.13.1 By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of: Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or, NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", December 1979. Copies of these documents are attached to Order for Modification of License DPR-67 dated October 24, 1980.

6.13.2 By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.

6.14 SYSTEMS INTEGRITY

6.14.1 The licensee shall implement a program to reduce leakage from systems outside containment that would or could contain highly radioactive fluids during a serious transient or accident to as low as practical levels. This program shall include the following:

- 1. Provisions establishing preventive maintenance and periodic visual inspection requirements, and
- 2. Integrated leak test requirements for each system at a frequency not to exceed refueling cycle intervals.

6.15 IODINE MONITORING

6.15.1 The licensee shall implement a program which will ensure the capability to accurately determine the airborne iodine concentration in vital areas under accident conditions. This program shall include the following:

- 1. Training of personnel,
- 2. Procedures for monitoring, and
- 3. Provisions for maintenance of sampling and analysis equipment.

ADMINISTRATIVE CONTROLS

6.16 BACKUP METHOD FOR DETERMINING SUBCOOLING MARGIN

6.16.1 The licensee shall implement a program which will ensure the capability to accurately monitor the Reactor Coolant System subcooling margin. This program shall include the following:

1. Training of personnel, and

2. Procedures for monitoring.

ST. LUCIE - UNIT 1

Amendment No. 37

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-355

FLORIDA POWER AND LIGHT COMPANY

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY

OPERATING LICNESE

The U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 37 to Facility Operating License No. DPR-67, issued to Florida Power and Light Company, which revised Technical Specifications for operation of the St. Lucie Plant, Unit No. 1 (the facility), located in St. Lucie County, Florida. The amendment is effective as of its date of issuance.

The amendment changes the Technical Specification to add requirements associated with actions taken to satisfy the NRC's "Category A" Lessons Learned Recommendations. These changes include adding operability requirements for relief block valves, adding safety injection as an actuation signal for containment isolation and adding requirements for accident monitoring instrumentation.

The applications for the amendment comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.



- 2 -

The Commission has determinded that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the applications for amendment dated January 22 and October 31, 1980, (2) Amendment No. 37 to License No. DPR-67 and (3) the Commission's related letter dated January 19, 1981. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D.C. and at the Indian River Junior College Library, 3209 Virginia Avenue, Ft. Pierce, Florida. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 19th day of January 1981.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Clark, Chief Operating Reactors Branch #3 Division of Licensing