ADMIN TASK:	Perform an RCS Inventory Balance	
TASK #: EPE009002		
K/A #s: 2.1.23		
References: STS BB-004	4, Rev. 22	
Examinee's Name	SS No	SRO RO_<u>X</u>_
The examinee's performa	nce was evaluated against the standards in this JPM and determined to	be :
SATISFACTORY	UNSATISFACTORY	
Reason if UNSATISF.	ACTORY:	
Estimated JPM comple	etion Time: 20 min.	
Actual Performance Ti	me:min.	
Location of Performan	ce: Classroom	
Method of Performance	ce: Perform	
Evaluators Signature: _		Date

Notes: ADMIN JPM

The exam group shall verify that the procedure revision for this JPM is current and that any change against the referenced procedure does not invalidate this JPM.

Provide the **GREEN** "Information Only" copy of STS BB-004 with cover sheet.

Initial Conditions:

You are a Relief Crew Licensed Operator; the plant is stable at 100% power. The operating crew has indications of a leak in Containment.

Initiating Cues:

The Control Room Supervisor had the RO perform a 4 hour STS BB-004 for RCS leakage and has completed the data collection. The CRS directs you to complete STS BB-004 calculations, beginning at Step 9.6, to determine if there is an RCS leak. The CRS provides you with the following information.

Chemistry performed <u>no</u> sampling or chemical additions. STN CH-020 results are < 0.815 gallons per day. STS PE-019, RCS Pressure Isolation valve Leakage, is 0.145 gpm.

READ TO EXAMINEE:

If you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

When you have completed the JPM inform your evaluator that you are done by handing this Initial Conditions/Initiating Cues sheet back to him.

TASK STANDARD:

Upon completion of this JPM the operator will have calculated the leak rate on the RCS per STS BB-004. Final Value for unidentified leakage is $0.485 \text{ gpm} \pm .05 \text{ gpm}$, and Identified T.S. Leakage of $0.164 \text{ gpm} \pm .05 \text{ gpm}$.

Element #	Step #	Element	Standard	Score
1.*	9.7	Calculate RCS leakage using Attachment B and log the results in the Control Room Log.	Complete calculations.	S U

Cue:

Comments: Logging the results in the Control Room Log is not required for this JPM.

2.	9.8	If individual component leakage is to be determined then perform Attachment C. If not mark this step N/A.	Ask CRS if individual component leakage needs to be determined.	S U
----	-----	---	---	-----

Cue:

Reply as CRS that individual component leakage will not be determined.

Comments:

Termination: Calculation of RCS leakage completes this JPM.

Stop Time ____

NOTE: Calculated values should be as follow: Step B.1.2 = 6.142 gallons Step B.2.2 = -295.8 gallons Step B.3.3 = -19.25 gallons Step B.4.3 = 430 gallons Step B.4.6 = 0 gallons Step B.5 = 121.092 gallons Step B.6.2 = 0.5045 gpm Step B.7.3.2 = 4.508 gallons Step B.7.5 = .0188 gpm

Step B.7.8 = Total Identified Leakage ≈ 0.0188 gpm.

Step B.8.1 = Unidentified Leakage Rate ≈0.4852 gpm.

Step B.9.1 = Total Identified T.S. Leakage 0.1643 gpm.

Initial Conditions:

You are a Relief Crew Licensed Operator; the plant is stable at 100% power. The operating crew has indications of a leak in Containment.

Initiating Cues:

The Control Room Supervisor had the RO perform a 4 hour STS BB-004 for RCS leakage and has completed the data collection. The CRS directs you to complete STS BB-004 calculations, Step 9.6, to determine if there is an RCS leak. The CRS provides you with the following information.

Chemistry performed <u>no</u> sampling or chemical additions. STN CH-020 results are 0.815 gallons per day. STS PE-019, RCS Pressure Isolation valve Leakage, is 0.145 gpm.

Notes:

If you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

When you have completed the JPM inform your evaluator that you are done by handing this Initial Conditions/Initiating Cues sheet back to him.

ADMIN TASK: Manually Determine Quadrant Power Tilt Ratio (QPTR).			
TASK: 01500032.			
K/A #s: 2.1.20			
References: STS RE-012, Rev. 7			
Examinee's Name SS No SRO SRO SRO			
The examinee's performance was evaluated against the standards in this JPM and determined to be:			
SATISFACTORY UNSATISFACTORY			
Reason, if UNSATISFACTORY:			
Estimated JPM Completion Time: 25 min.			
Actual Performance Time:min.			
Location of Performance: Classroom			
Method of Performance: Perform			
Tools and Equipment: None			
Evaluators Signature:			

Notes:

Provide the **GREEN** information only copy of STS RE-012, "QPTR Determination," with cover sheet and prerequisites completed.

After the examinee has determined that they need to use section 8.5 provide YELLOW table of the present NIS detector currents, Attachment A to this JPM.

Ensure a copy of the Curves and Tables book is available.

Initial Conditions:

You are the Reactor Operator, the plant has been stable at 100% power for the last 24 hours. The NPIS computer is out of service.

Initiating Cues:

The Control Room Supervisor directs you to determine Quadrant Power Tilt Ratio using of STS RE-012. The highest NI channel indicates 100.0 % power.

Provide the **GREEN** information only copy of STS RE-012 to the examinee.

TASK STANDARD: Final values should be within \pm .005 of the values in the Answer Key.

Element #	Step #	Element	Standard	Score
1.	8.1	Record highest NI channel.	Record 100%. Recognize NPIs not available for computer point.	
Comment	ts: Provi	ded in Initiating Cues.		
2.*	8.2	Perform QPTR per the method of section 8.3, 8.4 or 8.5.	Examinee must determine that section 8.5 of the procedure must be used since NPIS is unavailable.	
Comment	ts: With appro	NPIS unavailable the Operator should determine that priate box.	only section 8.5 can be performed and check the	
		Start Time		
3.*	8.5.1	Record the Normalization factor for each of the upper (detector A) and lower (detector B) detectors from page 7.5 of the Curve Book.	Locate the Wolf Creek Generating Station Control Room Operating Curves and Tables Reference Manual. Record the normalization factors for the upper and lower detectors for step 8.5.1. in the space provided in the procedure.	S U
Comment	ts: Table	es will not be provided in the element boxes.		
4.*	8.5.2	Record the present values of the NIS detector currents.	Record the values provided by the examiner in the procedure.	S U
Cue: Provide Attachment A to the examinee.				
Comment	ts:			
5.*	8.5.3	Normalize each of the detector currents recorded in 8.5.2 by dividing each current by the corresponding normalization factor recorded in 8.5.1.	Normalize each of the detector currents by dividing each current by the corresponding normalization factor. Record the values in the space provided in the procedure.	S U
Comment	ts:			
5.a.*	8.5.3.1.	Calculate the average of the upper normalized currents.	Calculate the average of the upper normalized currents (N41 Upper + N42 Upper + N43 Upper + N44 Upper) divided by 4. Record the values in the space provided in the procedure. (See Answer Key)	S U
Comment	ts:			

* Critical Step

5.b.* 8.5.3.2. Calculate the average of the lower normalized currents. Calculate the average of the lower normalized currents (N41 Lower + N42 Lower + N43 Lower + N44 Lower) divided by 4. Record the values in the space provided in the procedure. (See Answer Key)	S U
--	-----

Comments:

.

Element #	Step #	Element	Standard	Score
6.*	8.5.4	Calculate the upper tilts by dividing each of the upper normalized currents in step 8.5.3 by the average of the upper normalized currents in 8.5.3.1.	Calculate the upper tilts by dividing each upper normalized current by the average upper normalized current from step 8.5.3.1. Record the values in the space provided in the procedure. (See Answer Key)	S U

Comments:

7.*	8.5.5	Calculate the lower tilts by dividing each of the lower normalized currents in 8.5.3 by the average of the lower normalized currents in 8.5.3.2.	Calculate the lower tilts by dividing each lower normalized current by the average lower normalized current from step 8.5.3.2. Record the values in the space provided in the procedure. (See Answer Key)	S U
		1	1	1

Comments:

8.*	8.5.6	Record the maximum radial flux tilt.	Record in the space provided in the	S U
			procedure the highest radial flux tilt indicated	
			from the upper tilt values and the lower tilt	
			values. (See Answer Key)	

Comments: Final values should be within \pm .005 of the values in the Answer Key.

9.	8.5.7	Proceed to Section 8.7	Same as Element	
				i i

Comments

	10.	8.7	Verification that QPTR is within Limits	Complete section 8.7	
--	-----	-----	---	----------------------	--

Comments

11.*	8.7.1/2	Recognize QPTR is within Limits	Initial Step 8.7.1 and N/A Step 8.7.2.	
------	---------	---------------------------------	--	--

Comments

Termination: Completing Section 8.7 as being within limits completes the JPM.

Stop Time ____

* Critical Step

Initial Conditions:

You are the Reactor Operator, the plant has been stable at 100% power for the last 24 hours. The NPIS computer is out of service.

Initiating Cues:

The Control Room Supervisor directs you to determine Quadrant Power Tilt Ratio using STS RE-012. The highest NI channel indicates 100.0 % power.

Notes:

If you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

WCGS -SRO/RO TRAINING PROGRAM JOB PERFORMANCE MEASURE EVALUATION FORM

Attachment A

Training Use Only

	N41	N42	N43	N44
I _{top}	238	237	246	249
I _{bot}	240	234	265	259

*



STS RE-012

QPTR DETERMINATION

Responsible Manager

Manager Nuclear Engineering

Revision Number	7
Use Category	Reference
Administrative Controls	No
Infrequently Performed Procedure	No
Program Number	29

DC30 11/27/1997

TABLE OF CONTENTS	
1.0 PURPOSE	2
SEC2T.IONSCOPE TITLE	PAGE
3.0 REFERENCES AND COMMITMENTS	2
4.0 PRECAUTIONS/LIMITATIONS	3
5.0 TEST EQUIPMENT	3
6.0 ACCEPTANCE CRITERIA	3
7.0 PREREQUISITES	3
8.0 PROCEDURE	4
9.0 RESTORATION	9
10.0 RECORDS	9

Ϊż ³Revision: 7 OPTR DETERMINATION ³ STS RE-012 3 ³Page 2 of 10 3 ³Reference Use ³ ÄÙ This procedure is used to determine the Ouadrant Power Tilt Ratio (QPTR) and to verify QPTR is within acceptable limits. 1.2 This procedure is applicable in Mode 1 above 50% RTP. 1.3 The OPTR shall be determined to be within the limit above 50% RTP by: NOTE The OPTR alarm function is met if: Annunciators 00-078B, PR UPPER DETECTOR FLUX DEV, AND 00-078C, PR LOWER DETECTOR FLUX DEV, are operable; OR Annunciator 00-079C, RPI DEV OR PR TILT, is operable. 1.3.1 Calculating the ratio at least once per 7 days when the OPTR alarm is operable. Calculating the ratio at least once per 12 hours when 1.3.2 the QPTR alarm is inoperable. With one PR channel inoperable and power level above 75% RTP, 1.4 the movable incore detectors shall be used to confirm that the normalized symmetric power distribution is consistent with the indicated QPTR at least once per 12 hours. 2.0 SCOPE2.0 SCOPE 2.1 This procedure fulfills the Surveillance Requirements of Technical Specifications 4.2.4.1 and 4.2.4.2 (SR 3.2.4.1 and SR 3.2.4.2). 2.2 This procedure satisfies the requirements of USAR Section 16.3.1.1 (TR 3.3.10) if the QPTR is determined with the Movable Incore Detector System. 3.0 REFERENCES AND COMMITMENTS3.0 REFERENCES AND COMMITMENTS 3.1 References 3.1.1 Control Room Operating Curves and Tables Reference Manual (Curve Book)

3.1.2 SYS SR-200, MOVABLE INCORE DETECTOR OPERATION

Ϊż 3

³Revision: 7 3 ãäääääääääääääääää OPTR DETERMINATION

³ STS RE-012

3

³Reference Use ³

³Page 3 of 10 ÄÙ

STS IC-932, POWER RANGE NEUTRON HIGH FLUX TRIP 214 SETPOINT REDUCTION

3.2 Commitments

> 3.2.1 None

4.0 PRECAUTIONS/LIMITATIONS4.0 PRECAUTIONS/LIMITATIONS

- 4.1 If the Incore Movable Detector System is used for OPTR determination, at least 75% of the thimbles (44 thimbles), with a minimum of two thimbles per core quadrant, are to be operable as required by USAR Section 16.3.1.1 (TR 3.3.10).
- 4.2 With one excore detector inoperable, the remaining three detectors shall be used for computing the average.
- The recorded reactor power must be from the indication being 4.3 used to control reactor power (i.e., the highest reading NI channel or the calorimetric).
- STS IC-932, POWER RANGE NEUTRON HIGH FLUX TRIP SETPOINT 4.4 REDUCTION, shall be used for reduction of the Power Range Neutron Flux-High Trip Setpoints as required by Technical Specification 3.2.4 (ITS 3.2.4.A.4).
- 5.0 TEST EQUIPMENT5.0 TEST EQUIPMENT
- 5.1 None
- 6.0 ACCEPTANCE CRITERIA6.0 ACCEPTANCE CRITERIA
- 6.1 QPTR shall not exceed 1.02.
- 7.0 PREREQUISITES7.0 PREREQUISITES
- 7.1 The Reactor is operating at a steady power level above 50% RTP.

Ο

AÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄ	VÄÄ VÄÄ	15 RE-012
AÄÄÄ BRQGEDU	BEŠ A G PROSEDURE AAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAA	ÄÄÄÄÄÄÄÄÄÄÄ
1 Record	the present reactor power level.	
RJ	U157MA MWT/35.65 = % RTP	
	OR	
Hi	ghest NI Channel % RTP	
2 Perform Section	QPTR determination per the method of 8.3, 8.4, or 8.5. Indicate method used.	
	NOTE	
that the no with the in done per Se of QPTR mon QPTR determ	ormalized symmetric power distribution is condicated QPTR at least once per 12 hours. In action 8.6. Section 8.6 is not a stand-alor ditoring. Section 8.6 may only be used to contained in Section 8.3, 8.4 or 8.5.	onsistent This is ne method confirm
	*NSSS Menu Tilting Factors - Section 8.3	0
	*NSSS Menu Tilting Factors - Section 8.3 *NPIS Computer Points - Section 8.4	0
	*NSSS Menu Tilting Factors - Section 8.3 *NPIS Computer Points - Section 8.4 *NIS Current - Section 8.5	0 0 0
	*NSSS Menu Tilting Factors - Section 8.3 *NPIS Computer Points - Section 8.4 *NIS Current - Section 8.5 Movable Incore Detectors - Section 8.6	0 0 0 0
3 <u>NSSS ME</u>	*NSSS Menu Tilting Factors - Section 8.3 *NPIS Computer Points - Section 8.4 *NIS Current - Section 8.5 Movable Incore Detectors - Section 8.6 <u>NU - Tilting Factors Determination Of QPTR</u>	0 0 0 0
3 <u>NSSS ME</u> 8.3.1	*NSSS Menu Tilting Factors - Section 8.3 *NPIS Computer Points - Section 8.4 *NIS Current - Section 8.5 Movable Incore Detectors - Section 8.6 <u>NU - Tilting Factors Determination Of QPTR</u> Select <u>NSSS Menu</u> on an NPIS terminal.	
3 <u>NSSS ME</u> 8.3.1 8.3.2	*NSSS Menu Tilting Factors - Section 8.3 *NPIS Computer Points - Section 8.4 *NIS Current - Section 8.5 Movable Incore Detectors - Section 8.6 <u>NU - Tilting Factors Determination Of QPTR</u> Select <u>NSSS Menu</u> on an NPIS terminal. Select <u>Tilting Factors</u> .	
3 <u>NSSS ME</u> 8.3.1 8.3.2 8.3.3	*NSSS Menu Tilting Factors - Section 8.3 *NPIS Computer Points - Section 8.4 *NIS Current - Section 8.5 Movable Incore Detectors - Section 8.6 <u>NU - Tilting Factors Determination Of QPTR</u> Select <u>NSSS Menu</u> on an NPIS terminal. Select <u>Tilting Factors</u> . Record the following data:	
3 <u>NSSS ME</u> 8.3.1 8.3.2 8.3.3 Radial Uppe	*NSSS Menu Tilting Factors - Section 8.3 *NPIS Computer Points - Section 8.4 *NIS Current - Section 8.5 Movable Incore Detectors - Section 8.6 <u>NU - Tilting Factors Determination Of QPTR</u> Select <u>NSSS Menu</u> on an NPIS terminal. Select <u>Tilting Factors</u> . Record the following data: <u>NIS N-43</u> <u>NIS N-42</u> <u>NIS N-44</u> <u>NIS</u> (Q1) (Q2) (Q3) (Q3)	0 0 0 0 0 0 0 0 0 0 0 0 0
3 <u>NSSS ME</u> 8.3.1 8.3.2 8.3.3 Radial Uppe Flux Tilt	*NSSS Menu Tilting Factors - Section 8.3 *NPIS Computer Points - Section 8.4 *NIS Current - Section 8.5 Movable Incore Detectors - Section 8.6 <u>NU - Tilting Factors Determination Of QPTR</u> Select <u>NSSS Menu</u> on an NPIS terminal. Select <u>Tilting Factors</u> . Record the following data: NIS N-43 NIS N-42 NIS N-44 NIS (Q1) (Q2) (Q3) (Q3)	0 0 0 0 0 0 0 0 0 0 0 0 0
3 <u>NSSS ME</u> 8.3.1 8.3.2 8.3.3 Radial Uppe Flux Tilt Radial Lowe Flux Tilt	*NSSS Menu Tilting Factors - Section 8.3 *NPIS Computer Points - Section 8.4 *NIS Current - Section 8.5 Movable Incore Detectors - Section 8.6 <u>INU - Tilting Factors Determination Of QPTR</u> Select <u>NSSS Menu</u> on an NPIS terminal. Select <u>Tilting Factors</u> . Record the following data: NIS N-43 NIS N-42 NIS N-44 NIS (Q1) (Q2) (Q3) (Q3) er	O O O O O O O O O O
3 <u>NSSS ME</u> 8.3.1 8.3.2 8.3.3 Radial Uppe Flux Tilt Radial Lowe Flux Tilt Radial Lowe Flux Tilt	*NSSS Menu Tilting Factors - Section 8.3 *NPIS Computer Points - Section 8.4 *NIS Current - Section 8.5 Movable Incore Detectors - Section 8.6 <u>NU - Tilting Factors Determination Of QPTR</u> Select <u>NSSS Menu</u> on an NPIS terminal. Select <u>Tilting Factors</u> . Record the following data: NIS N-43 NIS N-42 NIS N-44 NIS (Q1) (Q2) (Q3) (G er 	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0

ÚÄ	ÄÄÄ	ÄÄ	ÄÄÄ	ÄÄÄÄÄ	ÄÄÄÄÄ	ÄÄÄ	ÄÄÄÄÄ	ÄÄÄ	ÄÄÄÄ.	ÄÄÄÄ.	ääääää	ÄÄÄÄÄ	ÄÄÄÄÄ	ÄÂÄÄÄÄ	ÄÄÄÄ	ÄÄÄÄ	ÄÄ
AZ 3R ÃÄ ÃÄ	evi ÄÄÄ äää	si ÄÄ ää	on: ÄÄÄ äää	7 ÄÄÄÄÄÄ äääää	³ ÀÄÄ ´ Àä ä ´		QI	PTR	DET	ERMI	NATION	1	3	STS	RE-C	12	3
³R ÀÄ ÄÙ	efe: ÄÄÄ	re ÄÄ	nce ÄÄÄ 8.	Use ÄÄÄÄÄ 3.5	3 ÄÄÄÁÄ Pro	ÄÄÄ cee	ÄÄÄÄÄÄ ed to s	ÄÄÄ Sec	ÄÄÄÄ tion	ÄÄÄÄ 8.7	ÄÄÄÄÄ •	ÄÄÄÄÄ	³ <u>i</u> ÄÄÄÄÄ	Page 5 ÄÄÄÄÄÄÄ	of 1 Äääää O	0 Äääää	з ÄÄ
	8.4		NP	IS Co	mpute	er 1	Points	De	eterr	ninat	cion O	f QPTI	R				
			8.	4.1	Add rec	res	s the l the o	fo dat	llow a be	ing low:	points	s on a	n NPI	S term	inal	and	
					1.	SE	U1151	((AVG	RAD	LOWER	TILT	Q1) _		-		
					2.	SE	U1152	((AVG	RAD	LOWER	TILT	Q2) _		-		
					3.	SE	U1153	((AVG	RAD	LOWER	TILT	Q3)_		-		
					4.	SE	U1154	((AVG	RAD	LOWER	TILT	Q4) _		-		
					5.	SE	U1159	((AVG	RAD	UPPER	TILT	Q1) _				
					б.	SE	U1160	((AVG	RAD	UPPER	TILT	Q2)_		-		
					7.	SE	U1161	((AVG	RAD	UPPER	TILT	Q3)_		-		
					8.	SE	U1162	((AVG	RAD	UPPER	TILT	Q4) _		-		
			8.	4.2	Rec	ord	l maxim	num	rad	ial	flux t	tilt.	QPTR	=		_	
			8.	4.3	Pro	cee	ed to a	Sec	tion	8.7					0		
	8.5		NI	S Cur	rent	Det	termin	ati	lon (Df QI	PTR						
			8.	5.1	Rec of (de the	the tec Cu	l the 1 e uppe: tor B urve Bo	Nor r () d cok	mali dete etec (Re	zati ctor tors fere	on fac A) ar from nce 3	ctor f nd low page .1.1).	or ea ver 7.5 o	ch f			
										N4	1	N42	2	N43		N44	
					Upp	er	(Dete	cto	r A)							_	
					Low	rer	(Dete	cto	r B)							_	

ÚÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄ	ÄÄÄÄÄÄÄ 3 Ä	ÄÄÄÄÄÄÄ	ÄÄÄÄÄÄ DETER	ÄÄÄÄÄÄ MINATI	ÄÄÄÄÄÄÄÄÄÄ ON	AÄÄÄÄÄÄÄÄÄ 3 sts 1	ÄÄÄÄÄÄÄÄÄ RE-012 ³
ÃÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄ	ä 3 Record ä detecto	t à c à c à cà cà r curre:	FAT AN nts.	aj azaz	QAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAA	³Page 6 d Säääääääää	of 10 ³ ÄÄÄÄÄÄÄÄÄ
	Present	NIS de	tector	curre	nts (micro	camps)	
				N41	N42	N43	N44
1	Upper (Detecto	r A)				
:	Lower (Detecto	r B)				
8.5.3	Normali recorde by the recorde	ze each d in 8. corresp d in 8.	of th 5.2 by onding 5.1.	e dete divid norma	ctor curre ing each d lizing fao	ents current ctor	
]	<u>Detecto</u> Normali:	r Curr zation	ent Facto:	 r		
	Nor	malized	NIS c	urrent	s (microan	nps)	
				N41	N42	N43	N44
1	Upper (Detecto	r A)				
:	Lower (Detecto	r B)				
	1. Cal nor	culate malized	the av curre	erage nts.	of the upp	per	
	(Up	per)	N	141	N42	N43 +	N44
	+						
	λικο	rade IIn	per No	rmaliz	4 ed Current	_	
	2. Cal nor	culate malized	the av curre	erage nts.	of the low	wer	
	(Lo	wer)	Ν	141	N42	N43	N44
	+				4		
	Ave	rage Lov	wer No	rmaliz	ed Current		

ÚÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄ	ÄÄÄÄÄÄÄÄÄÄÄÄÄÄ	XÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄ	ÄÄÄÄÄÄÄÄÄ	ÄÄÄÄÄÄÄÄ	ÄÄÄÄÄÄÄÄ	ÄÄÄ
³ Revision: 7 ³ ÃÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄ	QPTR	DETERMINATION	1	3 STS	RE-012	3
				2 D a a a 7	- 5 10	2
ິREIErence Use ິ ລຸສຸສຸສຸສຸສຸສຸສຸສສສສສສສສສສສສສສສສສສສສສສ		טאסאסאביזרה להה אל אל אבהה אסא	75 x2151 x751 x2151 x150	Page /	OI LU %	
ÄNAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAA	the upper no	ormalized curr	cents in 8	.5.3	AAAAAAAA	IAAA
Ь	r the average	of the upper	normalize	d		
cu	rrents in 8.	5.3.1.				
	Each upper	Normalized Cu	irrent	_		
	Avg. of upp	per Normalized	l Currents			
	Upper Tilt	Values				
	N41	N42	N43	N44		
				<u> </u>		

UAAAAAA Äż ³ Revisi ÃÄÄÄÄÄÄ õääääää	AAAAAAAAA on: 7 ÄÄÄÄÄÄÄÄÄÄÄ ääääääääää	AAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAA	RE-012 ³
³ Refere ÀÄÄÄÄÄÄ ÄÙ	nce Use ÄÄÄÄÄÄÄÄÄÄ 8.5.5	³ ³ Page 8 AÁAÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄ	of 10 ³ ÀÄÄÄÄÄÄÄÄÄÄÄÄ
		by the average of the lower normalized <u>In 8.5.3</u> currents in 8.5.3.2.	<u>IIT/DATE</u>
		Each Lower Normalized Current Avg. Lower Normalized Currents	
		Lower Tilt Values	
		N41 N42 N43 N44	
	8.5.6	Record the maximum radial flux tilt.	
		QPTR =	
	8.5.7	Proceed to Section 8.7.	0
8.6	Movable	Incore Detectors	
	8.6.1	Perform a symmetric or full core flux map per SYS SR-200, MOVABLE INCORE DETECTOR OPERATION.	0
	8.6.2	Reduce and analyze flux map data per RXE 03-001, INCORE DATA REDUCTION AND ANALYSIS.	0
	8.6.3	<u>IF</u> a full core flux map was performed, <u>THEN</u> verify that at least 44 thimbles were used with a minimum of two detector thimbles per core quadrant.	/
	8.6.4	<u>IF</u> a symmetric flux map was performed, <u>THEN</u> verify that only core locations C-8, E-5, E-11, H-3, H-13, L-5, L-11, and N-8 were used.	/
	8.6.5	Attach a copy of the detector plateaus.	0
	8.6.6	Record the following data:	
		NIS N-43 NIS N-42 NIS N-44 NIS N-44 (Q1) (Q2) (Q3) (Q4)	1
	Radial U Flux Til	pper t	
	Radial L	ower	

ÚÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄ	ĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂ	ÄÄÄÄÄÄ	ÀÄÄÄÄÄÄÄÄÄ	ÄÄÄÄÄÄ
Äż				
³ Revision: 7 ³ OF	PTR DETERMINATION	3	STS RE-01	.2 ³
ãääääääääääääää ´				
ãäääääääääääääää ´				
³ Reference Use ³		³Paq	e 9 of 10	3
ÀÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄÄ	ĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂĂ	ÄÄÄÄÄÄ	Äääääääää	ÄÄÄÄÄ
ÄÙ Flux Tilt				

		NOTE	INIT/DATE
Ind QP: eva	core tilts IR normali aluation.	s at the time of the most recent excore dete ization should be taken into account in this	ctor
	8.6.7	Confirm that the tilts recorded in the previous step are consistent with the indicated QPTR determined per this procedure.	/
8.7	<u>Verifica</u>	ation of QPTR within Limits	
	8.7.1	$\underline{\text{IF}}$ QPTR is less than or equal to 1.02, $\underline{\text{THEN}}$ restore system per SS direction.	/
	8.7.2	<u>IF</u> QPTR is greater than 1.02 <u>THEN</u> perform to following:	the
		 Refer to Technical Specification 3.2.4 (ITS 3.2.4). 	/
		2. Contact Reactor Engineering.	/
		3. Confirm the out-of-limit condition by verifying the method used and by performing other available methods per this surveillance.	/
		 Determine if the out-of-limit condition is sustained by performing this surveillance at least every hour. 	/
9.0	RESTORAT	TION9.0 RESTORATION	
9.1	None		
10.0	RECORDS1	10.0 RECORDS	
10.1	The foll procedur	owing QA records are generated by this re:	
	0 Sectio	ons 7.0 and 8.0	

0 Incore detector plateaus (if Section 8.6 was used)

ÚÄÄÄÄÄÄ	ÄÄÄ	ÄÄÄÄ	ÄÄÄÄÄ	äääääää	ÄÄÄÄÄ	ÄÄÄÄÄÄÄ	<u> AÄÄÄÄÄ</u>	ÄÄÄÄÄÄ	ÄÄÄÄ	ÄÄÄ	ÄÄÄÄ	ÄÄÄÄÄ	ÄÄÄÄ	ÅÄÅ
Äż														
³ Revisi	on:	7	3		OPTR	DETERM	INATIC	ON		3	STS	RE-0	12	3
ãääääää	ÄÄÄ	ÄÄÄÄ	ÄÄÄ		~									
ãääääää	ÄÄÄ	ÄÄÄÄ	ÄÄÄ											
³ Refere	nce	Use	3							³ Pac	ye 10) of 1	10	3
àääääää	ÄÄÄ	ÄÄÄÄ	ÄÄÄÄÄ	ÄÄÄÄÄÄÄ	ÄÄÄÄÄ	ÄÄÄÄÄÄÄ	AÄÄÄÄÄ	ÄÄÄÄÄÄ	ÄÄÄÄ	ÄÄÄÄ	ÄÄÄÄ	ÄÄÄÄÄ	ÄÄÄÄ	ίÄÄ
ÄÙ	0.	Any	calcu	lations	supp	porting	Step	8.6.7	(if	pert	Eorm	ed)		

– END –	INIT/DATE

ADMIN TASK: Complete the Following Two Question for	Admin Area A.2.			
TASK:.				
K/A #s: See Attached				
References: See Attahced				
Examinee's Name	SS No			
The examinee's performance was evaluated against the sta	andards in this JPM and det	termined to be:		
SATISFACTORY UNSATISFACTORY				
Reason, if UNSATISFACTORY:				
Estimated JPM Completion Time: 20 min.				
Actual Performance Time:min.				
Location of Performance: Classroom				
Method of Performance: Perform				
Tools and Equipment: None				
Evaluators Signature:				

ID #	RO-A.3.1
NRC KA reference	2.2.22 LCO's and Safety Limits
	(GFR 43.2/43.2, RO 3.4)
	Ability to explain and apply all system limits and precautions.
Question Source	NEW
WCGS objective tie	Objective 7, SY 13 002 00, Tech. Specs and Operational Requirements.
WCGS lesson plan	SY 13 002 00, Rev. 10, Reactor Coolant System
reference	LO17 327 00, Rev. 004 Introduction to Technical
	Specifications (Contractor provided Class)
WCGS reference	WCGS Technical Specifications, Section 2.0
Question	A plant transient with a loss of load caused a power reduction.
	From analysis the peak transient conditions occurred at 95 % power when Tavg reached 629 degrees and RCS pressure was at 2235 psig.
	Determine what actions would be required?
Answer	Shutdown the plant and be in Mode 3 within 1 hour.
Comment section	OPEN REFERENCE QUESTION

QUESTION: RO-A.3.1

OPEN REFERENCE QUESTION

A plant transient with a loss of load caused a power reduction. The plant is currently stable.

From analysis the peak transient conditions occurred at 95 % power when Tavg reached 629 degrees and RCS pressure was at 2235 psig.

Determine what actions would be required?

OPEN REFERENCE QUESTION

ID #	RO-A.3.2
NRC KA reference	2.2.25 (CFR 43.2, RO 2.5) Bases for LCO's and Safety Limits.
Question Source	NEW
WCGS objective tie	SY 13 006 00, Objective 13, Technical Specifications
WCGS lesson plan reference	SY 13 006 00, Rev. 08, Emergency Core Cooling System. LO17 327 00, Rev. 004 Introduction to Technical Specifications (Contractor provided Class)
WCGS reference	WCGS Technical Specifications and Bases.
Question	During Surveillance Testing it is determined that the motor on BG HV-8357A is shorted and the valve will not open.
	now does this affect the Operability of A CCF?
Answer	Words to the effect of:
	Per the Bases for T.S. 3.5.2, BG HV-8357A and BG HV- 8357B are specifically listed as not affecting the operability of their associated CCP. "A" CCP is still operable.
Comment section	OPEN REFERENCE QUESTION

QUESTION: RO-A.3.2

OPEN REFERENCE QUESTION

During Surveillance Testing it is determined that the motor on BG HV-8357A is shorted and the valve will not open.

How does this affect the Operability of "A" CCP?

OPEN REFERENCE QUESTION

ADMIN TASK:	Determine Max Stay Time and Protective Clot	hing Requirements	
TASK #:2.3-1			
K/A #s:2.3.2 Facility A	LARA practices.		
References: Rad Worker	II Training		
Examinee's Name		SS No	SRO ROX_ _
The examinee's performan	nce was evaluated against the standards in this J	PM and determined to be :	
SATISFACTORY	UNSATISFACTORY		
Reason if UNSATISFA	ACTORY:		
Estimated JPM comple	tion Time: <u>15</u> min.		
Actual Performance Tir	ne:min.		
Location of Performance: Plant			
Method of Performance	e: Perform		
Evaluators Signature: _			Date

Notes:

PROVIDE GREEN Training Only copies of the RWP and the Survey Map to the Examinee.

Initial Conditions:

You are the Auxillary Building Operator, the Control Room request you to manually control BG FCV-121 locally in the Normal Charging Pump Room.

Initiating Cues:

Given a Survey Map of the NCP Room and a copy of the RWP, determine the maximum stay time you would be allowed and the Protective Clothing requirements.

Task Standard: Upon Completion of this JPM, the operator will have determined a maximum stay time of 40 minutes and that a full set of Anti-C's are required to remain in the area.

Element #	Step #	Element	Standard	Score
1.	N/A	Using the Survey map determine the highest dose in the contaminated area is 30 mrem per hour. Using the RWP determine that the maximum dose allowed is 20 mrem.	Determine stay time to equal 40 minutes. $\frac{20 \text{ mrem limit}}{30 \text{ mrem/hr}} = \frac{20 \text{mrem}*60 \text{min}}{30 \text{ mrem}} = 40 \text{ min.}$ Correct Answer = 40 minutes	S U

Cue:

Comments:

2

Cue: IF asked by Examinee state that the controller can not be reached from outside the boundary and they will have to remain in the area.

Comments:

Termination: Determining Stay Time and Protective clothing requirements completes this JPM.

Initial Conditions:

You are the Auxillary Building Operator, the Control Room request you to manually control BG FCV-121 locally in the Normal Charging Pump Room.

Initiating Cues:

Given a Survey Map of the NCP Room and a copy of the RWP, determine the maximum stay time you would be allowed and the Protective Clothing requirements.

Notes:

Plant equipment should not be operated, if you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

When you have completed the JPM inform your evaluator that you are done by handing the Initial Conditions/Initiating Cues sheet back to him.

ADMIN TASK: Perform the correct OFN procedure attachment(s) for a PK Bus Annunciator malfunction.		
TASK: OFN029005		
K/A #s: 2.4.32, Knowledge of operator response to a loss of all annunciator		
References: OFN PK-029, Loss of Non Vital 125 VDC Bus PK01, PK02, PK03, PK04, and Annunciators		
Examinee's Name SS No SRO SRO SRO		
The examinee's performance was evaluated against the standards in this JPM and determined to be:		
SATISFACTORY UNSATISFACTORY		
Reason, if UNSATISFACTORY:		
Estimated JPM Completion Time: 20 min.		
Actual Performance Time:min.		
Location of Performance: Control Room or Simulator		
Method of Performance: Perform		
Tools and Equipment: NPIS Terminal if available		
Evaluators Signature:		

WCGS -SRO/RO TRAINING PROGRAM JOB PERFORMANCE MEASURE EVALUATION FORM

Notes:

The examiner shall verify that the procedure revision for this JPM is current and that any changes against the referenced procedure does not invalidate this JPM.

Provide YELLOW information only copy of OFN PK-029, "Loss of Non Vital 125 VDC Bus PK01, PK02, PK03, PK04 and Annuciators" after applicant has determined it is the appropriate procedure.

AFTER Examinee has the correct screen on the NPIS Terminal then provide the **YELLOW** copy of Attachment A to this JPM.

Initial Conditions:

An Event has occurred in the plant and theControl Room Supervisor (CRS) suspects a Loss of Annunciators.

The NPIS computer is available.

Initiating Cues:

The Shift Manager has requested you to determine the percentage of lost Annunciators for E-Plan purposes.

(Unplanned loss of greater than or equal to 75% of MCB Annunciators or indication for > 15 minutes will require Notification of Unusual Event as a minimum)

Element #	Step #	Element	Standard	Score
1.		Obtain copy of OFN PK029, "Loss of Non Vital 125 VDC Bus PK01, PK02, PK03, PK04, and Annunciators"	Examinee obtains a current copy of OFN PK- 029, "Loss of Non Vital 125 VDC Bus PK01, PK02, PK03, PK04, and Annunciators"	S U

Cue: After Examinee determines to use OFN PK-029, provide YELLOW copy.

Comments: Not provided in Initiating Cues, so the candidate determine which procedure to use.

2.	1 thru 3	For: Annunciator Malfunction a. Go to ATTACHMENT L	Examinee must determine that <u>Attachment L</u> is the required section to be used.	S U

Comments: Use NPIS computer in Shift Managers office if available.

3.*	L.1	Determine which Annunciator power supplies were lost by using Turn On Code ANNPANL.	Examinee goes to the available NPIS computer and retrieves "Turn On Code ANNPANL".	SU
-----	-----	--	--	----

CUE: The ANNPANL screen shows these failed power supplies.

NOTE: Once the Examinee has called up ANNPANL on a NPIS Terminal, then hand them the **YELLOW** copy of Attachment A which lists the affected Power Supplies.

WCGS -SRO/RO TRAINING PROGRAM JOB PERFORMANCE MEASURE EVALUATION FORM

4.*	L.2	Determine appropriate total percentages for the failed power supply using table below: The following are given as failed Power Supplies:	Examinee calculates the total percentage by adding the listed percentages for those power given as lost: Percent Annunciators Lost	S U
		• E1PS1	10.6 %	
		• E1PS2	12.0 %	
		• E1PS3	9.5 %	
		• E1PS4	11.6 %	
		• E2PS1	11.2 %	
		• E2PS2	7.6 %	
		• E2PS3	10.1%	
		• E2PS4	6.9 %	
			<u>79.5 % TOTAL</u>	

Comments: Ensure 79.5% is the answer calculated.

5.*	N/A	Inform Shift Manager that 79.5 % of the Annunciators have been lost.	Examinee Informs the Shift Manager that 79.5 % of all Annunciators have been lost.	S U
-----	-----	--	---	-----

CUE: The Shift Manager has been informed that 79.5 % of Annunciators have been lost

6.	L.3	Determine affected annunciators using the	Examinee starts to address the associated	S U
		associated attachment page.	attachment page in the procedure.	

CUE: Another Operator will determine the affected annunciators.

WCGS -SRO/RO TRAINING PROGRAM JOB PERFORMANCE MEASURE EVALUATION FORM

7.	L.4	Refer to EPP 06-005, Emergency Classification	The Examinee starts to refer to EPP 06-005, Emergency Classification	S U
----	-----	---	---	-----

CUE: The Shift Manager has declared a Notification of an Unusual Event

INFORM CUE: What would be the minimum directions given to the watchstanders?

Element #	Step #	Element	Standard	Score
8.*	L.5	Increase tours where the annunciation has been lost.	Examinee contacts Watchstanders to increase frequency of tours throughout the plant.	S U

CUE:

All Watchstanders have been informed.

Termination: Completing Section L.5 completes the JPM.

Stop Time _____

* Critical Step

WCGS -SRO/RO TRAINING PROGRAM JOB PERFORMANCE MEASURE EVALUATION FORM

Initial Conditions:

An Event has occurred in the plant and theControl Room Supervisor (CRS) suspects a Loss of Annunciators.

The NPIS computer is available.

Initiating Cues:

The Shift Manager has requested you to determine the percentage of lost Annunciators for E-Plan purposes.

(Unplanned loss of greater than or equal to 75% of MCB Annunciators or indication for > 15 minutes will require Notification of Unusual Event as a minimum)

Notes:

If you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.
ADMIN RO-A5

WCGS -SRO/RO TRAINING PROGRAM JOB PERFORMANCE MEASURE EVALUATION FORM

Attachment A Training Use Only

Failed Power Supply
E1PS1
E1PS2
E1PS3
E1PS4
E2PS1
E2PS2
E2PS3
E2PS4

FOR TRAINING USE ONLY

WCGS RADIOLOGICAL SURVEY MAP

RPF02-210-1(Q)REV 3		Page	of	Date	Time	
1974' AUX BLDG NORMAL CHARGING PUMP RM #111	5			∦ All unle	Dose Rates in mrem ss specified.	/hr
	-			All unle	Dose Rates <2 mRem ss specified.	/hr
				Beta unle	/Gamma <1000 dpm/1 ss specified.	OOcm 2
×			ଭ	All Alph unle	Smears which were a <20 dpm/100cm ² ss specified.	counted for
si j	F	⁻²⁻		All <100	Large Area Smears 0 dpm/LAS, unless :	(LAS) specified.
×		2	8	STA	ATUS BOARD UPDATED:	
		۶ ۲			NO CHANGE	
					Smear Data Fo Smears > Limits	r above
		-			(DPM/Smear Ar	ea)
		HS-1	▁▋▋	NO.	Beta/Gamma	Alpha
			抓			
			ľ			
		r				
		¥	X 🖉			
			×			
ව	$\left(\begin{array}{c} \end{array} \right)$	l				
•						
	1115					
		FPWIN\MTHI	LY\3RD\1115			
SURVEY REASON			RWP#		* POWER	
INST(S)/WC#	/		/		/	/
REMARKS						
		HP D	Dose for Su	irvey	mR	em
Performed By:	D F	Reviewed	By:	Superviso	or Operations	Date
G = GAITRON	NICS P = PHONE	LR =	= LADDER R <i>i</i>	CK		
$\Delta = \text{radiation area} \qquad \Delta = \text{contaminated area} \qquad \Delta$	- HOT PARTICLE ARE	A	$\underline{A}_{=}$	AIRBORNE R	ADIOACTIVITY AREA,	DUE TO NOBLE G
\underline{A} = locked high radiation area \underline{A} = potential hot particle area	= AIRBORNE RADIOAC	TIVITY A	REA A=	RADIOLOGIC	L MAIDRIALS AREA	EA

ADMIN TASK:	Perform an RCS Inventory Balance			
TASK #: EPE009002				
K/A #s: 2.1.23				
References: STS BB-004	4, Rev. 22			
Examinee's Name		_ SS No		SRO_X _ RO
The examinee's performa	nce was evaluated against the standards in this JPM	and determined	to be :	
SATISFACTORY	UNSATISFACTORY			
Reason, if MARGINA	L or UNSATISFACTORY:			
Estimated JPM comple	tion Time: 20 min.			
Actual Performance Ti	me:min.			
Location of Performan	ce: Classroom			
Method of Performanc	e: Perform			
Evaluators Signature: _			Date	

Notes: ADMIN JPM

Provide a **GREEN** "Information Only" copy of STS BB-004 with cover sheet. Ensure initial conditions are signed off. Ensure the procedure signed off up through step 9.5 and Attachment A has initial and final data filled in.

Initial Conditions:

You are a Relief Crew Licensed Operator; the plant is stable at 100% power. The operating crew has indications of a leak in Containment.

Initiating Cues:

The Control Room Supervisor had the RO perform a 4 hour STS BB-004 for RCS leakage and has completed the data collection. The CRS directs you to complete STS BB-004 calculations, beginning at Step 9.6, to determine if there is an RCS leak. The CRS provides you with the following information.

Chemistry performed <u>no</u> sampling or chemical additions. STN CH-020 results are < 0.815 gallons per day. STS PE-019, RCS Pressure Isolation valve Leakage, is 0.145 gpm.

READ TO EXAMINEE:

If you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

When you have completed the JPM inform your evaluator that you are done by handing this Initial Conditions/Initiating Cues sheet back to him.

TASK STANDARD:

Upon completion of this JPM the operator will have calculated the leak rate on the RCS per STS BB-004. Final Value for unidentified leakage is 0.485 gpm \pm .05 gpm, and Identified T.S. Leakage of 0.164 gpm \pm .05 gpm.

Element #	Step #	Element	Standard	Score
1.*	9.7	Calculate RCS leakage using Attachment B and log the results in the Control Room Log.	Complete calculations.	S U

Cue:

Comments: Logging the results in the Control Room Log is not required for this JPM.

2.

Cue: Reply as CRS that individual component leakage will not be determined.

Comments:

Termination: Calculation of RCS leakage completes this JPM.

Stop Time ____

NOTE: Calculated values should be as follow: Step B.1.2 = 6.142 gallons Step B.2.2 = -295.8 gallons Step B.3.3 = -19.25 gallons Step B.4.3 = 430 gallons Step B.4.6 = 0 gallons Step B.5 = 121.092 gallons Step B.6.2 = 0.5045 gpm Step B.7.3.2 = 4.508 gallons

Step B.7.5 = .0188 gpm

Step B.7.8 = Total Identified Leakage ≈ 0.0188 gpm.

Step B.8.1 = Unidentified Leakage Rate ≈ 0.4852 gpm.

Step B.9.1 = Total Identified T.S. Leakage 0.1643 gpm.

Initial Conditions:

You are a Relief Crew Licensed Operator; the plant is stable at 100% power. The operating crew has indications of a leak in Containment.

Initiating Cues:

The Control Room Supervisor had the RO perform a 4 hour STS BB-004 for RCS leakage and has completed the data collection. The CRS directs you to complete STS BB-004 calculations, Step 9.6, to determine if there is an RCS leak. The CRS provides you with the following information.

Chemistry performed <u>no</u> sampling or chemical additions. STN CH-020 results are 0.815 gallons per day. STS PE-019, RCS Pressure Isolation valve Leakage, is 0.145 gpm.

Notes:

If you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

When you have completed the JPM inform your evaluator that you are done by handing this Initial Conditions/Initiating Cues sheet back to him.

ADMIN TASK : Determine the estimated time to boiling, estimated time to core uncovery.	time to onset of con	re uncovery,	and estimated
TASK: APE025004			
K/A #s: 2.1.25			
References: OFN EJ-015, Rev. 8			
Examinee's Name RO	_ SS No		SRO_ <u>X</u>
The examinee's performance was evaluated against the standards in the	nis JPM and determ	ined to be:	
SATISFACTORY UNSATISFACTORY			
Reason if UNSATISFACTORY:			
Estimated JPM completion Time: 10 min.			
Actual Performance Time:min.			
Location of Performance: Classroom			
Method of Performance Perform			
Evaluators Signature:		_ Date	

Notes:

The examiner shall verify that the procedure revision for this JPM is current and that any changes against the referenced procedure does not invalidate this JPM.

Provide the **GREEN**copy of Attachment A of this JPM to the Examinee.

Initial Conditions:

You are a spare SRO in the Control Room for Outage Support. The plant is in Mode 5 with water level in the reactor vessel at 3.5 feet below the vessel flange. Train "A" Residual Heat Removal (RHR) is in operation cooling the reactor core. Train "B" RHR System is in Standby. Reactor Coolant System temperature is 180°F. It has been 9 days since the reactor was shutdown.

Initiating Cues:

Train "A" Residual Heat Removal pump tripped. Attempts to start "B" RHR pump are unsuccessful. The Control Room Supervisor directs you to determine the following using Step 30 of OFN EJ-015,"LOSS OF RHR COOLING":

- 1. the time to boiling
- 2. the time to start of core uncovery.
- 3. the time to complete core uncovery.

Provide **GREEN** copy of Attachment A to the examinee.

Element #	Step #	Element	Standard	Score
1.*	30.a.	Start Time Check plant - IN REDUCED INVENTORY CONDITION.	Recognize the initiating cues stated the water level in the reactor vessel is 3.5 feet below the vessel flange. <i>Answer: YES</i>	S U

Comments:

2.*	30.b.	Estimate time to boiling using FIGURE 5.	Locate Figure 5 of OFN EJ-015. Recognize it has been 9 days since shutdown and that the vessel is not pressurized. Answer: 14 minutes ± 1 .	S U

Comments:

3.*	30.c. Estimate time to onset of core uncovery using FIGURE 6.	Locate Figure 6 of OFN EJ-015. Recognize it has been 9 days since shutdown. Utilize the ONSET OF CORE UNCOVERY graph line. <i>Answer: 127 minutes</i> \pm 5.	S U
-----	---	--	-----

Comments:

4.*	30.d.	Estimate time to complete core uncovery using FIGURE 6.	Locate Figure 6 of OFN EJ-015. Recognize it has been 9 days since shutdown. Utilize the COMPLETE CORE UNCOVERY graph line. <i>Answer: 268 minutes ± 5.</i>	S U

Comments:

Termination: Locating the estimated time to complete core uncovery completes the JPM.

Stop Time _____

_

* Critical Step

Initial Conditions:

You are a spare SRO in the Control Room for Outage Support. The plant is in Mode 5 with water level in the reactor vessel at 3.5 feet below the vessel flange. Train "A" Residual Heat Removal (RHR) is in operation cooling the reactor core. Train "B" RHR System is in Standby. Reactor Coolant System temperature is 180°F. It has been 9 days since the reactor was shutdown.

Initiating Cues:

Train "A" Residual Heat Removal System pump tripped. Attempts to start "B" RHR pump are unsuccessful. The Control Room Supervisor directs you to determine the following using Step 30 of OFN EJ-015,"LOSS OF RHR COOLING":

- 1. the time to boiling
- 2. the time to start of core uncovery.
- 3. the time to complete core uncovery.

Notes:

If you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

When you have completed the JPM inform your evaluator that you are done by handing this Initial Conditions/Initiating Cues sheet back to him.

ATTACHMENT A

KEY

PARAMETER	VALUE
Estimated time to boiling	14 minutes +/- one
Estimated time to onset of core uncovery	127 minutes +/- five
Estimated time complete core uncovery	268 minutes +/- five

ADMIN SRO-A.3

WCGS-SRO/RO/NSO TRAINING PROGRAM JOB PERFORMANCE MEASURE EVALUATION FORM

ADMIN TASK: Given a sequence of events determine the end t allowed by ITS 3.0.4.	ime of an LCO using any	extensions that would be
TASK #: 2.1-3		
K/A #s: 2.2.23, Ability to Track LCO's.		
References: WCGS Integrated Technical Specifications and Bases, LCC) 3.5.2 and Section 1.3.	
Examinee's Name	SS No	SROX RO
The examinee's performance was evaluated against the standards in this.	PM and determined to be :	
SATISFACTORY UNSATISFACTORY		
Reason if UNSATISFACTORY:		
Estimated JPM completion Time: 15 min.		
Actual Performance Time:min.		
Location of Performance: Classroom		
Method of Performance: Perform		
Tools and Equipment:None		
Evaluators Signature:		Date

ADMIN JPM
Notes:
Initial Conditions:
You are the Control Room Supervisor, the plant is stable in Mode 1.
Initiating Cues:
The "A" train SI pump has been declared inoperable. The time of discovery is 1000 on 12/08/2001. The "B" train SI is OPERABLE.
Twelve (12) hours after the "A" train SI is declared inoperable, the "B" train RHR pump is declared inoperable.
At 1000 on 12/09/2001, the "A" train SI pump is restored to OPERABLE status.
When must the "B" train RHR pump be restored to OPERABLE status to avoid commencing a unit shutdown, including any extensions permitted by Technical Specifications?
Task Standard : Upon Completion of this JPM, the operator will have determined that the extensions allowed by section 1.3, "Completion Times", would apply and that LCO 3.5.2 must be exited by 2200 on 12/11/2001.

Elemen t #	Step #	Element	Standard	Score
1.	N/A	"A" train SI pump declared inoperable1000 on 12/08/2001. The "B" train SI is OPERABLE. Enter LCO 3.5.2.	Action A. 72 hours to restore. 100% capacity of ECCS is still available. Restore by 1000 12/11/2001.	

Cue:

Comments:

"B" train RHR pump is declared inoperable2200 12/08/2001.	Still in LCO 3.5.2, Action A. 100% capacity of ECCS is still available. Restoration still 1000 12/11/2001.	S U

Cue:

Comments:

Cue:

Comments:

Termination: Determining that the "B" RHR must be restored by 2200 on 12/11/2001 completes this JPM.

Stop Time _____

*Critical Step

Initial Conditions:

You are the Control Room Supervisor, the plant is stable in Mode 1.

Initiating Cues:

The "A" train SI pump has been declared inoperable. The time of discovery is 1000 on 12/08/2001. The "B" train SI is OPERABLE.

Twelve (12) hours after the "A" train SI is declared inoperable, the "B" train RHR pump is declared inoperable.

At 1000 on 12/09/2001, the "A" train SI pump is restored to OPERABLE status.

When must the "B" train RHR pump be restored to OPERABLE status to avoid commencing a unit shutdown, including any extensions permitted by Technical Specifications?

TASK:	Determine Max Stay Time and Protective Clothing Re	quirements	
TASK #:2.3-1			
SAFETY FUN	NCTION #:N/A		
K/A #s:2.3.2 F	acility ALARA practices.		
References: Ra	d Worker II Training		
Examinee's Na	me	_ SS No	SRO_X_RO
The examinee's j	performance was evaluated against the standards in this	JPM and determined to be :	
SATISFACTO	RY UNSATISFACTORY		
Reason if UNS	ATISFACTORY:		
Estimated JPM	completion Time: <u>15</u> min.		
Actual Perform	ance Time:min.		
Location of Per	rformance: Plant		
Method of Performance: Perform			
Tools and Equi	pment: None		
Evaluators Sign	nature:		Date

Notes:

PROVIDE GREEN Training Only copies of the RWP and the Survey Map to the Examinee.

Initial Conditions:

You are the Auxillary Building Operator, the Control Room request you to manually control BG FCV-121 locally in the Normal Charging Pump Room.

Initiating Cues:

Given a Survey Map of the NCP Room and a copy of the RWP, determine the maximum stay time you would be allowed and the Protective Clothing requirements.

Task Standard: Upon Completion of this JPM, the operator will have determined a maximum stay time of 40 minutes and that a full set of Anti-C's are required to remain in the area.

Element #	Step #	Element	Standard	Score
1.	N/A	Using the Survey map determine the highest dose in the contaminated area is 30 mrem per hour. Using the RWP determine that the maximum dose allowed is 20 mrem.	Determine stay time to equal 40 minutes. $\frac{20 \text{ mrem limit}}{30 \text{ mrem/hr}} = \frac{20 \text{mrem} * 60 \text{min}}{30 \text{ mrem}} = 40 \text{ min.}$ Correct Answer = 40 minutes	SU

Cue:

Comments:

2	N/A	Using the Survey map determine that there is a contaminated area around BG FCV-121 and the highest contamination level inside the comtaminated area is 45k. Using the RWP determine the protective clothing requirements.	Determine that a full set of PC's is required.	SU
---	-----	---	--	----

Cue: IF asked by Examinee state that the controller can not be reached from outside the boundary and they will have to remain in the area.

Comments:

Termination: Determining Stay Time and Protective clothing requirements completes this JPM.

Initial Conditions:

You are the Auxillary Building Operator, the Control Room request you to manually control BG FCV-121 locally in the Normal Charging Pump Room.

Initiating Cues:

Given a Survey Map of the NCP Room and a copy of the RWP, determine the maximum stay time you would be allowed and the Protective Clothing requirements.

Notes:

Plant equipment should not be operated, if you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

When you have completed the JPM inform your evaluator that you are done by handing the Initial Conditions/Initiating Cues sheet back to him.

ADMIN TASK: Classify an Event using the Emergency Plan				
TASK #:OFN060011				
K/A #s: 2.4.41				
References: APF 06-002-01				
Examinee's NameNSO	SS No		_ SRO_	_RO
The examinee's performance was evaluated against the standards in	this JPM and de	etermined to be	:	
SATISFACTORY UNSATISFACTORY				
Reason if UNSATISFACTORY:				
Estimated JPM completion Time: <u>15</u> min.				
Actual Performance Time:min.				
Location of Performance: Simulator				
Method of Performance: Perform				
Tools and Equipment: Simulator				
Evaluators Signature:		Date		

Notes:

The examiner shall verify that the procedure revision for this JPM is current and that any changes against the referenced procedure does not invalidate this JPM.

This Classification will take place at the conclusion of the scenario where the applicant fills the SRO position.

Initial Conditions:

- 1) You have just seen an event(s) take place on the simulator. You are free to look at your notes and look at any reference material.
- 2) Classify the event per the EALs.
- 3) To pass the JPM you must classify at the right level on the correct tree and complete the Emergency Notification Form blocks 1 through 8..

Standard: Blocks 4, 5, 7 and 8 must be filled out correctly.

Page 2 of 4

Start Time _____

SCENARIO #	CLASSIFICATION	EAL TREE
1	ALERT	EAL-4, Main Steam Line Break
		MSLB-1 -2 -5 -6 - ALERT
2	SAE	EAL-8, Safety System Failure/Malfunction SSFM -
		1 - 2 - 3 - SAE
		PAR Evacuate CCL and JRR
3	ALERT	EAL-6, Loss of Electrical Power
		LEP/AC 1 –2 –5 - ALERT
4	NOTIFICATION OF UNUSUAL EVENT	EAL-4, Main Steam Line Break
		MSLB 1 –2 –5 –7 –NUE.

Refer to Immediate Nlotification Forms as Answer Keys. Critical Blocks are 4 - 5 - 7 and 8.

IF asked by examinee for what time to use, cue "Use current time."

Comments: The Critical Step is to correctly classify the event, NOT the time limit.

Classifying the event terminates the JPM

Stop Time _____

ADMIN SRO-A.5

WCGS -SRO/RO TRAINING PROGRAM JOB PERFORMANCE MEASURE EVALUATION FORM

Initial Conditions:

- 1) You have just seen an event(s) take place on the simulator. You are free to look at your notes and look at any reference material.
- 2) Classify the event per the EALs.
- 3) To pass the JPM you must classify at the right level on the correct tree and complete the Emergency Notification Form blocks 1 through 8..

ADMIN SRO-A.5

Page 4 of 4

EPF 06-007-01 Rev 4	MESSAGE NO.:
WOLF CREEK GENERATING STAT	ION EMERGENCY NOTIFICATION
1. <u>STATUS</u> : D ACTUAL D DRILL	STABILITY CLASS: PRECIPITATION: YES
2. CODE WORD (County/State only):	NO
3. NOTIFICATION TYPE:	7. RADIOLOGICAL RELEASE STATUS:
$\square \text{ IMMEDIATE (Steps 1-8, & 13)} \square$	NONE DIANNED MONITORED
FOLLOWUP (ALL)	TERMINATED UNPLANNED UNMONITORED
4. EMERGENCY CLASSIFICATION:	(If NONE, do not complete steps 10, 11, & 12)
TIME: DATE:/ /	8. PROTECTIVE ACTION RECOMMENDATION: N/A
UNUSUAL EVENT ALERT SITE AREA	EVACUATECCL & JRRC
General Recovery Termination	0-2 MILES EVACUATEN-2SHELTER
5. <u>REASON FOR CLASSIFICATION</u> : (EAL)	EVACUATECTRSHELTER EVACUATENE-2SHELTER
□ 1-RER □ 2-SGTF □ 3-LRCB □ 4-MSLB	2-5 MILES EVACUATE NE-3 SHELTER
5-FEF 6-LEP/AC 7-FHA 8-SSFM	EVACUATE N-1 SHELTER EVACUATE E-2 SHELTER
9-LPC/SC 10-FR 11-NP 12-OH	EVACUATE NE-1 SHELTER EVACUATE SE-2
13-ADM	EVACUATE E-1 SHELTER EVACUATE SE-3 SHELTER
EAL Step Numbers	EVACUATESE-1SHELTER EVACUATESE-4SHELTER
6. <u>METEOROLOGICAL DATA</u> :	EVACUATE S-1 SHELTER EVACUATE S-2 SHELTER
WIND: AT: MPH, FROM: TOWARDS:	EVACUATE SW-1 SHELTER EVACUATE SW-2 SHELTER
Degrees	EVACUATEW-1SHELTER EVACUATEW-2SHELTER
	EVACUATE NW-1 SHELTER EVACUATE NW-2 SHELTER
 9. <u>CURRENT PLANT CONDITION</u>: LI IMPROVING LI TIME REACTOR TRIE 10. <u>FIELD TEAM DATA</u>: Not Available; Time C 	STABILIZED DEGRADING PPED ollected: At Miles
From CTMT =	
mR/hr GAMMA, (uCi/cc) IODINE, (uCi/cc) PART.
11. <u>RELEASE RATE</u> : Release Start Time:	Estimated Total Release Time In Hours:
At (Time) Release Rate = RADIOIODINE	Ci/Sec NOBLE GAS and Ci/Sec
12. <u>CENTERLINE DOSES</u> (Based on):	
\square rad monitoring system \square usar source	TERM ESTIMATE \Box FIELD TEAM MONITORING DATA
INTEGRATED DOSES PROJECTED (TIME)	: RELEASE START RELEASE STOPPED
TEDE (REM)	THYROID (REM)
2 MT	
5 MI	
10	
MI	
COMMENTS: [Commitment Step 3.2.1]	
	/ /
Signatur	e Title Time
(FOR WCNOC USE ONLY) PRIMARY	ALTERNATE CONTACTS PERSON/TIME

COFFEY COUNTY SHERIFF	620-364-2123	STATION RADIO	KHP 785-827-4437	
KANSAS DIVISION OF EMERGENCY MANAGEMENT	785-296-3176 LEAVE MESSAGE	STATE RADIO	STATE EOC ACTIVATED 785-274-1422	
NRC RESIDENT INSPECTOR	OFFICE EXT. 4574	FRANK BRUSH Hor NRC P	Cell: 620-343-0577 ne: 620-364-3631 AGER 816-466-5209	
TOPEKA SYSTEM DISPATCH	785-575-6078			
ANI (ALERT OR HIGHER)	860-561-3433; OFF HOURS LEAVE MESSAGE			
INPO (ALERT OR 800-321-0614 HIGHER)		4		

TASK: Perform Hydrogen Recombiner Startup	
TASK #: 02800003	
Safety Function: #5	
K/A #s: A1.01, 1.02; A2.01, 2.02, 2.03; A4.01, 4.02, 4.03.	
References: SYS GS-120, Rev. 10	
Examinee's Name SS No	SRORO
The examinee's performance was evaluated against the standards in this JPM and determined to be :	
SATISFACTORY UNSATISFACTORY	
Reason, if MARGINAL or UNSATISFACTORY:	
Estimated JPM completion Time: <u>17</u> min.	
Actual Performance Time:min.	
Location of Performance: Control Room	
Method of Performance: Simulate	
Tools and Equipment: Simulator	
Evaluators Signature:	Date

Notes:

Provide the **GREEN** "Information Only" copy of SYS GS-120 to the examinee.

Cues are in BOLD TEXT.

This JPM is performed in the Control Room.

Initial Conditions:

You are the Reactor Operator, EMG FR-C1 is in effect. Conditions are as follows:

- Containment hydrogen concentration is 1.3%.
- Containment Pressure is 6.1 PSIG.
- Pre-LOCA Containment Temperature was 90 degrees F.
- Atmosperic Pressure is 14.7 PSIA.

Initiating Cues:

The Control Room Supervisor directs you to start-up Hydrogen Recombiner "B" and verify proper operation by thermocouple temperature using steps <u>6.4.1</u> through <u>6.4.4</u> of SYS GS-120. Prerequisites have been completed for the "B" Hydrogen Recombiner.

Do not operate any equipment in the plant.

Element #	Step #	Element	Standard	Score
		Start Time		
1.*	6.4.1	At GS065B , turn the $\rm H_2$ recombiner Power Out switch on to ON.	Locate GS HIS-29B on GS065B located behind the Control Boards ,just south of RP068. Turn the switch to ON.	S U
		GS HIS-29B		

Cue: GS HIS-29B is ON.

Comments:

2.	6.4.2	Verify Red lamp on the Power Out switch Plate is lit.	Locate the Switch Plate on GS065B. The Red lamp is above GS HS-29B. Verify the Red	S U
			light is lit.	

Cue: Red lamp is lit.

Comments:

3.	6.4.3	Determine Recombiner setting by performing the following:	Complete elements 3a through 3d.	N/A
----	-------	---	----------------------------------	-----

Cue:

Comments:

3a.6.4.3.1Record from Plant Operating Logs the Pre- LOCA containment temperature.Same as element.	3a.	S U
--	-----	-----

Cue:

Comments: From Initial Conditions Pre-LOCA containment Temperature - 90°F

3b.*	6.4.3.2	Determine pressure factor (Cp) using Figure 1, RECOMBINER POWER CORRECTION FACTOR VERSUS CONTAINMENT PRESSURE CURVE.	Use Figure 1 to determine the pressure factor using the containment pressure given in the Initial Conditions (6.1 psig) and the given Pre- LOCA Containment Temp (90). Pressure factor recorded should be:	S U
			$1.5 \pm .01 (1.29 - 1.51)$	

Cue:

Comments: Examinee must convert psig to psia to use chart. 6.1 + 14.7 = 20.8 PSIA.

* Critical Step

<u>Element</u> <u>#</u>	<u>Step #</u>	Element	Standard	<u>Score</u>
3c.*	6.4.3.3	Multiply the Reference Power (OA88-10-2) by Cp to determine the required recombiner power setting as indicated on the power meter. SGS01B Reference PowerX Cp= Power Setting	Get reference power off plaque located on the recombiner panel. Calculated the corrected Power for the recombiner. 43 X 1.3 = 55.9 Acceptable range 55.47 to 56.33 (The power calculated will depend on the Cp that was determined from Figure 1.)	S U

Cue:

Comments: OA88-10-2 is the Operator Aid plaque located on the "B" H2 Recombiner.

21*	(121			C II
3a.*	6.4.3.4	Furn Power Adjust Potentiometer to obtain	Adjust GS HK-29 to obtain the calculated	50
		the power setting calculated in step 6.3.4.3	power as indicated on II0029.	

Cue:

Comments:

4.	6.4.4	Verify recombiner operation using Attachment A, VERIFICATION OF RECOBINER OPERATION.	Complete elements 4a through 4c.	N/A

Comments:

NOTE: E	NOTE: Examinee should read and adhere to the NOTES prior to A.1.1.					
4a.	A.1.1	Verify proper recombiner heatup rate using Figure 2.	Same as element. Examinee should use the plot as a guide to the proper heatup rate.	S U		

Cue:

Comments: The examinee needs to demonstrate how to obtain temperature readings before using time compression for final readings. Optional: Provide data sheet to examinee.

4b.*	A.1.2	Record temperatures for the operating	Record Channel 1, 2 and 3 temperatures from TI0029 and calculate the average temperature	S U
		temperature indicator (TI0029 for SGS01B)	Average = 1226 degrees.	

Cue: Thermocouple readings after 5 hours are T1= 1216, T2= 1223, T3=1239.

Comments: Minimum average temperature to ensure recombiner operation is 1225° F.

*Critical Step

Element #	Step #	Element	Standard	Score
4c.*	A.1.3	Verify the average temperature is > 1225°F	Compare the Average temperatures to verify they are $> 1225^{\circ}$ F.	S U

Cue:

Comments: Calculated average should be 1226°F.

5.	A.2	Verification by observation of H2 Concentration in Containment	NOT REQUIRED FOR THIS JPM.	N/A
----	-----	---	----------------------------	-----

Cue: Another Operator will perform section A.2

Comments: NOTE: Examinee will not be required to perform A.2 of Attachment A.

6.	6.4.4	Examinee returns to step 6.4.4	Recognize this completes this JPM.	N/A
----	-------	--------------------------------	------------------------------------	-----

Termination: Verifying recombiner thermocouple operation completes the JPM.

Stop Time _____

*Critical Step

Initial Conditions:

You are the Reactor Operator, EMG FR-C1 is in effect. Conditions are as follows:

- Containment hydrogen concentration is 1.3%.
- Containment Pressure is 6.1 PSIG.
- Pre-LOCA Containment Temperature was 90 degrees F.
- Atmosperic Pressure is 14.7 PSIA.

Initiating Cues:

The Control Room Supervisor directs you to start-up Hydrogen Recombiner "B" and verify proper operation by thermocouple temperature using steps <u>6.4.1</u> through <u>6.4.4</u> of SYS GS-120. Prerequisites have been completed for the "B" Hydrogen Recombiner.

Notes:

Plant equipment should not be operated, if you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

When you have completed the JPM inform your evaluator that you are done by handing this Initial Conditions/Initiating Cues sheet back to him.

TASK:	Isolate ESW Drains					
TASK #:OFN003003						
SAFETY FU	NCTION #: 4					
K/A #s: 2.4.1	K/A #s: 2.4.1					
References: OF	FN SG-003 "Natural Events", DCP 07225 "Emergency Makeup Water Requirement For AFW From ESW/UHS."					
Examinee's Na NSO	ame SS No SRO RO					
The examinee's p	performance was evaluated against the standards in this JPM and determined to be :					
SATISFACTO	DRY UNSATISFACTORY					
Reason if UNS	SATISFACTORY:					
Estimated JPM completion Time: 15 min.						
Actual Performance Time:min.						
Location of Performance: Control Room Simulator Plant X						
Method of Performance: Simulate X Perform						
Tools and Equipment: None						
Evaluators Sigr	nature: Date					

Г

WCGS -SRO/RO/NSO TRAINING PROGRAM JOB PERFORMANCE MEASURE EVALUATION FORM

Notes:				
READ TO EXAMINEE				
Plant equipment should not be operated, if you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You may not solicit technical information from other operators, engineers or technical advisors.				
Upon arriving at a component, describe to your evaluator what you expect to see (e.g. how valve, breaker, etc. position is determined), v do (e.g. turn switch to run, rotate handwheel clockwise to open, etc.) and what you expect to happen (e.g. pump will start and red light w will rotate until valve is open, etc.).				
When you have completed the JPM inform your evaluator that you are done by handing the Initial Conditions/Initiating Cues sheet back to him.				
When recording data on Data Sheets, indicate the instrument used and vocalize the value you will record for each parameter.				
* Denotes Critical Step				
Initial Conditions: You are the Turbine Building Operator, the plant has experienced a Seismic Event which has caused a Cooling Dam failure. The Control Room has entered OFN SG-003, "Natural Events", Attachment D.				
Initiating Cues:				
The Control Room Supervisor directs you to close ESW To Aux Feedwater Pumps Inlet Header Drains:				
 AL-V136, "ESW TO MDAFW PUMP A SUCTION LINE VENT" AL-V137, "ESW TO MDAFW PUMP B SUCTION LINE VENT" AL-V138, "ESW TRAIN A TO TDAFWP SUCTION LINE VENT" AL-V139, "ESW TRAIN B TO TDAFWP SUCTION LINE VENT" 				
Task Standard: Upon Completion of this JPM, the operator will have isolated the leak paths from ESW to the floor drains for the Aux Feedwater System.				

Elements 1,2 and 3 of this JPM may be performed in any order

Element #	Step #	Element	Standard	Score		
1.		Start Time	Complete elements 1a through 1c.	N/A		
		Isolate ESW to TDAFW pump inlet header drains.				
Cue: drain."	Cue: IF examinee discusses looking for flow at tail pipe drain to floor drain, THEN cue "water is flowing from pipe to drain."					
Comment	Comments: Examinee may not check for flow indication and go straight to valves.					
1a. *		Isolate Red Train ESW drain to TDAFW pump suction.	Locate AL-V138 in the TDAFW pump room and close.	S U		
Cue:	Cue: After examinee locates valve and properly discusses closing it cue, "AL-V138 indicates closed".					
Comment	s:					
1b. *		Isolate Yellow Train ESW drain to TDAFW pump suction.	Locate AL-V139 in the TDAFW pump room and close.	S U		
Cue:	Cue: After examinee locates valve and properly discusses closing it cue, "AL-V139 indicates closed".					
Comment	s:					
1c.		Check for flow from tell tale drain to floor drain	Locate tell tale drain to floor drain on west side of TDAFW pump and verify flow has stopped.	S U N/A		
Cue: IF examinee discusses looking for flow at tail pipe drain to floor drain AND has discussed properly closing both valves, THEN cue "no water is seen flowing from pipe to drain."						
Comment	Comments: Examinee should check for flow as diverse indication to ensure valves are fully shut. Not required for this JPM.					
2.		Isolate Inlet Header drain on Red Train ESW to "A" AFW pump suction.	Complete elements 2a and 2b	N/A		
Cue: drain."	IF examinee discusses looking for flow at tail pipe drain to floor drain, THEN cue "water is flowing from pipe to 1. "					

Comments: Examinee may not check for flow indication and go straight to valves.

* Denotes Critical Step

Element #	Step #	Element	Standard	Score		
2a. *		Isolate drain on Red Train ESW to "A" AFW pump suction.	Locate AL-V136 in the "A" AFW pump room and close.	S U		
Cue:	Aft	ter examinee locates valve and properly discusses clos	sing it cue, "AL-V136 indicates closed".			
Comment	s:					
2b.		Check for flow from tell tale drain to floor drain	Locate tell tale drain to floor drain on south side of "A" AFW pump and verify flow has stopped.	S U N/A		
Cue: IF examinee discusses looking for flow at tail pipe drain to floor drain AND has discussed properly closing valve, THEN cue "no water is seen flowing from pipe to drain."						
Comment	s: Exa	aminee should check for flow as diverse indication to e	ensure valve is fully shut. Not required for this JPM	[.		
3.		Isolate inlet header drain on Yellow Train ESW to "B" AFW pump suction.	Complete elements 3a and 3b			
Cue: drain."	Cue: IF examinee discusses looking for flow at tail pipe drain to floor drain, THEN cue "water is flowing from pipe to drain."					
Comment	s: Exa	aminee may not check for flow indication and go straig	t to valves.			
3a. *		Isolate drain on Yellow Train ESW to "B" AFW pump suction.	Locate AL-V137 in the "B" AFW pump room and close	S U		
Cue: After examinee locates valve and properly discusses closing it cue, "AL-V137 indicates closed".						
Comment	s:					
3b.		Check for flow from tell tale drain to floor drain	Locate tell tale drain to floor drain on south side of "B" AFW pump and verify flow has stopped	S U N/A		
Cue:	IF examinee discusses looking for flow at tail pipe drain to floor drain AND has discussed properly closing valve, THEN cue "no water is seen flowing from pipe to drain."					
Comment	s: Exa	Examinee should check for flow as diverse indication to ensure valve is fully shut. Not required for this JPM.				
	Te	Termination: Closing of all four valves terminates this JPM.				
	Sto	Stop Time				

* Denotes Critical Step
Initial Conditions:

You are the Turbine Building Operator, the plant has experienced a Seismic Event which has caused a Cooling Dam failure. The Control Room has entered OFN SG-003, "Natural Events", Attachment D.

Initiating Cues:

The Control Room Supervisor directs you to close ESW To Aux Feedwater Pumps Inlet Header Drains:

o AL-V136, "ESW TO MDAFW PUMP A SUCTION LINE VENT"

o AL-V137, "ESW TO MDAFW PUMP B SUCTION LINE VENT"

o AL-V138, "ESW TRAIN A TO TDAFWP SUCTION LINE VENT"

o AL-V139, "ESW TRAIN B TO TDAFWP SUCTION LINE VENT"

Notes:

Plant equipment should not be operated, if you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

Upon arriving at a component, describe to your evaluator what you expect to see (e.g. how valve, breaker, etc. position is determined), v do (e.g. turn switch to run, rotate handwheel clockwise to open, etc.) and what you expect to happen (e.g. pump will start and red light w will rotate until valve is open, etc.).

When you have completed the JPM inform your evaluator that you are done by handing the Initial Conditions/Initiating Cues sheet back to him.



OFN SG-003

NATURAL EVENTS

Responsible Manager

Manager Operations

ሹ ጅ ጅ ጅ ጅ ጅ ጅ ጅ ጅ	₳₢₢₢₢₢₢₢₢₢₢₢₢₢₢₢₢₢₢	<i>፞፞፞፞፞፞፞፞፞ቝ፼ቘቘቘቘቘቘቘቘቘቘቘቚ</i>	₢₢₢₯
	¤ Revision Number ታሁሁሁሁምምምምምምም	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	₽ ₽
₶₶₶₶₶₶₶	치 Use Category	Ц	Continuous
<i>₻₽₽₽₽₽₽₽</i> ₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽	ੑੑ <i>ਖ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼</i>	<i>፞፞ቚ፞፞፞፞ቚ፞ቝ፞ቚ፞ቝ፞ቚ፞</i> ቝ፞ቝ	<i>₠₦₽₽₽₽₽₽</i> ₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽
	¤ Administrative Controls Procedure ቻ፟፟፟፝፝)	ኇኇኇኇኇኇኇኇ ጟ
<i>\$\$\$\$\$\$\$\$\$\$\$\$\$</i> \$	¤ Infrequently Performed Procedure ታሌሌሌሌሌሌሌሌሌሌሌሌሌሌሌሌሌሌ	RRRRRRRR n No	ᠴ ᢑᢑᢘ᠋ᢐ᠋ᠼᢑᢘᢘᢘᢘ
₲₲₲₲₲₲	¤ Program Number	¤ 21A	Д
$\hat{\varphi}\hat{\varphi}\hat{\varphi}\hat{\varphi}\hat{\varphi}\hat{\varphi}\hat{\varphi}\hat{\varphi}\hat{\varphi}\hat{\varphi}$	<i>ᠿᡧᡧᡧᡧᡧᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩ</i>	᠈ℰℰℰℰℰℰℰℰ	₢₢₢₢₢₢

DC12 09/27/2000

1.0 <u>PURPOSE</u>

Continuous Use

- 1.1 This procedure provides instructions for operator response to any of the following naturally occurring events.
 - * Earthquake
 - * Tornado
 - * Flooding
 - * Loss of cooling lake

2.0 <u>SYMPTOMS OR ENTRY CONDITIONS</u>

- 2.1 This procedure is entered after an earthquake based on any of the following symptoms:
 - * Annunciator 00-098A, R SPCTRM SSE EXCEED LIT
 - * Annunciator 00-098B, SSE LIT
 - * Annunciator 00-098C, R SPCTRM OBE EXCEED LIT
 - * Annunciator 00-098D, OBE LIT
 - * Annunciator 00-098E, SEISMIC RECORDER ON LIT
 - * The effects of an earthquake are heard, seen, or felt.
- 2.2 This procedure is entered to respond to a tornado based on any of the following symptoms:
 - * Tornado warning is in effect for the area.
 - * A tornado has been sighted near or is traveling toward the plant.
- 2.3 This procedure is entered to respond to flooding based on the following.
 - * Reported flooding
 - * Annunciator 00-097A, COND PIT LEV HI LIT
- 2.4 This procedure is entered to respond to loss of cooling lake based on any of the following symptoms:
 - * Reported cooling dam failure.
 - * Cooling lake level less than 1080 feet
 - * Condenser vacuum absolute pressure increasing.
 - * Condenser temperature greater than 130°F.

3.0 <u>REFERENCES AND COMMITMENTS</u>

3.1 <u>References</u>

- a. Bechtel Calculation Number FL-05 Rev. 0, "Control Building Flooding"
- - Ц

c. CCP 07784, Missile Shield/Hatch Cover Requirement. [Attachment B, Step B1 NOTE] H

Revision: 8		OFN SG-003
Continuous Use	NATURAL EVENIS	Page 2 of 23
		-
3.2 <u>Commitme</u>	ents	

a. Letter WO 92-0045 [Attachment A, Step A16]

Ц

Revision: 8		א ג כוווים איז		OFN SG-003
Contin	uous Use	NATURAL	EVENIS	Page 3 of 23
STE	ACTION	/EXPECTED	RESPONSE NOT	
1.	Determin Attachme From Tak	ne Appropriate ent For Natural Event ole Below:	<u>IF</u> a natural e progress, <u>THEN</u> procedure and	vent is <u>NO</u> T in return to step in effect.
		✓♥♥♥♥♥♥♥♥♥ □ EVENT □ ↓ [#] ♥♥♥♥♥♥♥ □ EARTHQUAKE □ ↓ [#] ♥♥♥♥♥♥♥♥ ↓ TORNADO □ ↓ [#] ♥♥♥♥♥♥♥♥♥ ↓ FLOODING □ ↓ [#] ♥♥♥♥♥♥♥♥ ↓ FLOODING □ ↓ [#] ♥♥♥♥♥♥♥♥ ↓ COOLING DAM □ ↓ FAILURE □ [#] ¶ ¶ ♥ ♥ ♥ ♥ ♥ ♥ ♥ ♥ ♥ ♥ ♥ ♥ ♥	 \$	> <i>A</i> AAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAA
2.	Go To Ar For Natı	ppropriate Attachment 1ral Event		
3.	Return 1 In Effec	To Procedure And Step st		
		-END-		

	Revision: 8				NATURAL EVENTS			OF	OFN SG-003				
	Coi	ntin	uous Use	NATONAL EVENTS		Page	20	of	23				
1	SI	'E	ACTION	/EXPEC	CTED		$\neg \dashv$	RESPO	ONSE NOT	1			
					COOLIN	ATTACI (Page IG DAM F	HMENT 1 of AILUF	'D 4) Re respo	INSE				-
1. M. M. M. M.	м. м.	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	₽ ₽ ₽ ₽ ₽ ₽ ₽ ₽ ₽ ₽ ₽ ₽ ₽ ₽ ₽	56666	<i>₠₦₦₦</i>	৽৵৵৵৵৵৵	\$\$\$	*\$\$\$\$\$	<i>ᡩᡭᡩᡭ</i> ᡩ	₽₽₽₽	\$\$	€₽€₽	₽₽₽₽₽
\$ <i>\$\$\$\$\$</i> \$	ц Ц Ц	ゆゆよ	>\$\$\$\$\$\$\$\$	>\$\$\$\$\$\$) O	<u>N(</u>	DTE						п
	пп	Coo com	ling lake puter poi	e leve int EF	l of 1 L0027.	980 fee	t cor	respond	s to 108	30 fe	et c	on	пп
€₽₽₽₽	\$ \$ \$ \$	<i>\$`\$`\$</i> \$\$\$	` <i>````````````````````````````````````</i>	` <i>`</i> ` \$`\$`\$`\$`	> v &&&&&&	\$ <i>\$\$\$\$\$\$</i> \$	\$\$\$\$\$	おおおおお	₲₽₽₽₽₽₽	\$ <i>\$\$</i> \$\$	\$\$	€₽€₽	? <i>&&</i> & 7
	I	01.	Check Co HAS OCCU	oling JRRED	Dam Fa OR IS 3	ailure · IMMINEN:	- Г:	Return in effe	to proc ect.	edure	an	d s	tep
			* Report damage	s of a	dam fa:	ilure on	2						
			<u> </u>										
			* Coolin THAN 1	g lake 080 Fi	e level EET	l – LESS	5						
			OR										
			* Conden PRESSU	ser va RE IN(acuum · CREASII	- ABSOLU NG	JTE						
			OR										
			* Conden GREATE	ser to R THAI	emperat N 130ºI	ture - F							
ппп	I	52.	Begin Pl The Foll Directed	ant S owing l By S	hutdown Proceo M/CRS	n Using dures As	5						
			* GEN 00	-004,	POWER	OPERATI	ION						
			<u>OR</u>										
			* GEN 00 HOT SI	-005, ANDBY	MINIM	JM LOAD	ТО						
			OR										
			* OFN MA SHUTDO	-038, WN	RAPID	PLANT							
	I	03.	Notify C Of Plant	offey Stat	Count _i us	y Sheri	E£						
			o Teleph	ione ni	umber (364-2123	3						

Continuo	ous Use ACTION	NATURAL	C 1 11 1 V C	Page 21 of 23
STE -	ACTION			
		/EXPECTED	RESPONSE NOT]
		ATTACHM (Page 2 COOLING DAM FAI	ENT D of 4) LURE RESPONSE	
D4. P. Se	lace Bo ervice	oth ESW Trains In		
a	. Start	both ESW pumps		
b	. Ensur	e ESW to UHS - OPEN	b. Locally ope	n valves.
	o EF	HIS-37 for train A		
	O EF	HIS-38 for train B		
C	. Ensur water	e ESW to service isolation - CLOSED	c. Locally clc	se valves.
	o Tra	in A		
	οE	F HIS-23		
	οE	F HIS-25		
	οE	F HIS-39		
	οE	F HIS-41		
	o Tra	in B		
	οE	F HIS-24		
	οE	F HIS-26		
	οE	F HIS-40		
	οE	F HIS-42		

	Revision: 8 Continuous Use			8						OFN	SG-003
				s Use		NATURAL .	EVEI	NTS		Page 22 of 23	
I	SI	'E	A	CTION	/EXPECTED		[I	RESPONSE NOT		
杀杀杀杀杀	А Ч Ч Ч Ч Ч Ч Ч Ч Ч Ч Ч Ч Ч	文字 分 の Coc	چچ¢ چچچ	چپچچ چچچچ g lake er poi	COOLING پېپېپېپېپېپې پېپېپې e level of 19 int EFL0027.	ATTACHM (Page 3) DAM FAI	ENT of LUR & & E COT	D 4) E R \$\$	ESPONSE 安安安安安安安安安 ponds to 107	今時時時代 75 feet	on 口 口 口 口 口 口 口 口 口
おおおおお	<i>фф</i> , Фф Д	\$ <i>\$</i> \$ \$	>& \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	<i>\$\$\$\$</i> \$\$\$\$ -	<i>`\$`\$</i> \$\$\$\$\$\$ \$`\$\$\$\$\$\$\$\$\$\$\$\$\$	\$ <i>\$\$\$\$\$\$</i> \$	ዽዽ	\$\$	<i>₳₳₳₳₳₳₳</i>	ঽ৾৾৵ড়৾৾ড়৾ড়৾৾ঀ	\$ <i>&&&</i> &&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&
нцц	Ī	05.	Che Tr: a. b.	eck If ipped: Check GREAT Consu Manag Super direc	Reactor Sho cooling lake ER THAN 1075 It Shift er/Control Re visor for fu tion.	uld Be e level - FEET pom rther	-	Pei 1. 2. 3.	form the fo Manually tr Stabilize t EMGs while this proced Stop Circ W 0 1HS-CW0012 0 1HS-CW0022	llowing ip reac he plan continu ure. ater Pu A A	: tor. t using ing with mps.
								 4. 5. 6. 7. 	<pre>At circ wath house, stop a) In diesel room, in place pur control s b) Open fire breakers o 1SL31 (1FP001 o SL4A1RE Break conder using SYS CO MAIN CONDEN Shutdown al cooled by Se</pre>	er scree fire p l fire p panel 1 mp contr switch t e pumps CUB-6 fo PA 5 for 1 SER VAC SER VAC l equipt ervice 1 ce Wate:	en umps. pump lPL06J coller to OFF. or FP002P cuum BREAKING UUM. ment Water. r Pumps
									in Pull-To- o 1HS-WS0012 o 1HS-WS0022	Lock. A A	

o 1HS-WS003A o 1HS-WS004A

		ΝΆΨΙΙΡΑΙ ΕΥΓΕΝΤΡΟ			OFN SG-003	
Contin	uous Use	NATURAL 1	TAFINI 2		Page 23 of 23	
STE -	ACTION/EXPE	CTED	RESPON	SE NOT		
		ATTACHMI (Page 4 d COOLING DAM FAI	ENT D of 4) LURE RESPONS	SE		
D6.	Determine Eme Level Using E EMERGENCY CLA	ergency Action IPP 06-005, ASSIFICATION				
D7.	Establish Cor Watches:	tinuous Fire				
	o In plant ar	eas				
	o In areas wi equipment	th operating				
D8.	Close ESW To Pumps Inlet H	Aux Feedwater Ieader Drains				
	 AL-V136 AL-V137 AL-V138 AL-V139 					
D9.	Inspect The D Piping Associ B Air Compres	Integrity Of The ated With A And sors				
	a. At least e inspect al	every 4 hours, 1 of the	a. Isola compre	te affe essor:	ected air	
	non-safety portions o water syst	r related of the service em associated	1) Clo ini	ose ser let iso	vice water plation valve.	
	B to ensur have occur	red	* I * I	EF HV-4 EF HV-4	13 for train <i>H</i> 14 for train H	
	o CKA01A o CKA01B		2) Clo out	ose ser tlet is	rvice water solation valve	
			* I * I	EF-V346 EF-V345	5 for train A 5 for train B	
D10.	Direct Fire E Specialist To For Backup Fi Equipment	Protection Make Provisions re Protection	3			
D11.	Consult Shift Room Supervis Direction	Manager/Control sor For Further	L			
		-END-				

TASK: Demonstrate the ability to transfer a vital 120 VAC instrument power supply.						
SAFETY FUNCTION: #6						
TASK #:05700018						
K/A #s: 057 AA1.01; AA2.06, AA2.14						
References: OFN NN-021, Rev. 6						
Examinee's Name SS RO SS	S No	SRO				
The examinee's performance was evaluated against the standards in this JPM and	determined to be:					
SATISFACTORY UNSATISFACTORY						
Reason if UNSATISFACTORY:						
Estimated JPM completion Time: <u>15</u> min.						
Actual Performance Time:min.						
Location of Performance: Control Room Simulator	Plant X					
Method of Performance: Simulate X Perform						
Tools and Equipment: Hard Hat Safety glasses Hearing Protection						
Evaluators Signature:	Date					

Notes:

AFTER the Examinee has located a copy of OFN NN-021, "LOSS OF VITAL INSTRUMENT BUS", provide the YELLOW copy of OFN NN-021, Attachment A.

READ TO EXAMINEE

Plant equipment should not be operated, if you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

Upon arriving at a component, describe to your evaluator what you expect to see (e.g. how valve, breaker, etc. position is determined), v do (e.g. turn switch to run, rotate handwheel clockwise to open, etc.) and what you expect to happen (e.g. pump will start and red light w will rotate until valve is open, etc.).

When you have completed the JPM, inform your evaluator that you are done by handing the Initial Conditions/Initiating Cues sheet back to him.

When recording data on Data Sheets, indicate the instrument used and vocalize the value you will record for each parameter.

* Denotes Critical Step

Initial Conditions:

You are the Turbine Bldg. Operator. The plant is in Mode 3 with all checklist items for going into Mode 2 complete. The Control Room received MCB alarms 25A, "NN01 INST BUS UV" and 25B "NN11 INV UV". Subsequently the Reactor Operator verified from OFN NN-021 "Loss of 120 VAC Instrument Bus" that Bus NN01 is de-energized.

Initiating Cues:

The Control Room Supervisor directs you to obtain a copy of the OFN and perform the steps to restore power to bus NN01. All Control Room portions are complete.

Do not operate any equipment in the plant.

TASK STANDARD: Upon completion of this JPM the operator will have placed NN01 on the Sola Transformer per OFN NN-021.

Element #	Step #	Element	Standard	Score
1.	N/A	Start Time Locate a copy of OFN NN-021	The Examinee should demonstrate the ability to locate EOP's in the Turbine Building. They are kept in the Emergency Locker on the 2033' level by the PA / PB Buses. The Evaluator may have the Examinee only describe where they would obtain a copy.	S U

Cue: After Examinee has located a source, provide **YELLOW** copy of OFN NN-021, Attachment A.

Comments: Locating a copy of the procedure from any source completes the element.

2.	N/A	Attachment A, Steps A.1 – A.3	These step are performed in the Control Room.	S U
			Initiating cue says these steps are complete.	
			Examinee should proceed to step A.4	

Cue: If asked, respond "Steps A.1 through A.3 are complete."

Comments:

3. *	A.4.a	Check NN01 Bus – No Apparent Damage	Locate NN01, located on the 2016' level of the	S U
			Control Bldg.	

Cue: After examinee locates bus cue "No apparent damage."

Comments:

4.	A.4.b	Verify inverter output voltage NORMAL.	Locate the inverter output voltmeter on	S U
			NN11.Voltage should be ~ 120 VAC.	

Cue: After examinee describes checking the voltage, "Output voltage is 0 VAC".

Comments:

5.	A.4	Go to step A5	Recognize with no voltage indicated the	S U
	RNO.		Examinee should proceed to the RNO column	
			and go to step A5	

Cue:

Comments:

6.*	A.5	Align Backup Power To Bus NN01.	Perform Steps A5.a through A.5.e.	N/A

Cue:

Comments:

Element #	Step #	Element	Standard	Score
7.*	A.5.a	CLOSE backup transformer XNN05 power supply breaker NG01ACR3.	Locate the breaker on NG01A, north of NG03 in the north Class 1E Switchgear room. Turn NG01ACR3 to the ON position.	S U

Cue: After examinee locates and describes closing the breaker, "*NG01ACR3 indicates ON*."

Comments:

8.*	A.5.b	Verify Backup Power Available white light - LIT	Located on NN01 Panel, located on the 2016'	S U
			level of the control blug.	

Cue: After examinee locates the light, "White Light is LIT."

Comments: Turning the key will withdraw the pawl that locks the slide bar in place.

9.*	N/A	Utilize the Interlock key to operate the interlock	Install the key into the lock mechanism and	S U
		mechanism.	turn.	

Cue: After examinee describes operating the key, "The pawl is down."

Comments: While not listed as a procedure step the Examinee must utilize the key to defeat the interlock. Turning the key will withdraw the pawl that locks the slide bar in place.

9. A.5.c OPEN normal feeder breaker NN0101. The breaker is opened by pushing the left towards OFF.	he switch to S U
--	------------------

Cue: After examinee describes opening the breaker, "The breaker indicates off."

Comments:

10.*	A.5.d	CLOSE alternate feeder breaker NN0102	The slide bar is moved to the left and the switch	S U
			is moved to the left. The White line should be	
			showing on the breaker switch.	

Cue: After examinee describes closing the breaker, "Breaker indicates on."

Comments: The white line indicates the breaker is on. Examinee should contact the Control Room prior to closing the alternate breaker.

9.	A.5.e	Notify the Control Room that NN01 is being supplied from alternate power. T.S. 3.8.7 and 3.8.8 need to be reviewed.	Contact the Control Room and make the report.	S U
----	-------	---	---	-----

Cue: Acknowledge report, provide cue "The CRS will review the T.S.".

Comments:

Termination: Re-energizing NN01 completes this JPM.

Stop Time _____

* Denotes Critical Step

Initial Conditions:

You are the Turbine Bldg. Operator, the plant is in Mode 3 with all checklist items for going into Mode 2 complete. The Control Room received MCB alarms 25A, "NN01 INST BUS UV" and 25B "NN11 INV UV". Subsequently the Reactor Operator verified from OFN NN-021 "Loss of 120 VAC Instrument Bus" that Bus NN01 was de-energized.

Initiating Cues:

The Control Room Supervisor directs you to obtain a copy of the OFN and perform the steps to restore power to bus NN01. All Control Room portions are complete.

Notes:

Plant equipment should not be operated, if you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

Upon arriving at a component, describe to your evaluator what you expect to see (e.g. how valve, breaker, etc. position is determined), what you expect to do (e.g. turn switch to run, rotate handwheel CCW to open, etc.) and what you expect to happen (e.g. pump will start and red light will light, handwheel will rotate until valve is open, etc.).

When you have completed the JPM inform your evaluator that you are done by handing this Initial Conditions/Initiating Cues sheet back to him.

When recording data on Data Sheets, indicate the instrument used and vocalize the value you will record for each parameter.



OFN NN-021

LOSS OF VITAL 120 VAC INSTRUMENT BUS

Responsible Manager

Manager Operations

<u>ለ</u> ለ ለ ለ ለ ለ ለ ለ	<i>\\$</i>	<i>\$\$\$\$\$\$\$\$\$</i>	₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽
	ት Kevision Number ጃ Kevision Number	<i>ŶŔŔŔŔŔŔ</i> Ŕ ^I 6	₽ ₽ ₽
$\lor \lor \lor \lor \lor \lor \lor \lor \lor \lor \lor$	보 Use Category	Ц	Continuous
<u>ለጉ ለጉ ለጉ ለጉ ለጉ ለጉ ለጉ ላጉ የጉ</u> እን	ୢ ୠ <i>ଢ଼ଢ଼ଢ଼ଢ଼ଢ଼ଢ଼ଢ଼ଢ଼ଢ଼ଢ଼ଢ଼ଢ଼ଢ଼ଢ଼ଢ଼ଢ଼ଢ଼ଢ଼ଢ଼</i> ୡ	<i>\$\$\$\$\$\$\$\$\$</i>	₲₢₢₡₡₽
и [,] ⁽²⁾	¤ Administrative Controls Procedure ታሁሁሁሁሁሁሁሁሁሁሁሁሁሁሁሁ	$\begin{array}{ccc} \hat{r} \hat{r} \hat{r} \hat{r} \hat{r} \hat{r} \hat{r} r$	ዯ፞፞፞፞፞ <i>ዯ፞ዾዾዾዾዾዾ</i> ኯ
$\diamond \diamond \diamond$	ជ Infrequently Performed Procedure ማሌሌሌሌሌሌሌሌሌሌሌሌሌሌሌሌሌሌ	д No д No	ਸ਼ ਫ਼ੑਫ਼ੑਫ਼ੑਫ਼ੑਫ਼ੑਫ਼ੑਫ਼ੑਫ਼ੑਫ਼ੑਫ਼ੑਫ਼ੑਫ਼ੑਫ਼ੑਫ਼ੑਫ਼ੑਫ਼ੑਫ਼ੑਫ਼ੑਫ਼ੑ
₲₡₲₲₲₲₲	¤ Program Number	¤ 21A	Д
₡₡₡₡₡₡₡₡₡	<i>জি৾৾৾৾৾৾৾ড়৾৾৾ড়৾ড়৾ড়৾ড়৾ড়৾ড়ড়ড়ড়ড়ড়ড়ড়ড়ড়ড়ড়ড়ড়ড়</i>	<i>ዯ፞፞፞፞፞፞፞፞ቝ፞ቝ፞ቝ፞ቝ፞ቝ፞</i> ዾዾ	₽₽₽₩₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽
	DC12 09/29	/2000	

Continuous Use

LOSS OF VITAL 120 VAC INSTRUMENT BUS

1.0 <u>Purpose</u>

1.1 To provide operator response for loss of vital 120 VAC instrument bus NN01, NN02, NN03, or NN04 when in Modes 1 or 2. This procedure may be used as a reference in other conditions.

2.0 <u>Symptoms or Entry Conditions</u>

2.1 Any of the following vital 120 VAC bus undervoltage annunciators lit.

* 00-025A, NN01 INST BUS UV * 00-026A, NN02 INST BUS UV * 00-027A, NN03 INST BUS UV * 00-028A, NN04 INST BUS UV * 00-025B, NN11 INV UV * 00-026B, NN12 INV UV * 00-027B, NN13 INV UV * 00-028B, NN14 INV UV

3.0 <u>References And Commitments</u>

3.1. <u>References</u>

- a. OFN NN-021, LOSS OF VITAL 120 VAC INSTRUMENT BUS, ^H Supplemental Information
- b. SLNRC 84-0016 File: 0278, "Safe Shutdown Following Loss of Instrument Bus," February 2, 1984.

c. PMR 4590, PDP Replacement

3.2. <u>Commitments</u>

a. LER 92-002, Reactor Trip on Low-Low S/G Water Level μ

Following Loss of an Instrument Bus, RCMS #92-069 [Step 2] μ

Revisi	on: 6				100 1100			5110	OFI	N NN-	-021
Contin	uous	Use L	OSS OF	7 V1'I'AL	120 VAC	INSTRU	JMENT	BUS	Page 2	2 of	54
STE	ACT	TION/EX	PECTEI)		RESI	PONSE	NOT			
▼	\$\$\$\$\$ \$\$\$\$\$ ps 1	ب <i>ۈچچچ</i> ې through	\$\$\$\$\$ \$\$\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	bbbbbbbbbbbbbbbbbbbbbbbbbbbbbbbbbbbbbb	NOTE ne in an	بې orde	ψψψų er.	>\$\$\$\$	\$\$\$\$\$\$\$	\$ <i>\$\$</i> \$	С С С С С С С С С С С С С С С С С С С
<i>₽₽₽₽₽</i> ₽₽₽₽₽₽ ₽	<i>\$\$\$\$</i> \$\$\$\$\$ \$\$\$\$\$	<i>ŶŔŔŔŔ</i> <i>ŔŔŔŔŔ</i>	<i>ŶŔ</i> ŶŶ Ŷ <i>ŔŶŔ</i>	ዯ፞፞፞፞፞፞፞፞፞፞፞፞ቝ፞፼፞ዸ	` <i>&&&</i> &&&	᠅ᡩ᠅ᡩ᠅	かかかん	> <i>&&</i>	? <i>&&&</i> &&	ঽ৾৾৾ড়ড়৾৾ড়	<i>РФФФ</i> п
1.	Loss Conti	Of NNO rol Roc	1 Or 1 Is Ins	NN02 Wit erting:	h	Go To	Step	2.			
	a. ([Sy]) Pla ystem I	ce Rod n Manı	l Control ual:	1						
	1) Place switc	bank h in N	selecto MANUAL	r						
		o SE	HS-9								
	2) Verif	y rod	motion	-	2)	Perfo	orm t	che fo	llow	ing:
		STOPP	ED				a) P] ^J ^{SV} ^A ^D ^{SV} ^A ^C ^A ^C ^A ^C ^C ^A ^C ^C ^C ^C ^C ^C ^C ^C	lace vitch lace vitch roc ontir eacto sing ontir roced	bank h in A bank h in M d moti hues, <u>-</u> or and lize t EMGs huing dure.	sele UTO. sele ANUA on <u>THEN</u> he p whil with	ctor L. trip lant e this
	Revisi Contin STE YUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUU	Revision: 6 Continuous STE ACI YUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUU	Revision: 6 Continuous Use STE ACTION/EX WUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUUU	Revision: 6 Continuous Use STE ACTION/EXPECTEN PUSSUUSUUSUUSUUSUUSUUSUUSUUSUUSUUSUUSUUS	Revision: 6 Continuous Use STE ACTION/EXPECTED Y\$ H H Steps 1 through 3 can be don H O\$ 1. Loss Of NN01 Or NN02 Wit Control Rods Inserting: a. () Place Rod Control System In Manual: 1) Place bank selecto switch in MANUAL o SE HS-9 2) Verify rod motion STOPPED	Revision: 6 LOSS OF VITAL 120 VAC Continuous Use Istep I ACTION/EXPECTED YKKKKKKKKKKKKKKKKKKKKKKKKKKKKKKKKKKKK	Revision: 6 LOSS OF VITAL 120 VAC INSTRICT STE ACTION/EXPECTED RES Y%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%	Revision: 6 Continuous Use LOSS OF VITAL 120 VAC INSTRUMENT STE ACTION/EXPECTED RESPONSE Yt\$	Revision: 6 LOSS OF VITAL 120 VAC INSTRUMENT BUS STE ACTION/EXPECTED RESPONSE NOT Y\$	Revision: 6 LOSS OF VITAL 120 VAC INSTRUMENT BUS OFF Continuous Use NOTE STE ACTION/EXPECTED RESPONSE NOT Y\$	Revision: 6 Continuous Use LOSS OF VITAL 120 VAC INSTRUMENT BUS OFN NN- Page 2 of STE ACTION/EXPECTED RESPONSE NOT **\$

]	Revi	lsio	n: (б				- 10	0 0				OI	ΓN	NN-	021
	Cont	inu	ous	Use	بت ا	USS ()F. VI.I.A	L 12	U VAC	INSTRU	IMEN.I.	BUS	Page	3	of	54
ſ	STE	Н	AC	TIO	N/EX	PECTE	D		Н	RESI	PONSE	NOT				\neg
	2	2. 1	Ensu Are Char	ire Usi inel	S/G ng U s:	Cont: Inaff	rol Sys ected	tems	3							
<i>&&&&</i> &&	€₽₽	<i>\$\$\$</i> \$ <i>\$</i>	\$ <i>&&</i> \$ <i>&</i> \$	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	\$ <i>\$\$</i> \$ \$ \$ \$	\$\$# \$	<i>\$\$\$\$\$</i> 4	ঽ৾৻ঽ৻ঽ	<i>ᡩᡩᡩᡩ</i> ᢠ	? <i>&</i> &&&	>\$\$\$\$	於於於	\$\$\$	ዏዏ	\$\$	おおおお
ц		П						N	NO1 RE	D TRAI	N					
゙ゟゟゟゟゟ	���	д Ф Ф Ф Ф С Г	? \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$, Ф. Ф. Ф. Ф. Ф.	ᢕᢩᡃ᠋ᡃᡧᡧ ᢤᢤᢤᢤ	\$\$\$\$ \$\$\$ ``E` A M	EI OM ØØØØØ	シℰ℣ℰ	₽₽Ţ₽Ċ	ᢣ᠋᠋ᢕ᠋ᢆᡃ᠋ᡧᢆᡧᢕ	\$\$\$\$ \$	сть. ФФФ	ѵӹ	\$\$	Ч	\$\$\$ \$ CEIEC
ц		A D	97 G	T T									OM11	au	T T	
CHANNEL	Ц	д .мм. г	1. M. M.	Д. М. М.	SELE Am.m.	M. M. M.	SWITCH	<u></u> , м. м. м	CHANN 1. m. m. m. m		SELE(C.I.OR M. M. M.	SWII	"СН м. м.	д м. м.	M. M. M. M.
ゆゆゆゆ	���	\$ \$ \$ \$ \$ \$ \$ \$	\$ <i>6</i> \$ \$ <i>6</i> \$	` <i>ÊÊ</i> > <i>&&</i>	\$\$\$ \$	\$\$\$\$	\$\$\$\$\$\$	\$\$\$\$		\$ 77 \$ \$ \$	 >\$\$\$\$\$	 \$\$\$\$	-10~ >分分刃	$\phi\phi$	\$\$	
п		MM.	G A 1 M M	Д м. м.	AB	F'S-5.	м. м. м. м. м. 12С	Д. м. м. м	F513	д Г. А. М. М. М	AE M. M. M.	LS-	519C	м. м.	Д м. м.	1519 м. м. м. м.
ゟゟゟゟ	���	\$ \$ \$ \$ \$ \$ \$ \$ \$	\$ <i>\$</i> \$ <i>\$</i> \$ <i>\$</i> \$ <i>6</i>	` <i>ÊÊ</i> ` <i>ÊÊ</i>	\$ <i>\$</i> \$ \$ \$	\$\$\$\$	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	\$ <i>\$\$\$</i>	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	\$ <i>`</i> ₩ <i>\$</i> \$ <i>\$</i>	 >&&&&	 &&&&		<i>\$\$</i>	\$\$	~~~~ ~~~~~
Ц		AS/	G B	Д	AB	FS-5	22C м м м м м	Д	F523	Д	AE	LS-	529C	мм	Д	L552
ℭ⅌ℭ⅌℄	ঢ়ঢ়ঢ়	\$ \$ \$ \$ \$ \$ \$ \$ \$	\$ <i>\$</i> \$ <i>\$</i> \$ <i>\$</i> \$4	$\hat{\varphi}\hat{\varphi}_{i}$	\$ <i>\$\$</i> \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	<i>₽₽</i> ₽\$ ₽₽₽₽	<i>\$\$\$\$\$\$</i>	\$ <i>\$</i> \$ 6 6	<i>ᡩᡬᢤᡬᢤᢤ</i>	<i>ቅ ሣ </i>	\$ <i>&&</i> &	፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞ ቝ፟	ዾኇኇ	<i>\$\$</i>	$\phi\phi\phi$	ゆゆゆゆ
д		¤s/	GC	Д	AB	FS-5	32C	Д 	F533	Д	AE	LS-	539C		Д	L553
おおおお	╚╚╚	<i>₠</i> ₽¢ ₽₽¢	\$ <i>\$\$\$</i> \$ <i>\$</i> \$6	` <i>ÊÊ</i>	\$\$\$ 9	\$\$\$\$ \$\$\$\$	\$\$\$\$\$\$\$	\$ <i>\$</i> \$ <i>\$</i>	<i>ᡩᡩᡩᢤ</i> ᡬ	₽₽₽₽₽₽	\$ <i>\$\$\$</i> \$	かかん	᠅ᡬᡷᡬᡷᢙ	ゆゆ	$\mathcal{E}\mathcal{E}$	ゆゆゆゆ
ц		¤s/	G D	Ц	AB	FS-5	42C	Ц	F543	Ц	AE	LS-	549C		Ц	L549
おおおおお	���	д Ф. С. С. С. С. С. С. С. С. С. С. С. С. С.	\$ <i>\$\$\$</i> \$ <i>\$</i> \$ <i>\$</i>	` <i>&&</i> ` <i>&&</i>	\$ <i>\$\$</i> \$ 0 <i>\$</i> \$	\$\$\$ \$	<i>₠₠₠</i> ₡₡	\$ <i>\$\$</i> \$	<i>ᡩᡭᡩᢤ</i> ᡬ	ঢ়৾৾৾ড়ড়৾৾ড়	\$ <i>\$\$\$\$</i> \$	於於於	シىكىك	\$\$ \$\$	谷谷	おおおお
ц		П						NN02	WHITE	TRAIN	J					
ц		ዄኇዸ	ዮድዽ	ምድ	⊕৸৸	~~~~~	RRRRA	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	RRRRR	60666	~~~~~ ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	ዮዮዮ	ዾኇዸ	ዮዮ	55	RRRR
おおおおお	\$\$\$	\$0 # 5	\$\$\$ \/G	ц Ц Ц Ц	₹₩₩ ST	\$\$\$ Eam	FIOW	Д	SELEC	,-,, т ¤		SG I.	EVEL		ц	SELECT
Д		ц	, C	Ц	SELE	CTOR	SWITCH	пц	CHANN	- ਜਾ. ਖ	SELE		SWIT	'ਟਸ	Ц	
CHANNEL	Ц		1, U, U	ر لار لار	~~~ 2777	(U, U, U, U,		<i>, ע, ע, ע</i>		r < r < r < r		ش ش ش 1010	K K K K K K K K K K K K K K K K K K K	لام لام م	للرلار	K. K. K. K.
ゆゆゆゆ	���	<u>ис</u> /	\$\$\$ \$	ᢣᡩᢆᡛᡷᡝ	$\mathbb{C}^{\mathbb{N}}$	\$ \$ F C-5	120	л у у у М	v v v v v	т үүү ү Т	א לי לי א א די	тс_	510C	$\checkmark \checkmark$	Y Y M	T 5 5 1
ц			с д 1. U. U.	. U. U.	AD AL		עג עג עג עג ע ד ב כ	, U, U, U	ד. ס ד ב 1. ע. ע. ע. ע	ר לי גר גר גר ע		<u>т</u> р_		<u> </u>		
ゟゟゟゟ	₢₢₢	て () () () () () () () () () ()	~~~ ~ ~ ~ ~ ~	$\mathcal{P}\mathcal{P}$	$\mathcal{P} \mathcal{P} \mathcal{P} \mathcal{P}$	~~~~~ \$\$\$\$ ~~~~~~~~~~~~~~~~~~~~~~~~~~~	, , , , , , , , , , , , , , , , , , ,	м М	~~~~~~ ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	A M A A A	ᆠᄼᄿᄿ	ү У У У У У У У	~~~`A	$\checkmark \diamondsuit$	м М	ΫΫΫΫ
Д		ч 5 /	с В 1. Μ. Μ.	д . М. М.	АВ Ф. М. М.	г 5-5. м. м. м.	Δ <u>Δ</u>	д , м, м, м	Г Э <i>Д Д</i> 1. М. М. М. М	д . <u>с</u> м. м. м	AE	- СЦ	529C	М. М.	м. м.	⊔э∠у м. м. м. м.
おおおおお	╚ҾҾ	\mathcal{P}	$\phi \phi \phi$	$\hat{\varphi}\hat{\varphi}_{i}$	\$\$\$ \$\$\$	\$\$\$\$ \$\$\$\$	$\phi \phi \phi \phi \phi$	$\langle \phi \phi$	 \$\$\$\$\$\$	ッムなんたい	 \$\$\$\$\$		トゥウィ	$\Diamond \Diamond$	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	$\Delta \Delta \Delta \Delta \Delta$
ц		μS/	GĊ	Ц	AB	FS-5	32C	Ц	F532	Д	AE	LS-	539C		Ц	L539

µS/G D ¤ AB FS-542C ¤ F542 ¤ AE LS-549C ¤ L554

	Rev	isi	on: (5			0		100		TNORD			0	FN	NN-	021
	Con	tin	uous	Use	ΓO	55 (JF VI	IAL	120	VAC	INSIR	OMEN	I BUS	Page	4	of	54
1	STE		AC'	TION,	/EXP	ECTI	ED				RES	PONS	E NOT				\neg
।ম্বম্বয <u>়</u>	ୁ ଅଧିକ ଜ ଓ ଜ ଓ ଜ	presprie	BBB BBB ssuri	zer swa	BBB BBB pres	ssur SØG	SKK SKK SKK SKK SKK	SBB SBB ster ure	CAU CAU COI COI	TION TION TION TION	SØØØ ler mi	ØØR	skkk	iced	SØ) in	ළළ man	 888 0 .ual 0
জিমিয়	র মুদ্দ মুমুহ	88 88	i k k k K k k k	588 588	881 881	281 281	3881 888	a a a a a a a	irr Fr	() () () () () () () () () () () () () (sere	rr	s a a a	irra	201	rri	ষম্বহ
		3.	Ensu Are Chan	re P Usin nels	ZR (g Ur	Cont naff	rol s ected	Signa 1	als								
<i>`\$\$\$\$</i>	<i>\$</i> \$ <i>\$</i> \$	\$ \$ \$	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	<i>₽₽₽</i> ₽₽₽	<i>\$</i> \$\$ \$\$\$	ጶ₥⊕	\\$_\\$	<i>\$\$</i> \$	$\mathcal{P}\mathcal{P}$	ᡬᡷᡬᡷ᠙	ኇኇኇዸ	\$\$\$	かかかよ	ዾኇኇ	ኇዸ) U V	᠅ᡩ᠅
		Ц	AFF	ECTEI	D	Ц		I	PZR			Ц		F	ZR		
		Ц	BI	JS		Ц		PRI	ESSU	RE		П		LE	VEI	_	
ゕ゚゚ゟ゚ゟ゚ゟ゚	ゆゆゆ	ц Ч С С С С С С С С	\$\$D	ゆゆゆ	がなん	п \$ <i>\$\$</i>	\$\$\$ Swit(፝፝፝፝፝ ርዝ	ц Ц	۶ Sei	'ECL やかかかん	д Д	\$\$\$\$ Swit	CH &&&	ц Ц	¢¢,	\$\$\$ ELEC:
		П				Ц			Ц	CHA	NNEL	П			П	С	HANNI
M. M. M. M.	ለ፣ ረፖ ለ፣	따 따 '슈슈	~~~~~~ ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	5656	৾৾ড়৾৾ঀড়৾৾৾	おおお	$\psi\psi\psi$	ᡬᢓᡬ	ኇኇ፞፞፞፞፞ኇ	\$\$\$	かかかよ	` <i>₽</i> ₽₽	$\mathcal{P}\mathcal{P}\mathcal{P}$	\ \ \ \ \ \ \ \ \	ኇኇኇ
	5 W 5	×∽∽∽	N01	$\diamond \diamond \diamond \diamond$	$\nabla \phi \phi$	ц Ц	PS-45	55F	Ц	P457	/P456	Ц	LS-4	59D	Ц		
±61/L4	60	¤R	ED TI	RAIN		Ц			Ц			Ц			П		
<u> </u>	ለ፣ የፖ በ፣	따 따 '슈슈	~~~~~~ ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	5656	৬ ৬ ৬ ৬ ৬	ゆゆよ	$\psi\psi$	ᡬᢓᡬ	ኇኇ፞፞፞፞፞ኇ	\$\$\$	かかかよ	\$\$\$	$\mathcal{P}\mathcal{P}\mathcal{P}$	৯ঀ৾ড়	ኇኇኇ
	5 7 5	₩ ₩ ₩	N02	$\phi\phi\phi$	ゆむら	ц Ц	PS-45	55F	Ц	P455	/P458	Ц	LS-4	59D	Ц		
459/Ц4	6⊥	μW	HITE	TRA	IN	Ц			Ц			Ц			П		
M. M. M. M.	м. <u>~</u> м.	м. м.	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	555 M	৽৵৵৵	ᡬᡷᡬᡷ	ѷҾ҉Ҿ	ኇኇኇ	ኇኇ፝ኇ	\$\$\$	かかかよ	シ₡₺₡	ᢞᡬ	› ት ይ	ኇኇኇ
ヽ <u></u> タ タ タ タ タ タ タ 4 4 4 4 4 4 4 4 4 4 4 4 4	ゆうぼ	⊐N ⊅¢¢	N03	\$\$\$	444	ц УФV	PS-45	55F	Ц	P455	/P456	П	LS-4	59D	П		
459/L4	60	д ДВ	LUE '	FRAI	N	Ц			Ц			Ц			Ц		
мммм	м д м	گ	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	\mathcal{C}	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	ᡷᢘᢆᢠ	৾৾৵ড়৾৾৾৾	ᡧᡐᡧ	\sim	ኇኇኇ	ኇኇ፞፞፞፞፞ኇ	\$\$\$	かかかよ	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	$\mathcal{P}\mathcal{P}\mathcal{P}$	› ት ይ	ኇኇኇ
\$\$\$\$\$	ダダな	дN ФФ	<i>ФФФ</i> N04	ゆゆゆ	ŔŔŔ	д \$ <i>ф</i> \$	PS-45	55F	Ц	P455	/₽456	Ц	NO	Т	Ц		NOT
		¤γ	ELLO	W TRA	AIN	Ц			Ц			П	APPLI	CABL	ΞĦ		
PPLICA > 失失失失	BLE &®&	ц Ф¢	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	シৢ৻ৣ৻৵	ᡬ	\mathbb{Z}	\$\$\$	ঢ়ড়ৣ৻ড়৻	\$\$\$	かかかよ	ዾኇኇኇ	ኇዸ) U V V	ኇ፞፞፞፞፞፞፞፞፞፞፞ኇ፞ዸ
					. •												

	Revision: 6			T 100	112 0	TNOTE		DIIG	OF	νN	NN-	021	L
	Contir	nuous Use	LOSS OF VITA	L 120	VAC	INSTRU	JMEN.I.	BOS	Page	5	of	54	
1	STE	ACTION	/EXPECTED]-[RESI	PONSE	NOT					
пп	4.	(□) Che Occurred	ck RWST Switch 1:	over H	las	Go To	Step	5.					
пп		a. Close isola	e letdown orifi ation valves.	ce									
ппп		o BG o BG o BG	HIS-8149AA HIS-8149BA HIS-8149CA										
пп		b. Close contr	e charging flow col valve.	J									
ц		o BG	HC-182										
		c. Ensur NCP -	CE CCP A, CCP E - AT LEAST ONE	3, or RUNNII	NG								
пп		d. Estak injec	olish 32 gpm se ction flow.	eal									
п		o BG o BG	FCV-121 FK-462										
п	5.	Stabiliz	ze Plant:										
пп		a. Stop requi	any plant oper ring rod motic	ation: on	S								
ппп		b. (□) neces withi	Adjust Turbine ssary to mainta n 3°F of Tref	load ain Ta	as vg								
ппп	б.	Dispatch Instrume Breaker	n Operator To A ent Bus With Ba Interlock Key	Affecto Ackup	ed								
Ц	7.	Go To Ar	ppropriate Atta	chmen	t:								
		o Loss c o Loss c o Loss c o Loss c	of NN01 - ATTAC of NN02 - ATTAC of NN03 - ATTAC of NN04 - ATTAC	CHMENT CHMENT CHMENT CHMENT	A B C D								
				-END	_								

ſ	Revisi	on: 6 OFN NN-021
	Contin	uous Use
ſ	STE	ACTION/EXPECTED RESPONSE NOT
		ATTACHMENT A (Page 1 of 16) LOSS OF VITAL INSTRUMENT BUS NN01 (RED TRAIN)
п п	A1.	Defeat RCS Temperature Control For Loop 1:
		a. Position Loop Tavg Control Signal to - T412
		o BB TS-412T
		b. Position Loop IT Control Signal to - T411
		o BB TS-411F
Π	A2.	Ensure AC PT-506 Selected
		o AC PS-505Z
	A3.	Lock S/G A Atmospheric Relief Valve Manual Drive Lever In Closed Position
		o AB PIC-1A
n n	A4.	Locally Restore Power To Bus Go To Step A5. NN01:
		a. Check NN01 buss - NO a. Go to Step A6.
п		APPARENT DAMAGE
п П		b. Check inverter NN11 output b. Go to Step A5.
п		voltage - NORMAL
п п		c. Ensure inverter AC output breaker is closed
п		o Breaker 4CB - CLOSED
n n		d. Ensure normal feeder breaker is closed
д		o NN0101 - CLOSED
		e. Go To Step A6.

	Revisi	on: 6	OFN NN-021
	Contin	LOSS OF VITAL 120 VAC	INSTRUMENT BUS Page 7 of 54
1	STE	ACTION/EXPECTED	RESPONSE NOT
		ATTACHMENT (Page 2 of LOSS OF VITAL INSTRUMENT B	T A 16) SUS NN01 (RED TRAIN)
	A5.	Align Backup Power To Bus NN01:	
		a. Close backup transformer XNN05 power supply breaker.	
		o NG01ACR3	
		b. Verify Backup Power Available white light - LIT.	
		c. Open Normal Feeder Breaker.	
		o NN0101	
		d. Close Alternate Feeder Breaker.	
		o NN0102	
пп		e. Refer to applicable Technical Specification:	
пппп		 o 3.8.7, Inverters - Operating o 3.8.8, Inverters - Shutdown 	
П	A6.	Check VCT level - GREATER	Perform the following:
7		IRAN 5°	a. <u>IF</u> NN01 is energized, <u>THE</u> N
			initiate makeup using
			SYS BG-200, REACTOR MAKEUP ¤
			CONTROL SYSTEM NORMAL ¤ OPERATION. ¤
			b. <u>IF</u> NN01 is deenergized,
			THEN initiate makeup using
			SYS BG-216, REACTOR ¤

MAKE-UP CONTROL SYSTEM H ALTERNATE OPERATION. H

- c. <u>WHEN</u> VCT level greater than 5%, <u>THEN</u> do Steps A7, A8, A9 and A10.
- d. Continue with Step A12. ${\tt m}$

TASK: Perform Local Actions for Immediate Boration (ASP)				
TASK #: APE024003				
K/A #s: APE024 AA1.17, AA1.25				
References: OFN BG-009, Rev. 8				
Examinee's Name S	SS No	SRO		
The examinee's performance was evaluated against the standards in this JPM an	d determined to be :			
SATISFACTORY UNSATISFACTORY				
Reason if UNSATISFACTORY:				
Estimated JPM completion Time: 6 min.				
Actual Performance Time:min.				
Location of Performance: Control Room Simulator	Plant X			
Method of Performance: Simulate X Perform				
Tools and Equipment: Hard Hat Safety glasses Ear protection				
		_		
Evaluators Signature:		Date		

Notes:

After Examinee locates the procedure or provides sufficient description for location, provide the **YELLOW** copy of OFN BG-009 Attachment "A".

START this JPM in the south end of the hall at the 2026' level of the Auxiliary Building.

READ TO EXAMINEE

Plant equipment should not be operated, if you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

Upon arriving at a component, describe to your evaluator what you expect to see (e.g. how valve, breaker, etc. position is determined), v do (e.g. turn switch to run, rotate handwheel clockwise to open, etc.) and what you expect to happen (e.g. pump will start and red light w will rotate until valve is open, etc.).

When you have completed the JPM inform your evaluator that you are done by handing the Initial Conditions/Initiating Cues sheet back to him.

An * Denotes a Critical Step.

Initial Conditions:

You are a Licensed Operator in the Auxiliary Building; the plant was in Mode 1. A reactor trip has recently occurred leaving several rods stuck at various positions in the core.

Initiating Cues:

The Control Room Supervisor directs you to perform the local actions for OFN BG-009, Attachment A "ESTABLISHING ALTERNATE BORATION FLOWPATH". Step A.1 is complete and both Boric Acid pumps are running.

<u>DO NOT</u> operate any components in the plant.

TASK STANDARD: Upon completion of this JPM the operator will have established Emergency Boration by locally opening BG HV-8104.

Element #	Step #	Element	Standard	Score			
1. *		Start Time Examinee must locate a copy of OFN BG-009, "EMERGENCY BORATION"	Procedures are located in the Emergency Locker at the north end of the 2026' level, by the Aux. Shutdown Panel. The Examinee must physically locate the procedure or describe in sufficient detail so that the evaluator can determine the answer is correct.	SU			
Cue: After Examinee locates the procedure or provides sufficient description; provide the YELLOW copy of OFN BG-009 Attachment "A".							
Comment	Comments: There are other Emergency Lockers in the Aux. Building. If the examinee can locate a copy of the procedure this step is completed satisfactorily.						

2.	A1.	Align Make-Up system for manual boration.	Initiating Cues stated this step has been completed. Proceed to step A2	N/A
----	-----	---	---	-----

Cue:

Comments: The Control Room staff performs this step.

RNO 1978' level of the Aux. Bldg., in the "A" SI a. Pump Room. Close the instrument air isolation valves to the positioner and the valve by turning the handles so they are perpendicular to the air lines.	3.*	A2. RNO a.	Locate the valve and air isolation on the 1978' level of the Aux. Bldg., in the "A" SI Pump Room. Close the instrument air isolation valves to the positioner and the valve by turning the handles so they are perpendicular to the air lines.	S U
---	-----	------------------	---	-----

Cue: After examinee describes isolating both air valves report, "Handles are perpendicular to air lines."

Comments: Examinee must isolate both air valves to satisfy this element.

4.*	A2.	Locally Vent air pressure from valve.	Vent air off the operator by opening the filter	S U
	RNO		drains located at the bottom of the filters or	
	b.		by any other method that will bleed air off	
			the top of the operator.	

Cue: BG FCV-110A does not move.

5.*	A2. RNO c	If valve cannot be opened then go to step A8.	Recognize valve didn't open and skip to step A8.	S U
-----	--------------	---	--	-----

Cue:

Comments:

* Denotes Critical Step

Element #	Step #	Element	Standard	Score
4. *	A8.a	Locally OPEN Emergency Boration Valve.BG HV-8104.	Locate valve on the 1978' level of the Aux. Bldg., in the "A" SI Pump Room. Engage the manual operator by pulling gently down on the clutch lever and turning the handwheel several turns until the clutch key is engaged. Then pull the clutch lever all the way down and turn the handwheel in the counter- clockwise direction.	S U

Cue: As examinee describes opening the valve, "Valve stem is moving,--- valve indicates open."

Comments:

5.*	A8.b	Check Emergency Boration flow – Greater than 30 gpm.	Contact Control Room to request status of Emergency Boration Flow.	S U
			<u>OR</u>	
			Examinee may look at local indicator, BG FI- 183B, outside the "A" CCP room and then call the Control Room.	

Cue: Acknowledge report, respond, "*immediate boration flow is 37 gpm*"

If examinee looks at local gage then respond, "flow indicates 37 gpm".

Comments:

Termination: Opening BG HV-8104 completes the JPM.

Stop Time _____

* Denotes Critical Step

Initial Conditions:

You are a Licensed Operator in the Auxiliary Building; the plant was in Mode 1. A reactor trip has recently occurred leaving several rods stuck at various positions in the core.

Initiating Cues:

The Control Room Supervisor directs you to perform the local actions for OFN BG-009, Attachment A "ESTABLISHING ALTERNATE BORATION FLOWPATH". Step A.1 is complete and both Boric Acid pumps are running.

<u>DO NOT</u> operate any components in the plant.

Notes:

Plant equipment should not be operated, if you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

Upon arriving at a component, describe to your evaluator what you expect to see (e.g. how valve, breaker, etc. position is determined), what you expect to do (e.g. turn switch to run, rotate handwheel clockwise to open, etc.) and what you expect to happen (e.g. pump will start and red light will light, handwheel will rotate until valve is open, etc.).

When you have completed the JPM inform your evaluator that you are done by handing the Initial Conditions/Initiating Cues sheet back to him.



OFN BG-009

EMERGENCY BORATION

Responsible Manager

Manager Operations

ለ ለ ለ ለ ለ ለ ለ ለ ለ በ	₳₢₢₢₢₢₢₢₢₢₢₢₢₢₢₢₢₢₢	₢₢₢₢₢₢	℀ℰℛⅅℰℰℰℰ
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	¤ Revision Number ઋড়ড়ড়ড়ড়ড়ড়ড়ড়ড়ড়ড়ড়ড়ড়ড়ড়ড়ড়ড়	<i>~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~</i>	ᡩᡩᡩᡒᡇᡷᡩᡩᡩ
$\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$	보 Use Category	Ц	Continuous
<i>₳₳₳₳₳₳₳</i> ₽ <i>₳₳₳₳₳₳₳</i> ₽	<i>ୢ</i> ୶ <i>୶୶୶୶୶୶୶୶୶୶୶୶୶୶୶୶୶</i>	₢₲₲₲₲₲₲	₶₲₲₲₲
	¤ Administrative Controls Procedure ታሁሁሁሁሁሁሁሁሁሁሁሁሁሁሁሁ	e ^μ Nο ■ ^μ No	ਸ਼ ਸ਼
	۲ Infrequently Performed Procedure پهرهرهرهرهرهرهرهرهرهرهرهرهرهرهرهرهرهرهر	кккккккк д No	だをたかたたたた ゴ
₲₲₲₲₲₲₲		Y 017	M
おおおおおおおお	Эккккккккккккккккккккк	$\begin{array}{c} \phi \phi$	৵৾৾৵৵৽৽৾৾৵
	DC12	02/21/2001	

#### 1.0 PURPOSE

1.1 To describe the operations necessary to inject boric acid int $\phi$ the RCS whenever conditions exist that require the rapid insertion of negative reactivity without the use of control rods.

#### SYMPTOMS OR ENTRY CONDITIONS 2.0

- 2.1 The following symptoms/entry conditions that require emergency boration:
  - a. Excessive control rod bank insertion as indicated by:
    - o Annunciator 00-081C, ROD BANK LOLO LIMIT, is lit
    - o Bank step counters

Ц

- o Rod position indicators
- o Core Operating Limits Report, Technical Ц Specification 3.1.6 M
- b. Failure of two or more control rods to fully insert following a reactor trip or shutdown.
- c. Uncontrolled cooldown of the reactor coolant following a reactor trip or shutdown as indicated by two out of four loop Tavg less than 530°F.
- d. Unexplained or uncontrolled reactivity increase as

# indicated

```
by:
                 * Abnormal control bank insertion
                 * Increasing temperature or nuclear power
                 * Increasing neutron flux or count rate on source range
                   while shutdown
              e. Shutdown margin less than required as indicated by the
                 following:
                 * Shutdown margin less than 1.3% %k/k in Mode 2 with Keff
                 Ц
                   less than 1.0 and Modes 3, 4, or 5. Technical
                   Ц
                   Specification 3.1.1
                 * Keff greater than 0.95 K eff or boron concentration of
all
                 Ц
                   filled portions of the RCS and refueling canal less than
                   2300 ppm in Mode 6. Technical Specification 3.9.1
```
#### 3.0 <u>REFERENCES AND COMMITMENTS</u>

#### 3.1 <u>References</u>

- a. OFN BG-009 Supplemental Information
- b. ITIP 01969, Reactivity Management Expectations During Plant ^µ Shutdown ^µ
- c. PMR 4590, PDP REPLACEMENT

#### 3.2 <u>Commitments</u>

- a. SOER 94-02, Recommendation 4a, Monitoring of RCS boron µ concentration and verification of adequate shutdown margin µ [Step 1.1] µ
- b. RCMS 1985-113 and SLNRC 84-0070, Flushing the BIT After  $\mu$  Emergency Boration [Step 14]  $\mu$

	Revision: 8		on: 8	EMERGENCY BORATION		OFN BG-009	
	Conti	nu	ous Use	EMERGENCI			Page 3 of 19
1	STE	H	ACTION	/EXPECTED		RESPONSE NOT	·
	1.		Check Ch As The ( Injectic	narging System Aligned Operable Boron on Flowpath.	đ	Go to Attachme BORATION USING FLOWPATH.	nt B, EMERGENCY SI AS BORATION
	2.		Align Ch Emergend	narging Pumps For cy Boration:			
			a. Ensur is ru	re one Charging Pump unning			
ппп			* CCF * CCF * NCF	P A P B			
			b. ( <b>]</b> ) Path:	Align Boration Flow		b. ( <b>D</b> ) Align F Suction:	RWST to CCP
			1) En tr LE	asure boric acid Cansfer pumps - AT CAST ONE RUNNING		a) Ensure C Suction 1 Valves - OPEN	harging Pump From RWST AT LEAST ONE
			2) Op Tc Su	en Emergency Borate Charging Pump action Valve		O BN HIS O BN HIS	-112D -112E
			0	BG HIS-8104		b) Ensure V( Valves - CLOSED:	CT Outlet AT LEAST ONE
						O BG HIS O BG HIS	-112B -112C

Revision: 8			OFN BG-009
Continuous Use	EMERGENCI E	SORATION	Page 5 of 19
STE ACTION	/EXPECTED	RESPONSE NO	 T
4. Verify H - GREATH	Emergency Borate Flow ER THAN 30 GPM	Perform the f	ollowing: RWST to CCP
o BG FI-	-183A	suction: 1) Ensure ( Suction Valves - OPEN 0 BN HIS 0 BN HIS 2) Ensure V Valves - CLOSED: 0 BG HIS	Charging Pump From RWST - AT LEAST ONE S-112D S-112E /CT Outlet - AT LEAST ONE S-112B
		<pre>b. Check RWST charging sy THAN 90 GPI * BG FI-12: OR * EM FI-91 C. IF RWST flo charging sy H 90 gpm, THY alternate I H flowpath us H ATTACHMENT H</pre>	5-112C flow through ystem - GREATER 4 1A 7A 7B ow through ystem less than EN establish boration sing A, ESTABLISHING
		PATH. ¤	

Revision: 8		EMEDOENOV		OFN BG-009
Continuo	ous Use	EMERGENCI	BORATION	Page 12 of 19
	ACTION	/EXPECTED	RESPONSE NOT	
Al. A M a	Align Ma Manual E A. Place Makeu Switc o BG O. Manua one k * BG * BG	ATTACHMM (Page 1 of ESTABLISHING ALTERNAT Akeup System For Boration: A Reactor Coolant p Control Selector th in OFF position HS-25 Ally start at least poric acid pump HIS-5A HIS-6A	ENT A of 4) TE BORATION FLOWPA b. <u>IF</u> neither started, <u>TH</u> following: 1) Continue establis: from RWS 2) Return to Step 2.	TH pump can be <u>EN</u> perform the attempts to h boration flow T. o procedure,
A2. C	<b>Open Bor Inlet Is</b>	ric Acid Blending Tee solation Valve	<ul> <li>Fail open valv</li> <li>a. Locally iso air to valv</li> <li>b. Locally ven from valve.</li> <li>c. <u>IF</u> valve ca opened, <u>THE</u> step A8.</li> </ul>	re: late instrument e. t air pressure n <u>NO</u> T be <u>N</u> go to
A3. C E I	Close Re Boric Ac Isolatic	eactor Makeup Water To ad Blending Tee on 3-111A	<ul> <li>Perform the formation</li> <li>a. Stop both r water trans</li> <li>o BL HIS-3</li> <li>o BL HIS-4</li> <li>b. <u>IF</u> reactor transfer pustopped, <u>TH</u> Step A8.</li> </ul>	ellowing: eactor makeup fer pumps makeup water mp can <u>NO</u> T be <u>EN</u> go to

Revisi	on: 8	EMERGENCY BORATION		OFN BG-009	
Contin	uous Use	EMERGENCI	BORATION	Page 13 of 19	
STE -	ACTION	/EXPECTED	RESPONSE NOT		
		ATTACHMI (Page 2 ESTABLISHING ALTERNAT	ENT A of 4) TE BORATION FLOWPA	ТН	
Α4.	Check VC Valves -	CT Outlet Isolation - BOTH OPEN	Perform the fo	llowing:	
	o BG HIS	S-112B	a. Manually op	en valves.	
	o BG HIS	S-112C	opened, <u>THE</u> Step A7.	N go to	
A5.	(□) Ope Isolatic	n Makeup To VCT Outle on Valve	et ( <b>D</b> ) Open Maker Isolation Valv	up To VCT Inlet e	
	o BG HIS	G-110B	o BG HIS-111B		
A6.	Verify E	Boration Flow:			
	a. Check - GRE	normal boration flow CATER THAN 30 GPM	w a. Go to Step	Α7.	
	o BG o BG	FR-110 red pen FR-110 green pen			
	b. Retur Step	n to procedure, 2.			
A7.	Establis	sh Manual Boration:			
	a. (□) i open Charg Isola	Locally unlock and Blended Boric Acid To ging Pump Suction ation Valve	a. Go to Step	A8.	
	o BG-	V177			
	b. Check - GRE	normal boration flow CATER THAN 30 GPM	w b. Go to Step	A9.	
	o BG	FR-110 red pen			
	c. Retur Step	n to procedure, 2.			

Revisi	.on: 8	EMERGENCY BORATION		OFN BG-009	
Contin	uous Use	EMERGENC I	BURA	IIION	Page 14 of 19
STE -	ACTION	I/EXPECTED	$\square$	RESPONSE NOT	·
		ATTACHM (Page 3 ESTABLISHING ALTERNA)	ENT of 4 TE B(	A ) DRATION FLOWPA	TH
A8.	Establi Boratio	sh Manual Emergency n:			
	a. (□) Bora o BG	Locally open Emergenc tion Valve HV-8104	су а	<ul> <li>a. Perform the</li> <li>1) Continue establist from RWS</li> <li>2) Return to Step 2.</li> </ul>	following: attempts to h boration flow T. o procedure,
	b. Check flow c. Return Step	k Emergency Boration - GREATER THAN 30 GP rn to procedure, 2.	ł M	o. Go to Step	A9.
Α9.	Step Locally Filter 20 PSID o BG PD	2. Check Boric Acid P - LESS THAN I-108	I S S S S S S S S S S S S S S S S S S S	<ul> <li>Bypass boric a</li> <li>a. Open Boric Bypass Upst Valve.</li> <li>o BG-V173</li> <li>Open Boric Bypass Down Isolation V</li> <li>o BG-V172</li> <li>Close boric BAT "A" thr</li> <li>o BG-V319</li> <li>Close Boric Inlet Isola</li> <li>o BG-V149</li> <li>e. Close Boric Outlet Isol</li> <li>o BG-V152</li> <li>f. Direct Main change filt possible.</li> </ul>	cid filter: Acid Filter ream Isolation Acid Filter stream alve. acid filter to ottle valve Acid Filter tion Valve. Acid Filter ation Valve. tenance to er as soon as

Revision: 8		EMEDGENOV		OFN BG-009
Contin	uous Use	EMERGENCI	BORATION	Page 15 of 19
STE	ACTION	/EXPECTED	RESPONSE NOT	
		ATTACHM (Page 4 ESTABLISHING ALTERNA	IENT A of 4) TE BORATION FLOWPA	тн
A10.	Check If Flow Has	Alternate Boration Been Established:	Continue attem establish bora RWST	pts to tion flow from
	* Normal GREATE	boration flow - R THAN 30 GPM	Rubi .	
	o BG F	R-110 red pen		
	OR			
	* Emerge GREATE	ency Boration flow - CR THAN 30 GPM		
	o BG F	'I-183A		
A11.	Return 1	To Procedure, Step 2		
		-END-		

TASK:	Conduct a Liquid Radwaste Release				
TASK #: 06800004, 2.3-3					
SAFETY FUN	NCTION:#9				
K/A #s: 068A3	.02, 2.3.11				
References: SY	S SP-121, Rev. 10 ; ALR 61A, Rev. 15; OFN SP-010, Rev. 5.				
Examinee's Na RO	ame SS No	SRO			
The examinee's p	performance was evaluated against the standards in this JPM and determined to be :				
SATISFACTC	RY UNSATISFACTORY				
Reason if UNS	ATISFACTORY:				
Estimated JPM	completion Time: 20 min.				
Actual Perform	Actual Performance Time:min.				
Location of Per	Location of Performance: Control Room SimulatorX Plant				
Method of Perf	Method of Performance: Simulate PerformX_				
Tools and Equi	Tools and Equipment: Simulator				
Evaluators Sign	ature:	Date			

Notes:

BOOTH INSTRUCTIONS: Simulator set-up: IC 171. Ensure Simulator in RUN ENSURE Horns are ON

From the Instructor Station Malfunction list select mRMS0326L (HB RE-18). Set activity to 5.0 E-1 and tie event to trigger 1.

# EVALUATOR:

Provide Examinee with **GREEN** copy of Liquid Release Permit #01-001.

After Examinee obtains controlled copy then provide **YELLOW** copy of SYS SP-121 "OPERATION OF THE G.A. MONITOR SYSTEM"..

* Denotes a Critical Step

Initial Conditions:

You are the Reactor Operator, the plant is currently stable in Mode 1.

Initiating Cues:

The Control Room Supervisor directs you to perform the actions to release Waste Monitor Tank "A"(THB07A) to the environs. A new Liquid Release Permit for THB07A has been issued. The source Check has been completed. The Radwaste Operator is standing by and has a copy of the release permit.

Task Standard: Upon Completion of this JPM, the operator will have entered new setpoint data for the Liquid Rad Monitor and properly verified the termination of a release.

TERMINATION: Once verification is made that HB RV-18 is closed the JPM can be terminated.

Element #	Step #	Element	Standard	Score
N/A	N/A	Examinee may locate controlled copy of SYS SP-121 or perform from memory.	SYS SP-121 is a <u>reference</u> procedure. It is not required to be in hand while performing the evolution but must be complied with.	N/A

Cue: **IF Examinee obtains the controlled copy of SYS SP-121 then Provide Yellow copy of procedure.** 

# Comments:

1. *	6.3.1	Start Time	Reference Procedure Step 6.1.2	S U
	Step 1	<ul> <li>To change the value of a Supervisor RM-80 Database Channel Item, perform the following:</li> <li>1. Select the desired channel per step 6.1.2.</li> </ul>	<ul> <li>Ensure Grid 1 Displayed:</li> <li>a. Key in the three digit Channel Identification Number: (186)</li> <li>b. Press the SEL key.</li> <li>c. Selected Channel outlined in white.</li> </ul>	

Cue:

# Comments:

2.	6.3.1 Step 2	Place Supervisor Master Key in the key slot and turn it to SUPERVISOR position.	Lower right corner of console, key turned clockwise to the SUPERVISOR position.	S U
			I man a second	

# Cue:

# Comments:

3.	6.3.1	Display the Supervisor RM-80 Database	At the keyboard:	S U
	Steps		a. Press LIT key.	
	3,4,5,		b. Press the Grid 5 key.	
	6		c. Press the SEL key.	
			d. Verify the Supervisor RM-80	
			Database Screen is displayed.	

Cue:

Comments:

Element #	Step #	Element	Standard	Score
4. *	6.3.1 Steps 7,8,9, 10	Enter setpoint data for the HIGH channel.	<ul> <li>Select desired Channel Item to be changed. At the keyboard:</li> <li>a. Press the minus (-) key.</li> <li>b. Key in the desired Channel Item number. (09).</li> <li>c. Press the SEL key.</li> <li>d. Check the selected Channel Item is backlit.</li> </ul>	SU

Cue:

Comments:

5. *	6.3.1	Enter new setpoint data from Release Permit.	At the keyboard:	S U
	Steps 11,12		<ul> <li>a. Key in the desired channel item value in the correct format. 9.68</li> <li>E-2 is keyed in as 9, 6, 8, -, 0, 2.</li> </ul>	
			b. Press the ENTER key.	

Cue:

Comments:

Element #	Step #	Element	Standard	Score
6. *	6.3.1 Steps 13,14	Verify setpoint data is correct.	<ul> <li>On the CRT screen:</li> <li>a. A message area will appear at the bottom of the screen</li> <li>b. IF the data in the message area is correct, THEN press the ENTER key and proceed to step 6.3.1.14.</li> <li>c. IF the entry is accepted, THEN the message at the bottom of the CRT will indicate value accepted and the value for that item will be updated in the RM-80 Column and the Master Column.</li> </ul>	SU

# Cue:

# Comments:

7.	N/A	Repeat elements 4 through 6 for the Alert Channel setpoint	Examinee must realize that they need to repeat the steps required to also enter new setpoint for Channel Item 10.	S U

# Cue:

# Comments:

Element #	Step #	Element	Standard	Score
8. *	6.3.1 Steps 7,8,9, 10	Enter setpoint data for the ALERT channel.	<ul> <li>Select desired Channel Item to be changed. At the keyboard:</li> <li>a. Press the minus (-) key.</li> <li>b. Key in the desired Channel Item number. (10).</li> <li>c. Press the SEL key.</li> <li>d. Check the selected Channel Item is backlit.</li> <li>OR</li> <li>a. Press the SEL key.</li> <li>b. Check the selected Channel Item is backlit. (10)</li> </ul>	SU

# Cue:

Comments: Per the NOTE preceding step 11, the examinee may press the SEL key which will advance the selected channel to channel 010.

9. *	6.3.1	Enter new setpoint data from Release Permit	At the keyboard:	S U
	Steps 11,12		<ul> <li>a. Key in the desired channel item value in the correct format. 9.68 E-3 is keyed in as 9, 6, 8, -, 0, 3.</li> </ul>	
			b. Press the ENTER key.	

Cue:

Comments:

Element #	Step #	Element	Standard	Score
10. *	6.3.1 Steps 13,14	Verify setpoint data is correct.	<ul> <li>On the CRT screen:</li> <li>a. A message area will appear at the bottom of the screen</li> <li>b. IF the data in the message area is correct, THEN press the ENTER key and proceed to step 6.3.1.14.</li> <li>c. IF the entry is accepted, THEN the message at the bottom of the CRT will indicate value accepted and the value for that item will be updated in the RM-80 Column and the Master Column.</li> </ul>	S U

# Cue:

# Comments:

11.	6.3.1 Step 16	Return Supervisor Master key to the NORMAL position.	Lower right corner of console, key turned counter-clockwise to the NORMAL position	S U
	16		NORMAL position	

Cue:

Comments:

N/A	N/A	Release Permit must be verified and	NOTE: Extra Body will Sign as Shift	N/A
		authorized by the Shift Manager prior to	Manager on Release Permit for	
		initiating the release.	<b>Setpoints Verified and Release</b>	
			Approved	

# <u>Cue:</u> "Liquid Release Permit LRP # 01-001 is approved, phone the Radwaste Operator and inform them they can commence the release."

Comments: Give Permit back to Examinee after signing for release approval.

Element #	Step #	Element	Standard	Score
12.	N/A	Calls Ext. 5810 for Simulator Radwaste and provides LRP information.	May use Gaitronics.	S U

Cue:

Booth Operator: Wait approximately 10 seconds after examinee has called then enter **EVENT 1**. This will cause the activity level to increase on HB RE-18.

13.	N/A	Annunciator Alarms 061B and 061A.	Recognize and acknowledge alarms. Go to ALR 00-061A or Enter OFN SP-010.	SU
-----	-----	-----------------------------------	--------------------------------------------------------------------------	----

Cue:

- Comments: The "A" tier alarm is a higher priority and should be used even though the "B" tier alarm may come in first.
- **NOTE:** The examinee may recognize this alarm as an entry condition to OFN SP-010 and use the OFN. If so N/A JPM elements 14 through 17 and proceed to Element 18.

14.	Step 1	ALR 61A:	Deterrmine HB 186 is RED.	S U N/A
		Monitor: SP056A – Any RED.		

Cue:

Comments:

<ul> <li>15 Steps 2. Check For High Reactor Coolant Activity NO – RNO go to Step 3.</li> <li>3. Check For RCS Leakage To Containment NO – RNO go to Step 4.</li> <li>4. Check For Steam Generator Tube Leakage NO – RNO go to Step 5.</li> <li>5. Check For CCW System Leakage NO – RNO go to Step 6.</li> </ul>	Examinee should realize all these answers would be NO and continue down the RNO column to Step 6.	S U N/A
----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------	------------

Cue:

Comments:

16*	6	Check For High High Radiation On Normal Release Path.	Examinee should answer YES and proceed of Step 7.	S U N/A
		Torinar Refease Full.		10/11

Cue:

Comments:

17*	7	Ensure Associated Controlled Realease Path Isolated.	Contact the Radwaste Watch and direct them to ensure HB RV-18 is closed.	S U N/A
-----	---	---------------------------------------------------------	--------------------------------------------------------------------------	------------

Cue:

Booth Operator: When contacted as Radwaste Operator report "I have verified HB RV-18 is closed".

Termination: Contacting the Radwaste Watch to Ensure HB RV-18 is closed completes this JPM.

Stop Time _____

**NOTE:** If the Examinee completed the actions of ALR 061A, then steps 18 and 19 may be N/A'd.

**NOTE:** If examinee entered OFN SP-010 directly then continue at JPM Element 18.

18	Steps	OFN SP-010 Step 1-14.	Perform OFN SP-010 to step 14. The	S U
	1-14	Step 1 – NO RNO Go To Step 2	RNO column will be followed till step 14.	N/A
		Step 2 – NO RNO Go To Step 6		
		Step 6 – NO RNO Go To Step 7		
		Step 7 – NO RNO Go To Step 8		
		Step 8 – YES		
		Step 9 – NO RNO Go To Step 10		
		Step 10 – NO RNO Go To Step 11		
		Step 11 – NO RNO Go To Step 12		
		Step 12 – NO RNO Go To Step 13		
		Step 13 – NO RNO Go To Step 14		
		Step 14 – YES		

Cue:

Comments:

<u>NOTE</u>: Examinee may enter OFN SP-010, "ACCIDENTAL RADIOACTIVE RELEASE", directly. If so the procedure will work through the RNO column till step 14 where HB RV-18 is verified closed.

# * Denotes Critical Step

19*	N/A	OFN SP-010 Step 14	Contact the Radwaste Watch and direct them to ensure HB RV-18 is closed.	S U N/A
-----	-----	--------------------	--------------------------------------------------------------------------	------------

Cue:

# Booth Operator: When contacted report "I have verified HB RV-18 is closed".

Comments: May use telephone or Gaitronics

Termination: Contacting the Radwaste Watch to Ensure HB RV-18 is closed completes this JPM.

Stop Time _____

Initial Conditions:

You are the Reactor Operator, the plant is currently stable in Mode 1.

Initiating Cues:

The Control Room Supervisor directs you to perform the actions to release Waste Monitor Tank "A"(THB07A) to the environs. A new Liquid Release Permit for THB07A has been issued. The source Check has been completed. The Radwaste Operator is standing by and has a copy of the release permit.

Notes:

Upon arriving at a component, describe to your evaluator what you expect to see (e.g. how valve, breaker, etc. position is a you expect to do (e.g. turn switch to run, rotate handwheel clockwise to open, etc.) and what you expect to happen (e.g. pu red light will light, handwheel will rotate until valve is open, etc.).

When you have completed the JPM inform your evaluator that you are done by handing the Initial Conditions/Initiating Cues sheet back to him.

When recording data on Data Sheets, indicate the instrument used and vocalize the value you will record for each parameter.

CORRECTED COPY 06/13/2000



ALR 00-061A

# PROCESS RAD HIHI

## Responsible Manager

Manager Operations

<u>ለኛ ለኛ ለኛ ለኛ ለኛ ለኛ ለኛ መ</u>	$\mathbf{A}$ $\hat{\mathbf{A}}$	` <i>&amp;&amp;&amp;&amp;&amp;&amp;</i> &&&&&&&&&&&&&&&&&&&&&&&&&&&&&&	<i>&amp;&amp;</i> ##
<i>ккккккк</i> ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	μ Bevision Number Ακάκακακακακακα	マ 日 15 日 15 5 5 5 5 5 5 5 5 5 5 5 5 5	፞ዾ ዾ ዾ
$\diamond \diamond \diamond$	보 Use Category	Д	Continuous
ををををををををや	<u>ᠳ</u> <i>₳₳₳₳₳₳₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽</i>	₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽	<i>₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽</i>
	¤ Administrative Controls Procedure ታሁሁሁሁሁሁሁሁሁሁሁሁ	<i>~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~</i>	₶ ₶ ₶
<i>~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~</i>	۲ Infrequently Performed Procedure بالالالالالالالالالالالالالالالالالالال	и No Д No	KKK & K K K K K I
₶₶₶₶₶₶	U Program Number	۷ ۷ ۷ ۷ ۷ ۷ ۷ ۷	д Х Х Х М Х Х Х Х
$\kappa$ $\kappa$ $\kappa$ $\kappa$ $\kappa$ $\kappa$ $\kappa$ $\kappa$	<u></u>	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	<i>₳৾৾৾ঀ৾ড়ড়ড়ড়ড়</i>
, , , , , , , , ,			

Continuous Use

#### 1.0 <u>PURPOSE</u>

1.1 This procedure provides instructions for responding to actuation of alarm window 00-061A, PROCESS RAD HIHI.

#### 2.0 <u>SYMPTOMS OR ENTRY CONDITIONS</u>

2.1 This procedure is entered when any process radiation monitor

in high high alarm condition.

- 2.2 The high high alarm setpoints for liquid and gaseous effluents are set as calculated in AP 07B-003, Offsite Dose Calculation Manual (ODCM).
- 2.3 <u>IF</u> a controlled release is in progres<u>s</u> AND the monitor in the release path is high high, <u>THEN</u> the controlled release will automatically be terminated.

#### 3.0 <u>REFERENCES AND COMMITMENTS</u>

3.1 <u>References</u>

a. AP 07B-003, Offsite Dose Calculation Manual (ODCM)

b. PIR 95-0087

c. PIR 00-0039

3.2 <u>Commitments</u>

Ц

a. LER 90-24, RCMS 90-176, PDR 1991-0445, PIR 90-0234,

Unplanned Release Of Waste Gas Decay Tank Without Prior H Sampling Caused By Personnel Error [Commitment - Procedure H Step, Step 8].

Revision: 15		DROCESS RAD HIHT		ALR 00-061A	
Continuous Use		FROCESS R.		Page 2 of 4	
STE	ACTION	I/EXPECTED	RESPONSE NOT		
1.	Determin Radiatio	ne Affected Process on Monitor: panel SP056A - ANY SS MONITOR RED	Perform the fo a. <u>IF</u> either g monitor in isolation, Step 6.	llowing: aseous effluent accident <u>THEN</u> go to	
			* GH RE-10 Building * GT RE-21	for Radwaste for Unit Vent	
			b. <u>IF</u> gaseous monitors <u>NO</u> isolation,_ procedure a effect.	effluent <u>T</u> in accident <u>THEN</u> return to nd step in	
			o GH RE-10 Building o GT RE-21	for Radwaste for Unit Vent	
2.	Check Fo Coolant	or High High Reactor System Activity:			
	a. Check CVCS	<pre>c Auxiliary Building, Letdown Monitor - REI</pre>	a. Go to Step D	3.	
	o SJI	1016			
	b. Go to REACT Step	OFN BB-006, HIGH FOR COOLANT ACTIVITY, 1			
3.	Check Fo Contain	or RCS Leakage To nent:			
	a. Check Atmos RED	< Containment sphere Monitors - ANY	a. Go to Step	4.	
	* GTE * GTI * GTC * GTE * GTI * GTC	2311 1312 3313 2321 1322 3323			
	b. <u>IF</u> Ch the s go to LEAKA	lemistry cannot verify signal is a spike <u>THE</u> o OFN BB-007, RCS AGE HIGH, Step 1	У N		

Revision: 15		ALR 00		ALR 00-061A
Contin	uous Use	PROCESS R.	AD HIHI	Page 3 of 4
STE	ACTION	/EXPECTED	RESPONSE NOT	
4.	Check Fo Tube Lea	or Steam Generator akage:		
	a. Check monit	the following fors - ANY RED:	a. Go to Step	5.
	* Con mon	denser air discharge litor - RED		
	o G	EG925		
	<u>0</u>	R		
	* SG mon	blowdown and sample itors - EITHER RED		
	* B * S	ML256 for blowdown JL026 for sampling		
	<u>0</u>	<u>R</u>		
	* SG ANY	steamline monitors - RED		
	* A * A * A * A	BS114 for S/G A BS113 for S/G B BS112 for S/G C BS111 for S/G D		
	b. Go to GENER Step	OFN BB-07A, STEAM ATOR TUBE LEAKAGE, 1		
5.	Check Fo	or CCW System Leakage	:	
	a. Check EITHE	CCW monitors - CR RED	a. Go to Step	б.
	* EGL * EGL	096 for CCW train A 106 for CCW train B		
	b. Go to Leaka	OFN BB-007, RCS AGE HIGH, Step 1		

Revision: 15 PROCESS RAD HIHI Continuous Use		DROCESS RAD HIHI		ALR 00-061A	
		птит	Page 4 of 4		
STE -	ACTION	/EXPECTED	7_	RESPONSE NOT	
6.	Check Fo	or High High Radiati al Release Path:	_ .on	Return to proc in effect.	edure and step
	o Contro gaseou PROGRE	olled liquid or 1s release - IN SSS			
	AND				
	o Releas contro RED OF	se path monitor on olled release path - & HAS BEEN RED			
7.	Ensure <i>A</i> Release	Associated Controlle Path - ISOLATED	ed		
8.	Inform ( Process Direct ( Evaluati	Chemistry Of Affecte Radiation Monitor A Chemistry To Perform ion Of Release	ed and a		
9.	Go To OE RADIOACI	N SP-010, ACCIDENTA NIVE RELEASE, Step 1	L.		
		-END	) —		

CORRECTED COPY 06/13/2000



ALR 00-061B

PROCESS RAD HI

Responsible Manager

Manager Operations

ለ	$\mathbf{A}$ \$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	���₽□₽₽₽₽₽
<i>ккккккк</i> ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	ኳ Revision Number ኳዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮ	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	ዽ፞፞፞፞፞፞ዾዸዾኇዸኇ ጟ
$\diamond \diamond \diamond$	ローフィング ロージョン ロージョー ロー	Ц	Continuous
₢₢₢₢₢	<i><b>₠₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽</b></i>	₢₢₲₲₲₲	<i>\$\$\$\$\$\$\$\$\$\$</i>
M. M. M. M. M. M. M. M. A.	Administrative Controls Procedure	<i>,                                    </i>	ℭℰℰℰⅆℰℰℰℰ
$\phi \phi \phi$	^は Infrequently Performed Procedure 必めめめめのののののののでのののののです。	д No ККККККККК	 <i>⊾</i>
₡₡₡₡₡₡₡₡₡	¤ Program Number	¤ 21A	Д
₢₢₢₢₢₢	᠍ <i>᠅ᡩ᠅ᡩ᠅ᡩ᠅ᡩ᠅ᡩ᠅ᡩ᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅</i>	₲₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽	℀ℰℰℴℰℰℰ
	DC12	02/16/2000	

Continuous Use

#### 1.0 <u>PURPOSE</u>

1.1 This procedure provides instructions for responding to actuation of alarm window 00-061B, PROCESS RAD HI.

#### 2.0 <u>SYMPTOMS OR ENTRY CONDITIONS</u>

is

2.1 This procedure is entered when any process radiation monitor

in high alarm (alert) condition.

2.2 The high alarm (alert) setpoints for liquid and gaseous effluents are set as calculated in AP 07B-003, Offsite Dose Calculation Manual (ODCM).

#### 3.0 <u>REFERENCES AND COMMITMENTS</u>

#### 3.1 <u>References</u>

- a. AP 07B-003, Offsite Dose Calculation Manual (ODCM)
- b. Vendor manuals
  - o J-361.00072, GA Tech Airborne Radiological Monitoring System
  - o J-361.00109, GA Tech Process / Airborne Rad Monitor

#### System

c. PIR 95-0087d. PIR 00-0039

#### Ц

#### 3.2 <u>Commitments</u>

b. ITIP 02488 (SOER 93-01) [Entire Procedure]

Revision: 15		DROCESS RAD H		ν цт	ALR 00-061B
Contin	uous Use	PROCESS	KAL		Page 2 of 4
STE -	ACTION	I/EXPECTED	$\mathbb{H}$	RESPONSE NOT	
1.	Determin Radiatio o Check PROCES	<b>ne Affected Process on Monitor:</b> panel SP056A - ANY SS MONITOR YELLOW		Perform the fo a. <u>IF</u> either g monitor in isolation, Step 6.	llowing: aseous effluent accident <u>THEN</u> go to
				<ul> <li>* GH RE-10 Building</li> <li>* GT RE-21</li> <li>b. <u>IF</u> gaseous monitors <u>NO</u> isolation, _ procedure a effect.</li> </ul>	for Radwaste for Unit Vent effluent <u>T</u> in accident <u>THEN</u> return to nd step in
				o GH RE-10 Building o GT RE-21	for Radwaste for Unit Vent
2.	Check Fo Coolant	or High Reactor System Activity:			
	a. Checł CVCS YELL(	t Auxiliary Building, Letdown Monitor - DW		a. Go to Step	3.
	o SJI	J016			
	b. Go to REACI Step	) OFN BB-006, HIGH FOR COOLANT ACTIVITY, 1			
3.	Check Fo Contain	or RCS Leakage To nent:			
	a. Check Atmos YELLO * GTI * GTI * GTO * GTI * GTI * GTO	Containment phere Monitors - ANY W 2311 1312 3313 2321 1322 3323		a. Go to Step	4.
	b. <u>IF</u> Ch the s go to LEAKA	lemistry cannot verif signal is a spike <u>THE</u> > OFN BB-007, RCS AGE HIGH, Step 1	У N		

Revision: 15 Continuous Use		PROCESS RAD HI		ALR 00-061B	
		, 111	Page 3 of 4		
STE	ACTION	/EXPECTED		RESPONSE NOT	·
4.	Check Fo Tube Lea	or Steam Generator lkage:			,
	a. Check monit	the following fors - ANY YELLOW:		a. Go to Step	5.
	* Con mon	denser air discharge itor – YELLOW			
	o G	EG925			
	<u>0</u>	R			
	* SG mon	blowdown and sample itors - EITHER YELLO	N		
	* B * S	ML256 for blowdown JL026 for sampling			
	<u>0</u>	R			
	* SG ANY	steamline monitors - YELLOW			
	* A * A * A * A	BS114 for S/G A BS113 for S/G B BS112 for S/G C BS111 for S/G D			
	b. Go to GENER Step	OFN BB-07A, STEAM ATOR TUBE LEAKAGE, 1			
5.	Check Fo	or CCW System Leakage	:		
	a. Check EITHE	CCW monitors - CR YELLOW		a. Go to Step	б.
	* EGL * EGL	096 for CCW train A 106 for CCW train B			
	b. Go tc LEAKA	O OFN BB-007,RCS AGE HIGH, Step 1			

Revision: 15		PROCESS R		, IIT	ALR 00-061B
Continuous Use				, 111	Page 4 of 4
STE -	ACTION	/EXPECTED	$\left  - \right $	RESPONSE NOT	
6.	Check For High Radiation On Normal Release Path: o Controlled liquid or gaseous release - IN PROGRESS <u>AND</u> o Release path monitor on controlled release path - YELLOW OR HAS BEEN YELLOW Check Affected Process		<pre>Perform the following: a. Notify Chemistry of affected process radiation monitor. b. Go to OFN SP-010, ACCIDENTAL RADIOACTIVE RELEASE, Step 1. Perform the following:</pre>		
	Radiatic WITHIN I PERMIT	on Monitor Reading - LIMITS OF RELEASE		<ul> <li>a. Direct Chem perform eva release.</li> <li>b. Go to OFN S ACCIDENTAL RELEASE, St</li> </ul>	istry to luation of P-010, RADIOACTIVE ep 1.
8.	Check Building Gaseous Effluent Monitors - NONE IN ACCIDENT ISOLATION:		<u>IF</u> either monitor in accident isolation, <u>THEN</u> perform the following:		
	a. Radwa o GHF o GHI o At Isc - N b. Unit * GTF * GTI	aste Building 2101 - NOT GRAY 3102 - NOT GRAY GH RE-10, Accident 21ation red light NOT LIT Vent 2211 - NOT GRAY 3212 - NOT GRAY		<ol> <li>Notify Chem affected mon accident is</li> <li><u>IF</u> associat in alarm or perform the</li> <li><u>WHEN</u> comp release, <u>reset mon</u></li> </ol>	istry of nitor in olation. ed rate monitor alert, <u>THE</u> N following: leted with <u>THEN</u> locally itor.
9.	* At Isc - N Return 7 In Effec	GT RE-21, Accident olation red light NOT LIT <b>TO Procedure And Step</b>		OR * Reduce rei below ala: locally rei 3. <u>IF</u> associat <u>NOT</u> in alary <u>THEN</u> locally monitor.	lease rate rm setpoint and eset monitor. ed rate monitor m or alert, y reset



OFN SP-010

### ACCIDENTAL RADIOACTIVE RELEASE

Responsible Manager

Manager Operations

<b>ለ" ለ" ለ" ለ" ለ" ለ" ለ" ለ" (</b> " ህ	$\mathbf{A}$ \$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$
	^μ Revision Number Ψ৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬৬
<i>&amp;&amp;&amp;&amp;&amp;</i> &&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&	^μ Use Category μακακακακακακακακακακακακακακακακακακα
ゟ゙゚ゟ゚ゟ゚ゟ゚ゟ゚ゟ゚ゟ゚	<pre>µ Administrative Controls Procedure µ No µ</pre>
<i>₠₦₦₦₦₦</i> ₽₽₽₽	A Tretrocupative Doutermod Drocodure A No A
₡₡₡₡₡₡₡₡	ት <i>ትዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮ</i> ጵዮ 2 IULIEdueucly belloumed blogeduie 2 NO 2
	д Program Number д 21A д ማትትትትትትትትትትትትትትትትትትትትትትትትትትትትትትትትትትትት
$\vee \vee \vee \vee \vee \vee \vee \vee \Diamond \Diamond \land \checkmark$	

DC4 03/22/1999

#### 1.0 <u>PURPOSE</u>

Continuous Use

1.1 To provide operator actions in response to an accidental release of radioactive gas or liquid.

#### 2.0 <u>SYMPTOMS OR ENTRY CONDITIONS</u>

2.1 The following symptoms are indicative of a gaseous or liquid release:

a. Increased Radiation Monitor readings:

* AB RE-111 Steam Line D PORV Discharge * AB RE-112 Steam Line C PORV Discharge * AB RE-113 Steam Line B PORV Discharge * AB RE-114 Steam Line A PORV Discharge * BM RE-25 SG Blowdown * BM RE-52 SG Blowdown * EG RE-09 CCW Hx Train A * EG RE-10 CCW Hx Train B * FB RE-50 Aux. Steam Condensate X-fer Pump * FC RE-381 Aux FDWTR Turbin Disch * GE RE-92 Condenser Air Removal * GG RE-27 Fuel Bldg. Exhaust * GG RE-28 Fuel Bldg. Exhaust * GH RE-10 Radwaste Building * GH RE-22 Radwaste BLDG EXHST PART * GH RE-23 Waste Gas * GK RE-04 Control Bldg. Supply Air * GK RE-05 Control Bldg. Supply Air * GK RE-41 Access Control * GL RE-60 Aux. Bldg. Exhaust Filter * GT RE-21A Unit Vent * GT RE-21B Unit Vent * GT RE-22 Containment Purge * GT RE-31 Containment Atmosphere * GT RE-32 Containment Atmosphere * GT RE-33 Containment Purge * GT RE-59 CNTMT HI Range Area Mon * GT RE-60 CNTMT HI Range Area Mon * HB RE-18 Waste Monitor Tank Pump Disch * HE RE-16 Boron Recycle Evap. Distillate * HF RE-45 Secondary Liquid Waste Disch * HF RE-95 Waste Water Treatment Influent * LE RE-59 Turbine Bldg. Drains * SJ RE-01 CVCS Letdown * SJ RE-02 SG Blowdown b. Unexplained trends on any of the following recorders: * RR1 * RR2 * GH RR-10B * GH RR-51 * GT RR-21B * GT RR-58

Revision: 5

ACCIDENTAL RADIOACTIVE RELEASE

Continuous Use

Page 2 of 16

- 2.2 Any of the following annunciator lit is an indication of a gaseous or liquid release:
  - * Annunciator 00-061B, PROCESS RAD HI
  - * Annunciator 00-061A, PROCESS RAD HIHI

  - * Annunciator 00-107F, GASEOUS RADWASTE TROUBLE * Annunciator 00-108F, SEC LIQ RADWASTE TROUBLE
  - * Annunciator 00-109F, LIQUID RADWASTE TROUBLE

#### 3.0 REFERENCES AND COMMITMENTS

#### 3.1 <u>References</u>

a. AP 07B-003, OFFSITE DOSE CALCULATION MANUAL

3.2 <u>Commitments</u>

a. None

Revision: 5				OFN SP-010	
Continuous Use		ACCIDENTAL RADIOAC	IIVE RELEASE	Page 3 of 16	
STE	ACTION	/EXPECTED	RESPONSE NOT		
1.	Check L: - ANY HI	isted Gaseous Monitors I-HI ALARM ACTUATED	Go to Step 8.		
2.	* GE RE Remova * GG RE * GG RE * GG RE * GG RE * GH RE * GH RE Supply * GK RE Supply * GT RE * GT RE Atmosp * GT RE * GT RE Check I: Ventilat	-92 Condenser Air al -27 Fuel Bldg. Exhaust -28 Fuel Bldg. Exhaust -10 Radwaste Building -04 Control Bldg. 7 Air -05 Control Bldg. 7 Air -22 Containment Purge -31 Containment phere -32 Containment phere -33 Containment Purge <b>E Control Room</b> tion Isolation d:			
	a. HI-HI follo ACTUA * GG Exh * GG * GK Sug * GK Sug * GT Pun * GT Atr * GT Pun	I alarm on any of the pwing monitors - ATED RE-27 Fuel Bldg. haust RE-28 Fuel Bldg. haust RE-04 Control Bldg. oply Air RE-05 Control Bldg. oply Air RE-22 Containment osphere RE-31 Containment hosphere RE-33 Containment ge	a. Go to Step	б.	

Revision: 5			OFN SP-010	
Continuous Use	ACCIDENIAL RADIOA	CIIVE RELEASE	Page 5 of 16	
STE ACTION	/EXPECTED	RESPONSE NOT		
4. Check I should a. HI-Hi follo ACTU * GT * GT * GT * GT * GT * GT * GT * GT	f Containment Purge Be Isolated: I alarm on any of the owing monitors - ATED RE-22 Containment rge RE-31 Containment nosphere RE-32 Containment rge k ESFAS status panel section - ALL WHITE T LIT d train llow train	<ul> <li>a. Go to Step</li> <li>b. Perform the         <ol> <li>IF conta isolatio actuated actuate purge is</li></ol></li></ul>	5. following: inment purge n has <u>NOT</u> , <u>THEN</u> manually containment olation. 11 15 PIS component erly aligned, ually align t. <u>IF</u> t(s) can <u>NOT</u> be <u>THEN</u> manually ly isolate containment ion. Refer to NT A.	
Revisi	on: 5			OFN SP-010
--------	----------------------------	-----------------------------------------------------------------	----------------------------------------------------------------------------------	----------------------------------------------------------------------
Contin	uous Use	ACCIDENTAL RADIO	ACTIVE RELEASE	Page 6 of 16
STE -	ACTION	I/EXPECTED	RESPONSE NOT	
5.	Check I Isolati	f Fuel Building on Should Be Isolated:		
	a. HI-H foll ACTU	I alarm on any of the owing monitors - ATED	a. Go to Step	6.
	* GG Exl * GG Exl	RE-27 Fuel Bldg. haust RE-28 Fuel Bldg. haust		
	b. Chec FBIS LIGH	k ESFAS status panel section - ALL WHITE T LIT d train	b. Perform the 1) <u>IF</u> FBIS actuated actuate	following: has <u>NO</u> T , <u>THEN</u> manually FBIS.
	o Ye	llow train	o SA HS- o SA HS-	10 14
			2) <u>IF</u> any F <u>NOT</u> prop <u>THEN</u> man componen ATTACHME	BIS component erly aligned, ually align t.refer to NT B.

Revision: 5				07.07		OFN SP-010
Contin	uous	s Use	ACCIDENTAL RADIO	UACI	LIVE RELEASE	Page 7 of 16
STE -	A	CTION	/EXPECTED	$\vdash$	RESPONSE NOT	
6.	Che Blc	ck I: wdowi	f Steam Generator n Should Be Isolated:	-		
	a.	HI-HI Air I	I alarm on Condenser Removal - ACTUATED		a. Go to Step	7.
		o GE	RE-92			
	b.	Perfo	orm the following:		b. Manually cl	ose valves.
		1) Cł bl va	neck steam generator Lowdown isolation alves - CLOSED			
		0 0 0	BM HIS-1A BM HIS-2A BM HIS-3A BM HIS-4A			
		2) Or er sa -	n panel SJ-143,locall nsure SG blowdown ample isolation valve CLOSED	y s		
		0 0 0	BM HIS-5 BM HIS-6 BM HIS-7 BM HIS-8			
7.	Che Shc	ck I: ould 1	f Gas Decay Tank Be Isolated:			
	a.	HI-HI Build	I alarm on Radwaste ling – ACTUATED		a. Go to Step	8.
		o GH	RE-10			
	b.	Checl Tanks Build Isola	c 2 Inch Gas Decay s Outlet To Radwaste ding HVAC Auto ation - CLOSED		b. At Panel HA close valve	-116, locally
		о НА	HCV-14			

Revision: 5	ACCIDENTAL RADIOA			OFN SP-010
Continuous Use	ACCIDENTAL RADIO	JAC.	IIVE RELEASE	Page 8 of 16
STE ACTION	/EXPECTED	$\left  - \right $	RESPONSE NOT	
8. Check Li - ANY Hi * BM RE * BM RE * BM RE * EG RE * EG RE * EG RE * FB RE Conden * HB RE Pump I * HE RE Evap. * HF RE Waste	isted Liquid Monitors I-HI ALARM ACTUATED -25 SG Blowdown -52 SG Blowdown -09 CCW Hx Train A -10 CCW Hx Train B -50 Aux. Steam hsate X-fer Pp -18 Waste Monitor Tan Disch -16 Boron Recycle Distillate -45 Secondary Liquid Disch	k	Go to Step 18.	
<pre>% aste * LE RE- Drains * HF RE- treats * SJ RE- 9. Check I: Blowdown</pre>	-59 Turbine Bldg. 5 -95 Waste Water ment Influent -02 SG Blowdown f Steam Generator n Should Be Isolated:			
a. HI-HI follo ACTUZ o SJ o BM o BM	I alarm on the owing monitor - ATED RE-02, SG Blowdown RE-25, SG Blowdown RE-52, SG Blowdown		a. Go to Step	10.
b. Perfo 1) Ch b: va o o o o o o o o o o o o o o o o o o	orm the following: heck steam generator lowdown isolation alves - CLOSED BM HIS-1A BM HIS-2A BM HIS-3A BM HIS-3A BM HIS-4A h panel SJ-143 locall hsure SG blowdown ample isolation valve CLOSED BM HIS-5 BM HIS-6 BM HIS-7 BM HIS-8	Y	b. Manually cl	ose valves.

Revision: 5				OFN SP-010
Contin	uous Use	ACCIDENTAL RADIC	DACTIVE RELEASE	Page 9 of 16
STE -	ACTION	I/EXPECTED	RESPONSE NOT	
10.	Check I Be Isol	f CCW A Train Should ated:	ADELTHED	,
	a. HI-H Exch ACTU	I alarm on CCW Heat anger Train A - ATED	a. Go to Step	11.
	o EG	RE-09		
	b. Check vent	k CCW Surge tank A - CLOSED	b. Manually cl	ose valve.
	o EG	HIS-9		
	c. Chec to C Clos	k Demineralized water CW surge tank A - ed	c. Manually cl	ose valve.
	o EG	HIS-1		
11.	Check I Be Isol	f CCW B Train Should ated:		
	a. HI-H Exch ACTU	I alarm on CCW Heat anger Train B - ATED	a. Go to Step	12.
	o EG	RE-10		
	b. Check vent	k CCW Surge tank B - CLOSED	b. Manually cl	ose valve.
	o EG	HIS-10		
	c. Chec to C Clos	k Demineralized water CW surge tank B - ed	c. Manually cl	ose valve.
	o EG	HIS-2		
12.	Check I Pump Di Isolate	f Waste Monitor Tank scharge Should Be d:		
	a. HI-H Moni Disc	I alarm on Waste tor Tank Pump harge – ACTUATED	a. Go to Step	13.
	o HB	RE-18		
	b. Chec Pump	k Waste Monitor Tank Disch – CLOSED	b. Locally clo	se valve.
	o HB	RV-18		

Revisi	lon:	5			OFN SP-010
Contir	nuou	ıs Use	ACCIDENIAL RADIOA	CIIVE RELEASE	Page 10 of 16
STE -	A	CTION	I/EXPECTED	RESPONSE NOT	
13.	Ch Ev Be	eck I apora Dive	f Boron Recycle tor Distillate Should rted:		
	a.	HI-H Recy dist	I alarm on Boron cle Evaporator illate – ACTUATED	a. Go to Step	14.
		O HE	RE-16		
	b.	Chec Evap DIVE UP T	k Boron Recycle orator Distillate - RTED TO RECYCLE HOLD ANK	b. Locally div recycle eva recycle hol	ert boron porator to d up tank.
		O HE	HS-16		
	c.	Chec Feed BYPA	k Recycle Evaporator Demineralizers – SSED	c. Locally byp evaporator demineraliz	eass recycle feed ers.
		O HE	TCV-250		
14.	Ch Wa Is	eck I ste D olate	f Secondary Liquid isch Should Be d:		
	a.	HI-H Liqu ACTU	I alarm on Secondary id Waste Discharge - ATED	a. Go to Step	15.
		o HF	RE-45		
	b.	Chec Wast	k Secondary Liquid e Disch Valve - CLOSED	b. Locally clo	ose valve.
		o HF	RV-45		
15.	Ch Dr	eck I ains	f Turbine Building Should Be Isolated:		
	a.	HI-H Build	I alarm on Turbine ding Drains - ACTUATED	a. Go to Step	16.
		o LE	RE-59		
	b.	Chec Drai	k Turbine Building ns - CLOSED	b. Manually cl	ose drain.
		o LE	RV-59		
1					

Revision: 5		5				OFN SP-010
Continuous Use			ACCIDENIAL RADIC	JACI	LIVE RELEASE	Page 11 of 16
STE	P	CTION	/EXPECTED	$\vdash$	RESPONSE NOT	
16.	Ch Tr Is	eck I eatme olate	f Waste Water nt Influent Should be d:			
	a.	HI-H Trea ACTU	I alarm on Waste Wate tment Influent - ATED	r	a. Go to Step	17.
		o HF	RE-95			
	b.	Chec Trea -CLO	k Waste Water tment Influent Valve SED		b. Manually cl	ose valve.
		o HF	RV-95			
17.	Ch Co Sh	eck I ndens ould	f Auxiliary Steam ate Transfer Pump Be Isolated:			
	a.	HI-H stea	I alarm on auxiliary m - ACTUATED		a. Go to Step	18.
		o FB	RE-50			
	b.	Chec Pump	k Condensate Transfer s - OFF		b. Turn off pu	mps.
		O PFI	B01A			
		o PFI	B01B			
	c.	Chec AUX CONT	k RADWASTE BUILDING STEAM SUPPLY PRESS ROL VALVE CLOSED		c. Locally clo	ose valve.
		o FBI	PV029			
18.	De Of	termi: fsite	ne If Release Is			
	a.	1. HI-HI alarm on the following monitor - ACTUATED			a. Perform the 1) Direct H	e following: ealth Physics ate increased
		* GH * GT	RE-10 Radwaste Bldg. RE-21 Unit Vent		2) Notify C 3) Go to St	n levels. hemistry. ep 20.

ACTION/EXPECTED

ACCIDENTAL RADIOACTIVE RELEASE

Page 12 of 16

Continuous Use

STE

RESPONSE NOT

 μ
 NOTE
 μ

 μ
 μ

 μ
 μ

 μ
 μ

 μ
 radioactive material from the site boundary.
 μ

	19.	Evaluate Release		
		a. Direct Chemistry to evaluate for abnormal releases as follows:		
		1) Sample source of release		
		2) Perform dose calculations to determine if 10 CFR 20 release limits have been exceeded		
		b. Direct Health Physics to evaluate increased radiation levels		
		c. Refer to AP 07B-003, OFFSITE DOSE CALCULATION MANUAL, for release limits and remedial actions		
	20.	Identify Probable Leakage Source Using ATTACHMENT C, RADIATION SOURCE IDENTIFICATION		
	21.	Check Leakage Source - ISOLATED	Check need for evacuation.	local area
пппп	22.	Refer To Emergency Preparedness Procedure EPP 06-005, EMERGENCY CLASSIFICATION		
	23.	Consult Shift Supervisor/ Supervising Operator For Further Direction		
	24.	Return To Procedure And Step In Effect		
		-END-		

ACCIDENTAL RADIOACTIVE RELEASE

Ц

Ц

Ц

Ľ

Page 13 of 16

#### ATTACHMENT A

(Page 1 of 1)

VALVES CLOSED BY CONTAINMENT PURGE ISOLATION SIGNAL

> Ц Ц

> > Ц

<u>NOTE</u>

### $\mu$ All of the values have visible local position indication.

RED TRAIN atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TRAIN 
atural YELLOW TURAL 
atural YELLOW TURAL 
atural YELLOW TURAL 
atural YELLOW 
atural YELLOW TURAL 
atural YELLOW TURAL 
atural YELLOW TURAL 
atural YELLOW 
atura

¤ GT HZ-5	Ц	CTMT Mini-Purge	Ц	GT HZ-4	Ц	CTMT Mini-Purge	Ц
Ц	Ц	Supply Inside	Ц		Ц	Supply Outside	Ц
Ц	Ц	CTMT Iso	Ц		Ц	CTMT Iso	Ц

Ц	GT HZ-12¤	CTMT Mini-Purge	Ц	GT HZ-11 X CTMT Mini-Purge	1
Ц	Ц	Exh Outside	Ц	¤ Exh Inside ¤	I
Ц	Ц	CTMT Iso	Ц	A CTMT Iso	1

μG	T HZ-7	Ц	CTMT S/D Purge	Ц	GT HZ-6	Ц	CTMT S/D Purge	Ц
Ц		Ц	Supply Inside	Ц		Ц	Supply Outside	Ц
Ц		Ц	CTMT Iso	Ц		Ц	CTMT Iso	Ц

¤ GT HZ-9	¤ CTMT S/D Purge	¤ GT HZ-8	¤ CTMT S/D Purge	Ц
Ц	¤ Exh Outside	П	¤ Exh Inside	Ц
Ц	¤ CTMT Iso	П	¤ CTMT Iso	Ц

-END-

Continuous Use

٦

	ATTACHMENT B (Page 1 of 1)
	FBIS ACTUATION VERIFICATION
в1.	Ensure Emergency Exhaust Fans - RUNNING
	o CGG02A o CGG02B
в2.	Ensure Fuel Bldg. To Emergency Filter Units - OPEN
	o GG HZ-40 dampers GG-D025 o GG HZ-43 dampers GG-D018
в3.	Ensure Fuel Bldg. Air Supply Fans - STOPPED
	o SGG01A o SGG01B
в4.	Ensure Fuel Bldg. Air Supply Fan Discharge Damper - CLOSED
	o GG HZ-38 dampers GG-D5 o GG HZ-39 dampers GG-D6
в5.	Ensure Fuel Bldg. Air Inlet Dampers - CLOSED
	o GG RZ-36 dampers GG-D3 o GG RZ-37 dampers GG-D4
в6.	Ensure Spent Fuel Pool Discharge To Aux. Bldg. Damper - CLOSED
	o GG HZ-42 damper GG-D32
в7.	Ensure Fuel Bldg. Exhaust To Aux. Bldg. Vent Damper - CLOSED
	o GL HZ-62 damper GL-D58
в8.	Align Other Ventilation Systems Discharging To Unit Vent:
	o Ensure Access Control Exhaust Fans - STOPPED
	o GK HIS-47 for CGK02A o GK HIS-49 for CGK02B
	o Ensure Main Steam Enclosure Exhaust Fans - STOPPED
	o GF HIS-17 for CGF03A o GF HIS-18 for CGF03B
	o Ensure Aux/Fuel Normal Exhaust Fans - IN SLOW SPEED
	o GL HIS-30 for CGL03A o GL HIS-31 for CGL03B

-END-

ACCIDENTAL RADIOACTIVE RELEASE

Continuous Use

## ATTACHMENT C (Page 1 of 2) RADIATION SOURCE IDENTIFICATION

 $\stackrel{\amalg}{}$  If the source of radioactivity cannot be identified, the  $\stackrel{\amalg}{}$  possibility of a failed detector should be considered.

Ц

₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₽ ₳₳₳₳₳₳₳₳₳₳₳₳₳₽₽

Ц

GASEOUS MONITOR ALARM SOURCES

Ц

Ц

Ц

D

*₳₳₳₳₳₳₳₳₳₳₳₳₳₳* ₳*₳₳₳₳₳₳₳₳₳₳₳*₽₽

¤ DETECTOR ¤

POSSIBLE SOURCES

Ц

¤ GT RE-21A ¤ * Auxiliary Building HVAC	Ц
¤ GT RE-21B ¤ * Turbine Buidling HVAC	Ц
¤ ¤ * Fuel Building HVAC	Ц
¤	Ц
¤ ¤ * Control Building HVAC	Ц
¤ ¤ * Containment purge	Ц

Ц	GT RE-22	Ц *	Primary leak inside containment	П
Ц	GT RE-33	口 *	Failed fuel	Ц
Ц	GT RE-31	口 *	Damaged fuel	Ц
Ц	GT RE-32	Ц		Ц
Ц	GT RE-59	Ц		Ц
Ц	GT RE-60	Ц		Ц

¤ GH RE-10¤ * Gas decay tank release¤¤ GH RE-22¤ * Leaking gas decay tank relief valve¤¤µ * Pipe leak associated with Waste Gas System¤

¤ GH RE-23	Ц	*	Leak	from	gas decay tank	Ц
Ц	Ц	*	Pipe	leak	associated with Waste Gas System	Ц

لله المعنية المعني 

¤ GK RE-04¤ Temperature inversion¤¤ GK RE-05¤¤

 $\mbox{\tt \ \ } \mbox{\tt \ } \m$ 

 $\mathcal{A}$ 

 µ
 GK RE-41 µ
 * Ventilation from chemical equipment drain sump

 µ
 µ
 × Ventilation from Control Building floor and µ

 µ
 µ
 equipment drain sump
 µ

 µ
 µ
 × Ventilation from Health Physics Count Room µ
 µ

 µ
 µ
 × Ventilation from Hot Laboratory
 µ

 $^{\mu}$  GE RE-92  $^{\mu}$  Steam generator tube leak

Ц

 $\mathcal{A}$   $\mathcal{A}$ 

ACCIDENTAL RADIOACTIVE RELEASE

Continuous Use

Page 16 of 16

	ATTACHMENT C (Page 2 of 2) RADIATION SOURCE IDENTIFICATION	
<i>\$\$\$\$\$</i>	А А ААААААААА ААААААААААААААААААААААА	ਸ਼ ` <i>ŔŔŔŔŔ</i> Ŕ
	A GASEOUS MONIIOR ALARM SOURCES	
<i>ŶŶŶŶ</i> Ŕ	本 DELECLOB A DELECTOR A DELEC	H H
		M M M M M N
<i>やややや</i> は	\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$	$\cdot \phi \phi \phi \phi \phi \phi \phi$
	¤ SJ RE-01 ¤ * Crud burst in RCS ¤ ¤ * Failed fuel pin cladding	п п
	ዄ፞ፚዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾ	᠈ᡩ᠋ᢞᡩ᠋ᡩᡩᡩ
がかかかん	安安安安安安安安安 ロ SJ RE-02 ロ Steam generator tube leak ロ BM RE-25 ロ	ц
	$\mu$ BM RE-52 $\mu$	Д
	$\square$ AB RE-111 $\square$ $\square$ AB RE-112 $\square$	ц ц
	$\square$ AB RE-112 $\square$	ц
	Д АВ RE-114 Д Д FC RE-381 Д	л л
<u>ሱ</u> ሲ ሲ ሲ ሲ ሲ	ᢞᡊᡊᡊᡊᡊᡊᡊᢦ ᠳᢙ᠋ᢙ᠙ᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩᡩ	<i>፞፞፞፞፞፞፞፞፞፞፞፞፞፞ዾዾዾዾዾ</i>
$\gamma \gamma \gamma \gamma \gamma$	$\mu$ EG RE-9 $\mu$ * Leak in RCP thermal barrier	Д
	¤ EG RE-10 ¤ * Leak in letdown heat exchanger	Ц
	Д Д * Leak in excess letdown heat exchanger Д Д * Leak in RHR heat exchanger	Ц
	Image: A stand line     Image: A stand line       Imag	д
מי מי מי מי מ	$\phi$	゚ゟゟゟゟゟ
$\langle \langle \langle \rangle \rangle \rangle \langle \langle \rangle \rangle$	□ FB RE-50 □ * Liquid radwaste evaporator	ц
	HH* Boron recycle evaporator	Ц
	д	Д
<i>₽₽₽₽</i> 4	<i>``\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\</i>	` <i>&amp;&amp;&amp;&amp;</i> &&&&
	$\mu$ HB RE-18 $\mu$ * Bad sample of waste monitor tank THB07A	Ц
	PPBad sample of waste monitor tank THB07B	Д
<i>₽₽₽₽</i> ₽	<i>~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~</i>	` <i>&amp;&amp;&amp;&amp;</i> &&&&
	HE RE-16 A Evaporator malfunction	Д
ゟ゚ゟ゚ゟ゚ゟ゚ゟ	\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$	<i>`&amp;&amp;&amp;&amp;</i> && <i>\$</i>
	¤ HF RE-45 ¤ * Bad secondary liquid tank sample ¤ ¤ * Release from wrong tank	н н

Ц

Ц

 $^{\mbox{\sc LE}}$  LE RE-59  $^{\mbox{\sc M}}$  Steam generator tube leak

mu HF RE-95 mu Steam generator tube leak

-END-



#### SYS SP-121

#### OPERATION OF THE G.A. MONITOR SYSTEM

#### Responsible Manager

Manager Operations

	<i><b>\</b>\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$</i>	<i>፞ቝ፞፞፼፼ዾዸዾዾ</i>	₺₡₡₯₡₡₡₡
	۲ Revision Number گرورورورورورورورورورورورو	口 10 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5	ਸ਼ ਸ਼
₶₶₶₶₶₶₶	A lise Category	д Т	Reference
		. M. M. M. M. M. M. M. I	1、M、M、人M、M、M、M、
₢₢₢₢₢₢	\$ <i>\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$</i>	2444444	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
	Administrative Controls Procedure	\$\$\$\$\$\$\$\$\$\$ ¤ No	₽₽₽₽₽₽₽₽₽ ₽
<i>&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;</i> &&&&&&&&&&&&&&&&&&&&&&&&&&&&	¤ Infrequently Performed Procedure	¤ No	Ц
₭₭₭₭₭₭₭₭%	<i><b>₠₼₼₼₼₼₼₼₼₼₼₼₼₼</b>₽</i>	<i>፞ኯ፼ኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯ</i>	\$ <i>\$\$\$</i> \$\$\$\$\$\$
	۲ Program Number مديريديديديديديديديديديديديديديديديديديد	д 21D 	т г г г
₽₽₽₽₽₽₽₽₽		$\rightarrow$	$\forall \forall \forall \diamond \diamond$

DC4 08/17/2000

Revi	sion	:	10

OPERATION OF THE G.A. MONITOR SYSTEM

	TABLE OF CONTENTS	
SECTION	I <u>TITLE</u>	<u>PAGE</u>
1.0	PURPOSE	2
2.0	SCOPE	2
3.0	REFERENCES AND COMMITMENTS	2
3.1	References	2
4.0	PRECAUTIONS/LIMITATIONS	3
5.0	PREREQUISITES	5
6.0	PROCEDURE	6
6.1	Process Monitor Readings Using RM-11R (SP056A)	6
6.2	Monitor Item Operations Using RM-11R (SP056A)	7
6.3	Channel Item & Release Setpoint Operations Using RM-11R	
	(SP056A)	9
6.4	Process Monitor Readings Using RM-23	11
6.5	Monitor Item Operations Using RM-23	12
6.6	Channel Item & Release Setpoint Operations Using RM-23	15
6.7	Source Checking Prior To Radioactivity Release	19
6.8	Process Monitor Pump Operations	21
6.9	RM-IIR (SP056A) Multiple Communication Failure	2.2
6 10	ACKNOWLEdgment	22
6.1U	Special Operations	∠ ⊃ ⊃ 4
5.11		24
7.U አጥጥአሮሮ	גבטאטס ואפאיד אסגם גייגת זיזאואגעס מאנייטא 20 איידאס	20 26
	IMENT R RM-25 MONITOR AND CHANNED DATA BASE TIEMS	20
	IMENT C RM-11R (SP056A) COLOR CODES AND DEDICATED KEV	27
111 1/101	FUNCTIONS	31
FTGURF	1 RM-11R (SP056A) NORMAL MODE PANEL KEY LAYOUT	32
FIGURF	2 RM-11R (SP056A) SUPERVISOR/LIT MODE (LITTERAL DATA	52
	MODE )	33

Reference Use

OPERATION OF THE G.A. MONITOR SYSTEM

#### 1.0 <u>PURPOSE</u>

1.1 This procedure provides instructions for the operation of the General Atomics (GA) Process Monitor Systems RM-11R (SP056A) and RM-23.

#### 2.0 <u>SCOPE</u>

- 2.1 This procedure provides instructions to take process monitor readings from the RM-11R (SP056A) or RM-23.
- 2.2 This procedure provides instructions for Monitor Item operations at the RM-11R (SP056A) or RM-23.
- 2.3 This procedure provides instructions for Channel Item operations at the RM-11R (SP056A) or RM-23.
- 2.4 This procedure provides instructions for check source operation.
- 2.5 This procedure provides instructions for process monitor pump operations.
- 2.6 This procedure provides instructions to acknowledge a multiple communication failure of the RM-11R (SP056A).
- 2.7 This procedure provides instructions to place the Unit Vent monitor in Accident mode.
- 2.8 This procedure provides instructions for special operations such as lamp testing RM-23.

#### 3.0 <u>REFERENCES AND COMMITMENT</u>S

#### 3.1 <u>References</u>

- 3.1.1 AP 07B-003, Offsite Dose Calculation Manual
- 3.1.2 PMR 4701
- 3.1.3 Vendor Manuals:
  - o J-316-00072 o J-361-00075 o J-361-0078 o J-361A-00041
- 3.1.4 PIR 95-2205
- 3.1.5 CCP 7860
- 3.1.6 Technical Specifications

Reference Use

#### 3.2 Commitments

3.2.1 None

#### 4.0 <u>PRECAUTIONS/LIMITATIONS</u>

- 4.1 The system must be in the Supervisor Mode to make data base changes from an RM-23 or RM-11R (SP056A).__IF the system is <u>NOT</u> in the Supervisor Mode,<u>_THEN</u> the changes will not be accepted.
- 4.2 Data base entries made from an RM-23 or RM-11R (SP056A) must be performed in the proper format. Steps to which this applies have an example given for the step describing data entry.
- 4.3 The source check is considered satisfactory when the radiation monitor source check is energized and source activity reaches or exceeds the check source limit. (Channel Item 15)
- 4.4 Refer to AP 07B-003, OFFSITE DOSE CALCULATION MANUAL for the following monitor operability requirements:

4.4.1 Liquid Effluent Monitors: (Table 2-2)

- o HB RE-18
- o BM RE-52
- o le re-59
- o HF RE-45
- o HF RE-95

4.4.2 Gaseous Effluent Monitors: (Table 3-2)

- o GT RE-21A
- o GT RE-21B
- o GT RE-22
- o GT RE-33
- o GH RE-10A
- o GH RE-10B

Refer to Technical Specifications or Technical Requirements

for the following monitor operability requirements: o GK RE-4 (TS 3.3.7) o GK RE-5 (TS 3.3.7) o GG RE-27 (TS 3.3.8) (TR 3.7.13) (TS 3.3.8) (TR 3.7.13) o GG RE-28 o GT RE-31 (TS 3.3.6) o GT RE-32 (TS 3.3.6) 4.6 IF RM-11R (SP056A) is INOPERABLE, THEN GT RE-10A and GT-RE-21A sample flows should be verified at the sample skids. OPERABILITY status of applicable liquid effluent monitors should be evaluated with the Shift Manager. 4.7 All command function operations of the safety-related monitors (GK RE-4, GK RE-5, GG RE-28, GG RE-27, GT RE-31, GT RE-32, GT RE-33 and GT RE-22) must be performed from the RM-23 on panel SP067. 4.8 WHEN monitors GH RE-10B or GT RE-21B go into alert OR high alarm, THEN the associated monitor, GH RE-10A or GT RE-21A, will go into accident isolate. 4.8.1 Accident isolate must be locally reset at the rad monitor. Chemistry shall be notified when GH RE-10A or 4.8.2 GT RE-21A go into accident isolate. 4.9 IF the RM-80 display (LIT, GRID 5, SELECT) is not used, THEN the Master Database will not update. 4.10 Contact I&C if a monitor loses power to ensure the proper data is reloaded into the monitor. Changes made at the RM-23 will not update the RM-11R 4.11 Ц Supervisor RM-80 Database Screen, Master Column. Manual Ц action must be taken to modify this column. M When using the RM-11R to place or remove monitors from poll 4.12 Ц (Monitor Item 100), only use the Monitor Items Screen. Do Ц not use the Supervisor RM-80 Database Screen (LIT, GRID 5, SELECT) as an unplanned data transfer could occur. Ц

Reference Use

4.5

4.13 Monitor Item 100 relay bypass allows I&C to do testing on the process monitors and receive alarms on the RM-11R. However, H this condition blocks the selected monitor alarm from the H Main Control Board. This condition is indicated on the H RM-11R Grid display by the channel bottom half being white. H

#### 5.0 <u>PREREQUISITES</u>

5.1 Process Monitors are energized.

Ц

Ц

Ц

Reference Use

OPERATION OF THE G.A. MONITOR SYSTEM

Ц

ц Ц

Ц

Ц

#### 6.0 <u>PROCEDURE</u>

6.1 <u>Process Monitor Readings Using RM-11R (SP056A)</u>

NOTE

## $^{\amalg}$ Refer to Figure 1 for a visual display of the RM-11R (SP056A) $^{\amalg}$ panel key layout.

- 6.1.1 To select a grid on the CRT, press the corresponding GRID NUMBER KEY.
- 6.1.2 <u>WHEN</u> desired grid is displayed, <u>THEN</u> select desired channel as follows:
  - 1. Key in the three digit Channel Identification Number displayed on the grid.
  - 2. Press the SEL key.
  - 3. Check the selected channel outlined in White.
- 6.1.3 To obtain a Process Monitor Activity Reading, perform the following:
  - 1. Select desired channel using Step 6.1.2.
  - 2. Select desired function key. Refer to Attachment C for function key functions.
    - o TREND 10 MIN o TREND HOURLY o TREND DAILY o STATUS
- 6.1.4 To obtain a Process Monitor Sample Pressure and Activity Reading, perform the following:
  - 1. Place Supervisor Master Key in the key slot and turn it to SUPERVISOR position.
  - 2. Select desired channel using Step 6.1.2.
  - 3. Press the LIT key.
  - 4. Press the STOP LOG key.
  - 5. Press the SEL key.
  - 6. <u>WHEN</u> no further sample pressures <u>AND</u> activity readings are desired, <u>THEN</u> return the Supervisor

Master Key to the NORMAL position.

OPERATION OF THE G.A. MONITOR SYSTEM

Ц

Ц

Ц

Reference Use

#### 6.2 <u>Monitor Item Operations Using RM-11R (SP056A)</u>

> Ц Ц NOTE Ц Ц Ц The only Monitor item that is normally changed by Operations is  $\pi$ Ц Ц Monitor item 100. All other changes must be directed by another Ц Ц procedure or approved by AI 15E-001, COMPUTER DATA BASE CHANGE Ц Ц Ц REQUEST. Ц

Ц

Ц

Ц

- 6.2.1 To view the Monitor Items list, perform the following:
  - 1. Select desired channel using Step 6.1.2.
  - 2. Press the MON ITEMS Channel Displays key.
  - 3. The CRT will display the first page of the MONITOR ITEMS and associated values.
  - 4. Press the ENTER key to page thru the Monitor Items.
- 6.2.2 To change the value of a Monitor Item, perform the following:
  - 1. Page to the desired Monitor Item using Step 6.2.1.
  - 2. Place Supervisor Master Key in the key slot and turn it to SUPERVISOR position.
  - 3. Key in the desired Monitor Item number.
  - 4. Press the SEL key.
  - 5. Check the selected Monitor Item is backlit.

 $egin{aligned} egin{aligned} egin{blackled} egin$ 

 $\mbox{$\mu$}$   $\mbox{$\mu$}$   $\mbox{$\mu$}$   $\mbox{$\mu$}$  The Monitor Item number may be advanced by depressing the SEL  $\mbox{$\mu$}$   $\mbox{$\mu$}$   $\mbox{$\mu$}$  key.  $\mbox{$\mu$}$ 

NOTE

- 6. Key in the desired Monitor Item value in the correct format. Example: 5.79x10⁻⁵ is keyed in as 5, 7, 9, -, 0, 5.
- 7. Press the ENTER Key.

-					-	$\sim$
ке	Vl	Sl	on	:	T	υ

- 8. <u>IF</u> the entry is accepted, <u>THEN</u> the message at the bottom of the CRT will indicate value accepted and the value for that item will be updated.
- 9. <u>IF</u> the entry is <u>NO</u>T accepted, <u>THEN</u> an error message will be displayed at the bottom of the CRT. Press the CLEAR key and return to Step 6.2.2.6.
- 10. <u>WHEN</u> no further changes are desired, <u>THEN</u> turn the Supervisor Master Key to the NORMAL position.
- 6.2.3 <u>WHEN</u> all Monitor Item operations are complete, <u>TH</u>EN press any grid or trend key to exit.

OPERATION OF THE G.A. MONITOR SYSTEM

Page 9 of 33

Reference Use

6.3 Channel Item & Release Setpoint Operations Using RM-11R

(SP056A)

Ц

 $\mathcal{R}$  $\mathcal{R}$ 

> Ц NOTE Ц Ц Ц Ц If entering release setpoints for a safety related monitor, Ц section 6.6, CHANNEL ITEM & RELEASE SETPOINT OPERATIONS USING Ц Ц Ц Ц RM-23 should be used. Ц Ц Ц Ц

- 6.3.1 To change the value of a Supervisor RM-80 Database Channel Item, perform the following:
  - 1. Select the desired channel per step 6.1.2.
  - 2. Place Supervisor Master Key in the key slot and turn it to SUPERVISOR position.
  - 3. Press the LIT key.
  - Press the Grid 5 key. 4.
  - 5. Press the SEL key.
  - 6. Verify the Supervisor RM-80 Database Screen is displayed.
  - 7. Press the minus (-) key.
  - Key in the desired Channel Item number. 8.
  - 9. Press the SEL key.
  - 10. Check the selected Channel Item is backlit.

 $oldsymbol{\lambda}$ 

Ц М																	]	NC	)T	Ε																				Ц
ц Ц	т1	he	C	ha	nr	ום ⁻	1	тŧ	em	<b>.</b> т	nıı	տե	he	r	m	av	b	e	а	đ٦	7a	nc		ьd	ł	v	ċ	lei	or	6	zs	iı	na	. 1	- he	2	SE			Ц
Ц	k	ey.					-							-		~1	~	Ŭ	~	~	-					-1			-	~						-	-			Ц
Ц		-																																						Ц
m M	м	мм	м	м	м	мм	ім	м	MM	I M	1 M	м	м	м	м	мм	м	м	м	м	м	м	м	м	м	ми	4 H	мм	м	м	м	м	м	м	MM	1 M	M	м	м	мм

 $\mathcal{P}$  $\mathcal{P}$ 

> 11. Key in the desired channel item value in the correct format. Example:  $5.79 \times 10^{-5}$  is keyed in as 5, 7, 9, -, 0, 5.

12. Press the ENTER key.

Revision	: 10
----------	------

R	ev	i	s	i	on	:	1	0

OPERATION OF THE G.A. MONITOR SYSTEM

6.4 <u>Process Monitor Readings Using RM-23</u>

6.4.1 On the selected monitor, press the desired Channel Display key.

- * GAS
- * PART
- * IOD

#### 6.4.2 Check the selected Channel Display key is backlit.

- * GAS
- * PART
- * IOD
- 6.4.3 Check the selected channel indication display for the current activity value.

Reference Use

OPERATION OF THE G.A. MONITOR SYSTEM

Ц

Ц

ц Ц

#### 6.5 Monitor Item Operations Using RM-23

 $egin{aligned} egin{aligned} egin{aligned} egin{aligned} eta & eb$ 

П П <u>NOTE</u>

# $\mbox{$\overset{\square}{$}$}$ Refer to Attachment A for a list of the commonly used Monitor $\mbox{$\overset{\square}{$}$}$ Items. $\mbox{$\overset{\square}{$}$}$

e

6.5.1	To obtain a display of the current value for a
	Monitor Item, perform the following:

- 1. Press the desired Channel Display key.
- 2. Press the MON key
- 3. Check the MON key is backlit.
- 4. Enter the three digit monitor item number.
- 5. Press the ITEM key.
- 6. Check the ITEM key backlit and the current value for that Monitor Item is displayed.
- 7. <u>IF</u> desired to read another Monitor Item, <u>THEN</u> enter the three digit number and press the ITEM key or sequentially read each item by pressing the plus (+) key to go forward.

OPERATION OF THE G.A. MONITOR SYSTEM

 $oldsymbol{\lambda}$ Ц NOTE Ц Ц Ц Ц The only Monitor item that is normally changed by Operations is  $\Xi$ Ц Ц Monitor item 100. All other changes must be directed by another Ц M Ц procedure or approved by AI 15E-001, COMPUTER DATA BASE CHANGE  $\square$ Ц Ц REQUEST. Ц Ц Ц Ц 6.5.2 To change the value of a Monitor Item, perform the following: 1. Obtain a display of the current value using Step 6.5.1.  $oldsymbol{\lambda}$ Ц Ц NOTE Ц Ц Ц S/G steamline monitors and turbine driven AFW pump exhaust Ц  $^{\amalg}$  monitor do not have Supervisor key slots and are always enabled  $^{\amalg}$ Ц to receive Monitor Item changes. Ц Μ M 2. IF changing S/G steamline monitors OR turbine driven AFW pump exhaust monitor, THEN Steps 6.5.2.3 through 6.5.2.5 are not applicable. * AB RE-111 * AB RE-112 * AB RE-113 * AB RE-114 * FC RE-385 3. Obtain the Supervisor Master Key and place it in the proper key slot on SP067 or SP010. o Two key slots are on SP067. One is for red train process monitors and one is for yellow train process monitors. o SP010 has 2 key slots. One is for GH RE-10B and one is for GT RE-21B. 4. Turn the Supervisor Master Key to the SUPV position.

- 5. Verify the SUPV mode red light is lit.
- 6. Key in the desired Monitor Item value in the correct format. Example: 5.79x10⁻⁵ is keyed in as 5, 7, 9, -, 0, 5.

- 7. Press the ENTER key.
- 8. <u>IF</u> the entry is accepted, <u>THEN</u> the display will momentarily go blank followed by a display of the new value.
- 9. <u>IF</u> the entry is <u>NOT</u> accepted, <u>THEN</u> the ERROR light will illuminate. Press the CLEAR key and return to Step 6.5.2.6.
- 10. <u>WHEN</u> no further changes are desired, <u>THEN</u> perform the following:
  - a. Press any Channel Display key.
    - * GAS
    - * PART
    - * IOD
  - b. Return the Supervisor Master Key to the NORM position.
  - c. Verify the SUPV mode red light goes out.
  - d. Remove the Supervisor Master Key.

Revision. 1	-0
-------------	----

OPERATION OF THE G.A. MONITOR SYSTEM

Page 15 of 33

6.6 Channel Item & Release Setpoint Operations Using RM-23 6.6.1 To obtain a display of the current value for a Channel Item, perform the following: 1. Press the desired Channel Display key. * GAS * PART * IOD Check the desired channel backlit. 2. * GAS * PART * TOD ulletЦ Ц NOTE Ц Ц Ц Refer to Attachment A for a list of the commonly used Channel Ц Ц Ц Items. Ц Ц 3. Enter the desired three digit channel item number. 4. Press the ITEM key. Check the ITEM key backlit and the current value 5. for that Channel Item is displayed. 6. IF desired to read another Channel Item, THEN enter the three digit number and press the ITEM key or sequentially read each item by pressing the plus (+) key to go forward. 6.6.2 To change the value of a Channel Item, perform the following: 1. Obtain a display of the current value for a Channel Item: a. Press the desired Channel Display key. * GAS * PART * TOD b. Check the desired channel backlit. * GAS * PART

* IOD

-				1 0
Rev	18.	i on	:	

Ц

ц Ц

Ц

Ц

Ц

Ц

 $\mathcal{R}$ 

ц Ц

Ц

Ц

Ц

Refer to Attachment A for a list of the commonly used Channel Items.

NOTE

ロ Item

- c. Enter the desired three digit channel item number.
- d. Press the ITEM key.
- e. Check the ITEM key backlit and the current value for that Channel Item is displayed.
- f. <u>IF</u> desired to read another Channel Item, <u>THEN</u> enter the three digit number and press the ITEM key or sequentially read each item by pressing the plus (+) key to go forward.

 $egin{aligned} egin{aligned} egin{blackled} egin{blackled} egin{aligned} egin{aligned\\ egin{aligned} egin{aligned} egin{aligned} egin{aligned} egin{aligned} egin{aligned} egin{aligned} egin{aligned} egin{aligned\\ egin{aligned} egin{aligned} egin{blackled} egin{blackled} egin{aligned} egin{aligned} egin{aligned} egin{aligned} egin{blackled} egin{blackle$ 

NOTE

 $\mathscr{O}$ 

- <u>IF</u> changing S/G steamline monitors OR turbine driven AFW pump exhaust monitor, <u>THEN</u> Steps 6.6.2.3 through 6.6.2.5 are not applicable.
  - * AB RE-111 * AB RE-112 * AB RE-113 * AB RE-114 * FC RE-385
- 3. Obtain the Supervisor Master Key and place it in the proper key slot on SP067 or SP010.
  - o Two key slots are on SP067. One is for red train process monitors and one is for yellow train process monitors.
  - o SP010 has 2 key slots. One is for GH RE-10B and one is for GT RE-21B.
- 4. Turn the Supervisor Master Key to the SUPV
position.

5. Verify the SUPV mode red light is lit.

_							-	~
R	A11	п.	q	п.	$\cap n$	:		()
τ.	$\sim $	_	c	_		-		0

Reference Use

-			
		б.	Key in the desired Channel Item value in the correct format. Example: 5.79x10 ⁻⁵ is keyed in a 5, 7, 9-, 0, 5.
		7.	Press the ENTER key.
		8.	<u>IF</u> the entry is accepted, <u>THEN</u> the display will momentarily go blank followed by a display of the new value.
		9.	<u>IF</u> the entry is <u>NO</u> T accepted, <u>THEN</u> the ERROR light will illuminate. Press the CLEAR key and return to Step 6.6.2.6.
		10.	<u>WHEN</u> no further changes are desired <u>, TH</u> EN perform the following:
			a. Press any Channel Display key.
			* GAS * PART * IOD
			b. Return the Supervisor Master Key to the NORM position.
			c. Verify the SUPV mode red light goes out.
			d. Remove the Supervisor Master Key.
	6.6.3	Veri	fy the RM11R Supervisor RM-80 Database Screen
	7	Mast	er and RM-80 columns are the sameIF not <u>, TH</u> EN
		upda ¤	te the Master Column at RM-11R as follows:
		1. ¤	Perform steps 6.3.1.1 thru 6.3.1.11.
		2. ¤	Press the ENTER key.
<i>₠₠₽₽</i> ₽	\$\$\$\$\$\$\$\$\$\$\$\$\$ \$\$\$\$\$\$\$\$\$\$\$\$\$\$	<i>\$\$\$</i> \$\$\$\$	ጵ⊕ ን <i>ሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱሱ</i> ጵጵጵ
	н н		NOTE I
	보 <b>On Safety re</b> 보	elate	d monitors, when the ENTER key is depressed in $µ$
	H the next ste	ep, t	he Master Column will update and the Message $\pi$
	$\mu$ area will in $\mu$	ndica	te the message is accepted, followed by a $\pi$
	$\overset{ extsf{med}}{\overset{ extsf{mes}}{\overset{ extsf{mes}}}{\overset{ extsf{mes}}{\overset{ extsf{mes}}{\overset{ extsf{mes}}}{\overset{ extsf{mes}}{\overset{ extsf{mes}}}{\overset{ extsf{mes}}{\overset{ extsf{mes}}{\overset{ extsf{mes}}{\overset{ extsf{mes}}{\overset{ extsf{mes}}{\overset{ extsf{mes}}{\overset{ extsf{mes}}}{\overset{ extsf{mes}}{\overset{ extsf{mes}}{$	sage	. The rejected message is normal and can be $\square$

ц Ц

3. ¤	A Message area will appear at the bottom of the
	screen, ¤
	a. <u>IF</u> the data in the message area is correct ${}^{\mu}$
	<u>THEN</u> press the ENTER key and proceed to ¤
	step 6.6.3.4 ¤

Ц

Re	ivz	чi	on	:	1	n
TCC	5 V L	ът	OIL	•	'	U

Reference Use

b. <u>IF</u> the d ¤	lata in the message area is incorrect,
<u>THEN</u> pre ¤	ess the CLEAR key and re-enter the
correct ¤	data and return to step 6.6.3.2.
4. WHEN no fur	ther changes are desired, THEN turn

the Supervisor Master key to the NORMAL

4. ¤

Ц

Д

position.

Ц

Ц

Ц

Ц

M

Reference Use

OPERATION OF THE G.A. MONITOR SYSTEM

Ц

Ц

Ц

Ц

Ц

Ц

Ц

#### 6.7 <u>Source Checking Prior To Radioactivity Release</u>

- NOTES
- ^{$\mu$} o Safety-related monitors (GK RE-4, GK RE-5, GG RE-28, GG RE-27,
- $\stackrel{\amalg}{}$  GT RE-31, GT RE-32, GT RE-33 and GT RE-22) can not be source  $\stackrel{\amalg}{}$  checked using RM-11R (SP056A).  $\stackrel{\amalg}{}$
- $\stackrel{\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox{$\mbox$
- possessing the process system automatic isolation on high alarm feature.
- - 6.7.1 Check source using the RM-11R (SP056A):
    - 1. Select the desired grid and channel using Step 6.1.2.
    - 2. Press the CHECK SOURCE key and verify the backlight is on.

and the test should be repeated.

 $egin{aligned} egin{aligned} egin{blackled} egin{blackled} egin{aligned} egin{aligned} egin{aligned} egin{aligned} egin{aligned} egin{blackled} egin{blackled$ 

NOTE

Ц Ц Ц Ц The Check Source backlight will remain illuminated during the Ц ¤ entire check source interval. Ц Ц 3. Check the RM-11R (SP056A) display bar color changes from green to half-intensity cyan. 4. In the lower left-hand corner of the CRT, check the displayed message reads CHECK SOURCE ENERGIZED. Check satisfactory check source: 5. a. <u>WHEN</u> check source is completed, <u>THEN</u> check that tested channel's green operate light is lit. b. IF the display bar color changed to dark blue, <u>THEN</u> the check source is unsatisfactory

c. <u>IF</u> the check source fails repeatedly, <u>TH</u>EN a work request should be generated.

Reference Use

OPERATION OF THE G.A. MONITOR SYSTEM

- 6.7.2 Check source using an RM-23:
  - 1. Select desired channel using Step 6.4.1.
  - Press the selected channel C/S pushbutton and check it is backlit.
  - 3. Check satisfactory check source:
    - a. <u>WHEN</u> check source is completed, <u>THEN</u> check the C/S backlight is off.
    - b. <u>IF</u> the GREEN OPER indicator is of<u>f</u> AND the selected channel backlight is blinking, <u>THEN</u> the check source is unsatisfactory and the test should be repeated.
    - c. <u>IF</u> the check source fails repeatedly, <u>THEN</u> a work request should be generated.

<b>D</b> -	·			10
Rev.	lSl	on	•	Τ0

ſ

Reference Use

٦

	6.8 <u>Process</u>	Monitor Pump Operations
8888	ଷ୍ୟଷ୍ୟଷ୍ୟଷ୍ୟ ଅଧ୍ୟ ଷ୍ୟସ୍ୟସ୍ୟସ୍ୟସ୍ୟସ୍ଥ୍ୟ 0	$\begin{array}{c} \mathbf{x} \mathbf{x} \mathbf{x} \mathbf{x} \mathbf{x} \mathbf{x} \mathbf{x} x$
	<ul> <li>B The effects</li> <li>C Technical Sp</li> <li>S SM/CRS prior</li> <li>B process moni</li> </ul>	on plant status and operability requirements of (S) ecifications and ODCM should be discussed with (S) to securing process monitor pump(s). Securing (S) tor pumps may require bypassing bistables associated
	© with the res © prevent inad	pective process radiation monitor in order to (S) vertent actuations.
8888	ଷ୍ୟଷ୍ୟଷ୍ୟଷ୍ୟଷ୍ୟ ଷ୍ୟଷ୍ୟଷ୍ୟଷ୍ୟଷ୍	କ୍ଷ୍ୟ୍ୟ୍ୟ୍ୟ୍ୟ୍ୟ୍ୟ୍ୟ୍ୟ୍ୟ୍ୟ୍ୟ୍ୟ୍ୟ୍ୟ୍ୟ୍ୟ୍ୟ୍
	6.8.1	To operate process monitor pumps from RM-11R (SP056A), perform the following:
		1. Select desired channel using Step 6.1.2.
		2. Secure or start process monitor pump on selected channel by depressing the FLOW Channel Monitor Control key.
	6.8.2	To operate process monitor pumps from an RM-23, perform the following:
		1. Secure or start process monitor pump on the desired monitor by depressing the FLOW key.
	6.8.3	To locally operate process monitor pumps at the process monitor skid, perform the following:
		1. Secure the process monitor pump by placing the skid mounted pump switch to OFF position.
		2. Start the process monitor pump by placing the skid mounted pump switch to AUTO position.
		a. <u>IF</u> process monitor pump does <u>NO</u> T start <u>, TH</u> EN start the pump using Step 6.8.1 or Step 6.8.2.

-					-	$\sim$
Rev	7.9	37	n	:		()
100 0		-	011			~

6.9	<u>RM-11R</u>	(SP056A) Multiple Communication Failure Acknowledgment
	6.9.1	Place Supervisor Master Key in the key slot and turn it to SUPERVISOR position.
	6.9.2	Press 0 three times.

6.9.3 Press the SEL key.

Reference Use

OPERATION OF THE G.A. MONITOR SYSTEM

Ц

Ц

#### 6.10 <u>Placing Unit Vent Monitor In Accident Mode</u>

Ц

Ц

Ц

Ц

```
Ц
The Unit Vent Monitor can not be verified in Accident Mode using
```

NOTE

#### $\square$ RM-11R (SP056A).

Ц Ц 

6.10.1	Pla Mod	cing Unit Vent Monitor GT RE-21B in Accident e using RM-11R (SP056A):
	1.	Press the GRID 1 key.
	2.	Place Supervisor Master Key in the key slot and turn it to SUPERVISOR position.
	3.	Key in the three digit channel identification number 213.
	4.	Press the SEL key and check the selected channel is outlined in white.
	5.	Press the LIT key.
	б.	Press the GRID 5 key.
	7.	Press the SEL key.
	8.	Press 1.
	9.	Press the SEL key and check Monitor Item 1 is backlit.
	10.	Press 4.
	11.	Press the ENTER key.
	12.	At GT RIC-21B, verify Unit Vent Monitor in Accident Mode as follows:
		a. Press the MON key.
		b. Press 139.
		c. Press the ITEM key.
		d. Check display reading 000.

- '				1 0
RAVI	ЧI	n	:	(1 )
TCAT	DT		•	<b>T</b> O

Reference Use

	6.10.2	Pla Mod	cing Unit Vent Monitor GT RE-21B in Accident e using SP010:
		1.	At GT RIC-21B, press the MON key and check button for GT RIC-21B is backlit.
		2.	Press 001.
		3.	Press the ITEM key and check ITEM button is backlit and monitor item 001 current value is displayed.
		4.	Place Supervisor Master Key in the key slot and turn it to SUPV position.
		5.	Check SUPV mode red light is lit.
		б.	Press 004.
		7.	Press the ENTER key to display the new value of 004.
		8.	Turn Supervisory Master Key to NORM.
		9.	At GT RIC-21B, verify Unit Vent Monitor in Accident Mode as follows:
			a. Press the MON key.
			b. Press 139.
			c. Press the ITEM key.
			d. Check display reading 000.
6.11	<u>Special</u>	Oper	<u>rations</u>
	6.11.1	Lam	p testing an RM-23:
		1.	At the desired RM-23 channel, perform lamp test as follows:
			a. Press 997.
			b. Press the ITEM key.
			c. Check the following lights lit:
			o Top 8 buttons
			o ITEM button

o MON button

Reference Use

- d. <u>IF</u> any lamp <u>NOT</u> lit, <u>THEN</u> contact I&C to change light bulbs.
- 2. Restore from lamp test as follows:
  - a. Press the CLEAR key
  - b. Press the ITEM key
  - c. Press 7
- 7.0 <u>RECORDS</u>
- 7.1 None

-END-

Reference Use

OPERATION OF THE G.A. MONITOR SYSTEM

	ATTACHMENT A (Page 1 of 1) RM-23 MONITOR AND CHANNEL DATA BASE IT	EMS
ダダダダ	<i>АФФФФФФФФФФФФФФФФФФФФФФФФФФФФФФФФ</i> <i>АФФФФФФФФФФ</i>	ц ц <i>кккккккккк</i> кк
於於於於於	<ul> <li>□ For a list of only monitor items, such as 033</li> <li>□ Pressure, refer to vendor manual J-361-00269.</li> <li>□ ③ \$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$</li></ul>	は Sample ユ
M. M. @	<i>₳₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽</i>	<i>ᢞ᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅᠅</i>
<i>\$\$</i>	H MONITOR ITEMS	д
MMA	<b>ᠳ<i>ᡊᡊᡊᡊᡊ</i>᠃<i>ᠺᡊᡊᢦᡊ</i>ᢦ<i>ᡊᡊᢦᡊᢦᢦᢦᢦᢦᢦᢦᢦᢦᢦᢦᢦᢦᢦᢦᢦᢦᢦᢦveeeeeeeeeeeee</i></b>	<i>ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼</i> ਖ਼
谷谷公	ユ ITEM ユ DESCRIPTION	н
ммл	<i>₠₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼₼</i>	<i>ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼</i> ਫ਼
谷谷公	¤ 016 ¤ Sample Flow Rate 1 Setpoint	н
мма	<i>ᠳ<i>ᡊᡊᡊᡊᡊ᠔᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙ᡭ᠙᠙ᡭ᠙ŶŶŶŶŶŶŶŶŶŶŶŶŶ</i></i>	<i>ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼</i> ਫ਼
<i>\$6</i> \$	¤ 020 ¤ Data Base Complete	ц
мма	<i>ᠳ<i>ᡊᡊᡊᡊᡊᡩ᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙ᡭ᠙᠙ᡭ</i></i>	<i>ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼</i> ਖ਼
谷谷令	¤ 033 ¤ Sample Pressure	ц
мма	<i><b>Ⴉ<i>ჁჁჁჁ</i>ჁჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄ</b></i>	<i>ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼</i> ਫ਼
<i>₽₽</i>	¤ 048 ¤ Purge Control Options	ц
мма	<i><b>Ⴉ<i>ჁჁჁჁ</i>ჁჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄჄ</b></i>	<i>ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼</i> ਫ਼
谷谷公	¤ 062 ¤ Sample Flow Rate Number 2 (WRGM) S	etpoint ¤
ммл	<i>ᠳ<i>ᡊᡊᡊᡊᡊ᠔᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙᠙ᡭ᠙᠙ᡭ</i></i>	<i>ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼ਲ਼</i> ਖ਼
$\phi\phi\phi$	¤ 100 ¤ Monitor Polling Status	д
$\hat{P}\hat{P}$	₲ <i>₦₦₦₦₽</i> ₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽	<i>₼₼₼₼₼₼₼₼₼₼₼</i>
M. M. 🔿	<i><b>₳</b>₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽</i>	<i>₠₦₦₽₽₽₽₽₽₽₽₽₽₽</i> ₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽
$\Diamond \Diamond \bigcirc$	X CHANNEL ITEMS	ц
u. u. a	৾ <i>৸৵৵৵৵৵৵</i> @ <i>₯₳₳₳₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽</i>	<i>ᢞᡊ᠅ᡭ᠅ᡭ᠅ᡭ᠅ᡭ᠅ᡭ᠅ᢤ</i>
$\Diamond \Diamond \lor \lor$	X ITEM X DESCRIPTION	Д

ቢ ቢ 🔊	ዄዸ፟ዸ፟ዸዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾ	$e^{e^{e^{e^{e^{e^{e^{e^{e^{e^{e^{e^{e^{e$
$\diamond \diamond \diamond$	¤ 009 ¤ Hi Alarm Setpoint	Ц
<u> </u>	ዄዸዾዸዸዸዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾ	おおおおおおおお
$\diamond \diamond \diamond$	¤ 010 ¤ Alert Alarm Setpoint	Ц
M. M. A	ዄዸዸዸዸዸዸዾዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸ	おおおおおおおお
$\Diamond \Diamond \diamond$	¤ 013 ¤ Channel Background	Ц
M. M. A	ዄዸዾዸዸዸዾዸዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾ	おおおおおおおお
$\diamond \diamond \diamond$	¤ 015 ¤ Check Source Reference	Ц
U. U. A	₲₡₺₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡	ゟゟゟゟゟゟゟゟ
$\diamond \diamond \diamond$	¤ 016 ¤ Channel Service State Request	Ц
M. M. A	ዄዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸ	゚ゟゟゟゟゟゟゟゟ
$\Diamond \Diamond \diamond$	¤ 018 ¤ Raw Counts Totalizer	Ц
$\mathcal{P}\mathcal{P}$	<i>᠍₳₳₳₳₳₽</i> @ <i>₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳₳</i>	<i>᠅ᡭŶŶŶŶŶŶŶŶ</i>

-END-

OPERATION OF THE G.A. MONITOR SYSTEM

Reference Use

Page 27 of 33

#### ATTACHMENT B (Page 1 of 4) RM-11R (SP056A) CHANNEL DESCRIPTIONS

#### LIQUID RADIATION MONITORS

MONITOR	ID NUMBER	TYPE	DESCRIPTION
BM RE-25	256	Gamma	Steam Generator Blowdown Process Monitor
BM RE-52	526	Gamma	Steam Generator Effluent Monitor
EA RE-04A	416	Gamma	Service Water Monitor
EA RE-04B	426	Gamma	Service Water Monitor
EG RE-09	096	Gamma	Component Cooling Water Monitor
EG RE-10	106	Gamma	Component Cooling Water Monitor
FB RE-50	506	Gamma	Auxiliary Steam Condensate Tank Monitor
HB RE-18	186	Gamma	Liquid Radwaste Process System Discharge Monitor
HE RE-16	166	Gamma	Boron Recycle Evaporator Distillate Monitor
HF RE-45	456	Gamma	Secondary Liquid Waste Discharge Monitor
HF RE-95	956	Gamma	Turbine Bldg Discharge to Waste Water Treatment
LE RE-59	596	Gamma	Turbine Bldg Drain Effluent Monitor
SJ RE-01	016	Gamma	CVCS Letdown Monitor
SJ RE-02	026	Gamma	Steam Generator Sampling Monitor

OPERATION OF THE G.A. MONITOR SYSTEM

Page 28 of 33

#### ATTACHMENT B (Page 2 of 4) RM-11R (SP056A) CHANNEL DESCRIPTIONS

WIDE RANGE GAS MONITORS

MONITOR	ID NUMBER	TYPE	DESCRIPTION
GH RE-10B	103	NG Activity (Channel #4) Release Rate	Radwaste Building Vent Monitor
	105	Low Range Noble Gas	
	108	Medium Range Noble Gas	
	109	High Range Noble Gas	
GT RE-21B	213	NG Activity (Channel #4) Release Rate	Unit Vent Monitor
	214	Low Range Noble Gas	
	215	Medium Range Noble Gas	
	216	High Range Noble Gas	

Reference Use

OPERATION OF THE G.A. MONITOR SYSTEM

SYS SP-121

Page 29 of 33

#### ATTACHMENT B (Page 3 of 4) RM-11R (SP056A) CHANNEL DESCRIPTIONS

#### PARTICULATE/IODINE/NOBLE GAS CHANNELS

MONITOR	ID NUMBER	TYPE	DESCRIPTION
GK RE-04	041	Particulate	Control Room Air Supply Monitor
	042	Iodine	
	043	Noble Gas	-
GK RE-05	051	Particulate	Control Room Air Supply Monitor
	052	Todino	
	052	Iodine	
	053	Noble Gas	
GT RE-22	221	Particulate	Containment Purge Monitor
	222	Iodine	
	223	Noble Gas	
GT RE-33	331	Particulate	Containment Purge Monitor
	332	Iodine	_
	333	Noble Gas	
GG RE-27	271	Particulate	Fuel Building Exhaust Monitor
	272	Iodine	
	273	Noble Gas	
GG RE-28	281	Particulate	Fuel Building Exhaust Monitor
	282	Iodine	
	283	Noble Gas	
GG RE-31	311	Particulate	Containment Air Monitor
	312	Iodine	
	313	Noble Gas	
GG RE-32	321	Particulate	Containment Air Monitor
	322	Iodine	
	323	Noble Gas	
L			

OPERATION OF THE G.A. MONITOR SYSTEM

#### ATTACHMENT B (Page 4 of 4) RM-11R (SP056A) CHANNEL DESCRIPTIONS

#### PARTICULATE/IODINE CHANNELS

MONITOR	ID NUMBER	TYPE	DESCRIPTION
GH RE-10A	101	Particulate	Radwaste Building Effluent Monitor
	102	Iodine	
GH RE-21A	2111	Particulate	Radwaste Building Effluent Monitor
	212	Iodine	

#### PARTICULATE CHANNELS

MONITOR	ID NUMBER	TYPE	DESCRIPTION
GH RE-22	224	Particulate	Radwaste Building Exhaust Monitor
GK RE-41	414	Particulate	Access Control Area Ventilation Exhaust Monitor
GL RE-60	604	Particulate	Auxiliary Building Ventilation Exhaust Monitor

#### NOBLE GAS CHANNELS

MONITOR	ID NUMBER	TYPE	DESCRIPTION
GH RE-23	235	Noble Gas	Waste Gas Radiation Monitor
GH RE-92	925	Noble Gas	Condenser Air Discharge Monitor

-END-

OPERATION OF THE G.A. MONITOR SYSTEM

SYS SP-121

Page 31 of 33

Reference Use

					ATTA	ACHM	ENTC						
		RM-11I	R (SP05	6A) COI	(Page LOR COE	)ES I	of 1) AND DE	DICAT!	ED KEY	Y FUNC	CTION	S	
	<i>₳₿₿₿₿</i>	، ش ش ش ش ش ش ش ش	^ҵ ҅҂ <i>ҾҾҾ</i> ҝ	<i>\$&amp;&amp;&amp;</i> &	С( <i>фффф</i> 4	ららら DLOR	、 CODE {	2 ` <i>ŶŔŔŔ</i>	` <i>፞፞፞፞፞፞፞፞፞፞፞፞፞ቚ፞</i> ዸ፟ዸ	₽₽₽₽	д <i>РРРА</i>	\$ <i>\$</i> \$\$\$4	\$ <b>⊕</b>
	\$\$ <i>\$\$\$\$\$\$\$\$\$</i>	) > <i>企企企在</i>	ц > <i>ҾҾҾҾ</i> ¢	ዮጵጵጵጵ Color	<i>₽₽₽₽€</i>	D&& ¤	᠂ᡬᢞᡬᡷᡬ	。 STA	、安安安女 TUS	₽₽₽₽₽	ц <i>РРР</i>	\$ <i>\$\$</i> \$\$	50
	<i>ᠳᡭ<i>ᡬᡭᡭ</i></i>	) ` <i>企企企</i> 在	ュ MHILE >	; ? <i>&amp;&amp;&amp;&amp;</i> &	₲₲₲₲₵	口 日 日	、	, <i>ゆめん</i> な DR OFF	、 了 了 了 了 了 了 了 了 了 了 了 了 了 了 了 了 了 了 了	? <i>?</i> ????	д <i>Р Р Р Р</i>	\$ <i>\$\$</i> \$4	<b>\$</b> \$
	\$\$\$\$\$\$\$\$	) ` <i>企企企在</i>	ロ MAGEN	1LY ? <i>&amp;&amp;&amp;&amp;</i> &	₲₲₲₲₲	口 日 日	、 COMMUI	、存合を存 、存存を存	、安安安女 ONS F	? AILUR AILUR	E I R	? <i>\$</i> ? <i>\$</i> \$	<b>\$</b> \$
	ዄዸ፟ዸ፟ዸ	) , <i>企 企 企 企</i>	口 DARK	名称の 名字の 名 A A A A A A A A A A A A A A A A A A	₢₡₡₡₡₡	ム で 日	、失失失失 SYSTEI	、安安安安 M FAIL	'NKE 外谷谷谷	₽₽₽₽₽	д <i>Р Р Р Р</i>	\$ <i>\$\$</i> \$\$	<b>\$</b> @
	ዄዸ፟ዸ፟ዸ	) > <i>企企企在</i>	ュ LIGHI > <i>谷谷谷谷</i> 6	、 予 <i>合合合合</i> PTAE	(CYAN)	よ で 日	、&&&&& EQUIPI	、安安安安 MENT F	、谷谷谷谷 、谷谷谷谷	\$ <i>\$</i> \$\$\$ E	ц АААА	\$ <i>\$\$</i> \$\$	\$\$
	ዄዽ፟ዸ፟ዸ	, 分 <i>合合</i> 存	ュ 日 日 日 日 日 日 日 日	\$\$\$\$\$\$ INTENS	SSSS ITY CY1	7N ロ タ合合	MONI.	,失失失失 IOR FU	、谷谷谷谷 NCTIO	588 NS	<u>п</u> ФФФб	\$ <i>\$\$</i> \$\$	50
	ዄኇ፟ኇዸ	, 企 <i>论论依</i> 存	口 RED	<i>₽₽₽₽₽</i> ₽	<i>&amp;&amp;&amp;</i> &&&<	д <i>фф</i> Д	、	、必 <i>於於於</i> 於	H ALA	5 <i>5</i> 55 RM	<u>н</u> ФФФ4	\$ <i>\$</i> \$ <i>\$</i> \$	50
	\$\$\$\$\$\$\$\$\$	᠈ ፝፞፞ቝቝ፞፞ዾ፞ዸ	ロ AETTC > <i>合合合合は</i>	)M おおかかか	ኇኇኇኇ	口 日 日	、 、	EL ALE 、	、安安安な RT AL	ዮጵጵጵ arm	ュ <i>合合合</i> 在	\$ <i>\$</i> \$\$\$4	50
	\$\$\$\$\$\$\$\$\$	᠈ ፝፞፞ቝቝ፞፞ዾ፞ዸ	口 GREEN	1 存存存存存	ኇኇኇኇ	口 日 日	、 S NORMAI	,依依依依 L OPER	、会会会は ATION	\$ <i>\$\$\$</i> \$	ュ <i>合合合</i> 在	\$ <i>\$</i> \$\$\$4	50
	ዄ <i>፝ኯዸኯዾኯ</i>	، ش <i>ه</i> و هر ۲	>失失失失失 ¤ BOTTOI ¤	\$&&&& M HALF	必 <i>必必必必</i> く WHITE	、 ゴ I ビクク	、 SELAY 口 (PRE	、 、 、 、 、 、 、 、 、 、 、 、 、 、	3 ` <i>论论论</i> 在	₽₽₽₽ PCI	ATVI A ATVI	> & & & & & & & & & & & & & & & & & & &	\$⊘ ¤
ⓓ⋫⋫⋫⋭	₡₡₡₡₡₡	<i>፞ዸ፞፞ዾዾዾ</i> ዾ	゙ゟ゚ゟ゚ゟ゚ゟ゚ゟ	৾৾৵৵৵৵৾৾৻	? <i>&amp;&amp;</i> &&&	谷谷白	<i>ŶŔŔ</i> Ŕ	ዯ፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞ቝ፞ዸ፟	\$ <i>\$\$</i> \$\$	<i>`₽₽₽</i> ₽	৵৻ৡ৻		
<i>⋭⋭⋭⋭</i> ⋭	<i>~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~</i>	፟ <i>ዯ፞፞፞፞፞፞፞፞፞፞፞ቝ፞፞ዾ፞</i> ፞ <i>ዯ፞ዯ፞ዯ፞</i> ዸ፞	ᠳ ᠈ <i>ᡩ᠅ᡬ᠅</i> ᡬ᠅	<i>ŶŔŔŔŔ</i>	<i>\$\$\$\$\$</i> 4	\$\$\$	` <i>₽₽₽₽</i>		 ` <i>论论论</i> 存	ዮዽዽዽ	<i>\$\$\$\$</i> 4	\$ <i>\$</i> \$\$\$4	۲ ۴ ۴ ۴
	Ц				DEDIC	CA'I'E	'D KEY	FUNCI	'IONS				Ц
<i>������</i> ¢	<u>н</u> РРРРР С	KE	`∧ \$ `\$\$\$\$\$\$\$	\$\$0\$\$ T	於於於於於	ঽ৾৾৾৵৾৾৻৾৾৵	<u></u>	₽ĊŢŢŎŊ	` <i>₽</i> ₽₽	? <i>&amp;&amp;</i> &&	かかかな	᠈ᡭᡃᡬᡷᡬ	5994 T
	፟፟ዹ፝፝፝፝፝፞፞፞፞፞ቝ፟ዸ፟	> <i>ዽ፞፞፞ዸዾ</i> ዸ	<i>&gt;₽₽₽₽₽</i> ₽	\$&\$\$\$	᠂ᡬᠻᡬᡬᡬ	PPP	`\$\$\$\$\$	` <i>\$\$\$\$</i> \$	^ <i>ÈÈÈ</i> á	???	谷谷谷在	\$ <i>\$</i> \$ <i>\$</i> \$	铲砕섬
ダダダダダ	ц РРРРССС Г	ららのから SAND TREND		<u>1</u> ¤ Tre	end cha	.nne]	l acti	vity (	over t	the la	ıst 4	hour	rs
	ዄኇኇኇ	› <i>ዽዽዽ</i> ዸ	፟ <i>፞ቝ፞፞ቝ፞ቝ</i> ዸ	\$\$\$\$\$	᠂ᡬᠻᡬᡬᡬ	\$ <i>\$</i> \$	<i>፞</i> ፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞ቚ፞፼ቘ	፞፞፞፞፞፞፞፞፞፞፞፞፞ቝ፟ዸ፝	ን <i>ዽ፞፞፞፞ዸ፞ዯ፞ዸ</i>	₽₽₽₽	ᡬᢞᡬᡷ᠙	\$ <i>\$</i> \$ <i>\$</i> 4	仓仓住

# TREND HOURLY # Trend channel activity over the last 24 hours

Ц

> ¤ TREND DAILY ¤ Trend channel activity over the last 28 days Ц

Ц

MON ITEMS A Display of Monitor Data Base Items

*<i><b>ŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶ*Ŷ Ц

¤ CHAN ITEMS ¤ Display of Channel Data Base Items

¤ STATUS ¤ Display of Monitor and Channel Status Ц

-END-

Reference Use

OPERATION OF THE G.A. MONITOR SYSTEM

#### SYS SP-121

Page 32 of 33



Reference Use

OPERATION OF THE G.A. MONITOR SYSTEM

#### SYS SP-121

Page 33 of 33



TASK: Transfer CCW Service Loop		
SAFETY FUNCTION: #8		
TASK #: 00800004		
K/A #s: 008 A1.01 – A1.04; A3.03,06,10; A4.01,03,05,08,09.		
References: SYS EG-201, Rev. 22		
Examinee's Name RO	_ SS No	SRO
The examinee's performance was evaluated against the standards in this JPM	and determined to be	
SATISFACTORY UNSATISFACTORY		
Reason if UNSATISFACTORY:		
Estimated JPM completion Time: 25 min.		
Actual Performance Time:min.		
Location of Performance: Control Room Simulator X	Plant	
Method of Performance: Simulate PerformX_		
Tools and Equipment: Simulator		
Evaluators Signature:		_ Date

Notes:

BOOTH INSTRUCTIONS: SIMULATOR SETUP: IC 171 RUN

EVALUATOR:

Provide GREEN copy of SYS EG-201 to the examinee.

* Denotes a Critical Step

Initial Conditions:

You are the BOP, the plant is stable in Mode 1, the CCW service loop is on the "B" Train CCW. An STS is pending on the "B" Train CCW Pumps. Lake temperature is 65° F.

Initiating Cues:

The Control Room Supervisor directs you to shift the CCW service loop to "A" Train CCW per SYS EG-201 section 6.1. Use the "A" CCW Pump. Leave the "B" Train CCW pump running. The Aux Bldg. is performing Section 6.2. The CRS directs that SFP Cooling will be swapped later. A Reactivity Brief has been provided.

Element #	Step #	Element	Standard	Score
		Start Time		
1.	6.1.1	Start the desired Train A CCW Pump. N/A if a Train A CCW Pump is already running.	Recognize a CCW pump will have to be started.	N/A

Cue:

Comments:

1a.6.1.1.1Turn off motor space heater supply breaker for the pump to be started. N/A the other breaker.Contact the Aux. Bldg. Operator to OPEN PG19NJF118.S U	1a.
---------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----

Cue:

#### BOOTH OPERATOR: Acknowledge request and report PG19NJF118 is OFF.

Comments:

1b.*	6.1.1.2	Start the desired CCW Pump.	Locate EG HIS-21 on RL019. Start the pump by turning the switch to the RUN position. Verify the Red light is lit and the Green light	S U
			is out.	

Cue:

#### Comments: Per Initial Conditions the Reactivity Brief has already been provided..

1c.	6.1.1.3	Verify operating CCW Pump discharge flow > 1.5E6 lbm/hr (3000 gpm). N/A non-running train.	Dispatch Aux Operator to check the "A" CCW Pump flow > 1.5E6 lbm/hr on EG FI-95 <u>Or</u> observe flow on computer point.	S U

Cue:

#### BOOTH OPERATOR: If paged as Aux Watch report "flow at 1.8E6 lbm/hr."

Comments:

2.	6.1.2	Locally verify CCW Train A Pump room cooler is running.	Contact the Aux. Bldg. Operator to verify the CCW Pump Room Cooler SGL11A running.	S U
		• SGL11A - RUNNING		

Cue:

#### BOOTH OPERATOR: Acknowledge request and report "SGL11A is running."

Comments:

* Denotes Critical Step

Element #	Step #	Element	Standard	Score
3.	6.1.3	IF CCW Pump A was started THEN verify proper room cooler damper alignment.	Dispatch Aux Watch to verify GL-D156 open and 157 closed.	S U

Cue:

## BOOTH OPERATOR: Acknowledge direction and report "GL-D156 is open and 157 is closed."

Comments:

4.	6.1.5	IF RHR train B is not in service, THEN align SFP HX B CCW Outlet valve is open to provide a flow path for CCW Train B.	Locate EC HIS-12 on RL021. Verify the Red light is lit.	S U
----	-------	------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------	-----

Cue:

#### Comments:

5.*	6.1.6	<ul> <li>Close CCW Surge Tank "A" and "B" Vent Valves.</li> <li>EG HIS-10 - CLOSED</li> <li>EG HIS-9 - CLOSED</li> </ul>	Locate EG HIS-10 on RL019. Close the valve by pressing the CLOSE P/B. Verify the Green light comes on and the Red light goes out.	S U
-----	-------	--------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------	-----

Cue:

Comments:

6.*	<ul><li>6.1.7 OPEN CCW Supply/Return valves .</li><li>EG HS-15 - OPEN</li></ul>	Locate EG HIS-15 on RL019. Open the valves by pressing the OPEN P/B. Verify the Red lights come on and the Green lights go out. Annunciator 51F should come in and stay in until the "B" Train Service Loop valves are closed.	SU
-----	---------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----

Cue:

Comments:

* Denotes Critical Step

Element #	Step #	Element	Standard	Score
7.*	6.1.8	<ul><li>Close CCW Train "B" Supply/Return Valves.</li><li>EG HS-16 - CLOSED</li></ul>	Locate EG HIS-16 on RL019. Close the valves by pressing the CLOSE P/B. Verify the Green lights come on and the Red lights go out. Verify annunciator 51F clears when both valves indicate closed.	S U

Cue:

EXTRA RO: After "B" Train Service Loop Supply Valves are closed, restore ALL thermal barrier valves to OPEN Position.

Comments:

8.	6.1.9	Verify CCW to RW and RCS flow indication.	Locate EG FI-55A on RL019. Verify flow indicated.	S U
		• EG FI-55A - Between 1.6E6 and 4.3E6.		

Cue:

#### Comments:

9.*	6.1.10	Open CCW Surge Tank "A" and "B" Vent valves.	Locate EG HIS-10 on RL019. Open the valve by pressing the OPEN P/B. Verify the Red light comes on and the Green light goes out.	S U
		• EG HIS-10 - OPEN		
		• EG HIS-9 - OPEN		

Cue:

Comments:

Termination: Restoring CCW Surge Tank Vents completes this JPM.

Stop Time _____

* Denotes Critical Step

Initial Conditions:

You are the BOP, the plant is stable in Mode 1, the CCW service loop is on the "B" Train CCW. An STS is pending on the "B" Train CCW Pumps. Lake temperature is 65° F.

Initiating Cues:

The Control Room Supervisor directs you to shift the CCW service loop to "A" Train CCW per SYS EG-201 section 6.1. Use the "A" CCW Pump. Leave the "B" Train CCW pump running. The Aux Bldg. is performing Section 6.2. The CRS directs that SFP Cooling will be swapped later. A Reactivity Brief has been provided.

Notes:

If you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

When you have completed the JPM inform your evaluator that you are done by handing this Initial Conditions/Initiating Cues sheet back to him.



#### SYS EG-201

#### TRANSFERRING SUPPLY OF CCW SERVICE LOOP AND CCW TRAIN SHUTDOWN

#### Responsible Manager

Manager Operations

<u>ለኛ ለኛ ለኛ ለኛ ለኛ ለኛ ለኛ መ</u>	<i><b>▲</b><i>ŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶŶ</i></i>	? <i>&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;</i>	᠈ℰℰℰℿℰℰℰℰ
кккккккк \$\$\$\$\$\$\$	¤ Revision Number ታሁሁሁሁሁሁሁሁ A	<i>₽</i> 22 22	᠈ <i>ዽ፞፞፞ዽ፞፞ዾ፟፟፟፟፟፟፟፟ ^ፗ</i>
$\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$	H Use Category	Ц	Continuous
$\kappa$ $\kappa$ $\kappa$ $\kappa$ $\kappa$ $\kappa$ $\kappa$ $\kappa$ $\otimes$	ᠳ <i>ᡈᡊᡊᡊᡊᡊᡊᡊᡊᡊᡊᡊᡊᡊᡊᡊᡊᡊ</i> ᠴ	₣₡₡₡₡₡₡₡₡	<i>፞፞፞፞፞፞፞፞፞ዾዾ፟ዸዾዾዾዾ</i>
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	¤ Administrative Controls Procedur ታሁሁሁሁሁሁሁሁሁሁሁሁሁሁሁሁሁ	^{.e μ} Νο	ዾ ዾ ዾ ዾ
	¤ Infrequently Performed Procedure ታጜጜጜጜጜጜጜጜጜጜጜጜጜ	P $P $ $P $ $P $ $P $ $P $ $P $ P	ৢ ৢ ৢ ৢ ৢ ৢ ৢ ৢ ৢ ৢ ৢ ৢ ৢ ৢ ৢ ৢ ৢ ৢ ৢ
<i>~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~</i>	ኳ Program Number መፍምም እስደ የመን የትር የ	д 21D ККККККККККК	<i>\ККК\</i> Ф <i>КККК</i> Д
₶₡₶₡₶₡₶₽₽		~ <i>~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~</i>	· · · · · · · · · · · ·

DC12 03/12/2001

Continuous Use

TRANSFERRING SUPPLY OF CCW SERVICE LOOP AND CCW TRAIN SHUTDOWN

SYS EG-201

Page 1 of 15

TABLE OF CONTENTS <u>SECTION</u> <u>TITLE</u> PAGE 2 1.0 PURPOSE 2 2.0 SCOPE 2 3.0 REFERENCES AND COMMITMENTS 2 3.1 References 3 3 3.2 Commitments 4.0 PRECAUTIONS/LIMITATIONS 4 5.0 PREREQUISITES 5 6.0 PROCEDURE 5 Transferring CCW Service Loop To Train A 6.1 6.2 Transfer Of CCW Supply To Post Accident Sampling Station 8 Coolers 10 6.3 Securing CCW Train B 6.4 Transferring CCW Service Loop To Train B 11 6.5 Transfer Of CCW Supply To Post Accident Sampling Station 13 Coolers Securing CCW Train A 15 6.6 15

7.0 RECORDS

Continuous Use

1.0 <u>PURPOSE</u>

1.1 This procedure provides instructions for transferring supply of the component cooling water (CCW) service loop between CCW trains.

2.0 <u>SCOPE</u>

- 2.1 This procedure transfers the component cooling water non-safety related service loop from one CCW train to the other CCW train.
- 2.2 This procedure secures the CCW train that was previously supplying the CCW non-safety related service loop at the discretion of the Shift Supervisor.
- 2.3 This procedure transfers CCW supplies to PASS sample coolers.
- 2.4 This procedure will partially satisfy the exercise μ

requirements associated with ASME Code Case OMN-1 for values μ EGHV0015 and EGHV0016 μ

3.0 <u>REFERENCES AND COMMITMENTS</u>

- 3.1 <u>References</u>
 - 3.1.1 M-12EG01(Q)
 - 3.1.2 M-12EG02(Q)
 - 3.1.3 M-02EG03(Q)
 - 3.1.4 M-12EF02(Q)
 - 3.1.5 ED 95-0059, OPERATION OF THE COMPONENT COOLING WATER SYSTEM BELOW 60°F
 - 3.1.6 PMR 2149
 - 3.1.7 E-03EG01A
 - 3.1.8 E-03EG01B
 - 3.1.9 E-03EG01C
 - 3.1.10 E-03EG01D
 - 3.1.11 E-13EG03
 - 3.1.12 E-13EG05A
 - 3.1.13 E-13EG05B

3.1.14 E-11PG21

Continuous Use

- 3.1.15 SFR 1-EG-43, "Closing Surge Tank Vent Valves During Switch Over"
- 3.1.16 Calculation EG-24, "CCW Nuclear Auxiliary Component Train Switch Over Single Valve Failure Analysis"

3.1.17 STS VT-001, VERIFICATION OF OMN-1, MOV EXCERCISE M REQUIREMENTS.

ц

3.2 <u>Commitments</u>

- 3.2.1 WM 90-0013 Updated response to NRC Bulletin 88-04, Engineering Disposition CWR 01404-90, Rev. 1 (Low Flow Cavitation)
- 3.2.2 PIR 96-0316, INADEQUATE WARMING LINE DESIGN
- 3.2.3 PIR 97-0958, Unplanned LCO Entry due to CCW Surge Tank Level Indication Concerns During Train Swap

4.0 <u>PRECAUTIONS/LIMITATIONS</u>

- 4.1 <u>IF</u> CCW to the service loop is lost, <u>THEN</u> it must be restored before reactor coolant pump motor bearing temperatures increase to 195°F or the reactor coolant pumps must be stopped.
- 4.2 <u>IF</u> a CCW train is being secured, <u>THEN</u> ensure there are no ECCS pumps operating in the train being secured.
- 4.3 <u>WHEN opening OR closing the service loop supply and return</u> valves for either train <u>AND</u> a valve fails to reposition as desired, <u>THEN</u> a condition could exist where one train could empty and the other train overfill. This situation is prevented by closing the surge tank vent valve for the affected train before starting the evolution and opening the valve after the evolution. (3.1.15, 3.1.16) [3.2.3]
- 4.4 Component cooling water pump flow must be greater than 1.5 E6 lbs/hr for continuous operation. Refer to Standing Order 17. [3.2.1]
- 4.5 During Modes 5, 6 or Defueled when lake temperature is below 35°F operation of an ESW pump is prohibited unless an associated CCW pump and the corresponding train CCW heat exchanger are in service. [3.2.2]

Continuous Use

TRANSFERRING SUPPLY OF CCW SERVICE LOOP AND CCW TRAIN SHUTDOWN SYS EG-201

Page 4 of 15

<u>INIT/DATE</u> 5.0 **PREREQUISITES** 5.1 Either CCW train A or CCW train B is supplying the service loop and the associated safety loop. 5.2 IF both CCW pumps in a train are to be secured, THEN the following must be met or the ESW pump in that train must be declared inoperable: [3.2.2] N/A if not securing a CCW train. o The plant is in Mode 1, 2, 3 or 4 or lake temperature is greater than 35°F.

Continuous Use

TRANSFERRING SUPPLY OF CCW SERVICE LOOP AND CCW TRAIN SHUTDOWN SYS EG-201

Page 5 of 15

6.0	PPOCEDII	DE	INIT/DATE
6 1	Transfe	rring CCW Service Loop To Train A	
0.1	6.1.1	Start desired Train A CCW pump: N/A if Train A CCW pump already running.	
		 Turn off the motor space heater supply breaker for the CCW pump to be started N/A the other breaker. 	Z 1.
		* PG19NJF118 for CCW Pump A - OFF * PG19NJF119 for CCW Pump C - OFF	
		Start desired CCW pump. N/A other pump.	
		* EG HIS-21 for CCW Pump A - STARTED * EG HIS-23 for CCW Pump C - STARTED	
		 Verify operating CCW Pump discharge flow is greater than 1.5 E6 lbs/hr (3000 gpm). N/A non-running train. [3.2.1] 	
		 * EG FI-95 or EGF0095 for CCW pump A - GREATER THAN 1.5 E6 LBS/HR (3000 GPN * EG FI-97 or EGF0097 for CCW pump C - GREATER THAN 1.5 E6 LBS/HR (3000 GPN 	- 1) - 1)
		 <u>IF</u> operating CCW pump discharge flow the second se	is c
	6.1.2	Locally verify CCW Train A Pump Room Coole running.	er
		o SGL11A - RUNNING	
	6.1.3	<u>IF</u> CCW pump A was started, <u>THE</u> N verify proper room cooler damper alignment:	
		1. Locally check CCW Pump A Room Cooler 11A Discharge Isolation Damper open:	
		o GL-D156 - OPEN	
		2. Locally check CCW Pump C Room Cooler 11A Discharge Isolation Damper closed	:
		o GL-D157 - CLOSED	

Continuous Use

TRANSFERRING SUPPLY OF CCW SERVICE LOOP AND CCW TRAIN SHUTDOWN SYS EG-201

Page 6 of 15

6 1 4	TE COM numb C was started THEN worify	INIT/DATE
0.1.4	proper room cooler damper alignment:	
	 Locally check CCW Pump C Room Cooler 11A Discharge Isolation Damper open: 	
	o GL-D157 - OPEN	
	2. Locally check CCW Pump A Room Cooler 11A Discharge Isolation Damper closed:	
	o GL-D156 - CLOSED	
6.1.5	<u>IF</u> RHR train B is <u>NO</u> T in service, <u>THE</u> N ensure Spent Fuel Pool Heat Exchanger B CCW Outlet Valve is open to provide a flow path for CCW train B.	∛ 1
	o EC HIS-12 - OPEN	
6.1.6	Close CCW Surge Tank A and B Vent Valves. [3.2.3]	
	o EG HIS-9 - CLOSED	
	AND	
	o EG HIS-10 - CLOSED	
<i>⋉⋉⋉⋉⋉⋉</i> > <i>⋩⋩⋩⋩⋩⋩⋩</i>	^ለ ዾዾዾዾ ዾዸዸዸዸዸዸኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯ	፟ኇዸ፟ኇዸዸዸ
, , , , , , , , , , , , , , , , , , ,	NOTE	Д М
nunciator til Step	00-051F, CCW SPLY RTN VLVS MISALIGN, will a 6.1.8 is completed.	larm n
<i>ŔŔŔŔŔŔŔ</i> ŶŔŔŔŔŔŔ	$^{ m o}$ <i>AAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAA</i>	<i>ᡩᡩᡩᡩᡩᡩᡩᡩ</i>
6.1.7	(\square) Open CCW Train A Supply/Return Valves.	
	o EG HS-15 - OPEN	
6.1.8	Close CCW Train B Supply/Return Valves.	
	o EG HS-16 - CLOSED	
6.1.9	Verify CCW To RW and RCS Flow indication.	
	ο FC FI-55Δ - ΒΕΥΨΕΓΕΝ 1 6v106	
	6.1.4 6.1.5 6.1.5 6.1.6 پېپېپېپېپې مunciator til Step پېپېپېپېپې 6.1.7 6.1.8 6.1.9	 6.1.4 IF CCW pump C was started, THEN verify proper room cooler damper alignment: Locally check CCW Pump C Room Cooler 11A Discharge Isolation Damper open: GL-D157 - OPEN 2. Locally check CCW Pump A Room Cooler 11A Discharge Isolation Damper closed: GL-D156 - CLOSED 6.1.5 IF RHR train B is NOT in service, THEN ensure Spent Fuel Pool Heat Exchanger B CCW Outlet Valve is open to provide a flow path for CCW train B. EC HIS-12 - OPEN 6.1.6 Close CCW Surge Tank A and B Vent Valves. [3.2.3] EG HIS-9 - CLOSED AND EG HIS-10 - CLOSED 5.4545454545454545454545454545454545454
Revision:	22	
-----------	----	
-----------	----	

TRANSFERRING SUPPLY OF CCW SERVICE LOOP AND CCW TRAIN SHUTDOWN SYS EG-201

Page 7 of 15

6.1.10	Open CCW Surge Tank A and B Vent Valves. [3.2.3]	<u>INIT/DATE</u>
	o EG HIS-9 - OPEN	
	AND	
	o EG HIS-10 - OPEN	
6.1.11	Section 6.1 complete	

Continuous Use

SYS EG-201

Page 8 of 15

6.2	<u>Transfer</u> <u>Coolers</u>	<u>INIT/DA</u> r Of CCW Supply To Post Accident Sampling Station	<u>Т.</u> Е
	6.2.1	Inform Chemistry of a momentary loss of cooling flow to the PASS sample coolers while transfer is taking place.	
	6.2.2	Locally close and lock CCW Train B Supply To Post Accident Sampling Station Coolers.	
		o EG-V413 - CLOSED AND LOCKED	
		Verified	
	6.2.3	Locally close and lock CCW Train B Return From Post Accident Sampling Station Coolers.	
		o EG-V415 - CLOSED AND LOCKED	
		Verified	
	6.2.4	Locally unlock and open CCW Train A Supply To Post Accident Sampling Station Coolers.	
		o EG-V414 - UNLOCKED AND OPEN	
		Verified	
	6.2.5	Locally unlock and open CCW Train A Return From Post Accident Sampling Station Coolers.	
		o EG-V416 - UNLOCKED AND OPEN	
		Verified	
	6.2.6	Record the above valve manipulations in the "Log of Locked Component Manipulations" as follows:	
		 Complete the "Installing Locking Device" section of the log for the following valves: 	
		o EG-V413 - CLOSED <u>AN</u> D LOCKED o EG-V415 - CLOSED <u>AN</u> D LOCKED	
		2. Make an entry in to the "Removing Locking Device" section of the log for the following valves:	
		o EG-V414 - UNLOCKED <u>AN</u> D OPEN o EG-V416 - UNLOCKED <u>AN</u> D OPEN	

Revi	sion	:	22
------	------	---	----

TRANSFERRING SUPPLY OF CCW SERVICE LOOP AND CCW TRAIN SHUTDOWN

SYS EG-201

Page 9 of 15

,

6.2.7 Section 6.2 complete.

<u>INIT/DATE</u>

Continuous Use

TRANSFERRING SUPPLY OF CCW SERVICE LOOP AND CCW TRAIN SHUTDOWN SYS EG-201

Page 10 of 15

			<u>INIT/DATE</u>
6.3	Securing	<u>CCW Train</u> B	
	6.3.1	Ensure all train B ECCS pumps - STOPPED	
	6.3.2	Align Spent Fuel Pool Cooling Train A for operation using SYS EC-120, FUEL POOL COOLING AND CLEANUP SYSTEM STARTUP.	
	6.3.3	Stop the running train B CCW pump(s). N/A other pump.	
		* EG HIS-22 for pump B - STOPPED * EG HIS-24 for pump D - STOPPED	
	6.3.4	Ensure the motor space heater breakers for the CCW pumps are turned on.	
		* PG20GBR240 for CCW pump B - ON * PG20GBR241 for CCW pump D - ON	
	6.3.5	Section 6.3 complete.	

-						-	~ ~ ~
к	eν	٦.	S	٦.	n	-	- 2.7
τ.	$\sim \cdot$	-	\sim	-	O T T		

TRANSFERRING SUPPLY OF CCW SERVICE LOOP AND CCW TRAIN SHUTDOWN SYS EG-201

Page 11 of 15

6.4	<u>Transfer</u>	rring CCW Service Loop To Train B	<u>INIT/DATE</u>
	6.4.1	Start desired Train B CCW pump: N/A if Train B CCW pump already running.	
		 Turn off the motor space heater supply breaker for the CCW pump to be started. N/A the other breaker. 	
		* PG20GBR240 for CCW Pump B - OFF * PG20GBR241 for CCW Pump D - OFF	
		Start desired CCW pump. N/A other pump.	
		* EG HIS-22 for CCW Pump B - STARTED * EG HIS-24 for CCW Pump D - STARTED	
		 Verify operating CCW Pump discharge flow is greater than 1.5 E6 lbs/hr (3000 gpm). N/A non-running train. [3.2.1] 	
		 * EG FI-96 or EGF0096 for CCW pump B - GREATER THAN 1.5 E6 LBS/HR (3000 GPM) * EG FI-98 or EGF0098 for CCW pump D - GREATER THAN 1.5 E6 LBS/HR (3000 GPM) 	
		 <u>IF</u> operating CCW pump discharge flow is less than 1.5 E6 lbs/hr,<u>THEN</u> refer to Standing Order 17. 	
	6.4.2	Locally verify CCW train B Pump Room Cooler running.	2
		O SGL11B - RUNNING	
	6.4.3	<u>IF</u> RHR train A is <u>NO</u> T in service, <u>THE</u> N ensure Spent Fuel Pool Heat Exchanger A CCV Outlet Valve is open to provide a flow path for CCW train A.	V 1
		O EC HIS-11 - OPEN	
	6.4.4	Close CCW Surge Tank A and B Vent Valves. [3.2.3]	
		o EG HIS-9 - CLOSED	
		AND	
		o EG HIS-10 - CLOSED	

f

Continuous Use

TRANSFERRING SUPPLY OF CCW SERVICE LOOP AND CCW TRAIN SHUTDOWN SYS EG-201

Page 12 of 15

	<i>`</i> ₩₩₩₩₩₩₩₩₩ ₩₩₩₩₩₩₩₩₩₩	ϫϫϫϫ ͻ <i>ϴ</i> ϼ <i>ϴ</i> ϼϙϙϙϙϙϙϙϙϙϙϙϙϙϙϙϙϙϙϙϙϙϙ	<u>INIT/DATE</u>
	/	NOTE NOTE	ц
	Annunciator until Step 6	00-051F, CCW SPLY RTN VLVS MISALIGN, will a .4.6 is completed.	.larm ת ת ח
<i>₽₽₽₽₽₽₽</i> ₽₽₽ @	፞ዾኇዾኇዸኇዸኇዾ ኯኯኯኯኯኯኯኯኯኯ ኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯኯ	ዽዽዽዽᢦ ፟፟ቝዸ፟ዸ፟ዸ፟ዸዾዾዸዾዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸዸኯኯኯኯኯኯኯኯኯኯ	<i>ঽ৾ড়ড়ড়ড়ড়ড়৾</i> ৾৽
	6.4.5	(□) Open CCW Train B Supply/Return Valves.	
		o EG HS-16 - OPEN	
	6.4.6	Close CCW Train A Supply/Return Valves.	
		o EG HS-15 - CLOSED	
	6.4.7	Verify CCW To RW and RCS Flow indication.	
		o EG FI-55A - BETWEEN 1.6x10 ⁶ and 4.3x10 ⁶ lbm/hr	
	6.4.8	Open CCW Surge Tank A and B Vent Valves. [3.2.3]	
		o EG HIS-9 - OPEN	
		AND	
		O EG HIS-10 - OPEN	
	6.4.9	Section 6.4 complete.	· ·

Continuous Use

SYS EG-201

Page 13 of 15

6.5	<u>Transfer</u> <u>Coolers</u>	Of CCW Supply To Post Accident Sampling Sta	<u>iti</u> on
	6.5.1	Inform Chemistry of a momentary loss of cooling flow to the PASS sample coolers while transfer is taking place.	
	6.5.2	Locally close and lock CCW Train A Supply To Post Accident Sampling Station Coolers.	
		o EG-V414 - CLOSED AND LOCKED	
		Verified	,
	6.5.3	Locally close and lock CCW Train A Return From Post Accident Sampling Station Coolers.	
		o EG-V416 - CLOSED AND LOCKED	
		Verified	/
	6.5.4	Locally unlock and open CCW Train B Supply To Post Accident Sampling Station Coolers.	,
		o EG-V413 - UNLOCKED AND OPEN	
		Verified	,
	6.5.5	Locally unlock and open CCW Train B Return From Post Accident Sampling Station Coolers.	
		o EG-V415 - UNLOCKED AND OPEN	
		Verified	/
	6.5.6	Record the above valve manipulations in the "Log of Locked Component Manipulations" as follows:	,
		 Complete the "Installing Locking Device" section of the log for the following valves: 	
		o EG-V414 - CLOSED <u>AN</u> D LOCKED o EG-V416 - CLOSED <u>AN</u> D LOCKED	
		2. Make an entry in to the "Removing Locking Device" section of the log for the following valves:	
		o EG-V413 - UNLOCKED <u>AN</u> D OPEN o EG-V415 - UNLOCKED <u>AN</u> D OPEN	

Revi	sion	: 22
------	------	------

TRANSFERRING SUPPLY OF CCW SERVICE LOOP AND CCW TRAIN SHUTDOWN

SYS EG-201

Page 14 of 15

,

6.5.7 Section 6.5 complete.

<u>INIT/DATE</u>

Continuous Use

TRANSFERRING SUPPLY OF CCW SERVICE LOOP AND CCW TRAIN SHUTDOWN SYS EG-201

Page 15 of 15

6 6	Soguring	COM Train A	<u>INIT/DATE</u>
0.0	<u>Becui Inc</u>	<u>CCW IIaIII A</u>	
	6.6.1	Ensure all train A ECCS pumps - STOPPED	
	6.6.2	Align Spent Fuel Pool Cooling Train B for operation using SYS EC-120, FUEL POOL COOLING AND CLEANUP SYSTEM STARTUP.	
	6.6.3	Stop the running train A CCW pump(s). N/A other pump.	
		* EG HIS-21 for pump A - STOPPED * EG HIS-23 for pump C - STOPPED	
	6.6.4	Ensure the motor space heater breakers for the CCW pumps are turned on.	
		* PG19NJF118 for CCW pump A - ON * PG19NJF119 for CCW pump C - ON	
	6.6.5	Section 6.6 complete.	
7.0	<u>RECORDS</u>		
7.1	The foll	lowing QA records are generated by this proc	edure:
	7.1.1	Section 5.0	

7.1.2 Section 6.0

-END-

WCGS-SRO/RO TRAINING PROGRAM JOB PERFORMANCE MEASURE EVALUATION FORM

TASK: Start H2 Analyzers Post LOCA	
SAFETY FUNCTION: #5	
TASK #: EPE074008	
K/A #s: 028 A4.03	
References: EMG FR-C1, Rev. 12, Step 8 RNO	
Examinee's Name SS No RO	SRO
The examinee's performance was evaluated against the standards in this JPM and determined to be :	
SATISFACTORY UNSATISFACTORY	
Reason if UNSATISFACTORY:	
Estimated JPM completion Time: 10 min.	
Actual Performance Time:min.	
Location of Performance: Control Room Simulator X Plant	
Method of Performance: Simulate PerformX_	
Tools and Equipment: Simulator	
Evaluators Signature	Data

Containment.

WCGS -SRO/RO TRAINING PROGRAM JOB PERFORMANCE MEASURE EVALUATION FORM

Notes:
BOOTH INSTRUCTIONS: Simulator setup: IC 177 RUN HORNS: On
EVALUATOR: Provide GREEN copy of Step 8 from EMG FR-C1.
* Denotes a Critical Step
Initial Conditions:
You are the Reactor Operator, EMG FR-C1, Response to Inadequate Core Cooling, is in effect. The Crew has reached Step 8 and has received information that "B" Train H2 Analyzer has broken tubing.
NOTE: The simulator is NOT setup for EMG FR-C1 conditions.(Ignore RCS and CTMT parameters)
Initiating Cues:
The Control Room Supervisor directs you to perform Step 8 RNO of EMG FR-C1 for Train A H2 Analyzer only.
TASK STANDARD : Upon completion of this JPM the operator will have aligned the Train A Hydrogen Analyzers per EMG FR- C1, step 8 RNO. Aligning "B" Train Valves would constitue a failure since this would cause an opening to

WCGS -SRO/RO TRAINING PROGRAM JOB PERFORMANCE MEASURE EVALUATION FORM

Element #	Step #	Element	Standard	Score
1.*	8. RNO a.	Start Time On RL011, place the power lockout switches for the containment sample valves, in the NON-ISO position. GS HIS-40 GS HIS-42	Locate the switches on RL011. Push down the NON-ISO P/B and ensure the button locks down. Verify the White light is lit.	SU

Cue:

Comments:

2.*	8. RNO b.	OPEN only one Hydrogen Analyzer Inner Ctmt. Isolation Valve, GS HIS-13 or GS HIS- 14.	Locate the switches on RL011. Open the valve by pressing the OPEN P/B. Verify the Red light comes on and the Green light goes out.	S U
-----	--------------	---	--	-----

Cue:

Comments:

3.	8. RNO c.	Open the remaining Hydrogen Analyzer Ctmt. Isolations for Train A.	Complete elements 3a through 3c.	N/A
----	--------------	---	----------------------------------	-----

Cue:

Comments:

3a.*	8. RNO c.	OPEN GS HIS-12.	Locate the switch on RL011. Open the valve by pushing the OPEN P/B. Verify the Red light comes on and the Green light goes out.	S U
------	--------------	-----------------	---	-----

Cue:

Comments:

* Denotes Critical Step

WCGS -SRO/RO TRAINING PROGRAM JOB PERFORMANCE MEASURE EVALUATION FORM

Element #	Step#	Element	Standard	Score
3b.*	8. RNO c.	OPEN GS HIS-17.	Locate the switch on RL011. Open the valve by pushing the OPEN P/B. Verify the Red light comes on and the Green light goes out.	S U

Cue:

Comments:

3c*	8. RNO c.	OPEN GS HIS-18.	Locate the switch on RL011. Open the valve by pushing the OPEN P/B. Verify the Red	S U
			light comes on and the Green light goes out.	

Cue:

Comments:

4.*	8. RNO d.	On RL020, place the CTMT Hydrogen Analyzer control switch, GS HIS-16A, to ANALYZE.	Locate the switch on RL020. Rotate the switch until the arrow points to ANALYZE. The Red light should come on.	S U
			The Rea light should come on.	

Cue:

Comments:

4.	8. RNO e.	Monitor CTMT Hydrogen concentration.	Locate GS AI-19 on RL020.	S U
----	--------------	--------------------------------------	---------------------------	-----

Cue: "Meter indicates 0% Hydrogen."

Comments:

5.	N/A	Return to step in effect.	Notify the CRS that Hydrogen Analyzer A is in service.	S U
----	-----	---------------------------	--	-----

Cue:

Comments:

Termination: Hydrogen analyzer A is aligned to sample CTMT hydrogen.

Stop Time:_____

* Denotes Critical Step

WCGS -SRO/RO TRAINING PROGRAM JOB PERFORMANCE MEASURE EVALUATION FORM

Initial Conditions:

You are the Reactor Operator, EMG FR-C1, Response to Inadequate Core Cooling, is in effect. The Crew has reached Step 8 and has received information that "B" Train H2 Analyzer has broken tubing.

NOTE: The simulator is NOT setup for EMG FR-C1 conditions. (Ignore RCS and CTMT parameters)

Initiating Cues:

The Control Room Supervisor directs you to perform Step 8 RNO of EMG FR-C1 for Train A H2 Analyzer only.

Notes:

JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

Upon arriving at a component, describe to your evaluator what you expect to see (e.g. how valve, breaker, etc. position is determined), what you expect to do (e.g. turn switch to run, rotate handwheel CCW to open, etc.) and what you expect to happen (e.g. pump will start and red light will light, handwheel will rotate until valve is open, etc.).

When you have completed the JPM inform your evaluator that you are done by handing this Initial Conditions/Initiating Cues sheet back to him.



EMG FR-C1

RESPONSE TO INADEQUATE CORE COOLING

Responsible Manager

Manager Operations

ሺ ሺ ሺ ሺ ሺ ሺ ሺ ሺ ሺ ፹ ፲	<i>₳₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽</i>	\$ <i>&&&</i> & <i>&</i> & <i></i>	₲₡₡₯₡₡₡₡
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	¤ Revision Number ታሁሁሁሁሁሁሁሁሁ ABBBBBBBBBBBBBBBBBBBBBBBBBBB	口 12 \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	<i>ᢘᡩᡊ᠅ᡩ᠅ᡩ᠅ᡩ</i> ᠅
$\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$	보 Use Category	Ц	Continuous
<i>ᢞᢞᢞᢞᢞᢞᢞᢞ᠅</i>	<u></u> % % % % % % % % % % % % % % % % % % %	\$ <i>&amp;&amp;&amp;</i> & <i>&amp;</i> &&&&&&&&&&&&&&&&&&&&&&&&&&&&&	<i>₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽</i>
M. M. M. M. M. M. M. A.	¤ Administrative Controls Procedur ሥሁይይይይይይይይይይይይይይይይይይይይይይይይይይይይይይይይይይይይ	<i>ЭААААААААА</i> 6 д No	ዽዽዽዏዸዸዸዸ
$\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi$	¤ Infrequently Performed Procedure ሥሁይይይይይይይይይይይይይይይይይይ	Z NO	ਸ਼ ਸ਼
₲₲₲₲₲₲	¤ Program Number	¤ 21A	ц
RRRRRRRR	<i>᠍₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽</i>	\$ <i>&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;</i>	₢₢₢₢₢
	DC12	05/01/2001	

Continuous Use

#### 1.0 <u>PURPOSE</u>

- 1.1 This procedure provides actions to restore core cooling.
- 1.2 Major Action Categories

o Establish safety injection flow to the RCS

o Rapidly depressurize S/Gs to depressurize the RCS

o Start RCPs and open all RCS vent paths to containment

# 2.0 <u>SYMPTOMS OR ENTRY CONDITIONS</u>

2.1 This procedure is entered from the following procedure on any red path condition:

 EMG F-0, CRITICAL SAFETY FUNCTION STATUS TREES (CSFST), FIGURE 2, CSF F-02 CORE COOLING

2.2 This procedure is entered from the following procedure if stopping RCPs and depressurizing S/Gs results in a red path condition for core cooling:

o EMG FR-C2, RESPONSE TO DEGRADED CORE COOLING, Step 18

RESPONSE TO INADEQUATE CORE COOLING

#### 3.0 <u>REFERENCES AND COMMITMENTS</u>

#### 3.1 <u>References</u>

- a. Technical Specifications for Wolf Creek Generating Station
- b. Updated Safety Analysis Report for Wolf Creek
- c. As-built plant drawings
- d. Generic Technical Guidelines developed by the Westinghouse Owners Group (WOG). This consists of the following documents:
  - 1) High pressure version of the WOG Optimal Recovery Guidelines, Status Trees, and Functional Restoration Guidelines
  - Background documents for each high pressure version Optimal Recovery Guideline, Status Tree, and Functional Restoration Guideline
  - 3) WOG Emergency Response Guideline Executive Volume
  - 4) WOG Emergency Response Guideline Maintenance Program Summary
- e. CCP 4590, PDP REPLACEMENT
- f. USAR Table 10.4-13B ( Sheet 2 ), AFW supply switchover criteria, ( Foldout page )

#### 3.2 <u>Commitments</u>

a. None

RESPONSE TO INADEQUATE CORE COOLING

Page 3 of 56

### FOLDOUT PAGE FOR EMG FR-C1

# 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

# 2. AFW SUPPLY SWITCHOVER CRITERIA

[	Revisi	on: 12						EMO	G FR-C1	
	Contir	nuous Use	RESPONS	E TO INADI	EQUATE	CORE C	OOLING	Page 4	1 of 56	5
]	STE	ACTION	/EXPECTED		$\neg -$	RESPO	NSE NOT			$\square$
যুষষ	AAA AAAA Q Q Q If Q Sha	CCW is not	FFFFFFFF FFFFFFF ot aligned Frun on 1	SKKKKKK SKKKKKK <u>CA</u> I to the R recirculat	ZAAA ZO <u>UTION</u> HR hea ion lo	at exch	AAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAA	RHR pu hours	mps	8338 8338 0 0
8888	ଷ୍ୟସ୍∉ ସ୍ୟସ୍ୟସ	8888888 8888888	AAAAAA AAAAAAA	1444444 1444444	a D D D D D D D D D D D D D D D D D D D	arara	rrrrr	i a a a a a a a a a a a a a a a a a a a	38888	ୢୖ୶ୠୄୄୢ୵
<i>������</i>	П П АФФФФ	\$ <i>\$\$\$\$\$\$\$\$\$</i> \$\$\$\$\$\$\$\$\$\$\$ \$\$\$\$\$\$\$\$\$\$\$\$\$\$	<i>`&amp;&amp;&amp;&amp;</i> @ \$ <i>&amp;&amp;&amp;&amp;</i>	<u></u> ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩	<u>оте</u>	<i>龄龄龄龄龄</i> 的	\$ <i>\$\$\$\$\$\$</i>	<i>₽₽₽₽₽</i> ₽	> <i>&amp;</i> &&&&	ц П П П
余谷谷谷谷	р Fol п ©&&& &&&&	dout page پ پ پ پ پ پ پ پ پ پ پ پ پ پ پ پ پ پ پ	e shall be &&&&& &&&&&	e monitore	d thro پېږېږې	oughout 失失失失失	this pr &&&&&	coceduı ५५५५५५	re. >\$\$\$\$\$\$	С С П П П
	1.	Verify S ALIGNED:	SI Valves	- PROPERL	Y	<u>IF</u> any <u>NOT</u> pro	SIS sec perly a	tion c ligned	ompone: , <u>THE</u> N	nt
		a. Check SIS s LIGHT ECCS	ESFAS st ection - S LIT FOR LINEUP	atus pane ALL WHITE CURRENT	1	compone SIS lin	ent to e eup.	stabli	sh proj	per
		* Inj	ection							
		<u>0</u>	<u>R</u>							
		* Col	d leg rec	irculatio	n					
		<u>0</u>	<u>R</u>							
		* Hot	leg reci	rculation						

RESPONSE TO INADEQUATE CORE COOLING

Page 5 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

# 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

#### 2. AFW SUPPLY SWITCHOVER CRITERIA

Revisi	on: 12		EMG FR-C1							
Contin	uous Use	RESPONSE IO INADEQU	Page 6 of 56							
STE	ACTION	I/EXPECTED	RESPONSE NOT							
2.	Verify I Trains: a. Check Pumps Tank INDIC o EM	ECCS Flow In All C Centrifugal Charging To Boron Injection Flow meters - FLOW CATED FI-917A FI-917B	Pe 1. 9 2.	<ul> <li>Perform the following:</li> <li>1. Start pumps and alig valves as necessary establish normal ECC injection.</li> <li>2. Ensure CCP Discharge Charging Header isol</li> </ul>						
	b. Check Flow INDIC o EM o EM	FI-917B SI Pump Discharge meters - FLOW CATED FI-918 FI-922	3.	* BG-8483A * BG-8483C <u>IF</u> normal E can <u>NOT</u> be <u>THEN</u> try to alternate h	for CCP A for CCP B CCS injection established, establish igh head	N				
	c. Check Injec - FLC o EJ o EJ	x RHR TO Accumulator ction Loop Flow meters DW INDICATED FI-618 FI-619	з 4.	injection u ATTACHMENT <u>IF</u> ECCS floc can <u>NOT</u> be <u>THEN</u> establ to hot legs Shift Manag Room Superv	sing A. w to cold legs established, ish ECCS flow as directed by er or Control isor.	Y				

RESPONSE TO INADEQUATE CORE COOLING

Page 7 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

#### 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

# 2. AFW SUPPLY SWITCHOVER CRITERIA

Revisi	on: 12			EMG FR-C1						
Contin	uous Use	NESCONSE IO INADEQU	ATE CORE COOLING	Page 8 of 56						
STE	ACTION	/EXPECTED	RESPONSE NOT	RESPONSE NOT						
3.	Check RO - AVAILA	CP Support Conditions	Try to establi conditions.	sh support						
	a. Ensu: AVAII	re power to RCP(s)- LABLE								
	* PA( * PA(	)1 for RCPs A and B )2 for RCPs C and D								
	b. Ensur 00-05 LO -	re annunciator 52A, CCW TO RCP FLOW CLEAR								
	C. Ensui CCW f CLEAF	re RCP thermal barrien Elow annunciator - R	r							
	* 00- * 00- * 00- * 00-	-070C for RCP A -071C for RCP B -072C for RCP C -073C for RCP D								
	d. Ensur GREAT	re number 1 seal 🖗P - TER THAN 200 PSID								
	* BB * BB * BB * BB	PI-153A for RCP A PI-152A for RCP B PI-151A for RCP C PI-150A for RCP D								
	e. Ensur leako THAN	re number 1 seal off flow - GREATER 0.2 GPM								
	* BG * BG * BG * BG	FR-157 for RCP A FR-156 for RCP B FR-155 for RCP C FR-154 for RCP D								
	f. Ensu: - BEI	re seal injection flow WEEN 8 GPM AND 13 GPM	N M							
	* BG * BG * BG * BG	FR-157 for RCP A FR-156 for RCP B FR-155 for RCP C FR-154 for RCP D								
	g. Ensu: GREAI	re VCT pressure - TER THAN 15 PSIG								
	o BG	PI-115								

RESPONSE TO INADEQUATE CORE COOLING

Page 9 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

#### 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

#### 2. AFW SUPPLY SWITCHOVER CRITERIA

Revisi	on: 12	DECDONCE		זאידים	CO	DE COOLINC	EMG FR-C1			
Contin	uous Use	RESPONSE	IO INADEQU	KE COOLING	Page 10 d	of 56				
STE	ACTION	I/EXPECTED		$\vdash$	R	ESPONSE NOT	C			
4.	Check S Isolatio	I Accumulat on Valve St	or atus:	. –						
	a. Local SI ac valve	lly close b ccumulator ( e(s)	reakers fo: outlet	r						
	o NG01BGF3 for EP HV-8808A o NG02BGF3 for EP HV-8808B o NG01BGF2 for EP HV-8808C o NG02BHF2 for EP HV-8808D									
	b. Check Outle OPEN	c Accumulato et Isolation	or Tank n Valves -	]	b.	<u>IF</u> accumula discharged, accumulator valve(s).	ulator <u>NO</u> T ed, <u>THE</u> N open SI tor outlet			
	0 EP 0 EP 0 EP 0 EP	P HV-8808A P HV-8808B P HV-8808C P HV-8808D								
5.	Check Co THAN 120	ore Exit TC 00°F	s - LESS	(	Go	to Step 8.				
6.	Check R Circulat	VLIS Natura tion Range	l Indication	:						
	a. Checł	CRCPS - NO	NE RUNNING	i	a.	Return to procedure and step in effect.				
	b. Check circu indic	c RVLIS nat ulation ran cation - AV	ural ge AILABLE	]	b.	o. Go to Step 7.				
	c. Check circu	RVLIS nati	ural ge -		c.	Perform the	e followin	g:		
	GREAT	FER THAN 45	5			1) <u>IF</u> RVLIS increasi OBSERVE NOTE PRI and retu	INDICATI ng, <u>THEN</u> CAUTION A OR TO STE rn to Ste	on ND P 1 p 1.		
						2) <u>IF</u> RVLIS increasi Step 7.	indicationg, <u>THEN</u>	on <u>NO</u> T go to		
	d. Retu step	rn to proce in effect	dure and							

RESPONSE TO INADEQUATE CORE COOLING

Page 11 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

# 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

# 2. AFW SUPPLY SWITCHOVER CRITERIA

 $\underline{IF}$  CST suction pressure decreases to less than 6.9 psig,  $\underline{THEN}$  switch to alternate AFW suction supply.

Revision: 12			EMG FR-C1							
Continu	ious Use	RESPONSE IO INADEQ	Page 12 of 56							
STE	ACTION	/EXPECTED	RESPONSE NOT							
7.	Check Co	ore Exit TCs:								
	a. Core LESS	exit temperature - THAN 712°F	<ul> <li>a. Perform th</li> <li>1) <u>IF</u> core tempera <u>THEN</u> OB CAUTION TO STEP Step 1.</li> <li>2) <u>IF</u> core tempera decreas Step 8.</li> </ul>	e following: exit ture decreasing, SERVE AND NOTE PRIOR 1 and return to exit ture <u>NOT</u> ing, <u>THEN</u> go to						
	b. Retur step	n to procedure and in effect								

RESPONSE TO INADEQUATE CORE COOLING

Page 13 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

# 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

# 2. AFW SUPPLY SWITCHOVER CRITERIA

 $\underline{IF}$  CST suction pressure decreases to less than 6.9 psig, THEN switch to alternate AFW suction supply.

Revision: 12		EMG FR-C1
Continuous Use	RESPONSE IO INADEQUAI	Page 14 of 56
STE ACTION	/EXPECTED	RESPONSE NOT
8. Check Hy SERVICE	ydrogen Analyzers - IN	Place hydrogen analyzers in service:
		a. On RL011, place power lockout switches for containment sample valves in NON-ISO position.
		o GS HIS-40 o GS HIS-41 o GS HIS-42 o GS HIS-43
		b. On RL011, open one Hydrogen Analyzer Supply Inner Containment Isolation Valve per train.
		o GS HIS-13 <u>OR</u> GS HIS-14 for red train o GS HIS-4 <u>OR</u> GS HIS-5 for yellow train
		c. On RL011, open remaining hydrogen analyzer containment isolation valves.
		o GS HIS-12 o GS HIS-17 o GS HIS-18 o GS HIS-3 o GS HIS-8 o GS HIS-9
		d. On RL020, place containment hydrogen analyzer control switches in ANALYZE position.
		o GS HIS-16A o GS HIS-11A
		e. On RL020, monitor containment hydrogen concentration.
		o GS AI-19 o GS AI-10

RESPONSE TO INADEQUATE CORE COOLING

Page 15 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

# 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

# 2. AFW SUPPLY SWITCHOVER CRITERIA

 $\underline{IF}$  CST suction pressure decreases to less than 6.9 psig,  $\underline{THEN}$  switch to alternate AFW suction supply.

[	Revision	n: 12							EMG FR-C1				
	Continuo	ous Use	RESPONSE IO INADEQUATE CORE COOLING					Page	16 of	56			
I	STE -	ACTION	/EXPECTED		] - [	]	RESPONSE NOT	1					
<i>�����&amp;</i>	<i>ŶŶŶŶŶŶ</i> ¢ <i>ŶŶŶŶŶŶ</i> ¢	` <i>ĊĊĊĊĊ</i>	ዽዽዽዸ ዾዸዸዸዸዸ	\$\$\$\$\$\$\$\$	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	\$\$	<i>ŔŔŔŔŔŔŔŔ</i>	\$ <i>&amp;</i> \$\$\$	<i>ᡩᡭ᠙</i> ᡬ	` <i>&amp;&amp;</i> &&			
	П П			<u>NO</u>	TE					п			
	IIThisIIhydro	procedu ogen sam	re shall be ple.	e continu	ed wl	hil	e obtaining	conta	ainmer	it I I I			
をおおお	<i>&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;&amp;</i>	ŶŔŔŔŔŔ ŶŔŔŔŔŔŔ	<i>ŔŔŔŔ</i> Ŕ ŶŔŔŔŔŔŔŔ	<i>ŶŔŔŔŔŔ</i>	€₽₽₽	\$\$	<i>₳₳₳₳₳₳₳</i> ₽	ঽ৵৵৵৵	<i>\$\$\$\$</i> \$	<i>৽৾ড়ড়ড়৾ড়</i>			
	9. C	Check Co Concentr	ntainment H ation:	lydrogen									
	a	A. Hydro OPERA	gen analyze TION	rs - IN		a.	OBSERVE CAU TO STEP 10 Step 10.	TION and g	PRIOR o to				
	k	). Hydro LESS	gen concent THAN 3%	ration -		b.	Perform the	foll	owing	:			
		o GS . o GS .	AI-10 AI-19				1) Notify p engineer: hydrogen inside co	lant ing st conce ontain	taff c entrat nment.	of Lion			
							2) Periodica hydrogen measureme	ally o conce ent.	obtair entrat	n a cion			
							3) OBSERVE ( TO STEP 3 Step 10.	CAUTIO 10 ano	ON PRI d go t	IOR LO			
	с	c. Hydro LESS	gen concent THAN 0.8%	ration -		c.	Turn on hyd recombiners SYS GS-120.	rogen usin POST	g LOCA				
		o GS . o GS .	AI-10 AI-19				CONTAINMENT RECOMBINER	HYDR	OGEN TION.				

RESPONSE TO INADEQUATE CORE COOLING

Page 17 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

# 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

# 2. AFW SUPPLY SWITCHOVER CRITERIA

 $\underline{IF}$  CST suction pressure decreases to less than 6.9 psig,  $\underline{THEN}$  switch to alternate AFW suction supply.

[	Revisi	on:	12					۷۳۳	CODE	COC	NT TNC	EM	IG F	R-C	1
	Contin	uou	s Use	RESP	JN2E 1	IO IN.	ADEQU	AIL	CORE		)TING	Page	18	of	56
1	STE		CTION	/EXPEC	ΓED			-	RES	PON	SE NOT	1			]
য়েম্বম্ব	রম্বম্ব ম্বম্বম্ব য়ম্বম্বম্ব গ 11 গ্র	SKR SKR an	SKKK SKKK intact	RRRR RRRR 5/G i	BBBB BBBB s ava	KKK KKK ilabl	RRR RR <u>Cauti</u> Le, DC	о ио ОИ ОМ	XXX T USE	rr : A	ZØØR Faulti	(BBB ED OR	RUI	SØØ PTUR	ада () () ED ()
মুম্বম্ব	∍\ଃ ଥ ରୁଷ୍ପଷ୍∉ ସ୍କଷ୍ୟଷ୍ଥ	in SBR SBR	subse AAAA AAAA	equent KKKK KKKK	steps KKK KKK	888 888	। यूयूय () यूय	7 7 7	3881	rri	zere	a a a a	'rr	s k k	୍ର ଅ ଅ ସ ସ
	10.	Che	eck In	itact S	/G Le	vels:									
		a.	Check	narro	w rang	ge le	vel	a	. Per	rfoi	rm the	foll	owi	ng:	
			IN At GREAT	ER THA	one : N 6%	S/G - [29%]			1)	Mai flc 270 nar gre in	ntain w gre ,000 row r ater at le	tota ater lbm/h: ange than ast o	l fo thai r ui levo 6% ne :	eed n ntil el [29% S/G.	
									2)	<u>IF</u> gre 270 be per	total ater ,000 estab form	feed than lbm/h lishe the fo	fl r ca d, <u>-</u> oll(	ow an <u>N</u> <u>THE</u> N owir	10T 1 1g:
										a)	Contin estabi sink S/G.	nue at lish a in at	ter a he lea	mpts eat ast	to one
										b)	OBSER TO STI Step 2	VE NO EP 22 22.	re I and	PRIC d go	R to
		b.	Contr maint level 6% [2	ol fee ain na in al 9%] an	d flov rrow : l S/G; d 50%	w to range s bet	ween								

RESPONSE TO INADEQUATE CORE COOLING

Page 19 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

# 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

# 2. AFW SUPPLY SWITCHOVER CRITERIA

Revision: 12						EMG FR-C1		
Continu	uous Use	KESPONSE	TO TNADEQ	UALE CO	JKE COULING	Page 20 of 56		
STE	ACTION	/EXPECTED			RESPONSE NOT			
11.	Check R(	CS Vent Pat	hs:					
	a. Power valve	r to PZR PO ès - AVAILA	RV block BLE	a.	Restore pow valves:	er to block		
	o BB o BB	HIS-8000A HIS-8000B	for BB HV-8000A for BB HV-8000B					
	b. PZR E o BB o BB	PORVs – CLO HIS-455A HIS-456A	SED	b.	<u>IF</u> PZR pres 2335 psig, <u></u> close PORV. can <u>NOT</u> be manually cl valve.	sure less than <u>THEN</u> manually _IF any PORV closed, <u>_THE</u> N ose its block		
	c. RCS <u>p</u> 2185	PSIG -	LESS THAN	c.	<u>IF</u> PZR PORV <u>THEN</u> ensure block valve * BB HIS-80 BB HIS-45 * BB HIS-80 BB HIS-45	is closed, associated is open. 00A for 5A 00B for 6A		
	d. React - AT CLOSE 0 BB BB tra 0 BB BB tra	LEAST ONE LEAST ONE D IN EACH HIS-8001A HIS-8002A HIS-8001B HIS-8002B hin	head vents VALVE TRAIN OR for red OR for yellow	d.	Manually cl	ose valves.		

RESPONSE TO INADEQUATE CORE COOLING

Page 21 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

# 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

# 2. AFW SUPPLY SWITCHOVER CRITERIA

 $\underline{IF}$  CST suction pressure decreases to less than 6.9 psig,  $\underline{THEN}$  switch to alternate AFW suction supply.
Revision: 12		DECDONCE TO INADEOU	TNO	EMG FR-C1		
Contin	uous Use	RESPONSE IO INADEQUA	ALE CORE COO.	LING	Page 22 of 56	
STE	ACTION	/EXPECTED	RESPONS	E NOI		
12.	Check If Removal Normal:	E Condenser Air Should Be Returned To				
	a. Check o Mai val OPE	the following: n steamline isolation ves - AT LEAST ONE N	a. OBSERV STEP 1	E NOT 3 and	E PRIOR TO go to Step 13.	
	o Con LEA o Cir - A o Con EST	ndensate pumps - AT AST ONE RUNNING cculating water pumps AT LEAST ONE RUNNING ndenser vacuum - CABLISHED				
	b. Open Fan I o GE o GE	Condenser Air Removal Discharge Dampers HIS-103 HIS-104	b. OBSERV STEP 1	E NOT 3 and	E PRIOR TO go to Step 13.	
	c. Start Conde * CG * CG * CG	desired number of enser Vacuum Pumps HIS-1 HIS-2 HIS-3	c. OBSERV STEP 1	E NOT 3 and	E PRIOR TO go to Step 13.	
	d. Open Filtr Dampe o GE o GE	Condenser Air Removal ration System Supply ers HIS-101 HIS-102	d. OBSERV STEP 1	E NOT 3 and	E PRIOR TO go to Step 13.	
	e. Start Remov * GE * GE	c one Condenser Air val Fan HIS-82 HIS-83	e. OBSERV STEP 1	E NOT 3 and	E PRIOR TO go to Step 13.	

RESPONSE TO INADEQUATE CORE COOLING

Page 23 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

## 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

## 2. AFW SUPPLY SWITCHOVER CRITERIA

	Revision: 12						EM	G FR-C	21
	Contin	uous Use	RESPONSE TO	INADEQUATE		ORE COOLING	Page	24 of	56
	STE -	ACTION	/EXPECTED		]	RESPONSE NOT			
		1. ע. ע. ע. ע. ע. ע. ע	ג עג	ע, ע, ע, ע, ע, ע, ע, ע	1. U.	שג שג שג שג שג שג שג ש	<u>, , , , , , , ,</u>	۲. ۲. ۲. ۲. ۱	<u>מי מי מי מ</u>
゚ゟゟゟゟ	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	\$\$\$\$\$\$ \$\$\$\$\$\$\$	NORT	$\diamond \diamond$	$\langle \langle \langle \langle \rangle \rangle \rangle \rangle \langle \langle \langle \rangle \rangle \rangle \rangle \langle \langle \rangle \rangle \rangle \langle \langle \langle \rangle \rangle \rangle \langle \langle \rangle \rangle \rangle \langle \langle \langle \rangle \rangle \rangle \langle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \langle \rangle \rangle \rangle \langle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \langle \rangle \rangle \rangle \langle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \rangle \rangle \langle \rangle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \rangle \rangle \langle \rangle \langle \rangle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \rangle \langle \rangle \rangle \langle \langle \rangle \rangle \langle \rangle \rangle \langle \rangle \rangle \langle \rangle \langle \rangle \langle \rangle \rangle \langle \rangle \rangle \langle \rangle \rangle \langle \rangle \rangle \langle \rangle \langle \rangle \rangle \langle \rangle \langle \rangle \langle \rangle \langle \rangle \rangle \langle \rangle \langle \rangle \langle \rangle \langle \rangle \rangle \langle \rangle \langle \rangle \langle \rangle \langle \rangle \langle \rangle \rangle \langle \rangle \rangle \langle $	$\diamond \diamond \diamond \diamond \diamond$	$\diamond \diamond \diamond \diamond \diamond$	$\langle \gamma \rangle \langle \gamma \rangle$
	Ц			NOTE					ц
	H If high steam pressure rate setpoint (100 psi/50 sec) is $HH$ exceeded after low steamline pressure SI signal is blocked, main								
	д Д ste	amline is	olation will	occur.					П
ダダダダ	<i>₳₳₳₳</i> ₽ @ <i>₳₳₳</i> ₽	ŶŔŔŔŔŔŔ ŶŔŔŔŔŔŔŔ	<i>ŔŔŔŔ</i> Ŕ ŶŔŔŔŔŔŔŔŔŔ	<i>论论论论论论论</i>	\$\$	<i>₠₼₼₼₼₼₼₼</i> ₼₼	\$ <i>\$\$\$</i> \$	ዽ፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞ ፟፟፟፟፟፟፟፟፟፟፟፟፟	<i>ŔŔŔ</i> Ŕ
	13.	Check If Pressure Blocked:	Low Steamline SI Should Be	e					
		a. Check THAN	RCS pressure 1970 PSIG	- LESS	a.	WHEN RCS pro	essur	e is l <u>THE</u> N b	ess lock
		o P-1	1 light - LIT			OBSERVE NOT STEP 14 and Step 14.	E PRI cont	OR TO inue w	ith
		b. Block press	low steamline ure SI	2					
		o SB o SB	HS-9 HS-10						

RESPONSE TO INADEQUATE CORE COOLING

Page 25 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

## 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

## 2. AFW SUPPLY SWITCHOVER CRITERIA

[	Revision	n: 12	DEGDONG					EN	/IG FI	R-C1	٦
	Continuc	ous Use	RESPONS	E IO INAD.	LQUAIE		ORE COOLING	Page	26 0	of 56	
1	STE	ACTION	/EXPECTED	)		I	RESPONSE NOT				
於於於於於	YUUUUUU UUUUUUUUUUUUUUUUUUUUUUUUUUUUUU	بون بون بون بون بون بون Lal unco	by the form of a state of a stat	。 S/G tubes	OTE is ace	ceb	ਝਝਝਝਝਝ table in the	。 fol:	بر اowi:	ng ≻&&&¢	
<i>&amp;&amp;&amp;</i> &&&&	<i>\$\$\$\$\$\$\$\$</i> \$ @\$\$\$\$\$\$\$ T	<i>ŔŔŔŔŔ</i> ŶŔŔŔŔŔ	` <i>&amp;&amp;&amp;&amp;</i> & ? <i>&amp;&amp;</i> &&&&&	\$ <i>&amp;&amp;&amp;</i> & <i>&amp;</i> & <i>&amp;</i> & <i>&amp;</i>	<i>ᡩᡩᡩᡩ</i> ᠙	ᡷ᠋᠊᠋ᡬ	₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽	\$ <i>&amp;</i> \$\$\$	ኇኇዸ	৽৵ড়ড়ড়৽	<i>ф</i> п
	14. D T	epressu o 160 F	rize All SIG:	Intact S/	Gs						
	a	. Dump maxim	steam to um rate	condenser	at	a.	Dump steam a using S/G AM	at ma RVs.	ximu	ım rat	e.
	b	). Check THAN	S/G pres 160 PSIG	ssures – L	ESS	b.	<pre>Perform the 1) <u>IF</u> S/G pr decreasir OBSERVE ( TO STEP 1 to Step 1 2) <u>IF</u> S/G pr or increa OBSERVE N STEP 22 a Step 22.</pre>	foll ressund CAUTI 10 and 10. ressund sing NOTE and g	owin re <u>HE</u> N ON P d re s , <u>TH</u> PRIO o to	Ig: RIOR turn table <u>EN</u> R TO	:
	c	. Check tempe TWO L	RCS hot ratures - ESS THAN	leg - AT LEAST 375°F		с.	<pre>Perform the 1) <u>IF</u> RCS ho    temperatu    decreasin    OBSERVE 0    TO STEP 1    to Step 1 2) <u>IF</u> RCS ho    temperatu    increasin    OBSERVE N    STEP 22 a    Step 22.</pre>	foll ot le ures ng, <u>T</u> CAUTI 10 an 10. ot le ures ng, <u>T</u> NOTE and g	owin g ON P d re g stab <u>HE</u> N PRIO o to	RIOR turn le or R TO	
	d	. Stop	S/G depre	essurizati	on						

RESPONSE TO INADEQUATE CORE COOLING

Page 27 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

## 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

# 2. AFW SUPPLY SWITCHOVER CRITERIA

	Revisi	on: 12				EMG FR-C1
	Contin	uous Use	RESPONSE TO	INADEQUATE	CORE COOLING	Page 28 of 56
[	STE	ACTION	/EXPECTED		RESPONSE NOT	
।ম্বম্বম্ব ।	∜βββ ββββββ © © © If © req © con	SBBBBBB SBBBBBB offsite p uired to figuratic	RRRRRRRR RRRRRRRR RRRRRRR R R R R R R	SKKKKKK SKKK <u>CAUTION</u> after SI re uards equip	SSSSSSSSSSSS eset, manual ac pment to the re	CTION MAY DE C CUITED C CUITED C C CUITED C C C C
8888	ୁୁ ସୁସୁସୁହୁ ସୁସୁସୁସୁ	444444 444444	13777777777777777777777777777777777777	ଷ୍ୟଷ୍ୟଷ୍ୟ ଅଷ୍ୟଷ୍	, , , , , , , , , , , , , , , , , , ,	<b>କ୍</b> ଷ୍ୟୁଷ୍ୟୁଷ୍ୟୁଷ୍ୟ ଭ
	15.	Reset SI	:			
		o SB HS- o SB HS-	42A 43A			
	16.	Check If Should E	SI Accumulate Se Isolated:	ors		
		a. Check leg t THAN	at least two emperatures - 375°F	RCS hot LESS	a. OBSERVE NOT STEP 22 and	E PRIOR TO go to Step 22.
		b. Close Outle	Accumulator 5 t Isolation Va	Tank alves	b. <u>IF</u> any accu be isolated the followi	mulator can <u>NO</u> T , <u>THE</u> N perform ng:
		0 EP 0 EP 0 EP 0 EP	HIS-8808A HIS-8808B HIS-8808C HIS-8808D		1) Open asso accumula valve(s)	ociated tor vent
					* EP HIS accumu * EP HIS EP HIS accumu * EP HIS accumu * EP HIS accumu	-8950A for lator A -8950B or -8950C for lator B -8950D or -8950E for lator C -8950F for lator D
					2) DO NOT DI BELOW UN ACCUMULA during su recovery	EPRESSURIZE RCS ISOLATED FOR PRESSURE ubsequent actions.
		c. Local SI ac valve	ly open break cumulator out s	ers for let		
		o NGO o NGO o NGO	1BGF3 for EP H 2BGF3 for EP H 1BGF2 for EP H	IV-8808A IV-8808B IV-8808C		

o NG02BHF2 for EP HV-8808D

RESPONSE TO INADEQUATE CORE COOLING

Page 29 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

## 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

## 2. AFW SUPPLY SWITCHOVER CRITERIA

Revisi	rision: 12			EMG FR-C1		
Contin	uous Use	RESPONSE IO INADEQU	AIE C	ORE COOLING	Page 30 of 56	
STE	ACTION	/EXPECTED		RESPONSE NOT		
17.	Stop All O BB HIS O BB HIS O BB HIS O BB HIS	<b>RCPs</b> -37 for RCP A -38 for RCP B -39 for RCP C -40 for RCP D				
18.	Depressu To Atmos	rize All Intact S/Gs spheric Pressure:				
	a. Dump maxim	steam to condenser at num rate	za.	Dump steam using S/G A	at maximum rate RVs.	
19.	Verify E	CCS Flow:	Pe	erform the fo	llowing:	
	* Check Pumps Tank F INDICA	Centrifugal Charging To Boron Injection 'low meters - FLOW TED	a.	Start pumps valves as n establish n injection.	and align ecessary to ormal ECCS	
	o EM F o EM F <u>OR</u> * Check Flow m INDICA	I-917A I-917B SI Pump Discharge Meters - FLOW TED	b. c.	Ensure CCP Charging He valves - AT * BG-8483A * BG-8483C <u>IF</u> normal E can <u>NOT</u> be	Discharge To ader isolation LEAST ONE OPEN for CCP A for CCP B CCS injection established,	
	o em f o em f <u>Or</u>	I-918 I-922		<u>IHEN</u> try to alternate h injection u ATTACHMENT	igh head sing A.	
	* Check Inject - FLOW o EJ F o EJ F	RHR TO Accumulator ion Loop Flow meters INDICATED I-618 I-619	d.	<u>IF</u> ECCS flo can <u>NOT</u> be <u>THEN</u> establ to hot legs Shift Manag Room Superv	w to cold legs established, ish ECCS flow as directed by er or Control isor.	
			e.	<u>IF</u> core exi 1200°F, <u>THE</u> Step 18.	t TCs less than $\underline{N}$ return to	
			f.	<u>IF</u> core exi than or equ <u>THEN</u> OBSERV STEP 22 and	t TCs greater al to 1200°F, E NOTE PRIOR TO go to Step 22.	

RESPONSE TO INADEQUATE CORE COOLING

Page 31 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

## 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

## 2. AFW SUPPLY SWITCHOVER CRITERIA

Revisi	on:	12						
Contir	uou	s Use	RESPONSE TO INADEQU	JAT	E CORE COOLING	 Page 32 of 56		
					RESPONSE NOT			
20.	Ch	eck Co	ore Cooling:					
	a.	Check THAN	core exit TCs - LES 1200°F	S	a. OBSERVE NOTH STEP 22 and	E PRIOR TO go to Step 22.		
	b.	Check tempe TWO L	RCS hot leg ratures - AT LEAST ESS THAN 350°F	b. Return to St	cep 18.			
	c.	Check circu indic	RVLIS natural lation range ation - AVAILABLE		c. Go to Step 21.			
	d.	Check circu indic 69%	RVLIS natural lation range ation - GREATER THAN		d. Return to St	cep 18.		
21.	Go RE Sto	To EM ACTOR ep 15.	IG E-1, LOSS OF OR SECONDARY COOLANT	,				

RESPONSE TO INADEQUATE CORE COOLING

Page 33 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

## 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

## 2. AFW SUPPLY SWITCHOVER CRITERIA

<u>IF</u> CST suction pressure decreases to less than 6.9 psig, <u>THEN</u> switch to alternate AFW suction supply.

	Revisi	on: 12	DEGDONGE MO INA	RESPONSE TO INADEQUATE CORE COOL:			1
	Contin	uous Use	RESPONSE IO INA	DEQUATE	CORE COOLING	Page 34 of	56
1	STE	ACTION	/EXPECTED		RESPONSE NOT		]
\$\$\$\$\$\$	▼	r ar	çççççççççççççççç ¢çççç tions are desire cuucuuuuu	\$\$\$\$\$\$ <u>NOTE</u> d but n	مدمدمدمدمدم ot required for پېچچچچچچچچچچ	LUUUUUUUUUUU	~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~
₲₲₲₲₲	<i>\$\$\$\$\$</i>	<i>~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~</i>	<i><i><b><i><i><i>KKKKKXXXXXXXXXXXXX</i></i></i></b></i></i>	$\forall \forall \forall \forall \forall \forall$	$\diamond$	$\langle \langle \langle \rangle \rangle \langle \rangle \rangle$	~~~
	22.	Check If Started	RCPs Should Be				
		a. Core THAN	exit TCs - GREATE 1200°F	lR.	a. Go to Step	23.	
		b. Check cooli	if an idle RCS ng loop is availa	able:	<pre>b. Perform the     1) Open all</pre>	following:	AND
		o Nar GRE o RCP AVA OPE	row range SG leve ATER THAN 6% [29% in associated lo ILABLE AND <u>NO</u> T RATING	1 - ] ) oop -	Block val 2) <u>IF</u> core e greater t <u>THEN</u> oper vessel he valves. 0 BB HIS- 0 BB HIS- 0 BB HIS- 0 BB HIS- 0 BB HIS- 0 BB HIS- 0 BB HIS-	lves. exit TCs ren than 1200°F, n reactor ead vent -8001A -8001B -8002A -8002B ep 23.	nain
		c. Start	RCP oil lift pun	ips.			
		d. Start cooli	RCP in one idle ng loop.	RCS			
		e. Retur	n to Step 22a.				
	23.	Try To I Intact S Pressure	epressurize All /Gs To Atmospher: :	LC	Use faulted or	ruptured S	/Gs.
		* Use cc OR	ndenser steam dun	າວຊ			
		* Use S/	G ARV				
		* Operat	e turbine driven t maximum load	AFW			

RESPONSE TO INADEQUATE CORE COOLING

Page 35 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

## 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

## 2. AFW SUPPLY SWITCHOVER CRITERIA

	Revision: 12		DECDONCE TO	RESPONSE TO INADEQUATE CORE CO		ODE COOLING	EMG	FR-C1	
	Contin	uous Use	KESPONSE IC	INADEQUA		ORE COOLING	Page 36	5 of 5	б
1	STE	ACTION	/EXPECTED		-	RESPONSE NOT	I		
। যুম্ব	AAAA AAAAA B B U U U U If C req C On	offsite puired to	FREEREE FREEREE ower is lost restore safe n.	アクスアクス (10) (10) (10) (10) (10) (10) (10) (10)	BB N rese	SSSSSSSSS et, manual ac ent to the re	CTION Ma equired	ay be	<b>NN</b> NN 0 0 0 0 0
RRRR	এ প্রস্ন্থ প্রস্নস্বস্থ	 333333 333333	aaaaaaaaa aaaaaaaaa	ଷ୍ୟଷ୍ୟଷ୍ୟ ଅଷ୍ୟଷ୍ୟ	881	788888888	adada	rrr	্র মন্দ্র
	24.	Reset SI							
		o SB HS- o SB HS-	42A 43A						
	25.	Check Co	re Exit TCs	- LESS	Pe	rform the fo	llowing	:	
		TIAN 120	0 F		a.	<u>IF</u> core exi are stable <u>THEN</u> OBSERV STEP 22 and Step 22.	t tempe or decr E NOTE return	rature easing PRIOR to	s , TO
					b.	<u>IF</u> core exi are increas SACRG-1, SE CONTROL ROO INITIAL RES	t tempe ing, <u>TH</u> VERE AC M GUIDE PONSE S	rature <u>E</u> N go CIDENT LINE tep 1.	to

RESPONSE TO INADEQUATE CORE COOLING

Page 37 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

## 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

# 2. AFW SUPPLY SWITCHOVER CRITERIA

Revisi	on: 12			EMG FR-C1
Contin	uous Use	RESPONSE IO INADEQUA	ALE CORE COOLING	Page 38 of 56
STE	ACTION	I/EXPECTED	RESPONSE NOT	
26.	Check I: Should	f SI Accumulators Be Isolated:		
	a. Check Injec - AT FLOW	C RHR TO ACCUMULATOR ction Loop Flow meters LEAST INTERMITTENT INDICATED	a. OBSERVE NOT STEP 22 and Step 22.	return to
	O EJ O EJ	FI-618 FI-619		
	b. Close Outle	e Accumulator Tank et Isolation Valves	b. <u>IF</u> any accu be isolated the followi	mulator can <u>NO</u> T , <u>THEN</u> perform ng:
	O EP O EP O EP O EP	HIS-8808A HIS-8808B HIS-8808C HIS-8808D	1) Open ass accumula valve(s)	ociated tor vent
			* EP HV- accumu * EP HIS EP HIS accumu * EP HIS EP HIS accumu * EP HIS accumu	8950A for lator A -8950B or -8950C for lator B -8950D or -8950E for lator C -8950F for lator D
			2) DO NOT D BELOW UN ACCUMULA during s recovery	EPRESSURIZE RCS ISOLATED FOR PRESSURE ubsequent actions.
	c. Local SI ac valve	lly open breakers for ccumulator outlet es		
	0 NG( 0 NG( 0 NG( 0 NG(	D1BGF3 for EP HV-8808A D2BGF3 for EP HV-8808B D1BGF2 for EP HV-8808C D2BHF2 for EP HV-8808D		
27.	Check I: Stopped	f RCPs Should Be :		
	a. Checl leg t THAN	k at least two RCS hot temperatures - LESS 350°F	a. Go to Step	28.
	b. Stop	all RCPs		

RESPONSE TO INADEQUATE CORE COOLING

Page 39 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

## 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

## 2. AFW SUPPLY SWITCHOVER CRITERIA

Revisi	on: 12	DECDONCE TO INADEOL	זאיידי ו	CODE COOLING	EMG FR-C1
Contin	uous Use	RESPONSE IO INADEQU	JAIL (	LORE COOLING	Page 40 of 56
STE	ACTION	/EXPECTED		RESPONSE NOT	
28.	Verify E * Check Pumps Tank F INDICA	CCS Flow: Centrifugal Charging To Boron Injection low meters - FLOW TED	P	erform the fo . Start pumps valves as n establish n injection.	llowing: and align ecessary to ormal ECCS
	O EM F O EM F OR * Check Flow m INDICA O EM F O EM F	I-917A I-917B SI Pump Discharge eters - FLOW TED I-918 I-922	b c	<ul> <li>Ensure CCP Charging He valves - AT</li> <li>* BG-8483A</li> <li>* BG-8483C</li> <li>. <u>IF</u> normal E can <u>NOT</u> be <u>THEN</u> try to alternate h</li> </ul>	Discharge To ader isolation LEAST ONE OPEN for CCP A for CCP B CCS injection established, establish igh head
	<u>OR</u> * Check Inject - FLOW o EJ F o EJ F	RHR To Accumulator ion Loop Flow meters INDICATED I-618 I-619	d e	INJECTION U ATTACHMENT . <u>IF</u> ECCS flor can <u>NOT</u> be <u>THEN</u> establ to hot legs Shift Manag Room Superv . OBSERVE NOT STEP 22 and Step 22.	sing A. w to cold legs established, ish ECCS flow as directed by er or Control isor. E PRIOR TO return to
29.	Check Co a. Check b. Check	re Cooling: RCPs - NONE RUNNING RCS hot leg	a b	. OBSERVE NOT STEP 22 and Step 22. . OBSERVE NOT	E PRIOR TO return to E PRIOR TO
	tempe TWO L c. Check circu indic d. RVLIS range	ratures - AT LEAST ESS THAN 350°F RVLIS natural lation range ation - AVAILABLE natural circulation indication - GREATEN	c d R	STEP 22 and Step 22. . Go to Step . OBSERVE NOT STEP 22 and	return to 30. E PRIOR TO return to
30.	THAN Go To EM REACTOR Step 15.	69% G E-1, LOSS OF OR SECONDARY COOLANT	,	Step 22.	

-END-

RESPONSE TO INADEQUATE CORE COOLING

Page 41 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

## 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

## 2. AFW SUPPLY SWITCHOVER CRITERIA

<u>IF</u> CST suction pressure decreases to less than 6.9 psig, <u>THEN</u> switch to alternate AFW suction supply.

Revis	ion: 12	$\cap$ II $\lambda$ $TT$	CORE COOLING	EMG FR-C1
Contir	nuous Use	QUAIL	CORE COOLING	Page 42 of 56
STE	ACTION/EXPECTED		RESPONSE NOT	·
	ATTACH (Page 2 ESTABLISHING ALTERNA	HMENT 1 of .TE HI	A 8) GH HEAD INJECT	ION
A1.	Verify Charging Pump Suction	on:	Perform the fo	llowing:
	* Charging Pump Suction Fro RWST valves - AT LEAST ON OPEN	om IE	a. Manually or valves as n establish c suction.	locally align ecessary to harging pump
	* BN HIS-112D * BN HIS-112E OR		b. <u>IF</u> charging can <u>NOT</u> be THEN return	pump suction established, to procedure
	* VCT Outlet Valves - BOTH OPEN		and step in	effect.
	o BG HIS-112B o BG HIS-112C			
A2.	Check CCPs - ANY RUNNING		Perform the fo	llowing:
			a. Manually st	art CCPs.
			o BG HIS-1A o BG HIS-2A	for CCP A for CCP B
			b. <u>IF</u> neither started, <u>TH</u> recirc:	CCP can be <u>EN</u> start NCP on
			1) Start NC	₽.
			o BG HIS	- 3
			c. <u>IF</u> no charg started, <u>TH</u> procedure a effect.	ing pump can be <u>EN</u> return to nd step in
। মুম্বমুদ্ধ আ	aaaaaaaaaaaaaaaaaaaaaa aaaaaaaaaaaaaaa	SARA SC <u>JTION</u>	, a a a a a a a a a a a a a a a a a a a	ଷ୍ୟଷ୍ୟଷ୍ୟଷ୍ୟ ୭
(S) If (S) req (S) cor (S)	offsite power is lost after quired to restore safeguards nfiguration.	SI r equi	eset, manual ac pment to the re	ction may be equired
ାସସହ ସେସସ	&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&	50 10 10	anananana A	&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&
A3.	Reset SI			
	o SB HS-42A			

o SB HS-43A

RESPONSE TO INADEQUATE CORE COOLING

Page 43 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

## 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

## 2. AFW SUPPLY SWITCHOVER CRITERIA

Revisio	DN: 12 RESPONSE TO INADEQUATE CORE COOLING	EMG FR-C1						
Continu	lous Use	Page 44 of 56						
STE	ACTION/EXPECTED RESPONSE NOT							
ATTACHMENT A (Page 2 of 8) ESTABLISHING ALTERNATE HIGH HEAD INJECTION								
A4.	Reset Containment Isolation Phase A And Phase B							
	o SB HS-56 for phase A o SB HS-53 for phase A o SB HS-55 for phase B o SB HS-52 for phase B							

RESPONSE TO INADEQUATE CORE COOLING

Page 45 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

## 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

## 2. AFW SUPPLY SWITCHOVER CRITERIA

Revisi	on: 12		ECDONCE TO INADEOUATE CODE COOLING		
Continuous Use				OKE COOLING	Page 46 of 56
STE	ACTION	/EXPECTED		RESPONSE NOT	
A5.	Establis Contain	ATTACHMEN (Page 3 of STABLISHING ALTERNATE 1 Sh Instrument Air To ment:	T A 8) HIGH	HEAD INJECT	ION
	a. Ensur Compr o EF o EF b. Reset Compr	re ESW To Air ressor Valves - OPEN HIS-43 HIS-44 c and close Air ressor Breaker Reset	a.	Locally open WHEN valves do Steps A5 and A5.e. Step A6.	n valve(s). are open, <u>THE</u> N .b, A5.c, A5.d Continue with
	o KA o KA c. Check	HIS-2C HIS-3C Instrument Air	c.	Dispatch op	erator to
	105 I	PI-40		<ol> <li>Reset ala</li> <li>Restart of</li> </ol>	compressors.
	d. Check contr OUTPU o BB	A PZR pressure master coller - LESS THAN 50% JT SIGNAL PK-455A	d.	<pre>Perform the 1) Place PZI master co manual. 2) Set PZR p controlle 50% outpu 3) WHEN inst been esta containme PZR press controlle automatic</pre>	following: R pressure ontroller in pressure master er to less than ut signal. trument air has ablished to ent, <u>THEN</u> place sure master er in C.
	e. Open Conta Valve o KA	Instrument Air Supply ainment Isolation HIS-29	e.	Locally ope	n valve.

RESPONSE TO INADEQUATE CORE COOLING

Page 47 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

## 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

# 2. AFW SUPPLY SWITCHOVER CRITERIA

Revision: 12 Continuous Use					EMG FR-C1	
		RESPONSE TO INADEQU	JATE COR	E COOLING	Page 48 of 56	
STE	ACTION	I/EXPECTED	RE	SPONSE NOT		
	E	ATTACHMI (Page 4 d ESTABLISHING ALTERNATE	ENT A of 8) 5 HIGH H	EAD INJECT	ION	
A6.	Establish Normal Charging Header Flow Path:			<u>IF</u> flow path through normal charging header can <u>NOT</u> be		
	a. Open Press	Charging Header Back sure Control valve	Step	A11.	<u>HEN</u> 90 CO	
	o BG	HC-182				
	b. Open Reger Excha Isola	Charging Pumps To nerative Heat anger Containment ation valves				
	o BG o BG	HIS-8105 HIS-8106				
	c. Aligr Excha valve one o	n Regenerative Heat anger To Loop Cold Leg es to establish only open	3			
	* BG * BG	HIS-8146 for loop 1 HIS-8147 for loop 4				
A7.	Check Co	CPs - ANY RUNNING	Perf	orm the fo	llowing:	
			a. 0 C	pen NCP Di ontrol Val	scharge Flow ve.	
			0	BG FK-462		
			b. G	o to Step	А9.	

RESPONSE TO INADEQUATE CORE COOLING

Page 49 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

## 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

## 2. AFW SUPPLY SWITCHOVER CRITERIA

<u>IF</u> CST suction pressure decreases to less than 6.9 psig, <u>THEN</u> switch to alternate AFW suction supply.

Revision: 12		RESPONSE TO INADEQUATE CORE COOLING		EMG FR-C1				
Continuous Use				RE COOLING	Page 50 of 56			
STE	ACTION	/EXPECTED	[	F	RESPONSE NOT			
ATTACHMENT A (Page 5 of 8) ESTABLISHING ALTERNATE HIGH HEAD INJECTION								
Α8.	Align CC Header: a. Ensur Charg valve OPEN * BG- * BG- b. Reset o BG o BG c. Open o BG o BG d. Open Contr	CPs To Normal Charging re CCP Discharge To ging Header isolation for running CCP(s) - 8483A for CCP A 8483C for CCP B c CCP Recirc Valves HS-8110 HS-8111 CCP Recirc Valves HIS-8110 HIS-8111 CCP Discharge Flow col valve	-	Per 1. 2.	form the fo Manually or valves as ne establish Co normal chary <u>IF</u> flow from be establish establish No a) Start NCH o BG HIS- o BG HIS- o BG HIS-	<pre>llowing: locally align ecessary to CP flow through ging header. m CCPs can<u>NO</u>T hed,<u>THEN</u> CP flow: -3 s running,<u>THEN</u> CCPs. -1A -2A</pre>		
А9.	Check Ch Meter -	TR-121 harging Header Flow FLOW INDICATED		Go	to Step All			
A10.	Return 7 In Effec	To Procedure And Step						
A11.	Open BI	Inlet Valves		Per	form the fo	llowing:		
	O EM HIS O EM HIS	5-8803A 5-8803B		a. b.	Locally oper valves. o EM HV-880 o EM HV-880 <u>IF</u> a flow po can <u>NOT</u> be <u>THEN</u> return and step in	n the BIT inlet 3A 3B ath to the BIT established, to procedure effect.		

RESPONSE TO INADEQUATE CORE COOLING

Page 51 of 56

#### FOLDOUT PAGE FOR EMG FR-C1

## 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

## 2. AFW SUPPLY SWITCHOVER CRITERIA
Revisi	on: 12	DECONCE TO INADEOR	EMG FR-C1			-C1	
Contin	uous Use	RESPONSE IO INADEQU	RESPONSE NOT		E 56		
STE	ACTION	/EXPECTED	$\square$	RE	SPONSE NOT	1	
	E	ATTACHM (Page 6 STABLISHING ALTERNATE	ENT of E HI	A 8) IGH HI	EAD INJECT	ION	
A12.	Open BIJ	'Outlet Valves		Perfo	orm the fo	llowing:	
	O EM HIS O EM HIS	5-8801A 5-8801B		a. Lo oi	cally ope utlet valv	n the BIT es.	
				0	EM HV - 880 EM HV - 880	1A 1B	
				b. <u>II</u> Bl es to ef	<u>7</u> a flow p IT can <u>NO</u> T stablished procedur ffect.	ath from t be , <u>THE</u> N ret e and step	he urn in
A13.	Check If Has Beer	CCP Flow Through BI Established:	т				
	a. Check	CCPs - ANY RUNNING		a.Go	o to Step	A15.	
	b. Check Pumps Tank INDIC	heck Centrifugal Charging umps To Boron Injection ank Flow Meters - FLOW NDICATED EM FI-917A EM FI-917B	a	b. Pe	erform the ) Close no: header i: valves	following rmal charg solation	: ing
	* EM * EM				O BG HC- O BG HIS O BG HIS	182 -8105 -8106	
				2 )	) <u>IF</u> CCP f can <u>NOT</u> ] <u>THEN</u> go	low throug be establi to Step Al	h BIT shed, 5.
A14.	Return 1 In Effec	To Procedure And Step St					

RESPONSE TO INADEQUATE CORE COOLING

Page 53 of 56

### FOLDOUT PAGE FOR EMG FR-C1

### 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

### 2. AFW SUPPLY SWITCHOVER CRITERIA

 $\underline{IF}$  CST suction pressure decreases to less than 6.9 psig,  $\underline{THEN}$  switch to alternate AFW suction supply.

Revisi	on: 12	ECDONCE TO I		C	ਹਾਸ	COOLTNC	EMG FR-C1	
Contin	uous Use	ESPONSE IO II	NADEQUALE		JKE	COOLING	Page 54 of 56	5
STE	ACTION/EX	PECTED		]	RESP	ONSE NOT		
	EST	AT (Pa BLISHING ALT:	TACHMENT ge 7 of 8 ERNATE HI	A 3) GH	HEA	D INJECT	ION	
A15.	Check NCP	- RUNNING		Sta	art	NCP on r	ecirc:	
				a.	Sta	rt NCP.		
					o B	G HIS-3		
				b.	<u>IF</u> ens sto	NCP is r ure all o pped.	unning, <u>THE</u> N CCPs are	
					0 B( 0 B(	G HIS-1A G HIS-2A		
				c.	<u>IF</u> <u>THE</u> and	NCP can <u>)</u> N return step in	<u>NO</u> T be starte to procedure effect.	d,
A16.	Establish 1 BIT:	NCP Flow Path	То					
	a. Ensure of from cha BIT - OI * BG-848	one train of arging header PEN 83A and	valves to	a.	Man val the est to	ually or ves. <u>IF</u> BIT can ablished procedur	locally open a flow path <u>NO</u> T be , <u>THE</u> N return e and step in	to
	EM HIS train * BG-848 EM HIS train	5-8803A for r 33C and 5-8803B for y	ed ellow		eff	ect.		
	b. Open NCI Control	P Discharge F Valve.	low					
	o BG FK-	462						
	c. Open CCI Control	P Discharge F Valve	low	c.	Ret ste	urn to p p in eff	rocedure and ect.	
	o BG FK-	-121						

RESPONSE TO INADEQUATE CORE COOLING

Page 55 of 56

### FOLDOUT PAGE FOR EMG FR-C1

### 1. <u>COLD LEG RECIRCULATION CRITERIA</u>

<u>IF</u> RWST level decreases to less than 36%<u>, TH</u>EN go to EMG ES-12, TRANSFER TO COLD LEG RECIRCULATION, Step 1.

### 2. AFW SUPPLY SWITCHOVER CRITERIA

 $\underline{IF}$  CST suction pressure decreases to less than 6.9 psig, THEN switch to alternate AFW suction supply.

Revisi	on: 12			יייז א			EMG FR-C1
Contin	uous Use	RESPONSE .	IO INADEQU	UAII		ORE COOLING	Page 56 of 56
STE	ACTION	/EXPECTED		$\left  - \right $	]	RESPONSE NOT	
	E	STABLISHING	ATTACHM (Page 8 ALTERNAT:	IENT of E HI	A 8) IGH	HEAD INJECT	ION
A17.	Check Ce	entrifugal C	harging	Ŀ	Рез	form the fo	llowing:
	Flow Met	ers - FLOW	INDICATED a. Close header	Close norma header isol	l charging ation valves.		
	* EM FI- * EM FI-	917A 917B				o BG HC-182 o BG HIS-81 o BG HIS-81	05 06
					b.	Locally ens Discharge H Outlet Isol	ure CCP A/B eader FCV-121 ation - OPEN
						o BG-8483B	
					c.	Locally ens Discharge I	ure NCP solation - OPEN
						o BG-8388	
A18.	Return 1 In Effec	o Procedure t	And Step	)			
			-END-				

TASK: Increase Accumulator Tank Pressure - Modes 1, 2 or 3		
TASK #: 00600029		
SAFETY FUNCTION #:3		
K/A #s: A1.13, A4.02		
References: SYS EP-200, Rev. 23		
Examinee's Name RO	_ SS No	SRO
The examinee's performance was evaluated against the standards in this JPM	and determined to be :	
SATISFACTORY UNSATISFACTORY		
Reason if UNSATISFACTORY:		
Estimated JPM completion Time: 10 min.		
Actual Performance Time:min.		
Location of Performance: Control Room Simulator _X Pla	ant	
Method of Performance: Simulate PerformX_		
Tools and Equipment: Simulator		
Evaluators Signature:		Date

Notes:
BOOTH INSTRUCTIONS:
Simulator set-up
IC 177
RUN
Open a Monitor screen and enter - SET ASISAG (3) = 960
EVALUATOR:
Provide the GREEN "Information Only" copy of SYS EP-200 to Examinee.
* Denotes a Critical Step
Initial Conditions: You are the Reactor Operator, the plant is in <u>Mode 1</u> . Accumulator "C" pressure is ≈600 psig, annunciator 45B is lit.
Initiating Cues:
The Control Room Supervisor directs you to raise SI Accumulator "C" pressure to 630 psig using section 6.6 of SYS EP-200. Prerequisites have been completed.
Provide the "Info Only" copy of SYS EP-200 to the examinee.

Element #	Step #	Element	Standard	Score
		Start Time		
1.	6.6.1	Ensure N ₂ pressure regulator at the N2 skid is set at 700 psig.	Contact Site Operator, verify regulator setting.	S U

Cue:

<u>Booth Instruction</u>: When called as Site Watch, report " $N_2$  high pressure regulator is set at 700 psig".

Comments:

2.	6.6.2	Ensure Accumulator N2 Supply Vent Valve Control is closed.	Locate EP HC-943 on RL018. Verify the pot output meter reads 0%.	S U
		• EP HCV-943 - CLOSED.		

Cue:

### Comments:

3.	6.6.5	IF increasing Accumulator Tank "C" pressure, THEN perform the following:	Complete elements 3a through 3d.	N/A
----	-------	-----------------------------------------------------------------------------	----------------------------------	-----

Cue:

Comments: The Examinee may use the NPIS computer points or NPIS Graphic display to monitor accumulator pressure.

3a.*	6.6.5.1	OPEN Accumulator Tank N ₂ supply valve .	Locate EP HIS-8875C on RL018. Open the	S U
		• EP HIS-8875C - OPEN	valve by pressing the OPEN P/B. Verify the Red light comes on and the Green light goes out.	

Cue:

Comments: Valves for other accumulators should be marked N/A.

3b.*	6.6.5.2	OPEN Accumulator Tanks N2 supply valve.	Locate EP HIS-8880 on RL018. Open the	S U
		• EP HV-8880 - OPEN	valve by pressing the OPEN P/B. Verify the Red light comes on and the Green light goes	
			out.	

Cue:

Comments:

* Critical Step

Element #	Step #	Element	Standard	Score
3c.*	6.6.5.3	<ul><li>WHEN desired pressure is reached, THEN CLOSE Accumulator Tanks N2 supply valve.</li><li>EP HV-8880 - CLOSED</li></ul>	Locate EP PI-964 and EP PI-965 on RL018. Verify pressure is $\approx$ 630 psig. Locate EP HIS-8880 on RL018. Close the valve by pressing the CLOSE P/B. Verify the Green light comes on and the Red light goes out.	S U

Cue:

Comments:

3d.	6.6.5.4	CLOSE the Accumulator Tank N ₂ supply valve.	Locate EP HIS-8875C on RL018. Close the valve by pressing the CLOSE P/B. Verify the	S U
		• EP HIS-8875C - CLOSED	Green light comes on and the Red light goes out.	

Cue:

### Comments: Valves for other accumulators should be marked N/A.

	4.	6.6.7	•	Procedure step for section 6.6 complete.	Sign off step.	S U
--	----	-------	---	------------------------------------------	----------------	-----

Cue:

Comments: Not a critical step or required to complete the JPM.

**Termination:** Closing EP HIS-8875C completes the JPM.

Stop Time _____

*Critical Step

Initial Conditions:

You are the Reactor Operator, the plant is in Mode 1. Accumulator "C" pressure is ≈600 psig, annunciator 45B is lit.

Initiating Cues:

The Control Room Supervisor directs you to raise SI Accumulator "C" pressure to 630 psig using section 6.6 of SYS EP-200. The prerequisites have been performed.

Notes:

If you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

When you have completed the JPM inform your evaluator that you are done by handing this Initial Conditions/Initiating Cues sheet back to him.



SYS EP-200

# SAFETY INJECTION ACCUMULATOR OPERATIONS

# Responsible Manager

Manager Operations

M. M. M. M. M. M. M. M.	$\mathbf{\Lambda}$ $\hat{\mathbf{\Lambda}}$ $\hat{\mathbf{A}}$	<i>`````````````````````````````````````</i>	₽₽₽©₽₽₽₽₽
кккккккк \$\$\$\$\$\$	¤ Revision Number ቻ፟፟፟፝፝፝፝፝፝፝፝	¤ 23 \$\$\$\$\$\$\$\$\$\$\$	₽₽₽₽₽₽₽₽₽₽ ₽
$\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$	보 Use Category	Ц	Continuous
ををををををををを	<u> </u>	<i>ዮጵ<b>ዯ</b>፞፞፞፞፞፞፞ዯ፞ዾዾዸ</i>	<i>₠₱₽₽₽₽₽₽</i> ₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽
	¤ Administrative Controls Procedure ታሁሁሁሁሁሁሁሁሁሁ	PPPP I No	ᠴ ৬৬৬৯৯৬৬৬৬
<i>&amp;&amp;&amp;&amp;&amp;&amp;</i> &&&&&&&&&&&&&&&&&&&&&&&&&&&&&&	۲ Infrequently Performed Procedure په په پ	ц No Д No	Г Ц
₢₢₢₢₢₢	Ä Program Number	¥ 21D	д Д
₢₢₢₢₢₢	ঞ <i>দ্দুপ্ৰুদ্দুপ্ৰদ্দুপ্ৰদ্দপ্ৰদপ্ৰদপ্ৰদপ্ৰদ্প</i> ৰ্থ উপন্দুপ্ৰ <u>দুপ্ৰদিপ্ৰদিপ</u> ্ৰদিপ্ৰদিপ্ৰদিপ্ৰদিপ্ৰদিপ্ৰদিপ্ৰদিপ্ৰদিপ	<i>፞ዾቘቘ</i> ፼፟ቝ፟፟፟ቚ፟፟፟ቚ	₽₽₽₩₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽

Continuous Use

SAFETY INJECTION ACCUMULATOR OPERATIONS

Page 1 of 41

### TABLE OF CONTENTS

### SECTION

### <u>TITLE</u>

PAGE

2 2

2

2

3 3

5

6

21

37

39

41

1.0	PURPOSE

- SCOPE 2.0
- 3.0 REFERENCES AND COMMITMENTS
- 3.1 References
- 3.2 Commitments
- 4.0 PRECAUTIONS/LIMITATIONS
- 5.0 PREREQUISITES
- 6.0 PROCEDURE
- Increasing Accum Level In Modes 1, 2, Or 3 Above 1700 PSIG 6 6.1
- Increasing Accum Level In Mode 3 Below 1700 PSIG 6.2 14 Increasing Accum Level In Mode 4, 5, 6, Or Defueled Using
- 6.3 SI Pump A
- 6.4 Increasing Accum Level In Mode 4, 5, 6, Or Defueled Using 27 SI Pump B 34
- 6.5 Decreasing Accum Level
- 6.6 Increasing Accum Pressure
- 6.7 Decreasing Accum Pressure
- 7.0 RECORDS

### 1.0 <u>PURPOSE</u>

1.1 This procedure provides instructions for maintaining SI accumulator tank level and pressure.

### 2.0 <u>SCOPE</u>

- 2.1 This procedure provides instructions to increase accumulator level in Modes 1, 2, or 3 above 1700 psig.
- 2.2 This procedure provides instructions to increase accumulator level in Mode 3 below 1700 psig.
- 2.3 This procedure provides instructions to increase accumulator level in Modes 4, 5, 6, or Defueled using SI pump A.
- 2.4 This procedure provides instructions to increase accumulator level in Modes 4, 5, 6, or Defueled using SI pump B.
- 2.5 This procedure provides instructions to decrease accumulator level.
- 2.6 This procedure provides instructions to increase accumulator pressure.
- 2.7 This procedure provides instructions to decrease accumulator pressure.

### 3.0 <u>REFERENCES AND COMMITMENTS</u>

- 3.1 <u>References</u>
  - 3.1.1 M-12EP01 (Q)
  - 3.1.2 M-12EM01 (Q)
  - 3.1.3 M-12HE01
  - 3.1.4 M-12HE02
  - 3.1.5 M-12BN01 (Q)
  - 3.1.6 SER 21-87
  - 3.1.7 PIR 99-0429, During the scheduled safety injection pump surveillance run, it was observed that relief valve (EM8851) in the SIP common cold leg injection line had lifted and was passing flow.
  - 3.1.8 CCP 09289 SI Pump discharge relief valve setpoint increase.

#### 3.2 <u>Commitments</u>

- 3.2.1 LER 86-025, KMLNRC 86-100, Closure Of Valve EM HV-8835 Renders Both Trains Of Safety Injection Inoperable. (RCMS # 86-249)
- 3.2.2 PIR 97-0143, Entry Into T.S. Due To Low Accumulator Temperature

#### 4.0 <u>PRECAUTIONS/LIMITATIONS</u>

- 4.1 Maintain SI accumulators level, pressure and boron

  µ
  concentration in accordance with Technical

  µ
  Specification 3.5.1.
  µ
- 4.2 WHEN RCS temperature is less than or equal to 350°F, THEN the safety injection pump to be used to fill accumulators must be H isolated from the RCS by a closed isolation valve with power H removed, <u>OR</u> by a manual isolation valve secured in the closed H position in accordance with Technical Specification 3.5.3 or H 3.4.12 H
- 4.4 <u>IF</u> RCS temperature is greater than or equal to 350°<u>F</u> AND accumulator level must be increased, <u>THEN</u> ensure one of the following conditions is met: [3.2.1]
  - * Decrease RCS temperature to less than 350°F.

* Increase RCS pressure to greater than 1700 psig.

* Enter Technical Specification 3.5.2.

Ц

4.5 <u>IF</u> the accumulators are filled from the RWS<u>T AND</u> the RWST has

not been diluted since verifying that its boron concentration  $\mu$ is within the limits of Technical Specification 3.5.4<u>, THEN</u>  $\mu$ Chemistry sample of the accumulators is not required.  $\mu$ 

- 4.6 Accumulator level should not be adjusted between accumulators by use of fill lines. The globe valves in the fill lines are not designed for backflow and damage may result. (3.1.6)
- 4.7 Frequent filling of SI Accumulators may indicate improper check valve seating at RCS pressures below 1800 psig. Refer to SYS EP-201, SEATING ACCUMULATOR SAFETY INJECTION LINE CHECK VALVES, to seat the check valves.

Continuous Use

Page 4 of 41

- 4.8 <u>IF</u> accumulator leakage is present, <u>THEN</u> running the SI pump on recirc for between 5 minutes and 10 minutes after the accumulators have been filled may reseat the leaking check valve and reduce accumulator leakage.
- 4.9 SI Pump discharge relief valves have been known to lift on pump start. CCP 09289 installed discharge relief valves with A a higher lift setpoint. <u>IF</u> the discharge relief valves are still suspected of lifting on pump starts, <u>TH</u>EN the pump discharge valves should be closed. Contact the system A engineer for clarification.
- 4.10 Closing SI pump A Discharge Valve, EM HV-8821A will cause SI pump A to be inoperable.
- 4.11 Closing SI pump B Discharge Valve, EM HV-8821B will cause SI pump B to be inoperable.
- 4.12 <u>IF</u> using SI pump B to increase accumulator level in Mode 4, 5, 6, or Defueled, <u>THEN</u> closing EM HIS-8835, SI Pumps To Cold Leg Injection valve will cause both SI pumps to be inoperable.
- 4.13 Accumulator operating temperatures must be maintained between 45°F and 120°F per USAR Table 6.3-1. [3.2.2]

Continuous Use

## SAFETY INJECTION ACCUMULATOR OPERATIONS

SYS EP-200

Page 5 of 41

	5.0	PREREQUISITES	<u>INIT/DATE</u>
	5.1	CKL EP-120, ACCUMULATOR SAFETY INJECTION LINEUP, is complete.	
	5.2	CKL EM-120, SAFETY INJECTION SYSTEM LINEUP CHECKLISTS, is complete.	, 
	5.3	CKL BN-120, REFUELING WATER STORAGE SYSTEM LINEUP, is complete.	, 
$\mathcal{R}\mathcal{R}\mathcal{R}\mathcal{R}\mathcal{R}\mathcal{R}$	<i>~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~</i>	<i>ĸĸĸĸĸĸĸ</i> ĸ <i>Ċĸĸĸkkkkkkkkkkkkk</i>	<i>\$&amp;&amp;&amp;&amp;&amp;&amp;</i> &&&&&&&&&&&&&&&&&&&&&&&&&&&&&&
~ ~ ~ ~ ~		<u>NOTE</u>	П
	Image: Present and Present	ssurizing accumulators from atmospheric pressure to m nnical specification pressure of 585 psig will requi- st 65 inches of nitrogen.	minimum ¤ re at ¤
<i>&amp;&amp;&amp;</i> &&&&	<i>₽₽₽₽₽</i> ₽₽₽₽₽₽ ₽	₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽	<i>\$\$\$\$\$\$\$\$\$</i> 
	5.4	<u>IF</u> increasing accumulator tank pressure <u>, TH</u> EN the Nitrogen Supply System is available.	
	5.5	<u>IF</u> required, <u>THEN</u> the Boron Recycle System is available to decrease accumulator tank level.	
	5.6	<u>IF</u> initial level is below indicating range <u>, TH</u> EN accumulator vent valves are open prior to filling.	· 
	5.7 ¤	IF SI pump will be run, THEN the proper CCW train	,
		for the SI pump to be run is in service: (N/A other train). ¤	
		5.7.1 CCW train A for SIP A - RUNNING	
		5.7.2 CCW train B for SIP B - RUNNING	, 
	5.8	<u>IF</u> Section 6.1 or 6.2 is being performed, <u>TH</u> EN ensure both SI Train A and B are operable.	· ·

Continuous Use

SAFETY INJECTION ACCUMULATOR **OPERATIONS** 

Ц Ц

Ц

Ц

Ц

Ц

Ц

Ц

Ц

Ц

Ц

Ц

Ц

Ц

Page 6 of 41

#### INIT/DATE 6.0 PROCEDURE Increasing Accum Level In Modes 1, 2, Or 3 Above 1700 PSIG 6.1 Ц NOTE Ц Ц Step 6.1.1 is intended to minimize high pressure alarms caused Ц Ц by the pressure increase associated with raising accumulator Ц Ц level. If an alarm is received due to high pressure while Ц implie filling an accumulator, the alarm should clear after the Ц $\mu$ accumulator cools to ambient temperature. Ц Ц 6.1.1 IF accumulator level is less than 45% AND Ц accumulator pressure is greater than Ц 619 psiq, THEN adjust accumulator pressure Ц to less than 619 psig using section 6.7, Ц Decreasing Accum Pressure. Ц 6.1.2 Record RCS pressure read on any of the following indicators: (N/A indicators not used) * BB PI-455A - ____ * BB PI-456 - ____ * BB PI-457 -* BB PI-458 $oldsymbol{\lambda}$ NOTE Ц Ц Ц Depressurizing the RHR header should reduce back pressure on Ц Ц check valves EP-8818A, B, C and D, allowing the check valves to $\pi$ Ц Ц seat while the SI pump is running. This step should be Ц Ц performed at SM/CRS discretion. Ц Ц

- 6.1.3 <u>IF</u> desired, <u>THEN</u> depressurize the RHR header as follows:
  - 1. Ensure either RHR To Accumulator

Injection Test Line Valve is open. ¤ (N/A other valve) ¤ * EJ HIS-8890A - OPEN

* EJ HIS-8890B - OPEN

	Revision: 23			SY	S EP-	·200
	Continuous Use		OPERATIONS	Page	7 of	41
_						
		2.	Ensure SI System Test Line Outer Containment Isolation Valve is op	en.	<u>INIT</u>	<u>/ DATE</u>
			O EM HIS-8964 - OPEN		C	
		3.	Ensure SI System Test Line Inner Containment Isolation Valve is op	en.		
			O EM HIS-8871 - OPEN		C	
	6.1.4	<u>IF</u> THE	using SI pump A to fill accumulato <u>N</u> perform the following:	rs,		
		1.	Ensure SI Pump A Recirc To RWST isolation valve is open.			
			O EM HIS-8814A - OPEN		C	
		2.	Ensure SI Pumps Recirc To RWST isolation valve is open.			
			O BN HIS-8813 - OPEN		C	
ער ער ער ער ער	<i>ᢘᢘᢘᢘᢘᢘᢘᢘᢘᢘᢘ</i> ᠕ <i>ᡭᠻᡭᡭᡭᡭᡭᡭᡭᡭ</i> ᡭ		╯⋉℡ ѦѦѦѦѦѦѦѦѦѦѦѦѦѦѦѦѦѦ҂ѧҝѧҝ	ኇኇኇኇ	かかかな	ѷҾ҄Ҿ҄Ѧ
* * * * *		* * * *	<u>NOTE</u>			П
	H Closing EM	HIS-8	8821A, SI PUMP DISCH TO C/L causes	the S	SI Pun	ap A I
	H C/L injection	on pa	ath to be inoperable, refer to Tec	n. Spe	ec. 3.	.5.2 ¤
<i>&amp;&amp;&amp;</i> &&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&&	<i>₳₳₳₳₽₽₽₽₽</i> <i>₷₳₳₳₽₽₽₽₽₽</i> ₽ ॻ	\$\$\$\$\$ \$\$\$\$	፞ኇ፞ ዾ፟ኇዾ፟፟፟፟ዾ ዾ፟ዾ፟ዾ፟፟ዾ፟ዾዾ፟ዾ፟ዾዾ፟ዾ፟ዾዾ፟ዾዾዾዾዾዾዾዾ	ኇ፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞፞ቚ፞ኇ፞	於於於於	<i>\$\$\$\$\$\$</i> 4 ¤
		3.	<u>IF</u> SI Pump discharge relief valve	s are		
		Ц	expected to lift on pump start, <u>T</u>	<u>HE</u> N		
			Close SI Pump A Disch to C/L Inj	Iso		
			д Valve. (3.1.7) д			
			o EM HIS-8821A - CLOSED		C	
		4.	Start SI Pump A.			
			o EM HIS-4 - STARTED		C	
		5. ¤	<u>IF</u> closed to prevent discharge re	lief		

valve lift, <u>THEN</u> Open SI Pump A Disch Ц

to C/L Inj Iso Valve. (3.1.7) Ц

-					~ ~
Rev	18	11	on	:	23

SAFETY INJECTION ACCUMULATOR OPERATIONS

Page 8 of 41

	6.1.5	<u>IF</u> <u>THE</u>	using SI pump B to fill accumulators, N perform the following:	<u>INIT/DATE</u>
		1.	Ensure SI Pump B Recirc To RWST isolation valve is open.	
			O EM HIS-8814B - OPEN	
		2.	Ensure SI Pumps Recirc To RWST isolation valve is open.	
			o BN HIS-8813 - OPEN	
M. M. M. M. M.	и. и. и. и. и. и. и. и. и. и. АФФФФФФФФФФ	555 M. M. M	[┎] ᠃ Ŷ <i>ŔŶŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔ</i> ŔŔŔŔŔ	<i>₽₽₽₽₽₽₽₽</i> ₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽
<i>\$\$\$\$\$</i> \$	 Д <i>ФФФФФФФФФФФ</i>	\$\$\$\$	<u>NOTE</u>	ц
	H H Closing EM H	IIS-8	821B, SI PUMP DISCH TO C/L causes the S	I Pump B¤
	H H C/L injectio	on pa	ath to be inoperable, refer to Tech. Spec	c. 3.5.2¤
				Д
<i>₽₽₽₽₽</i>	$\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi\phi$	<i>\$\$\$</i> \$ <i>\$\$</i>	^{&gt;} $\beta^{\vee}$ \$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$	<i>&gt;\$\$\$\$\$\$\$\$\$</i> 6
		3.	IF SI Pump discharge relief valves are	
		Ц	expected to lift on pump start, <u>THE</u> N	
			¤ Close SI Pump B Disch to C/L Inj Iso	
			д Valve. (3.1.7) Д	
			o EM HIS-8821B - CLOSED	
		4.	Start SI Pump B.	
			o EM HIS-5 - STARTED	
		5.	<u>IF</u> closed to prevent discharge relief	
		Д	valve lift, <u>THEN</u> Open SI Pump B Disch	
			to C/L Inj Iso Valve. (3.1.7) ¤	
			O EM HIS-8821B - OPEN	
	6.1.6	Ope	n Accumulator Tanks Fill Line Valve.	
		οE	M HIS-8888 - OPEN	

- ·				0 0
Revi	<b>G</b> 1	$\cap n$		-23
TCC V T	. ר ב	011	-	20

### SAFETY INJECTION ACCUMULATOR OPERATIONS

INIT/DATE  $oldsymbol{\lambda}$ Ц NOTE Ц Ц Ц Ц If the RWST boron concentration is within T.S. and TRM limits, Ц Ц Ц Chemistry sample of the accumulators is not required. Ц Ц Ц Ц 6.1.7 IF filling accumulator tank A, THEN perform the following: 1. Record initial Accumulator Tank A Level Ц from the highest reading indicator. Ц (N/A indicator not used) Ц * EP LI-950 - ____ * EP LI-951 - ____ 2. Open Accumulator Tank A Fill Line Valve. O EP HIS-8878A - OPEN 3. WHEN Accumulator Tank A Level is Ц between 55% and 58% on the highest Ц reading indicator, THEN close Ц Accumulator Tank A Fill Line Valve. Ц (N/A indicator not used) Ц * EP LI-950 - BETWEEN 55% AND 58%  $\square$ * EP LI-951 - BETWEEN 55% AND 58% <u>AND</u> O EP HIS-8878A - CLOSED Record change in accumulator tank A 4. level

o Final level - Initial level =____% level change

,

10001011 00	Rev	is	io	n:	23
-------------	-----	----	----	----	----

Page 10 of 41

		II	NIT/DATE
6.1.8	<u>IF</u> the	filling accumulator tank B, <u>THE</u> N perform following:	
	1. M	Record initial Accumulator Tank B Level	
	6	from the highest reading indicator.	
		(N/A other indicator) ¤	
		* EP LI-952	
		OR	
		* EP LI-953	
	2.	Open Accumulator Tank B Fill Line Valve.	
		O EP HIS-8878B - OPEN	
	3.	<u>WHEN</u> Accumulator Tank B Level is	
	Д	between 55% and 58% on the highest	
		reading indicator, <u>THE</u> N close	
		Accumulator Tank B Fill Line Valve.	
		(N/A indicator not used) ¤	
		* EP LI-952 - BETWEEN 55% AND 58%	
		OR	
		* EP LI-953 - BETWEEN 55% AND 58%	
		AND	
		o EP HIS-8878B - CLOSED	
	4.	Record change in accumulator tank B level.	
		o Final level - Initial level =% level change	
6.1.9	<u>IF</u> the	filling accumulator tank C, <u>THEN</u> perform following:	
	1.	Record initial Accumulator Tank C Level	
	7	from the highest reading indicator. $\mbox{\tt M}$	

(1 ¤	J/A	indicat	tor not used)		
*	ΕP	LI-954			
		<u>OR</u>		,	
*	ΕP	LI-955			

/

Revision: 23		CAREWY INTROVION ACCUMULATOD	SYS EP-200
Continuous Use		OPERATIONS	Page 11 of 41
		1	
	2.	Open Accumulator Tank C Fill Line Valve.	<u>INIT/DATE</u>
		O EP HIS-8878C - OPEN	
	3. ¤	<u>WHEN</u> Accumulator Tank C Level is	
		between 55% and 58% on the highes ¤	t
		reading indicator, <u>THE</u> N close ¤	
		Accumulator Tank C Fill Line Valv ¤	е.
		(N/A indicator not used) ¤	
		o EP LI-954 - BETWEEN 55% AND 58%	
		OR	
		* EP LI-955 - BETWEEN 55% AND 58%	
		AND	
		o EP HIS-8878C - CLOSED	
	4.	Record change in accumulator tank level.	С
		o Final level - Initial level = level change	%
6.1.10	<u>IF</u> the	filling accumulator tank D, <u>THE</u> N p e following:	erform
	1.	Record initial Accumulator Tank D	Level
	Д	from the highest reading indicato:	r.
		(N/A indicator not used) ¤	
		* EP LI-956	
		OR	·
		* EP LI-957	
	2.	Open Accumulator Tank D Fill Line Valve.	
		o EP HIS-8878D - OPEN	

ſ	Revision: 23			SYS	SYS EP-200				
	Continuous Use		Page 12	of 41					
r									
		3.	WHEN Accumulator Tank D Level is	<u>I</u> ] 3	<u>NIT/DATE</u>				
		Ц	between 55% and 58% on the highe	est					
			reading indicator, <u>THEN</u> close						
			Accumulator Tank D Fill Line Val	.ve.					
			(N/A indicator not used) ¤						
			O EP LI-956 - BETWEEN 55% AND 58	18					
			OR						
			* EP LI-957 - BETWEEN 55% AND 58	00					
			AND						
			o EP HIS-8878D - CLOSED						
		4.	Record change in accumulator tar level.	ık D					
			o Final level - Initial level =_ level change	% 					
	6.1.11	Clos	se Accumulator Tanks Fill Line Va	alve.					
		o ei	M HIS-8888 - CLOSED						
רי גר גר גר גר	<i>ዂዂዂዂዂዂዂዂዂዂ</i> <i>ዹ፞ዀ፟ዀ፟ዀ፟ዀ፞ዀ፞ዀዀዀ</i>		፟ቝ $^{ m (W)}$ ዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮጵዮ	<i>₽₽₽₽₽₽₽</i> ₽₽	ን <i>ዽ፞፞፞፞፞፞ዸ፞ዸ፞ዸዾዾ</i> ዸ				
$\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$		$\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$	<u>NOTE</u>		д н				
	Image: Constraint of the state         Image: Constate         Image: Constrat	SI p follo	oump on recirc for between 5 minu wing accumulator fill may reseat	tes and a leakin	्र ug check				
	$\stackrel{\frown}{\amalg}$ valve and re	educe	accumulator leakage.		П				
\$\$\$\$	ҾҾҾҾҾҾҾҾҾҾ ҈ѼҾҾҾҾҾҾҾҾҾҾ	₽ <i>₽₽₽</i> ₽ ₽₽₽₽	Ҿ҅҄҄҄҂ ѷѽѽѽѽѽѽѽѽѽѽѽѽѽѽѽѽѽѽѽѽѽѽѽѽ	<i>፞፞፞ዯ፞፞፞፞፞፞ቝ፞፞፞፞፞፞ቝ፞</i> ቝ፞፞ <i>ዾ</i> ፞ኯ	` <i>````````````````````````````````````</i>				
	6.1.12	<u>IF</u> a allo bety	accumulator leakage is present, <u>r</u> ow the SI pump to run on recirc : ween 5 minutes and 10 minutes.	<u>THE</u> N For					
	6.1.13 5	Stop (N/A ¤	SI pump being used to fill. other pump)						
		* El	M HIS-4 for SI pump A - STOPPED						
			OR						
		<u>*</u> EI	M HIS-5 for SI pump B - STOPPED						

ſ	Revision: 23		SYS EP-200								
ŀ	Continuous Use	SAFETY INJECTION ACCUMULATOR OPERATIONS	Page 13 of 41								
L											
	I 6.1.14 Ensure both RHR To Accumulator Injection Test Line Valves are closed.										
		o EJ HIS-8890A - CLOSED									
		AND									
		o EJ HIS-8890B - CLOSED									
। মুম্বম্ব	ଷ୍ୟଷ୍ୟଷ୍ୟଷ୍ୟଷ୍ୟ ଷ୍ୟଷ୍ୟଷ୍ୟଷ୍ୟଷ୍ୟ ୍ଥ	AAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAA	ଷ୍ୟସ୍ୟସ୍ସ୍ୟସ୍ୟସ୍ୟ ୭ ୦								
	Closing EM B and Outer Co relief to 1	HIS-8964 and EM HIS-8871, SI System Tes ontainment Isolation Valves, may cause ift due to leakage past check valves.	t Line Inner () RHR discharge () ()								
8888	ଷ୍ୟଷ୍ୟଷ୍ୟଷ୍ୟଷ୍ୟ ଷ୍ୟଷ୍ୟଷ୍ୟଷ୍ୟଷ୍	aaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaaa	କୁ ବିଷୟ ସହ ସହ ସହ ସ								
	6.1.15	<u>IF</u> SI System Test Line Inner And Outer Containment Isolation Valves are <u>NOT</u> used for a relief path in accordance SYS EJ-323, RHR SYSTEM DEPRESSURIZATION <u>THEN</u> close both SI test line containment isolation valves.	r being with ON, ent								
		o EM HIS-8964 - CLOSED									
		AND									
		o EM HIS-8871 - CLOSED									
<i>₽₽₽₽₽</i>	<i>ŶŔŔŔŔŔŔŔŔ</i> ŔŔ <i>ĂŔŔŔŔŔŔŔŔ</i> Ŕ	$^{\circ}$ $\phi$	\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$ \$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$\$								
		NOTE	П								
	ロ If Chemistry ロ	y sample is required, satisfactory resu	ilts must be $\blacksquare$								
	ロ obtained wit	thin 6 hours or the affected accumulate	or must be ¤								
	ロ declared ind ロ	operable per Tech. Spec. 3.5.1	Д								
於於於於於於	<i>ф₽₽₽₽₽₽₽₽₽₽₽</i> ⊕ <i>₽₽₽₽₽₽₽₽₽₽</i> ¤	`ŔŔŔŔ ŶŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔŔ	$^{\diamond}$ $\phi$								
	6.1.16	<u>IF</u> any of the following conditions are <u>THEN</u> direct Chemistry to sample the affected accumulators.	e met, 								
		* RWST boron concentration can not be verified within USAR limits.									
		OR									

* RWST boron concentration has been diluted since last Chemistry sample.

,

6.1.17 Section 6.1, Increasing Accum Level In Modes 1, 2, Or 3 Above 1700 PSIG, is complete.

R	ev	i	s	i	on	:	23
	<b>·</b> ·	_	$\sim$	_	<b></b>		

SAFETY INJECTION ACCUMULATOR OPERATIONS

Page 14 of 41

	6	2	Tnar	Aadi	ina	Accum	Τ. Ο Υ Ο	l Tn	Mode	2 2 B	مامس	1700	DGTC	<u>_</u>	NIT/D	ATE
	0.	Δ		<u>easi</u>	<u> </u>	<u>ACCUIII</u>	пеле	<u> </u>	<u>- MOUE</u>	<u> </u>			<u></u>	, ,		
			6.2. ¤	T	<u> </u>	RCS t	emper	ratur	re is	grea	ater	than	or e	qua⊥		
					to ロ	350°F	<u>AND</u>	accı	ımula	tor 1	level	. must	t be			
					inc ¤	crease	d, <u>T</u> H	<u>IEN</u> e	ensur	e one	e of	the i	Eollo	wing		
					cor ¤	nditio	ns is	s met	:: [	3.2.1	L]					
					* I 3 6 1	Decrea 350°F either proced	se RC and f of t ure:	CS te Till the f	emper the Tollo	ature accum wing	e to nulat sect	less or us ions	than sing of tl	his		
					k k	* 6.3, 5, 6 * 6.4, 5, 6	Incr , Or Incr , Or	reasi Defu reasi Defu	ng A leled ng A leled	ccum Usir ccum Usir	Leve 1g SI Leve 1g SI	l In Pump l In Pump	Mode A Mode B	4, 4,		
						<u>OR</u>										
					* ] ] 2	Increa 1700 p Sectio	se RC sig a n 6.1	CS pr and f L.	ressu Till	re to the a	o gre accum	eater Nulato	than ors u	sing		
						<u>OR</u>										
					* <u>N</u>	<u>WHEN</u> S	I Pun	np A	Disc	harge	e To	Cold	Leg			
					Ĩ	Inject	ion v	valve	e is	close	ed , <u> </u>	<u>HE</u> N e	enter			
					ר ב ג	rech. ¤	Spec.	3.5	5.2.							
	к к к А <i>ф</i>	$\mathcal{C}$	$\mathcal{C}$	ድምድ እድድ	$\mathcal{C}$	₽₽₽ ₽₽₽₽₽₽ ₽₽₽₽₽₽	> <i>&amp;</i> &&&	谷谷存	> <i>&amp;</i> &&&	ᡬᡷᡬᡷᡬ	ゆゆゆ	かかかん	\$ <i>\$\$\$</i> \$	ᡬᡷᡬᡷᡬ	ኇኇኇኇ	ゆゆ
$\gamma\gamma\gamma\gamma\gamma\gamma$	Ц Ц Ч	$\langle \vee \vee \vee$	$\checkmark \lor \lor$	$\checkmark \lor \checkmark$	$\rightarrow \rightarrow \rightarrow$	$\diamond \diamond \bigcirc$		]	NOTE							Ц
	П	Step	6.2	2.2	is i	ntende	ed to	min	imizo	e hig	h pr	essur	e ala	arms o	caused	ЦД
		by t	he p	res	sure	incre	ease	asso	ciat	ed wi	th r	aisin	ig acc	cumula	ator	Ц
	Ц	leve	1.	If a	an a	larm	is re	ceiv	ed d	ue to	hig	h pre	ssure	e whi	le	Ц
	п	fill	ing	an a	accu	mulato	or, t	he a	larm	shou	ld c	lear	after	the		ц
	п	accu	mula	tor	coo	ols to	ambi	ent	temp	eratu	re.					Ц
	п	<b>.</b>				<b>.</b>	<b>.</b>		<b>.</b>	<b>M M M</b>			<b>,</b> , , , , ,		<b>, ,, ,,</b>	Ц
゙ゟ゚ゟ゚ゟ゚ゟ゚	\$\$ \$\$ \$\$	???? ?????????????????????????????????	やかぐ かかん	<i>₽₽₽</i> ₽₽₽	\$ <i>\$</i> \$ <i>\$</i> \$\$ \$\$	₽₽₽ ₽₽₽₽₽ ₽₽₽₽₽	シ₽₽₽	᠅ᡬᡬ	> <i>&amp;</i> &&&	᠅ᡭᡬᡭ	ゟゟゟ	<i>₽₽₽</i> ₽	ঽ৾৾৾ড়ড়ড়	᠅ᡧᡧᡧ	<i>ዮዽዽዽ</i> ι	ゆむは

6.2.2 IF accumulator level is less than 45%, AND  $\mu$ 

accumulator pressure is greater than Ц 619 psig <u>THEN</u> adjust accumulator pressure Ц to less than 619 psig using section 6.7 of Ц this procedure: Ц

/ /

- 6.2.3 Record RCS pressure read on any of the following indicators: (N/A indicators not used.)
  - * BB PI-403 _____ * BB PI-405 _____ * BB PI-406 _____

	Revision: 23	CAREENV INTEGRION ACCUMULATION	SYS EP-200						
[	Continuous Use	OPERATIONS	Page 15 of 41						
	6.2.4	Ensure SI Pump A Recirc To RWST isola valve is open.	tion						
		o EM HIS-8814A - OPEN							
	6.2.5	Ensure SI Pumps Recirc To RWST isolat valve is open.	ion						
		O BN HIS-8813 - OPEN							
? <i>&amp;&amp;</i> &&&	ĠŔŔŔŔŔŔŔŔŔŔ	҅҂҅Ѧ҅҂҄ѦѲ ҈ <i>ѦҞҞҞҞҞҞҞҞҞҞҞҟҞҟҞҟҞҟҞҟҞҞ</i> ҞҞҞҞ	<i>፞ኯዾቘቘቘቘቘቘቘቘ</i>						
	Д	NOTE	)						
	$\stackrel{\frown}{\amalg}$ Closing EM	HIS-8821A, SI PUMP DISCH TO C/L causes	the SI Pump A						
	Image: Classific transform       Image: Classific transform	on path to be inoperable, refer to Tech	n. Spec. 3.5.2						
? <i>&amp;&amp;</i> &&&	<i>₹₽₽₽₽₽₽₽₽₽₽₽₽</i> ₽ <i>₽₽₽₽₽₽₽₽₽₽₽₽₽</i> 	҅Ҏ҅҅҅҅Ҿ҅҅҅Ҿ҅Ҿ҅Ҿ Ҽ҄ <i>ҾҾҾҾҾҾҾҾҾҾҾҾҾҾҾ</i> ҾҾҾҾҾҾҾҨҨ	<i>ŶŔŔŔŔŔŔŔŔŔ</i> Ŕ Ŷ						
	6.2.6	Close SI Pump A Discharge To Cold Leg Injection Valve.							
		o EM HIS-8821A - CLOSED							
	6.2.7	Ensure SI Pump A Discharge To Hot Leg Injection valve is closed.							
		o EM HIS-8802A - CLOSED							
	6.2.8	Start SI Pump A.							
		o EM HIS-4 - STARTED							
	6.2.9	Open Accumulator Tanks Fill Line Valve	e.						
		O EM HIS-8888 - OPEN							

ţ

- ·			-	0 0
Revi	<b>G</b> 1	$\cap n$		シィ
TCC V T	. ר ב	011	-	20

### SAFETY INJECTION ACCUMULATOR OPERATIONS

Page 16 of 41

INIT/DATE  $oldsymbol{\lambda}$ Ц NOTE Ц Ц Ц Ц If the RWST boron concentration is within T.S. and TRM limits, Ц Ц Ц Chemistry sample of the accumulators is not required. Ц Ц Ц Ц 6.2.10 IF filling accumulator tank A, THEN perform the following: 1. Record initial Accumulator Tank A Level Ц from the highest reading indicator. Ц (N/A indicator not used) Ц * EP LI-950 - ____ * EP LI-951 - ____ 2. Open Accumulator Tank A Fill Line Valve. O EP HIS-8878A - OPEN 3. WHEN Accumulator Tank A Level is Ц between 55% and 58% on the highest Ц reading indicator, THEN close Ц Accumulator Tank A Fill Line Valve. Ц (N/A indicator not used) Ц 0 EP LI-950 - BETWEEN 55% AND 58% Π * EP LI-951 - BETWEEN 55% AND 58% <u>AND</u> O EP HIS-8878A - CLOSED Record change in accumulator tank A 4. level

o Final level - Initial level =____% level change

,
Rev	is	io	n:	23
	_ ~			

Page 17 of 41

	INIT/D2	\TE
6.2.11	<u>IF</u> filling accumulator tank B, <u>THE</u> N perform the following:	
	1. Record initial Accumulator Tank B Level	
	from the highest reading indicator.	
	(N/A indicator not used) ¤	
	* EP LI-952	
	OR	
	* EP LI-953	
	2. Open Accumulator Tank B Fill Line Valve.	
	O EP HIS-8878B - OPEN	
	3. <u>WHEN</u> Accumulator Tank B Level is	
	between 55% and 58% on the highest	
	reading indicator, <u>THE</u> N close	
	A Accumulator Tank B Fill Line Valve.	
	(N/A indicator not used) ¤	
	* EP LI-952 - BETWEEN 55% AND 58%	
	OR	
	* EP LI-953 - BETWEEN 55% AND 58%	
	AND	
	o EP HIS-8878B - CLOSED	
	4. Record change in accumulator tank B level.	
	o Final level - Initial level =% level change	
6.2.12	<u>IF</u> filling accumulator tank C, <u>THE</u> N perform the following:	
	1. Record initial Accumulator Tank C Level	
	from the highest reading indicator.	

(N/A indicator not used) * EP LI-954 - _____ OR * EP LI-955 - ____

,

,

Revision: 23		CARERY INTROMION ACCUMULATOR	SYS EP-200
Continuous Use		OPERATIONS	Page 18 of 41
		4	
	2.	Open Accumulator Tank C Fill Line Valve.	<u>INIT/DATE</u>
		O EP HIS-8878C - OPEN	
	3. ¤	<u>WHEN</u> Accumulator Tank C Level is	
		between 55% and 58% on the highest	t
		reading indicator, <u>THE</u> N close ¤	
		Accumulator Tank C Fill Line Valve	2.
		(N/A indicator not used) ¤	
		* EP LI-954 - BETWEEN 55% AND 58%	
		OR	
		* EP LI-955 - BETWEEN 55% AND 58%	
		AND	
		o EP HIS-8878C - CLOSED	
	4.	Record change in accumulator tank level.	С
		o Final level - Initial level = level change	%
6.2.13	<u>IF</u> the	filling accumulator tank D, <u>THE</u> N po e following:	erform
	1.	Record initial Accumulator Tank D	Level
	2	from the highest reading indicator	r.
		(N/A indicator not used) ¤	
		* EP LI-956	
		OR	
		* EP LI-957	
	2.	Open Accumulator Tank D Fill Line Valve.	
		o EP HIS-8878D - OPEN	

Revision: 23	CARETY INTEGUION ACCUMULATOR	SYS EP-200
Continuous Use	OPERATIONS	Page 19 of 41
	3. <u>WHEN</u> Accumulator Tank D Level is	<u>INIT/DATE</u>
	between 55% and 58% on the highest	:
	reading indicator, <u>THE</u> N close ¤	
	Accumulator Tank D Fill Line Valve	<b>2</b> .
	(N/A indicator not used) ¤	
	* EP LI-956 - BETWEEN 55% AND 58%	
	OR	
	* EP LI-957 - BETWEEN 55% AND 58%	
	AND	
	o EP HIS-8878D - CLOSED	
	<ol> <li>Record change in accumulator tank level.</li> </ol>	D
	o Final level - Initial level = level change	_ %
6.2.14	Close Accumulator Tanks Fill Line Valv	ze.
	O EM HIS-8888 - CLOSED	
6.2.15	Stop SI Pump A.	
	O EM HIS-4 - STOPPED	
6.2.16	Open SI Pump A Discharge To Cold Leg Injection Valve.	
	o EM HIS-8821A - OPEN Verit	fied
6.2.17	Position SI Pump A Discharge To Hot Le	∋ā `
	Injection valve as directed by the SM, $\varkappa$	CRS.
	(N/A position not used) ¤	
	* EM HIS-8802A - OPEN	
	OR	
	* EM HIS-8802A - CLOSED	

- '			~ ~
Revi	S101	n:	- 23

SAFETY INJECTION ACCUMULATOR OPERATIONS

Page 20 of 41

	<b>Α</b> <i>ἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀἀ</i>	<u>IT/DATE</u> なななななな
<i>ややややや</i>	¤ NOTE	ц
	$\mu$ $\mu$ If Chemistry sample is required and RCS pressure is greated	¤ r than
	$\square$	
	$\square$ 1000 psig, satisfactory results must be obtained within 6	nours A
	$ert^{t textstyle}$ or the affected accumulator must be declared inoperable perturbed $ert_{eta}$	er ¤
	д Tech. Spec. 3.5.1. д	Д
<i>\$\$\$\$\$\$</i>	҄҂҅҂҅҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂҂	<i>ŶŔŔŔŔ</i> ¤
	6.2.18 <u>IF</u> any of the following conditions are met, <u>THEN</u> direct Chemistry to sample the affected accumulators.	
	* RWST boron concentration can not be verified within USAR limits.	
	OR	
	* RWST boron concentration has been diluted since last Chemistry sample.	
	6.2.19 Section 6.2, Increasing Accum Level In Mode 3 Below 1700 PSIG, is complete.	

Revision: 23

Ц

Ц

Continuous Use

INIT/DATE

Ц

Ц

6.3 <u>Increasing Accum Level In Mode 4, 5, 6, Or Defueled Using SI</u> <u>Pump A</u>

NOTE

 $\[mu] \[mu] \[mu$ 

6.3.1	Ensure SI Pump A Discharge To Cold Leg Injection Valve is closed.	
	o EM HIS-8821A - CLOSED	
6.3.2	Ensure SI Pump A Discharge Accumulator Injection Isolation Valve EM HV-8821A breaker is off.	
	o NG01ADR1 - OFF	
6.3.3	Ensure SI Pump A Discharge To Hot Leg Injection valve is closed.	
	o EM HIS-8802A - CLOSED	
6.3.4	Ensure Power Lockout For EM HV-8802A is in ISO.	
	O EM HIS-8802AA - IN ISO	
6.3.5	Ensure SI Pump A Recirc To RWST isolation valve is open.	
	o EM HIS-8814A - OPEN	
6.3.6	Ensure SI Pumps Recirc To RWST isolation valve is open.	
	o BN HIS-8813 - OPEN	
6.3.7	Remove Clearance Order on SI pump A.	
6.3.8	Rack up SI Pump A breaker.	
	o NB0103 - RACKED UP	
6.3.9	Start SI Pump A.	
	o EM HIS-4 - STARTED	

Page 22 of 41

		<u>INIT/DATE</u>
6.3.10	Open Accumulator Tanks Fill Line Valve.	
	O EM HIS-8888 - OPEN	
6.3.11	<u>IF</u> filling accumulator tank A, <u>THEN</u> perform the following:	m
	1. Record initial Accumulator Tank A Level	1
	from the highest reading indicator.	
	(N/A indicator not used) ¤	
	* EP LI-950	
	OR	,
	* EP LI-951	
	2. Open Accumulator Tank A Fill Line Valve.	,
	O EP HIS-8878A - OPEN	
	3. <u>WHEN</u> Accumulator Tank A Level is between 55% and 58% on the highest reading indicator <u>OR</u> as directed by SM/CRS <u>THEN</u> close Accumulator Tank A Fill Line Valve. (N/A indicator not used)	
	* EP LI-950-BETWEEN 55% AND 58%_OR AS	
	DIRECTED BY SM/CRS	
	OR	
	* EP LI-951-BETWEEN 55% AND 58%_OR AS	
	DIRECTED BY SM/CRS	
	AND	
	o EP HIS-8878A - CLOSED	
	4. Record change in accumulator tank A level.	
	o Final level - Initial level =% level change	

-					-	$\sim$	2
Rev	٦.	S	٦.	n	:	2	3
1.0.0	<u> </u>	~	-	<u> </u>		~	-

Page 23 of 41

			INIT/DATE
6.3.12	<u>LF</u> filling the follow	; accumulator tank B, <u>THE</u> N perform /ing:	
	l. Record	initial Accumulator Tank B Level	
	from t	he highest reading indicator.	
	(N/A i ¤	ndicator not used)	
	* EP L	I-952	
	<u>(</u>	OR	
	* EP L	I-953	
	2. Open A Valve.	ccumulator Tank B Fill Line.	
	O EP H	IS-8878B - OPEN	
	3. <u>WHEN</u> A betwee readin SM/CRS Fill L (N/A i	ccumulator Tank B Level is n 55% and 58% on the highest g indicator <u>OR</u> as directed by <u>THEN</u> close Accumulator Tank B ine Valve. ndicator not used)	
	* EP L	I-952-BETWEEN 55% AND 58%_OR AS	
	DIRE	CTED BY SM/CRS	
	<u>(</u>	OR	
	* EP L	I-953-BETWEEN 55% AND 58%_OR AS	
	DIRE ¤	CTED BY SM/CRS	
	1	AND	
	O EP H	IS-8878B - CLOSED	
	4. Record level.	change in accumulator tank B	
	o Fina leve	l level - Initial level =% l change	

ICATOTOTI - DI	Rev	:i:	si	on	:	23
----------------	-----	-----	----	----	---	----

Page 24 of 41

			INIT/DATE
6.3.13	<u>IF</u> the	filling accumulator tank C, <u>THEN</u> perform following:	
	1. ¤	Record initial Accumulator Tank C Level	
		from the highest reading indicator.	
		(N/A indicator not used) ¤	
		* EP LI-954	
		OR	,
		* EP LI-955	
	2.	Open Accumulator Tank C Fill Line Valve.	,
		O EP HIS-8878C - OPEN	
	3.	<u>WHEN</u> Accumulator Tank C Level is between 55% and 58% on the highest reading indicator <u>OR</u> as directed by SM/CRS <u>THEN</u> close Accumulator Tank C Fill Line Valve. (N/A indicator not used)	
		* EP LI-954-BETWEEN 55% AND 58%_OR AS	
		DIRECTED BY SM/CRS	
		OR	
		* EP LI-955-BETWEEN 55% AND 58%_OR AS	
		DIRECTED BY SM/CRS	
		AND	
		O EP HIS-8878C - CLOSED	
	4.	Record change in accumulator tank C level.	
		o Final level - Initial level =% level change	

D	1	2			0	2
кеv	lS	l	on	•	Δ.	3

Page 25 of 41

6.3.14	<u>IF</u> filling accumulator tank D, <u>THEN</u> perform the following:	<u>NIT/DATE</u>
	1. Record initial Accumulator Tank D Level	
	from the highest reading indicator.	
	(N/A indicator not used) ¤	
	* EP LI-956	
	OR	
	* EP LI-957	
	2. Open Accumulator Tank D Fill Line Valve.	
	O EP HIS-8878D - OPEN	
	3. <u>WHEN</u> Accumulator Tank D Level is between 55% and 58% on the highest reading indicator <u>OR</u> as directed by SM/CRS <u>THEN</u> close Accumulator Tank D Fill Line Valve. (N/A indicator not used)	
	* EP LI-956-BETWEEN 55% AND 58%_OR AS	
	DIRECTED BY SM/CRS	
	OR	
	* EP LI-957-BETWEEN 55% AND 58%_OR AS	
	DIRECTED BY SM/CRS	
	AND	
	o EP HIS-8878D - CLOSED	
	4. Record change in accumulator tank D level.	
	o Final level - Initial level =% level change	
6.3.15	Close Accumulator Tanks Fill Line Valve.	
	o EM HIS-8888 - CLOSED	
6.3.16	Stop SI Pump A.	

Revision:	23
-----------	----

#### SAFETY INJECTION ACCUMULATOR OPERATIONS

Page 26 of 41

6.3.17	Direct Chemistry to sample accumulator	<u>INIT/DATE</u>
Д	boron concentration to ensure the	
	requirements of Tech. Spec.3.5.1 are meet prior to going above 1000 psig. ¤	,
6.3.18	Rack down SI Pump A breaker.	
	o NB0103 - RACKED DOWN Verified	· · · · · · · · · · · · · · · · · · ·
6.3.19	Place a Clearance Order on SI pump A.	
6.3.20	Turn on SI Pump A Discharge Accumulator Injection Isolation Valve EM HV-8821A breaker.	
	o NG01ADR1 - ON Verified	· · · · · · · · · · · · · · · · · · ·
6.3.21	Open SI Pump A Discharge To Cold Leg Injection Valve.	
	o EM HIS-8821A - OPEN Verified	· · · · · · · · · · · · · · · · · · ·
6.3.22	Section 6.3, Increasing Accum Level In Mode 4, 5, 6, Or Defueled Using SI Pump A, is complete.	
		,

Ц

Ц

Continuous Use

INIT/DATE

Ц

Ц

6.4 <u>Increasing Accum Level In Mode 4, 5, 6, Or Defueled Using SI</u> <u>Pump B</u>

NOTE

 $\[mu] \[mu] \[mu$ 

6.4.1	Ensure SI Pump A Discharge To Hot Leg Injection valve is closed.	
	o EM HIS-8802A - CLOSED	
6.4.2	Ensure Power Lockout For EM HV-8802A is in ISO.	
	o EM HIS-8802AA - IN ISO	
6.4.3	Ensure SI Pump B Discharge To Hot Leg Injection valve is closed.	
	o EM HIS-8802B - CLOSED	
6.4.4	Ensure Power Lockout For EM HV-8802B is in ISO.	
	o EM HIS-8802BA - IN ISO	
6.4.5	Ensure SI Pumps To Cold Leg Injection valve is closed.	
	o EM HIS-8835 - CLOSED	
6.4.6	Ensure Power Lockout For EM HV-8835 is in ISO.	
	o EM HIS-8835A - IN ISO	
6.4.7	Ensure SI Pump B Recirc To RWST isolation valve is open.	
	o EM HIS-8814B - OPEN	
6.4.8	Ensure SI Pumps Recirc To RWST isolation valve is open.	
	o BN HIS-8813 - OPEN	

Revision: 2
-------------

#### SAFETY INJECTION ACCUMULATOR OPERATIONS

Page 28 of 41

6 4 9	TE CI Dump diagharga reliaf valuag are	INIT/DATE
0.4.9 Д	<u>IF</u> SI Pump discharge reffer valves are	
	expected to lift on pump start, <u>THE</u> N Close	
	SI Pump B Disch to C/L Inj Iso Valve. ¤	
	(3.1.7) ¤	
	o EM HIS-8821B - CLOSED ¤	
6.4.10	Remove Clearance Order on SI pump B.	
6.4.11	Rack up SI Pump B breaker.	
	o NB0202 - RACKED UP	
6.4.12	Start SI Pump B.	
	o EM HIS-5 - STARTED	
6.4.13	<u>IF</u> closed to prevent discharge relief valve	2
Д	lift, <u>THEN</u> Open SI Pump A Disch to C/L Inj	
	Iso Valve. (3.1.7) ¤	
	o EM HIS-8821A - OPEN ¤	
6.4.14	Open Accumulator Tanks Fill Line Valve.	
	o EM HIS-8888 - OPEN	
6.4.15	<u>IF</u> filling accumulator tank A, <u>THE</u> N perform the following:	n
	1. Record initial Accumulator Tank A Level	-
	from the highest reading indicator.	
	(N/A indicator not used) ¤	
	* EP LI-950	
	OR	1
	* EP LI-951	
	2. Open Accumulator Tank A Fill Line Valve.	,
	0 EP HIS-8878A - OPEN	

-						$\sim$	-
RAV	п.	C.	٦.	$\cap n$	:	·)	~
	ж.	ο.	<b>-</b>		•	~	-

#### SAFETY INJECTION ACCUMULATOR OPERATIONS

SYS EP-200

Page 29 of 41

INIT/DATE 3. WHEN Accumulator Tank A Level is between 55% and 58% on the highest reading indicator, <u>OR</u> as directed by SM/CRS, THEN close Accumulator Tank A Fill Line Valve. (N/A indicator not used) * EP LI-950-BETWEEN 55% AND 58% OR AS Ц DIRECTED BY SM/CRS Ц * EP LI-951-BETWEEN 55% AND 58% OR AS Ц DIRECTED BY SM/CRS Ц AND O EP HIS-8878A - CLOSED  $\square$ 4. Record change in accumulator tank A level. o Final level - Initial level = % level change 6.4.16 <u>IF</u> filling accumulator tank B, <u>THEN</u> perform the following: Record initial Accumulator Tank B Level 1. Ц from the highest reading indicator. Ц (N/A indicator not used) Ц * EP LI-952 - _____ * EP LI-953 - ____ 1 2. Open Accumulator Tank B Fill Line Valve. O EP HIS-8878B - OPEN 

	Rev	ί	s	i	on	:	2	3
--	-----	---	---	---	----	---	---	---

#### SAFETY INJECTION ACCUMULATOR OPERATIONS

SYS EP-200

Page 30 of 41

	3.	<u>WHEN</u> Accumulator Tank B Level is between 55% and 58% on the highest reading indicator, <u>OR</u> as directed by SM/CRS, <u>THEN</u> close Accumulator Tank B Fill Line Valve. (N/A indicator not used)	INIT/DATE
		* EP LI-952-BETWEEN 55% AND 58% <u>O</u> R AS ¤ DIRECTED BY SM/CRS ¤	
		OR	
		* EP LI-953-BETWEEN 55% AND 58% <u>O</u> R AS ¤ DIRECTED BY SM/CRS ¤	
		AND	
		O EP HIS-8878B - CLOSED	
	4.	Record change in accumulator tank B level.	
		o Final level - Initial level =% level change	
6.4.17	<u>IF</u> the	filling accumulator tank C, <u>THE</u> N perform following:	'n
	1.	Record initial Accumulator Tank C Level	
	A	from the highest reading indicator. ¤ (N/A indicator not used) ¤	
		* EP LI-954	
		OR	,
		* EP LI-955	
	2.	Open Accumulator Tank C Fill Line Valve.	
		O EP HIS-8878C - OPEN	

P av	÷	c	÷	on	•	2	2
Rev	т	S	т	OII	•	4	С

#### SAFETY INJECTION ACCUMULATOR OPERATIONS

SYS EP-200

Page 31 of 41

INIT/DATE 3. WHEN Accumulator Tank C Level is between 55% and 58% on the highest reading indicator, <u>OR</u> as directed by SM/CRS, THEN close Accumulator Tank C Fill Line Valve. (N/A indicator not used) * EP LI-954-BETWEEN 55% AND 58% OR AS Ц DIRECTED BY SM/CRS Ц * EP LI-955-BETWEEN 55% AND 58% OR AS Ц DIRECTED BY SM/CRS Ц AND O EP HIS-8878C - CLOSED  $\square$ 4. Record change in accumulator tank C level. o Final level - Initial level = % level change 6.4.18 <u>IF</u> filling accumulator tank D, <u>THEN</u> perform the following: Record initial Accumulator Tank D Level 1. Ц from the highest reading indicator. Ц (N/A indicator not used) Ц * EP LI-956 - _____ * EP LI-957 - ____ 1 2. Open Accumulator Tank D Fill Line Valve. O EP HIS-8878D - OPEN 

Revi	sion	: 2	3
1001	0 - 0		-

#### SAFETY INJECTION ACCUMULATOR OPERATIONS

SYS EP-200

Page 32 of 41

	3. <u>WHEN</u> Accumulator Tank D Level is between 55% and 58% on the highest reading indicator <u>OR</u> as directed by SM/CRS, <u>THEN</u> close Accumulator Tank D Fill Line Valve. (N/A indicator not used)	<u>INII/DAIE</u>
	* EP LI-956-BETWEEN 55% AND 58%_OR AS	
	DIRECTED BY SM/CRS	
	OR	
	* EP LI-957-BETWEEN 55% AND 58%_OR AS	
	DIRECTED BY SM/CRS	
	AND	
	o EP HIS-8878D - CLOSED	
	4. Record change in accumulator tank D level.	
	o Final level - Initial level =% level change	
6.4.19	Close Accumulator Tanks Fill Line Valve.	,
	o EM HIS-8888 - CLOSED	
6.4.20	Stop SI Pump B.	
	O EM HIS-5 - STOPPED	
6.4.21	Direct Chemistry to sample accumulator boron concentration to ensure the requirements of Tech. Spec.3.5.1 are meet prior to going above 1000 psig.	·
6.4.22	Rack down SI Pump B breaker.	
	o NB0202 - RACKED DOWN Verified	·
6.4.23	Place a Clearance Order on SI pump B.	
6.4.24	Place Power Lockout For EM HV-8835 in NON ISO.	
	O EM HV-8835 - IN NON ISO	
6.4.25	Open SI Pumps To Cold Leg Injection valve.	

Verified

Rev	is	io	n:	23
v	- ~		**	

SAFETY INJECTION ACCUMULATOR OPERATIONS SYS EP-200

Page 33 of 41

								<u>INIT/DAT</u> E
6.4	.26	Place Por	wer Lock	cout For	EM HV	7-8835 in	ISO.	
		O EM HIS-	-8835A -	- IN ISO				
						Verified	£	/
6.4	.27	Section (	5.4, Inc	reasing	Accum	Level In	Mode	
		4, 5, 6,	Or Defi	leled Us	ing SI	Pump B, 3	is	
		combrete	•					,

#### SAFETY INJECTION ACCUMULATOR OPERATIONS

Page 34 of 41

#### <u>INIT/DATE</u> 6.5 Decreasing Accum Level Ц Ц NOTE Ц Ц Ц RCS pressure must be 100 psig greater than accumulator pressure µЦ prior to draining through the accumulator isolation valves. Ц Ц Ц 6.5.1 Check RCS pressure at least 100 psig greater than accumulator pressure. 6.5.2 IF decreasing level in accumulator tank A, THEN perform the following: Ensure Accumulator Tank A Outlet Valve 1. is open. O EP HIS-8808A - OPEN $\square$ 2. Open SI System Test Line Inner Containment Isolation Valve. O EM HIS-8871 - OPEN $\square$ Open SI System Test Line Outer 3. Containment Isolation Valve. O EM HIS-8964 - OPEN 4. Open Accumulator Tank A Upstream Test Valve. O EP HIS-8877A - OPEN $\square$ 5. WHEN desired accumulator tank A level is obtained, <u>THEN</u> close Accumulator Tank A Upstream Test Valve. O EP HIS-8808B - CLOSED 6.5.3 <u>IF</u> decreasing level in accumulator tank B, THEN perform the following: Ensure Accumulator Tank B Outlet Valve 1. is open. O EP HIS-8808B - OPEN Open SI System Test Line Inner 2. Containment Isolation Valve. O EM HIS-8871 - OPEN

R	<u>م</u> ر	i.	q	i.	οn	:	23
1/	C V	т.	Ð	т.	OII	•	

#### SAFETY INJECTION ACCUMULATOR OPERATIONS

Page 35 of 41

			INIT/DATE
	3.	Open SI System Test Line Outer Containment Isolation Valve.	
		O EM HIS-8964 - OPEN	
	4.	Open Accumulator Tank B Upstream Test Valve.	
		O EP HIS-8877B - OPEN	
	5.	<u>WHEN</u> desired accumulator tank B level is obtained, <u>THE</u> N close Accumulator Tank B Upstream Test Valve.	
		o EP HIS-8877B - CLOSED	
6.5.4	<u>IF</u> THE	decreasing level in accumulator tank C, <u>N</u> perform the following:	
	1.	Ensure Accumulator Tank C Outlet Valve is open.	
		O EP HIS-8808C - OPEN	
	2.	Open SI System Test Line Inner Containment Isolation Valve.	
		O EM HIS-8871 - OPEN	
	3.	Open SI System Test Line Outer Containment Isolation Valve.	
		O EM HIS-8964 - OPEN	
	4.	Open Accumulator Tank C Upstream Test Valve.	
		O EP HIS-8877C - OPEN	
	5.	<u>WHEN</u> desired accumulator tank C level is obtained, <u>THE</u> N close Accumulator Tank C Upstream Test Valve.	
		o EP HIS-8877C - CLOSED	
6.5.5	<u>IF</u> THE	decreasing level in accumulator tank D, <u>N</u> perform the following:	
	1.	Ensure Accumulator Tank D Outlet Valve is open.	
		O EP HIS-8808D - OPEN	

I	Revision: 23			SY	S EI	P-2	00
(	Continuous Use		OPERATIONS	Page	36	of	41
						/ I	
		2.	Open SI System Test Line Inner Containment Isolation Valve.			<u> </u>	<u>)A'I'E</u>
			o EM HIS-8871 - OPEN				
		3.	Open SI System Test Line Outer Containment Isolation Valve.				
			o EM HIS-8964 - OPEN				
		4.	Open Accumulator Tank D Upstream T Valve.	ſest			
			o EP HIS-8877D - OPEN				
		5.	<u>WHEN</u> desired accumulator tank D le is obtained, <u>THEN</u> close Accumulato Tank D Upstream Test Valve.	evel or			
			o EP HIS-8877D - CLOSED				
	<i>ዹ፼፟፼፟፼፼፼፼፼፼፼፼፼፼</i>	ኇ፟ኇ፟ኇ	<i>๛๎๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛๛</i>	>\$\$ \$\$ \$\$ \$\$	ゆゆん	ঽ৵৻৾	৽৵৵৵
$\phi\phi\phi\phi\phi\phi\phi\phi$	ヹ ヹ ゚ <i>ŶŔŔŔŔŔŔŔŔŔ</i> Ŕ	\$ <i>\$\$\$</i>	>收也 <u>NOTE</u>				Ц
	H Closing the Isolation V RHR dischar	SI I alves ge re	Test Line Outside And Inside Contai s may increase RHR System pressure elief valve to lift.	nment causi	: Ing	the	пппп
<i>\$\$\$\$\$\$\$\$\$</i> \$ ( (	҅҂ <i>ѷҞѷҞѷҞ</i> ҂Ҟ҂҂҂ ҈ <i>ҼҞѵѽѵѽѵ</i> ҂ п	\$ <i>\$\$\$</i> \$ \$\$ \$\$	^{&gt;} ዾ፞፞፞፞፞ ዾ፟ዾ፟ዾ ዾ፟ዾ፟ዾ፟ዾ፟ዾዾ፟ዾዾዾዾዾዾዾዾዾዾዾዾዾዾዾ	> <i>\$</i> \$\$\$	かかん	ঽ৻ঽ৻৻	> <i>&amp;&amp;&amp;</i> 1 1
	6.5.6	<u>IF</u> Out	desired, <u>THEN</u> close SI System Test er Containment Isolation Valve.	Line			
		o El	M HIS-8964 - CLOSED				
	6.5.7	<u>IF</u> Inne	desired, <u>THEN</u> close SI System Test er Containment Isolation Valve.	Line			
		o El	M HIS-8871 - CLOSED				
	6.5.8	<u>IF</u> inl acc	accumulator level was lowered due t eakage, <u>THEN</u> direct Chemistry to sa umulators for boron concentration.	co ample			
	6.5.9	Sec comj	tion 6.5, Decreasing Accum Level, s plete.	is			
					,		

Revision: 23

Continuous Use

#### SAFETY INJECTION ACCUMULATOR OPERATIONS

Page 37 of 41

6.6	Increasi	ing Accum Pressure	<u>INIT/DATE</u>
	6.6.1	Ensure $N_2$ pressure regulator at $N_2$ skid is set at 700 psig.	
	6.6.2	Ensure Accumulator $N_2$ Supply Vent Valve Control is closed.	
		o EP HC-943 - CLOSED	
	6.6.3	<u>IF</u> increasing accumulator tank A pressure, <u>THEN</u> perform the following:	
		1. Open Accumulator Tank $N_2$ Supply Valve.	
		o EP HIS-8875A - OPEN	
		2. Open Accumulator Tanks $N_2$ Supply Valve.	
		O EP HIS-8880 - OPEN	
		<ol> <li><u>WHEN</u> desired pressure is obtained, <u>THEN</u> close Accumulator Tanks N₂ Supply Valve.</li> </ol>	I
		O EP HIS-8880 - CLOSED	
		4. Close Accumulator Tank $N_2$ Supply Valve.	
		o EP HIS-8875A - CLOSED	
	6.6.4	<u>IF</u> increasing accumulator tank B pressure, <u>THEN</u> perform the following:	
		1. Open Accumulator Tank $N_2$ Supply Valve.	
		O EP HIS-8875B - OPEN	
		2. Open Accumulator Tanks $N_2$ Supply Valve.	
		O EP HIS-8880 - OPEN	
		<ol> <li><u>WHEN</u> desired pressure is obtained, <u>THEN</u> close Accumulator Tanks N₂ Supply Valve.</li> </ol>	Ţ
		o EP HIS-8880 - CLOSED	
		4. Close Accumulator Tank $N_2$ Supply Valve.	
		O EP HIS-8875B - CLOSED	

D	- 2				<u> </u>	
Rev	71	Sl	on	•	Ζ.	3

### SAFETY INJECTION ACCUMULATOR OPERATIONS

Page 38 of 41

6.6.5	<u>IF</u> :	increasing accumulator tank C pressure,	<u>INIT/DATE</u>
	1001		
	1.	Open Accumulator Tank $N_2$ Supply Valve.	
		O EP HIS-8875C - OPEN	
	2.	Open Accumulator Tanks $N_{\rm 2}$ Supply Valve.	
		O EP HIS-8880 - OPEN	
	3.	<u>WHEN</u> desired pressure is obtained, <u>TH</u> EN close Accumulator Tanks N ₂ Supply Valve.	
		o EP HIS-8880 - CLOSED	
	4.	Close Accumulator Tank $N_2$ Supply Valve.	
		o EP HIS-8875C - CLOSED	
6.6.6	<u>IF</u> : <u>THE</u> I	increasing accumulator tank D pressure, <u>N</u> perform the following:	
	1.	Open Accumulator Tank $N_2$ Supply Valve.	
		O EP HIS-8875D - OPEN	
	2.	Open Accumulator Tanks $N_2$ Supply Valve.	
		O EP HIS-8880 - OPEN	
	3.	<u>WHEN</u> desired pressure is obtained, <u>TH</u> EN close Accumulator Tanks N ₂ Supply Valve.	
		o EP HIS-8880 - CLOSED	
	4.	Close Accumulator Tank $N_2$ Supply Valve.	
		o EP HIS-8875D - CLOSED	
6.6.7	Sec comj	tion 6.6, Increasing Accum Pressure, is plete.	
			1

Rev	is	i	on	:	2	3

#### SAFETY INJECTION ACCUMULATOR OPERATIONS

Page 39 of 41

6.7	Decreasi	ing Accum Pressure	<u>INIT/DATE</u>
0.,	Deereas		
	6.7.1	Ensure Accumulator $N_2$ Supply Vent Valve Control is set at 0%.	
		o EP HC-943 - SET AT 0%	
	6.7.2	Ensure Accumulator Tanks $N_2$ Supply Valve is closed.	3
		o EP HIS-8880 - CLOSED	
	6.7.3	<u>IF</u> decreasing accumulator tank A pressure, <u>THEN</u> perform the following:	
		1. Open Accumulator Tank $N_2$ Supply Valve.	
		o EP HIS-8875A - OPEN	
		2. Slowly throttle open Accumulator $N_2$ Supply Vent Valve Control.	
		O EP HC-943 - SLOWLY THROTTLED OPEN	
		<ol> <li><u>WHEN</u> desired accumulator pressure is obtained, <u>THEN</u> close Accumulator Tank N₂ Supply Valve.</li> </ol>	
		o EP HIS-8875A - CLOSED	
		4. Close Accumulator $N_2$ Supply Vent Valve Control.	
		o EP HC-943 - CLOSED	
	6.7.4	<u>IF</u> decreasing accumulator tank B pressure, <u>THEN</u> perform the following:	
		1. Open Accumulator Tank $N_2$ Supply Valve.	
		O EP HIS-8875B - OPEN	
		2. Slowly throttle open Accumulator $N_2$ Supply Vent Valve Control.	
		O EP HC-943 - SLOWLY THROTTLED OPEN	
		<ol> <li><u>WHEN</u> desired accumulator pressure is obtained, <u>THEN</u> close Accumulator Tank N₂ Supply Valve.</li> </ol>	
		o EP HIS-8875B - CLOSED	

<b>D</b> -					0 0
Rev	18	51	on	:	23

Page 40 of 41

			INIT/DATE
	4.	Close Accumulator $N_2$ Supply Vent Valve Control.	
		o EP HC-943 - CLOSED	
6.7.5	<u>IF</u> THE	decreasing accumulator tank C pressure, <u>N</u> perform the following:	
	1.	Open Accumulator Tank $N_2$ Supply Valve.	
		O EP HIS-8875C - OPEN	
	2.	Slowly throttle open Accumulator $N_2$ Supply Vent Valve Control.	
		O EP HC-943 - SLOWLY THROTTLED OPEN	
	3.	<u>WHEN</u> desired accumulator pressure is obtained, <u>THE</u> N close Accumulator Tank N ₂ Supply Valve.	
		o EP HIS-8875C - CLOSED	
	4.	Close Accumulator $N_2\ $ Supply Vent Valve Control.	
		o EP HC-943 - CLOSED	
6.7.6	<u>IF</u> THE	decreasing accumulator tank D pressure, <u>N</u> perform the following:	
	1.	Open Accumulator Tank $N_2$ Supply Valve.	
		O EP HIS-8875D - OPEN	
	2.	Slowly throttle open Accumulator $N_2$ Supply Vent Valve Control.	
		O EP HC-943 - SLOWLY THROTTLED OPEN	
	3.	<u>WHEN</u> desired accumulator pressure is obtained, <u>THE</u> N close Accumulator Tank N ₂ Supply Valve.	
		o EP HIS-8875D - CLOSED	
	4.	Close Accumulator $N_2\ $ Supply Vent Valve Control.	
		o EP HC-943 - CLOSED	
6.7.7	Sec com	tion 6.7, Decreasing Accum Pressure, is plete.	

Revision: 23

Continuous Use

## 7.0 <u>RECORDS</u>

- 7.1 The following QA records are generated by this procedure:
  - 7.1.1 Section 5.0
  - 7.1.2 Section 6.0

-END-

TASK: Restore Charging after a loss of CCP(ASP)		
SAFETY FUNCTION: #2		
TASK #: 00400028		
K/A #s: 004 A1.04, 06,07,08; A2.02, 07,11,22; A3.02,09,10,11,	,14; A4.05, 06,08,11.	
References: SYS BG-201, Rev. 35; ALR 00-042A, Rev. 10; ALR 00-042	E, Rev. 8; SYS BG-120, Rev. 27	
Examinee's Name S	SS No	SRORO
The examinee's performance was evaluated against the standards in thi	is JPM and determined to be :	
SATISFACTORY UNSATISFACTORY		
Reason if UNSATISFACTORY:		
Estimated JPM completion Time: 30 min.		
Actual Performance Time:min.		
Location of Performance: Control Room SimulatorX	_ Plant	
Method of Performance: Simulate Perform X		
Tools and Equipment: Simulator		
Evaluators Signature:	I	Date

Notes:

BOOTH INSTRUCTIONS: Simulator setup: IC 177 RUN HORN: *On* BAT JPM026a.txt

EVALUATOR:

Provide the GREEN "Information Only" copy of SYS BG-201 to Examinee.

* Denotes a Critical Step

Initial Conditions:

You are the Reactor Operator, the plant is stable in Mode 3.

Initiating Cues:

The Control Room Supervisor directs you to start the "B" CCP and secure the NCP to support maintenance on the NCP next shift. Initial conditions of SYS BG-201 are complete.

Provide the GREEN "Info Only" copy of SYS BG-201 to the examinee.

Element #	Step #	Element	Standard	Score
1.	6.2.1	Start Time Verify CCP Flow Control BG FK-121, is in MANUAL and set at 20%.	Locate BG FK-121 on RL001. Depress the MANUAL P/B. Depress either the INCREASE or DECREASE button until the output reads 20% OPEN.	S U

Cue:

#### Comments:

2.	6.2.2	Verify CCP B Recirc Valve is OPEN.	Locate BG HIS-8111 on RL001. Verify the Red light is lit.	S U
		• BG HV-8111 OPEN		

Cue:

#### Comments:

3.	6.2.3	Verify CCW is being supplied to CCP B.	Locate EG HIS-22 and EG HIS-24 on RL019. START or verify CCW pump B or D running by the Red light lit on the bandswitch	S U
			by the Red light lit on the handswitch.	

Cue:

Booth Instruction: If Aux. Bldg. Operator is contacted, acknowledge request and report "CCW is lined up to CCP "B".

Comments:

4.	6.2.4	IF RCS temperature is greater than or equal to 200°F, THEN ensure CCP A discharge header FCV-121 inlet isolation valve is locked closed.	Contact the Aux Watch to verify BG-V8483A is locked closed.	S U
		BG-V8483A - LOCKED CLOSED		

Cue:

Booth Instruction: Report as the Aux Watch that "BG-V8483A is locked closed".

### Comments:

* Denotes Critical Step

Element #	Step #	Element	Standard	Score
5.	6.2.5	Lock open CCP B discharge Header FCV-121 Inlet Isolation valve.	Contact Aux. Bldg. Operator, verify the status of BG-V8483C.	S U
		• BG V8483C OPEN		

Cue:

## Booth Instructions: Acknowledge direction, report "BG-V8483C is open."

Comments:

6.	6.2.6	Ensure CCP B Aux. Lube Oil Pump in AUTO.	Locate BG HIS-2AX on RL001. Verify the	S U
		• BG HIS-2AX IN AUTO	switch in A010 and the Ked light ht.	

Cue:

#### Comments:

7.*	6.2.7	Start CCP B (PBG05B).	Locate BG HIS-2A on RL001. Start the pump	S U
		• BG HIS-2A STARTED	light comes on and the Green light goes out. Verify a flow increase on BG FI-121 (located on	
			RL002).	

Cue:

Comments:

Comments:

8.*	6.2.8	Place NCP Flow Controller in MANUAL.	Locate BG FK-462 on RL001. Depress the MANUAL P/B. Verify the MANUAL P/B is	S U
		• BG FK-462 IN MANUAL	lit.	

Cue:

Comments:

* Denotes Critical Step

Element #	Step #	Element	Standard	Score
9.*	6.2.9	<ul> <li>Slowly close NCP Discharge Flow Control valve to 20% while maintaining a constant charging header flow by performing the following simultaneously:</li> <li>Lower NCP Discharge Flow Controller to 20% output using BG FK-462</li> <li>Adjust CCP flow control valve as necessary to maintain a constant charging header flow using , BG FK-121.</li> </ul>	Push the LOWER P/B on BG FK-462 while pushing the RAISE P/B on BG FCV-121. Try to maintain a constant flow on BG FI-121.	S U

Cue:

Comments:

10.*	6.2.10	<ul> <li>When the NCP Discharge Flow Controller is at 20%, THEN stop the NCP.</li> <li>BG HIS-3 STOPPED</li> </ul>	Monitor BG FK-462, when the output reads 20%, turn BG HIS-3 (located on RL001) to OFF. Verify the Green light comes on and the Red light goes out	S U
------	--------	--------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------	-----

Cue:

Comments:

.

11.	6.2.11	Verify NCP Discharge Flow Controller in MANUAL with 20% output.	Same as element.	S U
		• BG FK-462 - MANUAL AT 20%		

Cue: Second Verification will be performed later.

Comments:

* Denotes Critical Step

## NOTE: If the CCP trips before steps 6.2.12 through 6.2.16 (elements 12 to 16) are performed, circle N/A for score.

Element #	Step #	Element	Standard	Score
12.	6.2.12	<ul><li>Adjust CCP flow control valve as necessary to maintain PZR level at program value.</li><li>BG FK-121 ADJUSTED</li></ul>	Locate BG FK-121 on RL001. Adjust the controller as necessary to obtain the desired flow on BG FI-121.	S U N/A

Cue:

### Comments:

13.	6.2.13	Adjust the charging header backpressure control valve as necessary to maintain RCP Seal Injection Flow between 8 and 13 gpm. N/A if not required.	Locate BG HC-182 on RL001. Adjust the pot to maintain 8 -13 gpm as indicated on BG FR-154, BG FR-155, BG FR-156, BG FR- 157 on RL022.	S U N/A
		WA II not required.	137 011 KL022.	

Cue:

#### Comments:

14.	6.2.14	OPEN CCP B discharge PI-119 isolation valve.	Direct Aux. Bldg. Operator to open BG-V094.	S U
		• BG V094 – OPEN		N/A

Cue:

### Booth Instructions: Report, "BG-V094 is open".

Comments:

15.	6.2.15	Close NCP Discharge PI-463 Isolation valve.	Contact the Aux Watch to close BG-V803.	S U
		• BG-V803 - CLOSED		N/A

Cue:

## Booth Instructions: Report, "BG-V803 is closed".

Comments:

16.	6.2.16	Close NCP Discharge PI-117 Isolation valve.	Contact the Aux Watch to close BG-V014.	S U
		• BG-V014 - CLOSED		N/A

Cue:

Booth Instructions: Report, "BG-V014 is closed".

Comments:
Element #	Step #	Element	Standard	Score
17.	N/A	Acknowledge and Report alarms.	Depress ANN ACK P/B. Ann. 42E will alarm first followed closely by 042A.	S U N/A
Cue:				
Comment	s:			
18.	N/A	Report CCP "B" trip to CRS.	Report CCP B has tripped.	S U
Cue:	Re	port Acknowledged, respond per ALR's.		
Comment	s: Ha	ve the examinee choose the appropriate ALR.		
19.	N/A	Refer to alarm responses.	ALR 00-042A and/or ALR 00-042E.	S U NA
Cue:				
Comment	s:			

# NOTES: For ALR 00-042A proceed to JPM Element 20, page 8. For ALR 00-042E proceed to JPM Element 21, page 13.

# N/A All of step 20 and go to page 13 if Examinee chose ALR 00-042E.

Element #	Step #	Element	Standard	Score
20.	N/A	ALR 00-042A, CHARGING FLOW HI/LO	Complete elements 20a through 21h.	N/A

Cue:

Comments:

20a.	1.	<ul><li>Check Charging header flow - Greater Than 150 gpm.</li><li>BG FI-121A</li></ul>	Locate BG FI-121A on RL001. Check if flow is greater than 150 gpm and verifies that flow is 0 gpm.	S U

Cue:

Comments: Examinee should go to step 5 per the RNO.

20a.1	1. GO TO STEP 5. RNO	Same as element.	S U
-------	-------------------------	------------------	-----

Cue:

Comments:

20b.	5.	Check if Charging header flow - Less Than 45 gpm.	Check if flow is less than 45 gpm on BG FI- 121A. Recognize that in previous step flow was 0 gpm.	S U
		• BG FI-121A		

Cue:

Comments:

Element #	Step #	Element	Standard	Score
20с.	6.	<ul> <li>Check Charging Pumps - ANY RUNNING.</li> <li>BG HIS-1A for CCP A</li> <li>BG HIS-1B for CCP B</li> </ul>	Recognize that since the NCP was secured and the CCP tripped that no charging pumps are running and go to the RNO.	S U
		• BG HIS-3 for NCP		

Cue:

# Comment:

20c.1.*	6.	Close Letdown Orifice Isolate valves.	Locate BG HIS-8149AA, 8149BA, 8149CA on	S U
	RNO a.	• BG HIS-8149AA	RL001. Depress the CLOSE P/B(s). Verify the Green lights come on and the Red light(s)	
		• BG HIS-8149BA	go off.	
		• BG HIS-8149CA		

## Cue:

## Comments:

20c.2*	6. DNOb	Start any available charging pump.	Start the NCP.	C II
		• BG HIS-1A for CCP A		30
		• BG HIS-1B for CCP B		
		• Start NCP		

Cue:

#### Comments:

20d.	<ul><li>7. Check PZR level - AT PROGRAM VALUE.</li><li>BB LR-459</li></ul>	7.	Locate BB LR-459 on RL002 and verify that PZR is NOT at PROGRAM VALUE.	S U
------	----------------------------------------------------------------------------	----	------------------------------------------------------------------------	-----

#### Cue:

Comments: Examinee should recognize that with no letdown PZR level will slowly increase and go to the RNO for step 7 to establishing letdown.

Element #	Step #	Element	Standard	Score
20d.2	7. RNO a.	Place running charging pump flow controller in manual and adjust charging flow as necessary to establish PZR level at program value.	Place BG FK-462 in manual and control charging flow to establish PZR level at program.	S U

Cue:

Comments:

20d.2	7. RNO b.	Establish desired letdown by performing step 6.5 of SYS BG-120.	Complete elements 20d.2(a) through 20d.2(d)	N/A
-------	-----------------	--------------------------------------------------------------------	---------------------------------------------	-----

# Comments:

20d.2(a)	6.5.1	Ensure PZR level greater than 17%.	Locate BB LR-459 on RL002. Verify level greater than 17%.	S U
----------	-------	------------------------------------	-----------------------------------------------------------	-----

Cue:

# Comments:

20d.2(b)	6.5.2	Ensure letdown hx outlet temperature control valve is in AUTO.	Locate BG TK-130 on RL001. Verify controller is automatic.	S U
		• BG TK-130 - IN AUTO		

Cue:

Comments:

20d.2(c)	6.5.3	IF RCS to letdown regen hx valves, BG HIS- 459 and BG HIS-460, are open, THEN perform the following:	Recognize that BG HIS-459 and 460 are open. Complete elements 20d.2(c)1 and 20d.2(c)6.	N/A
----------	-------	------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------	-----

Cue:

Comments:

20d.2(c) 1*	6.5.3.1	Place letdown hx outlet pressure controller in manual.	Locate BG PK-131 on RL001. Depress the Manual P/B.	S U
		• BG PK-131 - IN MANUAL		

Cue:

Comments: Critical Step to ensure Relief on Letdown Line does not lift.

Element #	Step #	Element	Standard	Score
20d.2(c) 2*	6.5.3.2	Adjust letdown hx outlet pressure controller to between 90% and 100%.	Same as element.	S U

Cue:

# Comments: Critical Step to ensure Relief on Letdown Line does not lift.

20d.2(c) 3*	6.5.3.3	Open letdown orifice isolation valves as	Open BG HIS-8149AA and 8149BA or CA to establish 120 gpm letdown	S U
5		necessary to establish desired fetdown.	establish 120 gpin letaown.	

## Cue: If examinee asks, "Desired letdown is 120 gpm."

#### Comments:

20d.2(c) 4	6.5.3.4	Adjust letdown hx outlet pressure controller to obtain 350 psig.	Using the decrease P/B close BG PV-131 to increase backpressure to 350 psig.	S U
		• BG PK-131 - ADJUSTED TO 350 psig		

Cue:

## Comments:

20d.2(c) 5*	6.5.3.5	Place letdown hx outlet pressure controller in AUTO.	Depress the AUTO P/B.	S U
		• BG PK-131 - IN AUTO		

Cue:

Comments:

20d.2(c) 6*	6.5.3.6	IF NCP is running, THEN place the NCP discharge flow controller in Automatic as directed by the SM/CRS.	Ask CRS if BG FK-462 should be placed in automatic.	S U
----------------	---------	---------------------------------------------------------------------------------------------------------	-----------------------------------------------------	-----

### Cue: *"Place BG FK-462 in automatic after Charging and letdown are matched."*

Comments:

Element #	Step #	Element	Standard	Score
20d.2(d)	6.5.4	IF RCS to letdown regen hx isolation valves, BG HIS-459 and BG HIS-460 are closed, THEN perform the following:	Recognize that BG HIS-459 and BG HIS-460 were open. This Step is N/A.	S U

Cue:

Comments:

20e.	8.	Check Letdown Hx Outlet Temperature - LESS THAN 130°F. • BG TI-130	Locate BG TI-130 on RL002. Check temperature less than 130°F.	S U N/A
------	----	--------------------------------------------------------------------------	---------------------------------------------------------------	------------

Cue:

Comments:

20f.	9.	Check charging header flow and letdown flow - BALANCED.	Check the flow indicators to see if charging and letdown are balanced.	S U
				N/A

Cue: When the examinee has balanced charging and letdown – terminate the JPM.

Comments:

Termination: Balancing charging and letdown completes the JPM.

Stop Time ____

# N/A THE FOLLOWING (SECTION 21) STEPS IF ALR 00-42A WAS PERFORMED

# Element 21 is for ALR 00-042E, N/A if Examinee uses ALR 042A.

Element #	Step #	Element	Standard	Score
21	N/A	ALR 00-42E CHARGING PUMP TROUBLE	Complete Elements	N/A

Comments: This section will be used if the examinee chooses ALR 00-042E

21a.	1.	Place the affected Charging Pump in Pull-To- Lock Position	Examinee places CCP B in Pull-To-Lock	S U

Cue:

# Comments:

21b.	2.	Check Charging Pumps – NONE RUNNING	Examinee verifies that NO Charging Pumps	S U		
		• BG HIS-1A for CCP A	are now running.			
				• BG HIS-2A for CCP B		
		• BG HIS-3 for NCP				

Cue:

### Comments:

21c.*	3.	Close Letdown Orifice Isolation Valves	Examinee closes Letdown Orifice Isolation	S U
		• BG HIS-8149AA		
		• BG HIS-8149BA	• BG HIS-8149AA	
		• BG HIS-8149CA	• BG HIS-8149BA	
			• BG HIS-8149CA	

Cue:

Comments:

21d.*	4. Establish Charging Flow by Starting the NCP using BG HS-3.	Examinee must recognize that CCP "B" was aligned for normal charging and that the Normal Charging Pump (NCP) is required and is then started.	S U
-------	---------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------	-----

Cue:

Comments: Examinee must realize that CCP "B" is not available and the NCP must be aligned.

Element #	Step #	Element	Standard	Score
21e.	5.	Ensure RCP Seal Injection – BETWEEN 8 GPM AND 13 GPM TO EACH RCP	Examinee observes proper Seal Injection flows on all 4 RCPs.	S U
		BG FR-157 for RCP A		
		BG FR-156 for RCP B		
		BG FR-155 for RCP C		
		BG FR-154 for RCP D		

Cue:

Comments:

21d.	6.	Reestablish Letdown:	Complete elements 21d.1 through 21d.6	N/A

## Comments:

21d.1	6.a	Check RCS Letdown To Regen HX valves open	Examinee checks BG HIS-459 and BG HIS-460 are OPEN.	S U
		BG HIS-459		
		BG HIS-460		

Cue:

Comments:

21d.2*	6.b	Place Letdown HX Outlet Pressure Control in Manual	Examinee places BG PK-131 in Manual	S U
		• BG PK-131		

Comments:

21d.3*	6.c	Open Letdown HX Outlet Pressure Control between 90% and 100% • BG PK-131	Examninee Opens Letdown HX Outlet Pressure Controller, BG PK-131, to between 90% and 100%.	S U

Comments:

21d.4*	6.d	Open desired Letdown Orifice Isolation Valve(s):	Examinee Opens BG HIS-8149A and 8149BA or 8149CA.	S U
		• BG HIS-8149AA		
		• BG HIS-8149BA		
		• BG HIS-8149CA		

#### Comments:

21d.5*	6.e	Adjust Letdown HX Outlet Pressure Control to establish Letdown HX Outlet Pressure between 340 psig and 360 psig	Using the decrease P/B closes BG PV-131 to increase backpressure to 340 – 360 psig.	S U
		• BG PI-131		

#### Comments:

21d.6*	6.f	Place Letdown HX Outlet Pressure Control in Auto	Depresses the Auto Pushbutton	S U
		• BG PK-131		

#### Comments:

21e.	7.	Check Charging Header Flow And Letdown Flow -BALANCED	Adjusts charging and letdown as necessary to maintain PZR level at program value.	S U

Cue: When the examinee has balanced charging and letdown - terminate the JPM.

#### Comments:

Termination: Balancing charging and letdown completes the JPM.

Stop Time ___

Initial Conditions:

You are the Reactor Operator, the plant is stable in Mode 3.

Initiating Cues:

The Control Room Supervisor directs you to start the "B" CCP and secure the NCP to support maintenance on the NCP next shift. Initial conditions of SYS BG-201 are complete.

Notes:

If you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.



ALR 00-042A

CHG LINE FLOW HILO

Responsible Manager

Manager Operations

	₳₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡₡	<i>\$\$\$\$\$\$\$\$\$</i>	₲₳₳₯₽₳₽₽
$\langle \langle \langle \langle \rangle \rangle \rangle \langle \langle \langle \rangle \rangle \rangle \langle \langle \rangle \rangle \rangle$	¤ Revision Number ታሌሌሌሌሌሌሌሌሌሌሌሌሌሌሌሌሌሌሌ	口 10 555555555555555555555555555555555555	ዽዽኇዏዸኇዸዸ ᠴ
₶₶₶₶₶₶₶₶			
	보 Use Category	Ц	Continuous
	፟ ዄ፼ኯ፟ዸኯ፟፟፟ ዀ፟፟፟ ዀ፟፟፟ ዀ፟፟ ዾ፟ዀ ዾ፟፟ ዾ፟ዀ ዾ፟ ዾ፟ ዾ፟ ዾ ዾ ዾ ዾ	₽₽₽₽₽₽₽₽₽	<i>₠₠₦₽₽</i> ₽₽₽₽
₶₶₶₶₶₶₶₶			
	Administrative Controls Procedure	REREREE I NO	<i>₽</i>
₢₢₢₢₢₢	* * * * * * * * * * * * * * * * * * * *	* * * * * * * *	* * * * * * * *
	부 Infrequently Performed Procedure 상동동동동동동동동동동동동동동동동동동동동동동동동동동동동동동동동동동동동	L NO NO	<i>₠₠₠₡₠₠₠</i> ₽ ¤
<i>₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽₽</i>			
	۲ Program Number ۳۵ Ա Ա Ա Ա Ա Ա Ա Ա Ա Ա Ա Ա Ա Ա Ա Ա Ա Ա Ա	T 21A LUUUUUUUU	$\mathcal{R}$
₲₲₲₲₲₲₲		$\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$ $\checkmark$	$\gamma \gamma \gamma \odot \gamma \gamma \gamma \gamma \gamma$

DC4 10/03/2000

Continuous Use

#### 1.0 <u>PURPOSE</u>

1.1 This procedure provides instructions for responding to actuation of alarm window 00-042A, CHG LINE FLOW HILO.

#### 2.0 <u>SYMPTOMS OR ENTRY CONDITIONS</u>

- 2.1 This procedure is entered when the following occurs:
  - * Charging header flow is greater than or equal to 150 gpm.

o BG FB-121A

* Charging header flow is less than or equal to 45 gpm.

o BG FB-121B

#### 3.0 <u>REFERENCES AND COMMITMENTS</u>

- 3.1 <u>References</u>
  - a. Total Plant Setpoint Document
  - b. EN 93-0170
  - c. CCP 6578, Low Flow Cavitation
  - d. PMR 4590, PDP Replacement
- 3.2 <u>Commitments</u>

Revisi	on: 10	CHG LINE FLOW HILO		ALR 00-042A
Contin	uous Use	CHG LINE FLC	JW HILO	Page 2 of 4
STE -	ACTION	/EXPECTED	RESPONSE NOT	
1.	Check Ch GREATER	harging Header Flow - THAN 150 GPM	Go to Step 5.	1
	o BG FI-	-121A		
2.	Verify a plant co	alarm is <u>NO</u> T due to ooldown.	Return to proc in effect.	edure and step
3.	Check PZ	KR Level - AT PROGRAM	Perform the fo	llowing:
	O BB LR-	-459	a. <u>IF</u> level le program, <u>TH</u> OFN BB-007, HIGH, Step OFN BB-07A, GENERATOR T Step 1.	ss than <u>EN</u> go to RCS LEAKAGE 1 <u>OR</u> STEAM UBE LEAKAGE
			b. <u>IF</u> level gr program, <u>TH</u> running cha controller decrease ch necessary t level at pr	eater than EN place rging pump flow in manual and arging flow as o establish PZR ogram value.
			* BG FK-121 * BG FK-462	for CCP for NCP
4.	Go To St	cep 9		
5.	Check Ch LESS THA	harging Header Flow - AN 45 GPM	Notify I&C to of alarm <u>AND</u> R procedure and	determine cause eturn to step in effect.
	o BG FI-	-121A	1	

Revisi	.on: 10	CUC ITNE E	CHG LINE FLOW HILO	
Contin	uous Use	CHG LINE F	LOW HILO	Page 3 of 4
STE	ACTION	/EXPECTED	RESPONSE NC	T
6.	Check Ch RUNNING * BG HIS * BG HIS * BG HIS	harging Pumps - ANY S-1A for CCP A S-2A for CCP B S-3 for NCP	Perform the f a. Close Letd Isolation o BG HIS-8 o BG HIS-8 o BG HIS-8 b. Start any charging p * Start ei * BG HIS * BG HIS <u>OR</u> * Start NC	ollowing: own Orifice valves. 149AA 149BA 149CA available ump: ther CCP. -1A for CCP A -2A for CCP B
7.	Check PZ VALUE O BB LR-	2 <b>R Level - AT PROGRAM</b> -459	o BG HIS Perform the f a. Place runn pump flow manual and flow as ne establish program va * BG FK-12 * BG FK-46 b. Establish by perform in SYS BG- VOLUME CON STARTUP.	-3 ollowing: ing charging controller in adjust charging cessary to PZR level at lue. 1 for CCP 2 for NCP desired letdown ing section 6.5 120 CHEMICAL <u>AND</u> TROL SYSTEM
8.	Check Le Outlet T THAN 130 o BG TI-	etdown Heat Exchanger Temperature - LESS )°F -130	Bypass CVCS d o BG HIS-129	emineralizers.
9.	Check Ch And Letc	narging Header Flow down Flow - BALANCED	Adjust chargi as necessary level at prog	ng and letdown to maintain PZR ram value.

	Revision: 10	CUC IINE FION HILO	ALR 00-042A	
	Continuous Use	Pa	age 4 of 4	
1	STE ACTION	/EXPECTED RESPONSE NOT		_

ADAMAT

Ц	NOTE	Ц
Ц		Ц
Ц	Total pump flow should be maintained above 175 gpm to minimize	Ц
Ц	the effects of low flow cavitation.	Ц
Ц		Ц

10.	Verify CCP Adequate Flow:	
	a. Check CCPs - ANY RUNNING	a. Go to Step 11.
	* BG HIS-1A for CCP A * BG HIS-2A for CCP B	
	b. Check CCP Recirc Valve - OPEN	b. Manually open CCP Recirc valve.
	* BG HIS-8110 for CCP A * BG HIS-8111 for CCP B	* BG HIS-8110 for CCP A * BG HIS-8111 for CCP B
11.	Return To Procedure And Step In Effect	
	-END-	

TASK: Startup the 'A' RHR Train							
Task#: 00500003							
SAFETY FUNCTION: SF4							
K/A's: A1.01; A2.02,2.03; A4.01							
References: SYS EJ-120, Rev. 39							
Examinee's Name RO	SS No	SRO					
The examinee's performance was evaluated against the standards in this JPM a	nd determined to be :						
SATISFACTORY UNSATISFACTORY							
Reason, if UNSATISFACTORY:							
Estimated JPM completion Time: <u>12</u> min.							
Actual Performance Time:min.							
Location of Performance: Simulator X							
Method of Performance: Perform <u>X</u>							
Tools and Equipment: Simulator							
Evaluators Signature:		Date					

Notes:

BOOTH INSTRUCTIONS: Simulator set-up: IC 177 RUN

EVALUATOR: Provide **GREEN** Copy of SYS EJ-120 to Examinee.

Initial Conditions: You are the Reactor Operator, the plant is in Mode 3.

Initiating Cues:

The Control Room Supervisor directs you to start RHR Train "B" for Chemistry Sample using Section 6.3 of SYS EJ-120. Initial conditions are signed off. The Aux Building Operator is standing by.

Element #	Step #	Element	Standard	Score
1.	6.3.1	Start Time Check CCW Train B in operation.	Locate "B" Train CCW on RL019. Verify that at least one pump is running in the Red Train.	S U

Cue:

Comments:

2.	6.3.2	<ul><li>OPEN CCW to RHR Hx "B" Isolation valve.</li><li>EG HIS-102 - OPEN</li></ul>	Locate EG HIS-102 on the lower left of RL017. Press the OPEN P/B and verify the Green light goes out and the Red light is on.	S U
----	-------	-------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------	-----

Cue:

Comments: Annunciators 53A and 52A may alarm due to low CCW flow. If the candidate attempts to take actions due to these annunciators, inform him/her that the spare operator will handle the alarm response.

3.	6.3.3	IF RHR Suction is aligned to the RWST AND RCS Pressure is less than 300 psig, THEN CLOSE RHR to Accumulator Injection Loops 1 and 2 and RHR Train "B" Hot Leg Recirc Valves: EJ HV-8809B, EJ-HV-8716A, and EJ HV-8840.	Locate one of the following pressure indicators; BB PI-405 on RL022, BB PI-406 on RL002 or BB PI-403 on RL022 and read the pressure. Candidate may look at digital display. If the pressure is > 300 psig ,mark steps 6.3.3, items 1-5 NA.	S U
----	-------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----

Cue:

Comments: Blocks for 8809A, 8716B, and 8840 should be marked N/A in the procedure as well as the power lockout for 8809A.

* Critical Step

Element #	Step #	Element	Standard	Score
4.	6.3.4	Verify CTMT Recirc Sump to RHR Pump "A" CLOSED.	Locate EJ HIS-8811B on RL017. Verify only the Green light is lit.	S U
		• EJ HIS-8811B - CLOSED		

Cue:

Comments:

5.	6.3.5	Verify RWST to RHR Pump "B" Suction OPEN.	Locate BN HIS-8812B on RL017. Verify only the Red light is lit.	S U
		• BN HIS-8812B - OPEN		

Cue:

Comments:

6.	6.3.6	Check open RHR HX "B" flow control valve.	Locate EJ HIC-607 on RL017. Verify output on controller indicates 100 %.	S U
		• EJ HIC-607 - OPEN		

Cue:

# Comments:

7.	6.3.7	Check CCW supplying RHR Train "B".	On RL019, check Red light lit on "B" CCW Pump handswitch, EG HIS-21 or on "D" CCW Pump handswitch, EG HIS-23.	S U
			1	

Cue:

Comments:

the following: Steps 8.3.8.1 – 8.3.8.4.	8.*	6.3.8 <u>IF</u> the plant is in Mode 1, 2 or 3, <u>THEN</u> perform the following:	6.3.8	Recognize the plant is in Mode 3. Perform Steps 8.3.8.1 – 8.3.8.4.	S U
-----------------------------------------	-----	------------------------------------------------------------------------------------	-------	-----------------------------------------------------------------------	-----

Cue:

Comments:

8.a*	6.3.8.1	Open RHR B TO SI PUMPS TEST LINE ISO VALVE. • EJ HIS 8890B - OPEN	Locate EJ HIS-8890B on panel RL017. Press the OPEN P/B and verify the Green light goes out and the Red light is on.	S U
------	---------	-------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------	-----

Cue:

Comments:

Element #	Step #	Element	Standard	Score
8.b*	6.3.8.2	Open SI TEST HEADER TO RWST ISO.	Dispatch Operator to align valves	S U
		Close SI TEST HEASER TO RECYCLE HOLD- UP TANK ISO		
		• BN-V004 – OPEN		
		EM-V120 - CLOSED		

Cue:

# BOOTH INSTRUCTIONS: Aknowledge request, report "BN-V004 is OPEN and EM-V-120 is CLOSED."

Comments:

8.c*	6.3.8.3	Open SI TEST LINE SYSTEM INSIDE CTMT ISO.	Locate EM HIS-8871 on panel RL017. Press the OPEN P/B and verify the Green light goes out and the Red light is on.	S U
		• EM HIS 8871 - OPEN		

Cue:

#### Comments:

8.d*	6.3.8.4	Open SI TEST LINE SYSTEM OUTSIDE CTMT ISO.	Locate EM HIS-8964 on panel RL017. Press the OPEN P/B and verify the Green light goes out and the Red light is on.	S U
		• EM HIS 8964 - OPEN		

Cue:

Comments:

9.*	6.3.9	START RHR Pump "B".	Locate EJ HIS-2 on RL017. Turn the switch to RUN and verify the Red light is on.	S U
		• EJ HIS-2 - STARTED		

Cue:

BOOTH INSTRUCTIONS: If asked report "Pre-start checks are complete."

Comments:

10.*	6.3.10	Verify RHR Pump "B" Miniflow valve OPEN.	Locate EJ HIS-611 on RL017 just below EG HIS-2. IDENTIFY RED LAMP IS NOT LIT,	S U
		• EJ HIS-611 - OPEN	GREEN LAMP IS ON.	

Cue:

Comments:

Element #	Step #	Element	Standard	Score
10a.*	6.3.10 cont.	INDICATION CHECK USING BLUE PEN CHART EJ-TR-613 CHECKED FOR FLOW <u>OR</u> RECOGNITION THAT THE SYSTEM HAS NO RECIRCULATION PATH	CANDIDATE RECOGNIZES THAT 'B' RHR PUMP IS RUNNING WITH NO RECIRC FLOW. CANDIDATE REPORTS TO SUPERVISING OPERATOR And: RECOMMENDS SECURING RHR PUMP. <u>OR</u> SECURES "B" RHR PUMP	S U

# Cue: Acknowledge report. IF Candidate Recommended Securing the "B" RHR Pump THEN give the order to secure the pump.

Comments:

Termination: Stopping "B" RHR Pump completes the JPM.

____

Stop Time ___

*Critical Step

Initial Conditions:

You are the Reactor Operator, the plant is in Mode 3.

Initiating Cues:

The Control Room Supervisor directs you to start RHR Train "B" for Chemistry Sample using Section 6.3 of SYS EJ-120. Initial conditions are signed off. The Aux Building Operator is standing by.

Notes:

If you have a question about the task or need clarification do not hesitate to ask your evaluator. JPM's are considered "open reference", therefore reference material that is normally available to you in the plant (including the Control Room) is available during this JPM. If you desire to use a reference, ask your evaluator if it is acceptable to do so for the task under consideration. You **may not** solicit technical information from other operators, engineers or technical advisors.

When you have completed the JPM inform your evaluator that you are done by handing this Initial Conditions/Initiating Cues sheet back to him.



# INITIAL LICENSE EXAM

# **DECEMBER 2001**

# **DYNAMIC SCENARIO #1**

Revision 1, 11/27/2001

/S/	/ 11/30/2001	<u>/S/</u>		/ 11/30/2001
Robert Acree		Howard Bundy		
WCGS Exam Author	DATE	NRC Chief Examiner	DATE	

# Scenario Objectives:

- 1. Evaluate the ability to perform normal operations by reducing power quickly due to a loss of a 345 KV Switchyard power line.
- 2. Abnormal actions and Technical Specifications usage are evaluated by diagnosing and correcting:
  - T-Ref Channel failure affecting rod control
  - Steam Pressure Channel failure affecting Steam Generator Level control.
  - Steam Leak in the Turbine Building
- 3. Emergency actions are evaluated for:
  - A Main Steam Line Break, outside of Containment.
  - Failure of Safety Injection to Automatically actuate.
- Contingency actions are evaluated for a failure of the Main Steam Line Isolation valves to close with a Main Steam Line Break, outside of Containment, using EMG C-21, "UNCONTROLLED DEPRESSURIZATION OF ALL STEAM GENERATORS".

# Scenario Assignments

# Crew A

Examiners:	<u>BUNDY (E1)</u> <u>GAGE (E2)</u> JOHNSTON (E3)	Operators:	PENDERGRASS (SO1) WILSON (RO1) PITT (RO2)
		Crew B	
Examiners:	<u>BUNDY (E1)</u> <u>GAGE (E2)</u> JOHNSTON (E3)	Operators:	<u>BELL (SO2)</u> <u>SIMMS (SO3)</u> LAZAROWSKI (RO3)

#### GENERAL REFERENCES

- NUREG 1021, Rev. 8, Supplement 1, "OPERATOR LICENSING EXAMINATION STANDARDS FOR POWER REACTORS"
- OFN SB-008, Rev. 11, "INSTRUMENT MALFUNCTIONS"
- OFN MA-038, Rev. 4, "RAPID PLANT SHUTDOWN"
- EMG E-0, Rev. 14, "REACTOR TRIP OR SAFETY INJECTION"
- EMG C-21, Rev. 12, "UNCONTROLLED DEPRESSURIZATION OF ALL STEAM GENERATORS".
- ALR 00-111C, Rev. 6, "SG D FLOW MISMATCH"

RESET TO IC 171 AND PLACE SIMULATOR IN RUN PRIOR TO LOADING BATCH FILE. Ensure simulator is in run or file will not load properly. You may freeze after file is loaded.

Insert Floppy disk and save the batch file LO01_001 to OPENSIM/BATCH, then open Ph.D. Expert and type "BAT LO01_001.txt"

<u>NOTE:</u> FILE **LO01_001.txt** preloads all LOAs and/or malfunctions required for this scenario. Simulator commands and other functions to be performed by the booth operator are shown in **BOLD**. Trigger commands are used to initiate events and commands.

HANG DNO tag on "A" CCW pump Handswitch, PLACE Handswitch in PTL.

**ENSURE** THE HORNS ARE ON

**ENSURE** CONTROL RODS ARE AT 229 STEPS

**ENSURE** placard is on the 'A' CCP.

Reset RM-11 alarms from previous Scenarios

Have the above verified by a second person as being correctly performed.

Core age is Middle of Life

Power is 100%. Xenon equilibrium.

Facility:	WCGS	5	Scenario No.: 1 Op-Test No.: 1			
Examiner	Examiners: Operators:					
See Exar	miner/Oper	ator assigr	ment sheet. This Scenario will be seen by multiple crews.			
	·	C				
Initial Cor	nditions: <u>10</u>	0% Power	, MOL, "A" CCW pump OOS for PM's.			
Turnover System C	: <u>Continue</u> Ops reports	plant operation of the second state of the sec	ations, make preps to return "A" CCW pump to service. lity problems. Weekday Nightshift.			
Event No.	Malf. No.	Event Type*	Event Description			
1 T+1.0	mPCS 02A	I (All)	AC PT-505 (T-Ref) fails low, Rods begin Inserting, BOP verifies no Turbine Runback in progress.			
2 T+14.0	mMSS 01D2	I -BOP I-CRS	AB PT-545 fails low, affects Steam Flow Channel AB FT- 543. BOP take manual Control of "D" SG FRV.			
3 T+25.0	mEPS 03A	R-RO N-BOP N-CRS	La Cygne Line in the switchyard opens, System Ops request expedite load reduction due to Grid problems. Load reduction commences to less than 968 Mwe per OFN AF-25. Using OFN MA-038.			
4 T+34.0	mMSS 11	C-All	Steam Leak commences in Turbine Building large enough to affect downpower.			
5 T+40.0	MMSS0 4A	M-All	CRS should direct a Reactor Trip, Upon the trip the leak becomes a MSLB. MSIV's will not close.			
6 T+43.0		C-RO C-CRS	SI fails to actuate in Automatic. Manual Available. RO/CRS must recognize that an SI will be required or the setpoint has already been reached and SI did not actuate.			
7 T+65.0		C-BOP C-CRS	<ul> <li>Uncontrolled de-pressurization of all SG's will require entry into EMG C-21. Scenario terminates after crew establishes 30K Aux Feedwater flow to each SG or at Lead Examiner discretion.</li> </ul>			

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

ILC Scenario #1

Time	Simulator	Events and Procedures	Applicant Actions or Behaviors	Notes
(min)	Instructions			
	Malfunction	Event 1	Event 1	
	clock starts			
	when the crew	T AC PT-505 fails low	<b>RO:</b> Report control rods stepping	
	has assumed		in.	
	the watch	P Rods begin inserting	<b>BOP:</b> Reports no turbine	
	(T=0)	P Turbine Runback NOT in progress.	runback.	
		P Ann. 065E Alarms	<b>CRS/RO:</b> Place Rods in Manual.	
	Incont Except 1	P Ann. 079C Alarms	CRITICAL TASK: Take	
	Insert Event 1		manual control of rod control	
	with <b>I rigger 1</b>	A Recognize Instrument Failure	system to prevent a reactor trip.	
			STANDARD: This action must	
			be taken in time to prevent a	
			reactor trip.	
		OFN SB 008 stops (roy 11)		
		1 Check if secondary system instrument channel	<b>RO/BOP:</b> Recognize AC PT-505	
		is malfunctioning Yes go to Attachment D	has failed low.	
		D1. Identify failed instrument channel AC PT-505		
		D2 Place rod control in manual	CRS: Enters and directs OFN	
		D3. Check failed Turbine Impulse Pressure channel	SB-008 Auch. D.	
		selected		
		D4. Select alternate channel		
		D5. ( $\rho$ ) Adjust rods to return $T_{avg}$ to $T_{ref}$ for existing	<b>CBS</b> : Conduct Reactivity Brief	
		plant power	<b>RO:</b> Withdraw Control Rods to	
		D6. Check $T_{avg}$ within 1°F of $T_{ref}$	restore Tays to within 1°F of Tref	
		D7. Place rod control in auto		
			<b>BOP:</b> Place Steam Dumps in	
		D8. Place steam dump actuation interlock to OFF	Steam Pressure Mode.	
		D9. Monitor rod control response to ensure proper		
	When called as	control		
	Work Week	D10. Check C-7 not lit		
	Manager	D11. Select Steam Pressure Mode		
	(WWM), state	b12. Place steam dump interlock selector switches		
	you will get a	D13. Place the trip/safeguards B/S in tripped mode	CRS: Contact WWM for	

# ILC Scenario #1

team together.	D14. Check C-16 Not Lit	Assistance.	
-	D15. Check Load 'HOLD' light Not Lit		
	D16. Place turbine impulse pressure channel in		
	proper condition for AMSAC		
	<b>NOTE:</b> AMSAC Panel is not simulated. Inform		
	Crew that the Shift Engineer will take care of		
	AMSAC.		
	D17. Request I&C to repair		
	D18. Go to T/S 3.3.1 and comply with action		
	statement	<b>CRS:</b> Comply with T.S.	
		T.S. 3.3.1. Table 3.3.1. Function	
		18f verify P-13 in its proper	
		state within 1 hour.	
	D19. Return to procedure in effect		
	r i i i i i i i i i i i i i i i i i i i		

Insert Event 2 with <b>Trigger 2</b>	Event 2TS/G 'D' AB PT-545 fails lowP'D' S/G Feed flow will decreaseP'D' S/G Level will decreasePANN 111C AlarmsARecognize FRV failure & Take manual control of AE FCV-540	Event 2 BOP: Report feedflow decreasing on 'D' S/G. BOP: Place FRV in manual. <u>OR</u> CRS: Direct manual control of 'D' S/G FRV. CRITICAL TASK: <u>Take</u> manual control of FRV as necessary to prevent reactor trip. STANDARD: <u>This action must</u> be taken in time to prevent a reactor trip.	
	<ul> <li>Annunciator Response 00-111C</li> <li>1. Check difference between steam generator D steam flow and feed flow - Greater than 0.7 MPPH</li> <li>2. Check for instrument failure.</li> </ul>	<b>CRS:</b> May direct use of ALR 111C or enter OFN SB-008 directly. ALR contains guidance for Manual control of FRV.	
	<ul> <li>OFN SB-008 steps: (Rev. 11)</li> <li>1. Check if secondary system instrument channel is malfunctioning <ul> <li>a. Determine appropriate attachment for malfunctioning channel</li> <li>b. Go to Attachment C</li> </ul> </li> <li>C1. Compare S/G Pressure indications to confirm S/G pressure channel failure.</li> <li>C2. Check if failed S/G pressure channel used for feedwater control.</li> </ul>	<ul> <li>CRS: Enters and directs OFN SB-008</li> <li>BOP: Confirms steam flow/feed flow mismatch.</li> <li>BOP/RO: Identify failed Steam Pressure Channel Failed and NOT the Steam Flow Channel.</li> </ul>	

	C3.	Select the alternate steam flow channel.		
	C4.	Monitor S/G level response to ensure proper	<b>BOP:</b> Select Alternate Channel	
		control.		
	05	Take manual control, if necessary.		
	C5.	Place the reactor trip/safeguards bistables for		
	CG	The failed channel in the TRIPPED mode.	<b>CRS:</b> Contact WWM for	
When called as	C0.	Request fact to repair failed channel.	assistance.	
Work Week	C7	Monitor the following Technical Specifications		
Manager	сл.	and comply with Action Statements:	CRS: Address T.S. issues	
(WWM), state		3.3.2	<b>CR5.</b> Address 1.5. Issues.	
you will get a		3.3.3 Table 3.3.3-1, Function #8		
team together.		3.3.4 Table 3.3.4-1, Function #7	3.3.2 Trip bistables in 6 hours	
		3.3.6	3.3.3 Attachment S	
		3.3.7	3.3.4 Attachment S	
	<b>C</b> 0		3.3.6 Verify CTMT Purge closed.	
	Cð.	inst	3.3.7 CREVS in 7 Days	
		liist.		
	C9.	Return to procedure and step in effect	CRS: Review Attach. S.	
	071			

			-
	<u>Event 3</u>		
Insert Event #3 with <b>Trigger 3</b>	Downpower maneuver due to loss of LaCygne Line using OFN MA-038, "RAPID PLANT S/D" Per OFN AF-025, "UNIT LIMITATIONS", Generator output is limited to 995 Gross Mwe. This would require a load reduction $\geq 1\%$ per minute. OFN MA-038 Steps	<b>Event 3</b> <b>CRS:</b> Direct Crew to reduce power to 80%. Give a rate $\geq 1\%$ per minute to the crew for the power reduction.	
IF crew does not notice breakers opening in switchyard, after 30 seconds: <b>Call</b> as System Ops	<ol> <li>Reduce Turbine Load:         <ol> <li>Check desired unloading rate-less than or equal to 5%/minute</li> <li>Set Loading/Unloading Rate Limit to desired value</li> <li>Select Decrease Loading Rate - ON</li> <li>Decrease Load Set MW toward desired load</li> <li>Continue with this procedure while reducing</li> </ol> </li> </ol>	<b>BOP:</b> Reduce Turbine load at designated rate	
and report "LaCygne Line has a failure. Request reduce load within 25 minutes due to	<ul> <li>turbine load</li> <li>Adjust Control Rods as necessary to establish a target Tavg/Tref Temperature Error between 0°F and +5°F</li> <li>Energize PZR Backup Heaters BB HIS-51A &amp; BB HIS-52A</li> </ul>	<b>RO:</b> Maintain Tavg/Tref using rods	
grid stability concerns."	<ul> <li>4. Borate RCS and adjust Control Rods as necessary to establish the following conditions: Maintain delta flux within target band Maintain control rods above rod</li> </ul>	<b>RO:</b> Energize backup heaters	
	insertion limits 5. Check PZR PORVs. 6. Check PZR Pressure - Stable at or trending to	<b>RO:</b> Maintain Delta I & RIL using boron and rods.	

		-	-
	2235 psig		
	7. Check PZR level - Stable at or trending to		
	program level.		
	8. Check S/G Levels - Controlling between 45%		
	and 55%.		
	9. Check AE HV-38 – Open		
	10. Check Reactor Power – less than 60%	<b>BOP</b> : Close AE HV-38	
	Event 4		
		Event 4	
	T Steam Leak commences in the Turbine		
	Building		
	Dunding.		
Insert Event #4	P Reactor Power increases	<b>DO/DOD:</b> Note that parameters	
with <b>Trigger 4</b>	P Steam Flow increases	<b>NO/DOL</b> . Note that parameters	
after power	P Taya decreases	then expected	
reduction starts	P Pressurizer Press and Level decrease	than expected.	
as directed by	I I I I I I I I I I I I I I I I I I I		
Lead Examiner	A Determine that a steam leak has occurred in		
	the power block	CRS: Recognize a trip is required	
	the power block.	and direct the RO to manually trip	
If crew pages		the reactor.	
building		<b>RO:</b> Manually trip the reactor.	
watches to look			
for leaks, wait		<b>CRS:</b> Enter and direct E-0.	
30 seconds		<b>RO/BOP:</b> Perform Immediate	
then page back	EMC E $A$ STEDS (DEV 14)	Actions of E-0, Steps 1 through 4.	
as Turbine Bldg	LIVIG E-U SIEFS (KEV 14)		
watch and	a Chack all red bottom lights lit		
report " there is	a. Check an four bolton nights in	<b>RO:</b> Verify Reactor Trip	
steam on the	b. Elisure reactor trip breakers and bypass		
2033' level of	o Charle neutron flux decreasing		
the Turbine	d. Transfer NP 45 recorder to intermediate		
Bldg"	u. Transfer INK-43 recorder to intermediate		
<del>-</del> .	2 Varify turbing trip		
Insert Event #5	2. Verify through the following:		
with <b>Trigger 5</b>	a. Check the following: Main stop values all alosed	<b>BOP:</b> Verify Turbine Trip	
with Higger 5	wain stop valves all closed		

# ILC Scenario #1

I				
	at time of	<u>OR</u>		
	reactor trip.	Turbine auto stop bistable lights at least		
		two lit		
		b. Check main generator breakers and exciter		
		breaker open		
		3 Check AC emergency busses at least one		
		onorgized		
		energizeu.		
			<b>RO:</b> Check AC Buses	
		4. Check if SI is actuated		
		<ul> <li>Annunciator 00-030A LIT</li> </ul>		
		• <u>OR</u>	<b>RO/BOP:</b> Check if SI is	
		Annunciator 00-031A LIT	required.	
		• OR	*	
		• ESEAS Status Danal ANV WHITE		
		• ESTAS Status Faller ANT WHITE	At completion of Immediate	
			actions BOP should request to	
		• <u>OR</u>	East Class MSW's	
		<ul> <li>Trip Status Panel SI RED LIGHT LIT</li> </ul>	Fast Close MISTV S.	
			<b>CRS:</b> Direct Fast Closure of	
			MSIV's.	
			<b>BOP:</b> Recognize MSIV's would	
			not close and attempt a slow	
		5 Check if SL is required:	close.	
		S. Check II SI is required.		
		• RCS press $\leq 1830$ psig		
		• S/G press $\leq 615$ psig	CDEW: Mars and line SL is	
		• CTMT press $\geq$ 3.5 psig	CREW: May realize SI is	
		• RCS subcooling < 30°F	inevitable due to steam break and	
		• PZR level $< 6\%$	initiate Safety Injection.	
			<b>RO:</b> RCS Press < 1400 psig.	
			Point,	

		RCP Trip Criteria met at	
		approximately two minutes after	
		the steam break.	
		While not a Critical Task, the RO	
		should recognize that a trip	
		criterion has been met	
	Event 5 and Event 6		
	Event 5 and Event 0		
	1 Steam Leak becomes a Main Steam Line	Event 5	
	Break.	<u>Event 5</u>	
Event #5	P Pressurizer Pressure will decrease.	<b>RO/BOP:</b> Determine SI is	
inserted at time	P Main Steam Line Pressures will decrease.	required	
of reactor trip	P Steam Flow is indicated with all Steam		
or reactor unp.	Dumps and Atmospheric Relief Valves	<u>Event 6</u>	
	closed		
		<b>RO:</b> Determine SI did not actuate	
	A Determine setpoints for SI have been	and initiate a Manual Safety	
	exceeded and initiate a Safety Injection	Injection.	
		<b>Critical Task:</b> Actuate at least	
		one train of SIS actuated	
		components	
	6. Verify automatic actions per Attachment F.	Standard: Prior to a needless red	
		or orange path	
		or orange path.	
	ATTACHMENT F		
		<b>CBS</b> : Direct <b>DO/DOD</b> to perform	
	F1. Verify feedwater isolation	$\Delta ttoh E of EMC E 0$	
	a. Main feedwater pumps tripped	Atten.F of EMG E-0.	
	b. Main feedwater reg valves closed		
	c. Main feedwater reg bypass valves closed	<b>KO/BOP:</b> Perform Attachment	
	d. Main feedwater isolation valves closed	F.	

 e. Main feedwater chemical injection valves	
closed	
f. Check ESFAS status panel SGBSIS section	
all white lights lit	
F2. Verify CISA	
a. Check ESFAS status panel CISA section all	
white lights lit	
F3. Verify AFW pumps running	
a. Check motor driven AFW pumps both	
running	
b. Check turbine driven AFW pump running	
F4. Verify ECCS pumps running	
a. Check CCPs both running	
b. Check SI pumps both running	
c. Check RHR pumps Both Running	
F5.Verify CCW alignment	
a. Check CCW pumps one running in each	
train	
b. Check one pair of CCW service loop supply	
and return valves for an operating CCW	
pump open	
F6. Check ESW pumps both running	
F7. Verify CTMT fan coolers running in slow speed	
F8. Verify CPIS	
a. Check ESFAS status panel CPIS section all	
white lights lit	
F9. Verify both trains of CRVIS	
a. Check ESFAS status panel CRVIS section	
all white lights lit	
b. Ensure control room outer door closed	
F10. Verify main steamline isolation not required	
a. Check CTMT pressure has remained < 17	
psig	
b. Check either conditions below - satisfied	
Low steamline pressure SI - NOT BLOCKED	
<u>AND</u> steamline pressure has remained $> 615$	
psig	
OR	
--------------------------------------------------------	--
Low steamline pressure SI - BLOCKED AND	
steamline pressure rate has remained $< 100$	
nsi/50 sec	
FII. Verify CIMI spray not required	
a. CTMT pressure has remained $< 27$ psig	
F12. Verify ECCS flow	
F13. Verify AFW valves - properly aligned.	
F14. Verify SI valves - properly aligned.	
7. Verify AFW flow $> 270,000$ lbm/hr.	
8. Check RCS cold leg temperature stable.	
• Less than or equal to 557°F for steam	
dumps	
• Loss than or equal to $561^{\circ}E$ for $S/C$ ADV's	
• Less mail of equal to 501 F for 5/0 ARV s.	
9. Establish S/G pressure control:	
a. Check condenser - AVAILABLE	
b. Place AB PK-507 in MANUAL	
c. Manually set AB PK-507 output to Zero	
d. Place Steam Dump Select Switch in STEAM	
PRESS position	
e. Place Steam Header Pressure Control in	
Automatic and adjust to maintain existing	
stoom hooder prossure	
steall header pressure.	
0 AB PK-50/	
10. Check PZR PORVs - closed	
11. Check normal PZR spray valves closed	
12. Check PZR safety valves - closed	
13. Check if RCPs should be stopped.	
14. Direct operator to monitor CSFSTs	
15. Check if SGs are not faulted	

	<ul> <li>EMG E-2 steps: (REV 9)</li> <li>1. Check steamline on All SG isolated <ul> <li>a. MSIVs closed</li> <li>b. MSIV bypasses closed</li> <li>c. Main steamline low point drain valves closed</li> </ul> </li> <li>2. Check if fault is inside Area 5</li> <li>3. Check if any SG is not faulted NO – RNO Go to EMG C-21</li> </ul>	<ul><li>BOP: Report ALL SG's faulted.</li><li>CRS: Transition to EMG E-2.</li><li>CRS: Conduct Transition Brief for EMG E-2.</li></ul>	
		<b>CRS:</b> Transition to EMG C-21.	
To locally isolate steam valves AB V- 085 and AB V- 087, <b>EVENT</b> 7. Call back after 2 minutes and report valves closed.	<ul> <li>EMG C-21 steps:(Rev. 11)</li> <li>1. Check steamline on all SGs isolated <i>RNO do</i> <i>ATTs A&amp;B</i> <ul> <li>a. Ensure MSIVs closed</li> <li>b. Ensure MSIV bypass valves closed</li> </ul> </li> <li>2. Isolate steam flow from all SGs <ul> <li>a. Locally close steam supply to turbine driven AFW pump</li> <li>b. Ensure SG ARV closed</li> <li>c. Ensure main steamline low point drain valves closed</li> </ul> </li> <li>3. Verify feedline isolated on all SGs <ul> <li>a. Main feed reg valve closed</li> <li>b. Feed reg bypass valve closed</li> <li>c. MFIV closed</li> <li>d. Chemical injection valve closed</li> </ul> </li> <li>4. Verify Blowdown and sampling isolated on all SG's <ul> <li>a. S/G Blowdown Containment Iso Valves closed.</li> <li>b. S/G Upper Sample Isolation valves closed.</li> </ul> </li> </ul>	<ul> <li>CRS: Conduct Transition Brief for EMG C-21.</li> <li>BOP: Contact Aux Bldg Operator to isolate TDAFWP steam supply valves.</li> </ul>	

Event 7	
5. Control feed flow to minimize RCS of	ooldown
a. Check cooldown rate in RCS cold	l legs <
100F/hr	Event 7
RNO - Decrease feed flow to 30.0	)00 lbm/hr
to each SG, go to step 5c	
b. Check SG narrow range levels < 5	50%
c. Check RCS hot leg temperatures	stable or <b>SRO/BOP:</b> Reduce AFW flow
decreasing	
	Critical Task: Reduce AFW
	flow prior to a severe challenge to
Terminate Scenario after crew establis	hes the Integrity Status Tree.
30 klbm/hr to each SG or at discretion of	lead <b>Standard:</b> Reduce AFW flow to
examiner.	30-35 klbm/hr.
	E-Plan Classification:
>Initial License Exam 01-001	Main Steam Line Break
>SI FAILS TO AUTO ACT	MSLB1 – MSLB2 – MSLB5 –
>LOW PZR PRESS	MSLB6 ALERT
IMF BST-JPB455D 1	
IMF BST-JPB456D I	
IMF BS1-JPB45/D I	
IWF B51-JPB458D 1	
>LOW STEAM LINE PRESS	
IMF DS1-JFDJ14A I IME BST IDB515A 1	
IME BST-JEBJIJA I IME BST-JEBS16A 1	
IMF BST-IPR524A 1	
IMF BST-IPB525A 1	
IMF BST-JPB526A 1	
IMF BST-JPB534A 1	
IMF BST-JPB535A 1	
IMF BST-JPB536A 1	
IMF BST-JPB544A 1	
IMF BST-JPB545A 1	

	IMF BST-JPB546A 1	
	>HI-1 CTMT PRESS	
	IMF BST-JPB934B 1	
	IMF BST-JPB935B 1	
	IMF BST-JPB936B 1	
	>MSIV's will not close Auto/Man	
	IMF mMSS02I	
	IMF mMSS02J	
	IMF mMSS02K	
	IMF mMSS02L	
	>Tag Out "A" CCW pump	
	IRF NEGP01A 1	
	IRF NEGP01AX 1	
	>FAILURE OF AC PT-505 LOW	
	IMF mPCS02A (1) 0 30	
	>Fail AB PT-545 Low	
	>Affects Stm Flow Channel AB FT-543, "D" SG	
	IMF mMSS01D2 (2) 0 10	
	>LaCygne Line opens in switchyard	
	IMF mEPS03A (3)	
	>Steam Leak in Turb Bldg	
	IMF mMSS11 (4) 4e+005 240	
	>Steam Break in Turb Bldg	
	IMF mMSS04A (5) 1e+7 120	
	>Isolate Steam Supplies to TDAFWP	
	IRF rMSS01 (7) 0 60	
	IRF rMSS02 (7) 0 90	
	> OVERRIDE ESFAS PANEL LIGHTS - CRVIS	
	TRGSET 8 "JPPLSI(1)"	
	IMF SA066Y_C14W (8) 1	
	IMF SA066Y_C15W (8 35) 1	
	IMF SA066Y_C16W (8 35) 1	
	IMF SA066Y_G15W (8) 1	
	>End of File	

APF 21-001-02 Rev. 1	3 Page 1	OF 4	זידי זאר	DNOVED CHECKI	тст		K02-001C	
	(	LONIROL ROC		RNOVER CHECKL				-
DATE : Today	1	NIGHT SHIFT		DAY SHIFT	•		MODE-	1
	~~~~~					~~~~		
FF-GOING: (PRINT)	CRS		(DN-COMING: (PRINT)		CRS		
	RO					R0		
	BOP					BOP		
	SE					SE		
		ON-COMIN	G CRS/	SE/RO/BOP REVIEW				
EVOLUTIONS IN PROGRES	s:							
1) System Ops reports	they are	having grid st	abilit	v concerns.				
,	1			1				
		1						
MAINTENANCE IN PROGRE	SS: [Comn	nitment Steps 3	.2.10,	3.2.12]				
1) "A" CCW pump.								
TESTING IN PROGRESS:	[Commitme	nt Stens 3 2 1	0 3 2	12]				
TESTING IN FROORESS:			0, 5.2	. 12]				

CONTROL ROOM TURNOVER CHECKLIST COMMENTS:	APF	21-001	-02	Rev.	13	Page	2 of 4			K02-001C
COMPETTS:							CONTROL	ROOM	TURNOVER	CHECKLIST
FOLLOW-UP RUTTONS:	CON									
NORE REQUEST:	CON	ITEN 15.								
NORK REQUEST:										
FOLLOW-UP BUTTORS:										
NORK REQUEST:										4
FOLLCM-UP BUTTONS:										
NORK REQUEST:										
FOLLOW-UP BUTTONS:										
FOTTON-DE BALLONS:										
FOLLOW-UP BUTTONS:										
NORK REQUEST:										
NORK REQUEST:										
NORK REQUEST:										
MORK REQUEST:										
NORK REQUEST:										
WORK REQUEST:										
WORK REQUEST:										
WORK REQUEST: WORK REQUEST:								-		
WORK REQUEST:										
NORK REQUEST:										
NORK REQUEST:							-		•	
WORK REQUEST:										
VORK REQUEST:										
FOLLOW-UP BUTTONS:	WOR	K REQUE	ST:							
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:						2)				
FOLLOW-UP BUTTONS:						-				
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:				1						
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:	EQ-			0110 -						
	FOL	TOM-Ob]	s∩.1.1.	UNS:						

APF 21-001-02 Rev.	13 Page 3 of 4	K02-001C
	CONTROL ROOM TURN	NOVER CHECKLIST
REACTOR POWER	% RCS:	586.5 °F 2235 PSIG
ROD CONTROL	AUTO V	
	MANUAL	li li
Control bank d	229 STEPS	
RCS BORON (C _b)	<u>911</u> PPM @ D	ATE/TIME Today / 0430
LEAK RATE (GPM):	IDENTIFIED 0.008 UNIDEN	TIFIED 0.067 @ DATE/TIME Today/0430
COND. AIR INLEAKAGE	29.1/ Today	SF
IAW STN CH-020)		
TANKS AP FILL	ING AN FILLING	BL FILLING BL ON RECIRC
CONDENSATE DEMINS IN	I SERVICE A B	
	ESF STATUS PANELS AND REA	ACTOR TRIP/BLOCK PANEL
PANEL	COMPONENT/TRIP/BLOCK	REASON
066x	"A" CCW Pump	PM's
) •	

	ONLY

FORTRAMME

APF 21-001-02 Rev. 13 Page 4 of 4

CONTROL ROOM TURNOVER CHECKLIST

ON-COMING CRS/SE/RO/BOP REVIEW (Check Box)

PR	IOR TO	ASSUM	ING WATO	CH					
	CRS	SE	RO	BOP					
					CONTROL ROOM LOGS				
					ESSENTIAL READING				
					CLEARANCE ORDER LOG				
					INSTRUMENT OUT-OF-SERVICE LOG				
					EQUIPMENT OUT-OF-SERVICE LOG				
					ACTION STATEMENT SUMMARY				
					SURVEILLANCE SCHEDULE				
		N/A			FIRE PROTECTION PERMITS				
		N/A	N/A	N/A	KC008 NOT DISABLED/DISARMED WITHOUT DOCUMENTATION				
		N/A	N/A	N/A	DISCHARGE PERMITS				
					MCB WALKDOWN WITH OFF-GOING WATCH				
AF	TER AS	SUMING	WATCH						
1	CRS	SE	RO	BOD					
		27 / 2	27 / 2	27.12	TEMP MOD LOG				
		N/A	N/A	N/A	LOCKED VALVE LOG				
		NT / N	NT / 7	NT / 7	COMPUTER ALARM SUMMARY				
		N/A	N/A	N/A	CONDUCT SHIFT BRIEF				
		NT / 7	N/A	N/A	P-2 SCHEDULE				
		N/A	N/A	N/A	OPEN PROCEDURES BOOK [Commitment Step 3.2.18]				
ļ				-	OPEN WCGS SUBSTATION WORK AUTHORIZATION FORMS [Commitment Step 3.2.27]				
AT	TACH AI	NY ADD	ITIONAL	PAGES N	EEDED TO DESCRIBE PLANT CONDITIONS. MARK THE NUMBER OF ADDITIONAL PAGES				
OF	F-GOIN	Ŧ			ON-COMING				
	CRS				CRS				
	RO				RO				
	BOP				вор				
	٩F				<u>्</u> म				
	10			INITIALS	INITIALS				

K02-001C

ALARM WINDOW DESCRIPTION

<u>Window</u>	Name	Reason	WR/WO
018F	NB01 BKR NOT OPERABLE	"A" CCW	

INTERMITTENT ALARMS

	KC008 ALARMS	

APF 21H-001-01 REV 02

INSTRUMENT OUT OF SERVICE LOG							
005	COMPUTER	DOCUMENT NUMBER	OOS	AFFECTED COMPUTER	REASON	SM/CRS VERIFIED	TAG REMOVAL
SEQUENCE	POINT	(2)	TIME/	PROCESS OR READ-OUT	APPLIED	APPLICABLE TS,	AUTHORIZATION
NUMBER	DESIGNATOR		DATE	DEVICE		TRM AND MODE	(SM/CRS INITIAL
	(1)					RESTRAINT	TIME AND DATE)
			0000 /	NE02 DIESEL FIELD	FAULTY		
96-3		SMP 96-135	3/27/97	AMP METEER	METER		
			0000 /	NE01 DIESEL FIELD	FAULTY		
96-4		SMP 96-135	3/27/97	AMP METEER	METER		
				C.L.			
				3			
			C				
		-FRAN					
	FO.	P					

NOTE: 1) FOR INSTRUMENTS OTHER THAN COMPUTER POINTS ENTER N/A.

2) VERIFY OOS SEQUENCE NUMBER IS ON ACTION/WORK REQUEST AND LIST ACTION/WORK REQUEST NUMBER IN THIS COLUMN.

APF 21F-001-01 REV 01

EQUIPMENT OUT OF SERVICE LOG							
EOL		DECLARED INOPERABLE	REQUIRED RETURN	APPLICABLE	MODE	TECH SPEC	DECLARED OPERABLE
DATE/NUMBER	SYSTEM	DATE/TIME/INITIAL	DATE/TIME/INITIAL	MODES	RESTRAINT	TRM	DATE/TIME/INITIAL
		(SM/CRS)	(SM/CRS)			ODCM	(SM/CRS)
REMARKS/EQUI	PMENT/AR/	TMO/CO/RETEST					
2001-001	EG	Today/1300/CRS	N/A	N/A	N/A	N/A	
"A" CCW Pump		· · ·			·		•
For Tracking	only, "A	A" Train CCW still ope	erable with only the	"C" pump.			
	•						•
	1						1
			·	·	·		
		2					
	FO						
			·	·	·		
	1	I					1

APF 21-001-10, Rev. 01

	ACTION STATEMENT SUMMARY LOG					
E.O.L.	TECH SPEC #	ENTERED	DEADLINE	REMARKS	RESTORED	
YR.		DATE/TIME/SM/CR S	DATE/TIME/SM/CR S		DATE/TIME/SM/CR S	
				04-		
			9*			
	*					

FORTRAMMEUSEONIN

>Initial License Exam 01-001 >SI FAILS TO AUTO ACT >LOW PZR PRESS IMF BST-JPB455D 1 IMF BST-JPB456D 1 IMF BST-JPB457D 1 IMF BST-JPB458D 1 >LOW STEAM LINE PRESS IMF BST-JPB514A 1 IMF BST-JPB515A 1 IMF BST-JPB516A 1 IMF BST-JPB524A 1 IMF BST-JPB525A 1 IMF BST-JPB526A 1 IMF BST-JPB534A 1 IMF BST-JPB535A 1 IMF BST-JPB536A 1 IMF BST-JPB544A 1 IMF BST-JPB545A 1 IMF BST-JPB546A 1 >HI-1 CTMT PRESS IMF BST-JPB934B 1 IMF BST-JPB935B 1 IMF BST-JPB936B 1 >MSIV's will not close Auto/Man IMF mMSS02I IMF mMSS02J IMF mMSS02K IMF mMSS02L >Tag Out "A" CCW pump IRF NEGP01A 1 IRF NEGPO1AX 1 >FAILURE OF AC PT-505 LOW IMF mPCS02A (1) 0 30 >Fail AB PT-545 Low >Affects Stm Flow Channel AB FT-543, "D" SG IMF mMSS01D2 (2) 0 10 >LaCyqne Line opens in switchyard IMF mEPS03A (3) >Steam Leak in Turb Bldg IMF mMSS11 (4) 4e+005 240 >Steam Break in Turb Bldg IMF mMSS04A (5) 1e+7 120 >Isolate Steam Supplies to TDAFWP IRF rMSS01 (7) 0 60 IRF rMSS02 (7) 0 90 > OVERRIDE ESFAS PANEL LIGHTS - CRVIS TRGSET 8 "JPPLSI(1)" IMF SA066Y_C14W (8) 1 IMF SA066Y_C15W (8 35) 1 IMF SA066Y_C16W (8 35) 1 IMF SA066Y_G15W (8) 1 >End of File



INITIAL LICENSE EXAM

DECEMBER 2001

DYNAMIC SCENARIO #2

Revision 1, 11/27/2001

/S/	/ 11/30/2001	<u>/S/</u>		/ 11/30/2001
Robert Acree		Howard Bundy		
WCGS Exam Author	DATE	NRC Chief Examiner	DATE	

Scenario Objectives:

- 1. Evaluate the ability to perform normal operations by rapidly shutting down the plant to remove a Main Feed Pump from service.
- 2. Abnormal actions and Technical Specifications usage are evaluated by diagnosing and correcting
- VCT level channel failure
- Power Range Channel failure
- Steam Generator "C" level controller malfunction
- Loss of CCW to the RCPs
- 3. Emergency actions are evaluated for a RCS Loop "A" 300 gpm leak
- 4. Contingency actions are evaluated for a failure of the Reactor to trip using EMG FR-S1 "RESPONSE TO NUCLEAR POWER GENERATION/ATWT"

Scenario Assignments

Crew A

Examiners:	<u>GAGE_(E2)</u> <u>BUNDY_(E1)</u> JOHNSTON_(E3)	Operators:	<u>PARTRIDGE (U)</u> <u>PENDERGRASS (SO)</u> <u>PITT (RO2)</u>
		Crew B	
Examiners:	GAGE (E2)	Operators:	SIMMS (SO3)

aminers:	GAGE (E2)
	BUNDY (E1)
	JOHNSTON (E3)

Operators:

SIMMS (SO3) BELL (SO2) LAZAROWSKI (RO3)

GENERAL REFERENCES

NUREG 1021, Rev. 8, Supplement 1, OPERATOR LICENSING EXAMINATION STANDARDS FORPOWER REACTORS OFN SB-008, Rev. 11, INSTRUMENT MALFUNCTIONS OFN MA-038, Rev. 4, RAPID PLANT SHUTDOWN EMG E-0, Rev. 14, REACTOR TRIP OR SAFETY INJECTION EMG E-1, Rev. 13, LOSS OF REACTOR OR SECONDARY COOLANT FR-S1, Rev. 12, RESPONSE TO NUCLEAR POWER GENERATION/ATWT OFN BB-007, Rev. 11, RCS LEAKAGE HIGH ALR 00-110C, Rev. 6, SG C FLOW MISMATCH ALR 00-042B, Rev7, VCT LEV HILO RESET TO IC 172 AND PLACE SIMULATOR IN RUN PRIOR TO LOADING BATCH FILE. Ensure simulator is in run or file will not load properly. You may freeze after file is loaded.

Insert Floppy disk and save the batch file LO01_002 to OPENSIM/BATCH, then open Ph.D. Expert and type "BAT LO01_002.txt"

<u>NOTE:</u> FILE **LO01_002.txt** preloads all LOAs and/or malfunctions required for this scenario. Simulator commands and other functions to be performed by the booth operator are shown in **BOLD**. Trigger commands are used to initiate events and commands.

HANG DNO tag on DG NE02 KJ HS-108A & NE HIS-26

HANG DNO tag on "B" CCP

HANG Orange DNO Isolated magnetic tag on "D" ARV.

ENSURE Green STS NB-01 Placard is displayed with due time of Today/2045.

ENSURE THE HORNS ARE ON

ENSURE CONTROL RODS ARE AT 229 STEPS

ENSURE placard is on the 'B' CCP.

Reset RM-11 alarms from previous Scenarios

Have the above verified by a second person as being correctly performed.

Core age is Middle of Life

Power is 100%. Xenon equilibrium.

Facility:	_WCGS		Scenario No.:2 Op-Test No.:1			
Examine	'S:		Operators:			
See Exar	miner/Oper	rator assigr	nment sheet. This Scenario will be seen by multiple crews.			
Initial Conditions: <u>The core age is Middle of Life (MOL)</u> . The plant has been operating at or near 100% power for the last 42 days. The "B" train Emergency Diesel Generator (EDG) and Centrifugal Charging Pump(CCP) are out of service (OOS) for preventative maintenance. The "D" SG atmospheric relief valve is isolated due to seat leakage. "B" MFP has abnormal vibration.						
Turnover	: Normal Sh	ift Activities	, Weekday Night Shift			
Event No.	Malf. No.	Event Type*	Event Description			
1 T+1.0		N(SRO) R(RO) N(BOP)	Downpower maneuver to remove the MFP from service.			
2 T+7.0	mCVL- 01	C(SRO) C(RO)	VCT divert valve LCV112A-control failure If the operator has begun to borate it will take 6 minutes to reach the low level alarm(first indication). If boration has not commenced an auto makeup will be his first indication within 1-2 minutes.			
3 T+17.	mNIS- 03A	I(SRO) I(RO)	Power Range NI-41 fails high			
4 T+30	mFWM- 03C	I(SRO) I(BOP)	Steam Generator "C" level controller fails in automatic causing the feed reg. valve to begin closing. Manual is available.			
5 T+38	mRCS- 06A	M(SRO) M(RO) M(BOP)	RCS loop A 300 gpm leak			
6 T+38.5	mPCS- 08A&B	C(SRO) C(RO) C(BOP)	The reactor will not trip in manual or automatic. EMG FR-S1 is used to make the reactor subcritical.			
7 T+58	P19046 D (8) 1 P19046 C (8) 0	C(SRO) C(RO)	Loss of CCW to the RCPs			
* (N)orma		tivity (1)	estrument (C)omponent (M)cier			

ILC Scenario #2

Time	Simulator	Events and Procedures	Applicant Actions or Behaviors	Notes
(min)	Instructions			
	Malfunction clock starts when the crew has assumed the watch (T=0) At time T+1 call	Event #1 Downpower maneuver to remove MFP B from service using OFN MA-038 OFN MA-038 Rev 04, Steps:	Event 1 SRO: Direct Crew to reduce power to 50%. Give a rate ≥ 1% to the crew for the power reduction. SRO: Conduct Reactivity Brief.	
	the crew and inform them of the following as the Shift Manager. SGFP vibration data indicates imminent bearing failure. You are directed to immediately begin a power reduction and to be below 50% Reactor Power in one hour.	 Reduce Turbine Load: a. Check desired unloading rate-less than or equal to 5%/minute b. Set Loading/Unloading Rate Limit to desired value c. Select Decrease Loading Rate - ON d. Decrease Load Set MW toward desired load e. Continue with this procedure while reducing turbine load Adjust Control Rods as necessary to establish a target Tavg/Tref Temperature Error between 0°f and +5°F Energize PZR Backup Heaters BB HIS-51A & BB HIS-52A Borate RCS and adjust Control Rods as necessary to establish the following conditions:	 BOP: Reduce Turbine load at designated rate RO: Maintain Tavg/Tref using rods RO: Energize backup heaters RO: Maintain Delta I & RIL using boron and rods 	
	Insert Event 2 with Trigger 2 as soon as down power is commenced ENSURE RO is not at RL002 panel.	 Check PZR level - Stable at or trending to 2255 Fsig Check PZR level - Stable at or trending to program level. Check S/G Levels - Controlling between 45% and 55%. Check AE HV-38 – Open Check Reactor Power – less than 60% 		

	Event 2	
	T VCT Divert Valve LCV112A-control failure	Event 2
It will take approximately 1 minutes to get ANN. 42B. If ti crew has not started to borat an auto makeup will be the first indication of a problem.	 P ALR 00-42B Alarm Window "VCT LEV HILO" is entered when the following occurs P VCT level is less than 22% on BG LB-149D A Place Divert valve in VCT Position ALR 00-42B Check VCT Level -Greater than 97% No - RNO Go to step 10 Check VCT level -Less than 22% BG LI-185 BG LI-185 BG LI-11211. Check Letdown Divert To VCT & RHT Valve- Full open to VCT position. BG HIS-112A No - RNO Place Divert Valve in VCT position Check Makeup to VCT in Progress Check Charging Header Flow and Letdown Flow - Balanced 	 RO: Recognize Actual VCT level low and Divert Valve in HUT position RO: Place Divert valve in VCT position prior to swap to the RWST. SRO: Direct ALR 00-42B RO: Go to step 10. RO: Place divert valve in VCT position
	 Check Annunciator 00-42C, VCT Press HILO clear Ensure BG HIS-112A, LTDWN TO VOL CONT TK/HDUP TK is in AUTO IF the Plant is in Modes 1 or 2 <u>OR</u> in VCT IF plant is in modes 3, 4, 5 or 6. Return to procedure and step in effect. 	SRO: Recognize BG HIS-112A cannot be returned to Auto.

Insert Event #3 with Trigger 3 at time T+33.	 Event 3 7 Power Range NI-41 fails to 120% P NI-41 indicates 120% Rods step in ANN Power Range Chan. DEV A Determine NI failure Determine no runback Take manual control of rods OFN SB-008 (Rev. 11) 1. Check if Secondary System Instrument is Malfunctioning NO 2. Check if Reactor Coolant System Instrument Channel is Malfunctioning. NO 3. Check if Containment or RWST Channels is Malfunctioning. NO 4. Check if Nuclear Instrumentation System Channels is Malfunctioning. NO 4. Check if Nuclear Instrumentation System Channels is Malfunctioning. a. Determine appropriate attachment for malfunctioning channel b. Go to Attachment R Attachment R. R1. Identify failed Instrument Channel. R2. Check Load Rejection - Not in Progress R3. Switch rod control bank selector switch to MANUAL. R4. Bypass Failed Power Range Flux Channel BOP or RO should go to NI racks and bypass channel. R5. Check Rod Control Bank Selector Switch in AUTO. R6 Monitor Rod Control System Response to Ensure 	Event 3 Rose Report problem with Power Range Inst. BOP: Verify no turbine runback in progresss SRO/RO: Take rods to manual CRITICAL TASK: Take manual CRITICAL TASK: Take manual CRITICAL TASK: Take manual control of rods as necessary to prevent reactor trip. STANDARD: This action must be taken in time to prevent a reactor trip. SRO: Enter & Direct OFN SB-008, Attachment R. RO: Identify NI channel is malfunctioning SRO: Go to Attachment R Rose is to manual, previously performed RO/BOP: Perform step R4. To bypass failed channel (5 switches on N panel). RO: Restore rod control to auto and	
	 BOP or RO should go to NI racks and bypass channel. R5. Check Rod Control Bank Selector Switch in AUTO. R6. Monitor Rod Control System Response to Ensure Proper Control R7. Check Failed Power Range Flux channel Not Used For Recording on NR45 and OPDT and OTDT Recorders 	 RO/BOP: Perform step R4. To bypass failed channel (5 switches on NI panel) RO: Restore rod control to auto and monitor rods, as directed. RO/BOP: Ensure SE NI-41 not selected on recorders. 	

ILC Scenario #2

When called as WWM, state you will get a team together to come to the Control Room.	 R8. Pull Control Power Fuses In Power Range Drawer For Failed Power Range Flux Channel. R9. Place Appropriate Reactor Trip/Safeguards Bistables For Failed Power Range Flux Channel in TRIPPED Mode. R10. Request INC Repair failed Channel R11. Monitor Tech Specs: 3.3.1 3.2.4, SR 3.2.4.1 & SR 3.2.4.2 	 RO/BOP: Pull control power fuses. SRO: Contact WWM to trip bistables and repair channel (Note: Tripping of bistables is not required but may be performed) SRO: Evaluate & apply Tech Specs. T.S. 3.3.1 – 6 hours to trip bistables T.S. 3.2.4 – Verify QPTR within 12 hours using incore detectors. 	
	R12. Return to Procedure & step in effect	SRO: Return to procedure and step in effect	

Insert Event #4 with Trigger 4 at time T+40	Event 4TS/G 'C' FRV AE FCV-530 fails closed in autoP'C' S/G Feed flow will decreaseP'C' S/G Level will decreasePALR 110C AlarmsPALR 110B AlarmsARecognize FRV failure & Take manual control of AE FCV-530	Event 4 BOP: Report feedflow decreasing on 'C' S/G. SRO: Direct manual control of 'C' S/G FRV. SRO: Direct use of ALR 00-110C CRITICAL TASK: Take manual control of FRV as necessary to prevent reactor trip. STANDARD: This action must be taken in time to prevent a reactor trip.	
	 Annunciator Response 00-110C Check difference between steam generator C steam flow and feed flow - Greater than 0.7 MPPH Check for instrument failure. Check secondary plant conditions - Stable Restore steam generator C level to program value Check feedwater control valve - Inservice to feed S/G C 	 BOP: Confirms steam flow/feed flow mismatch. BOP: NO Failure Instrument Failure. BOP: Place FRV in manual. BOP: Restore 'C' S/G level. 	
	 b. Place feedwater control valve in manual c. Adjust feedwater control valve as necessary to maintain program value 5. Check for S/G C tube leakage No - RNO Return to procedure and step in effect 	SRO: Return to procedure and step in effect	

Insert Event #5	Event 5 T 300 gpm RCS Leak ramped in over 5 minutes P Pressurizer Level will decrease P Pressurizer Pressure will decrease P Charging flow will increase P VCT level will decrease	Event 5 RO: Report indications of leak. SRO: Direct OFN BB-007	
with TRIGGER 5 at time T+43	A Determine RCS leak in excess of a CCP and initiate a Safety Injection		
	 OFN BB-007: (Rev. 11) 1. Check Plant in Mode 1, 2, or 3 with Accumulator Outlet Valves Open 2. Check PZR level > 6% 3. Check PZR level > 17% 4. Check PZR level stable or increasing NO - RNO Maximize Charging Flow Isolate Letdown 	 RO: Maximize flow from the NCP. RO: Isolate letdown as necessary. RO: Determine leak rate to be in excess of CCP with Letdown isolated SRO: Direct manual trip & SI based on fold out page criteria. RO: Trip the reactor and initiate Safety Inject 	

		1	
	EMG E-0 steps:		
		SRO: Enter and direct E-0.	
	1. Verify Rx trip.		
	a. Check an foo bottom lights in No - Manually trip reactor and Go to EMG	BO: Recognize Reactor did not trip	
	FR-S1.	Ko. Recognize Reactor did not unp	
		SRO: Enter & direct EMG FR-S1	
	<u>Event 6</u>		
		<u>Event 6</u>	
	EMG FR-S1 steps:		
	1. Verify Reactor trip		
	No - RNO	RO: Manually trip the reactor	
	1. Manually trip reactor 2. If reactor will not trip then perform the following	BOP: Manually trip the reactor BO: Insert control rods in manual or	
	a) Insert control rods in auto or manual	automatic.	
	b) Manually deenergize rod drive motor generators	CRITICAL TASK: Insert negative	
	1) Open the breakers for PG-19 and PG-20	reactivity into the core by at least one	
	2) Dispatch operator to trip & bypass breakers	of the following methods before the	
	3) When reactor trip breakers and bypass are	SGs dry out 1) De-energize the control	
	breakers for PG-19 & PG-20	control rods	
	4) Continue with step 2	STANDARD: The reactor must be	
When called as	, the second sec	made subcritical prior to 3 steam	
Aux Bldg. Watch		generator wide range levels reaching	
then Open		8%.	
Reactor Trip		ROP. Open DG HIS 16 and DG HIS 19	
breakers with		breakers that power the rod drive MG	
Trigger 7		sets.	
Call back to		RO: Dispatch NSO to locally open	
report trip		reactor trip breakers	
breakers open.	2. Verify Turbine trip 3. Verify AEW pumps running	BOD: Varify Turbing Trip	
_	4. Check SI - NOT in progress	bor. verny rurome mp	
	RNO - If total ECCS flow from the RWST to the RCS		
	is > 90 gpm then go to step 8.	RO: Determine SI is in progress.	

	8. Check PRZR pressure < 2335 psig	Should have initiated per CRS.	
	9 Verify containment purge isolation	RO : Verify ECCS flow is > 90 gpm	
	y. verny containinent purge isolation.	Ko. Venty Leeb now is > 50 gpm.	
	10. Check SI not actuated		
	No - RNO Perform steps 1-6 of E-0 while continuing	SRO: Direct performance of E-0,	
	with this procedure	Steps 1-6.	
	11. Check if the following trips have occurred	RO/BOP: Performs E-0 steps 1-6	
	a Reactor trip	1	
	h Turbine trip		
	12 Check SC levels		
	13. Verify all dilution paths isolated		
	14. Check for reactivity insertion from uncontrolled RCS	RO: Dispatch NSO to verify dilution	
	cooldown	paths closed	
BGV-187 is not	No - RNO negative MTC Go to step 20		
modeled. Report	20. Stop any controlled cooldown	BOP: Stop any uncontrolled	
BGV-187 is		cooldown.	
closed.			
•100•0	21 Check core exit TCs - Less than 1200°F	RO • Verify CETs $< 1200^{\circ}$ E on NPIS	
	22. Verify reactor subcritical		
	22. Chaole By trip brookers open		
	25. Check RX trip breakers open		
	24. Continue boration until adequate shutdown margin is	CREW: Continue boration until SDM	
	obtained	is obtained	
	25. Check CRDM fans - All available running	RO: Start all available CRDM fans.	
	26.Return to procedure and step in effect		
	EMG E-0 steps:	SRO: Enters EMG E-0 at Step 1. Will	
		perform steps 1-6.	
	1. Verify Rx trip.		
	a. Check all rod bottom lights lit		
	b. Ensure reactor trip breakers and bypass breakers		
	open		
	c Check IR neutron flux decreasing		
	d Transfor ND 45 recorder to intermediate record		
	u. Transfer INK-45 recorder to intermediate range		
	2. verity turbine trip.		
	a. Check the following:		
	Main stop valves all closed		
	OR		
l	Turbine auto stop bistable lights at least two lit		
	b. Check main generator breakers and exciter breaker		

open 3. Check AC emergency busses at least one energized		
 4. Check if SI is actuated Annunciator 00-030A LIT OR Annunciator 00-031A LIT OR ESFAS Status Panel ANY WHITE LIGHT LIT OR Trip Status Panel SI RED LIGHT LIT 5. Check if SI is required: SI manually actuated RCS pressure less than or equal to 1830 psig S/G Pressure less than or equal to 615 psig Containment pressure greater than or equal to 3.5 psig RCS subcooling less than 30°F PZR level less than 6% 6. Verify Automatic Actions Using Attachment F, Automatic Signal Verification 	RO/BOP: Determine SI is required	
ATTACHMENT F F1. Verify feedwater isolation a. Main feedwater pumps tripped b. Main feedwater reg valves closed c. Main feedwater reg bypass valves closed d. Main feedwater isolation valves closed e. Main feedwater chemical injection valves closed f. Check ESFAS status panel SGBSIS section all white lights lit F2. Verify CISA a. Check ESFAS status panel CISA section all white lights lit F3. Verify AFW pumps running	SRO: Direct performance of ATT. F in parallel with E-0/FR S.1RO/BOP: Perform Att. F	

	a Chack motor driven AFW numers both muning		
	a. Check motor unven AF w pumps both fulfilling		
	5. Check turbine unven AF w pump running		
	F4. Verify ECCS pumps running		
	a. Check CCPs both running		
	b. Check SI pumps both running	RO/BOP: Determine CCP B is tagged	
	c. Check RHR pumps Both Running	out.	
	F5.Verify CCW alignment		
	a. Check CCW pumps one running in each train		
	b. Check one pair of CCW service loop supply and		
	return valves for an operating CCW pump open		
	F6. Check ESW pumps both running		
	F7. Verify CTMT fan coolers running in slow speed		
	F8. Verify CPIS		
	a. Check ESFAS status panel CPIS section all white		
	lights lit		
	F9. Verify both trains of CRVIS		
	a. Check ESFAS status panel CRVIS section all white		
	lights lit		
	b. Ensure control room outer door closed		
	F10. Verify main steamline isolation not required		
	a. Check CTMT pressure has remained < 17 psig		
	b. Check either conditions below - satisfied		
	* Low steamline pressure SI - NOT		
	BLOCKED AND steamline		
	pressure has remained > 615 psig		
	* Low steamline pressure SI - BLOCKED		
	AND steamline pressure		
	rate has remained < 100 psi/50 sec		
	F11. Verify CTMT spray not required		
	a. CTMT pressure has remained < 27 psig		
	F12. Verify ECCS flow		
	F13. Verify AFW valves - properly aligned.		
	F14. Verify SI valves - properly aligned.		
	r in vonig si varies property anglesa		

	Event 7		
	T Loss of CCW to RCPs due to closure of CCW to Containment Isolation value	Event 7	
	P Annunciators 00-074A & 00-52A	SRO: Direct ALR usage 74A or 52A or OFN BB-005.	
	P RCP Motor Temperatures increasing rapidly		
	A Secure RCPs or open the CCW bypass valves	RO/BOP: Identify failed closed CCW isolation valve	
T (T) T (T) (T)	OFN BB-005 1. Monitor RCP temperatures		
with TRIGGER	 Check if RCPs can remain running All RCP seal leakoff < 6 gpm 	RO: Monitor RCP temperatures on	
o , at time 1+00.	4. Check #1 seal D/P > 200 PSID5. Verify CCW to service loop and CTMT	NPIS.	
	No - RNO Open bypass valve EG HIS-126Press Non-Iso on EG HIS-126A	RO: Identify failed closed CCW	
	• Press Open on EG HIS-126	isolation valve, EG HIS-71 SRO: Direct RO to open the CCW	
		isolation valve bypass EG HIS-126 or secure RCPs.	
If checked by		RO: Press Non-Iso and Open EG HV- 126.	
RO/BOP RCP Frame		CRITICAL TASK: Open EG HIS-26 or secure the RCP's	
vibration - 2 mils RCP Shaft vibration - 3 mils		STANDARD: Open EG HIS-26 or secure the RCP's within five minutes.	
	EMG E-0 Continued		
	7. Verify AFW flow > 270,000 lbm/hr. 8. Check RCS cold leg temperature - stable		
	a. < 557°F For Steam dumps		

 b. ≤561°F for S/G ARVs. 9. Establish S/G pressure control: a. Check condenser - AVAILABLE b. Place AB PK-507 in MANUAL c. Manually set AB PK-507 output to Zero d. Place Steam Dump Select Switch in STEAM PRESS position 	BOP: Establish Steam dump control to prevent heatup.	
 e. Place Steam Header Pressure Control in Automatic and adjust to maintain existing steam header pressure. o AB PK-507 		
 10. Check PZR PORVs 11. Check normal PZR spray valves closed 12. Check PZR safety valves - closed 13. Check if RCPs should be stopped. 14. Direct operator to monitor CSFSTs 15. Check if SGs are not faulted. 16. Check if SG tubes are intact. 17. Check SG levels increasing in an uncontrolled manner 18. Check if RCS is intact NO - RNO Ensure BIT Inlet and Outlet valves are open and 	RO: Determine RCS not intact	
Go To EMG E-1 EMG E-1 Steps:		
 Check if RCPs should be stopped Check if SGs are not faulted Check intact SG Levels Reset SI 	SRO: Enter and direct EMG E-1 SRO: Conduct Transition Brief.	
5. Reset Containment Isolation Phase A and Phase B	RO: Reset SI RO: Reset CISA/CISB	
Terminate Scenario after transition to EMG E1 or at discretion of Lead Examiner.	E-Plan Classification: -EAL-8, SSFM-1, 2, 3 – SAE PAR – Evacuate CCL and JRR	

	>SCENARIO #2	
	SINITIAL CONDITIONS	
	>OVERPIDE ANN 00-23E	
	IME ANN E023 0	
	NI ANT-20250	
	DE NRCD05P 1	
	> D EDUTAOOED	
	$\frac{1}{10000000000000000000000000000000000$	
	> D SOARVISOLATED	
	>SOFP VIDRATION PROBLEM	
	SET CFC25(2)=1.4	
	>VCI LEVEL DIVERI	
	INF MC VL01(2) 0	
	>UVERRIDE VCT VALVE ANNUNCIATOR	
	IMF ANN-BU58(2) I	
	>PR N41 FAILURE	
	IMF MNIS03A (3) 120 30	
	>SG "C" LEVEL CONTROL FAILURE	
	IMF MFWM03C (4) 50 10	
	>RCS LOOP A LEAK	
	IMF MRCS06A (5) 300 120	
	>ATWT Event 6	
	IMF MPCS08A	
	IMF MPCS08B	
	>OPEN TRIP BREAKERS	
	IRF RCRF05 (7) 1	
	IRF RCRF06 (7 3) 1	
	>LOSS OF CCW TO RCP'S	
	IOR P19046D (8) 1	
	IOR P19046C (8) 0	
	> OVERRIDE ESFAS PANEL LIGHTS - CRVIS	
	TRGSET 1 "JPPLSI(1)"	

ILC Scenario #2

	IMF SA066Y_C14W (1) 1 IMF SA066Y_C15W (1 35) 1 IMF SA066Y_C16W (1 35) 1	
	IMF SA066Y_G15W (1) 1	
	>End of File	

APF 21-001-02 Rev. 13	s Page	CONTROL	ROOM	[T]	URNOVER	CHECKI	IST		KUZ-UUIC	
DATE : Today		NIGHT SHIF	т		DAY	SHIFT	 ✓		MODE-	1
FF-GOING: (PRINT)	CRS				ON-COMING	(PRINT)		CRS		
	RO			_				RO		
	BOP							BOP		
	SE							SE		
		ON-0	COMING	CRS	/SE/RO/BOP	REVIEW				
EVOLUTIONS IN PROGRES	S:									
1) "D" SG ARV isolated	d due to	leakage.								
			R							
		A		-						
MATNITENANCE IN DROCPE	ss: [Co	mmitment Sta	ang 3 2	10	3 2 1 2 1					
1) "B" Emergency Di		anerator	-25 3.2		, J.Z.IZ]					
) »B" Changing Dump	eser Ge	Ellerator								
2) "B" Charging Pump										
TESTING IN PROGRESS:	[Commit	ment Steps	3.2.10.	3.	2.121					
	[COMMIT C		5.2.107	5.						

CONTROL ROOM TURNOVER CHECKLIST COMMENTS:	APF	21-001	-02	Rev.	13	Page	2 of 4			K02-001C
COMPETTS:							CONTROL	ROOM	TURNOVER	CHECKLIST
FOLLOW-UP RUTTONS:	CON									
NORE REQUEST:	CON	ITEN 15.								
NORK REQUEST:										
FOLLOW-UP BUTTORS:										
NORK REQUEST:										4
FOLLCM-UP BUTTONS:										
NORK REQUEST:										
FOLLOW-UP BUTTONS:										
FOTTON-DE BALLONS:										
FOLLOW-UP BUTTONS:										
NORK REQUEST:										
NORK REQUEST:										
NORK REQUEST:										
MORK REQUEST:										
NORK REQUEST:										
WORK REQUEST:										
WORK REQUEST:										
WORK REQUEST: WORK REQUEST:								-		
WORK REQUEST:										
NORK REQUEST:										
NORK REQUEST:							-		•	
WORK REQUEST:										
VORK REQUEST:										
FOLLOW-UP BUTTONS:	WOR	K REQUE	ST:							
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:						2)				
FOLLOW-UP BUTTONS:						-				
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:				1						
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:	EQ-			0110 -						
	FOL	TOM-Ob]	s∩.1.1.	UNS:						
APF 21-001-02 Rev.	13 Page 3 of 4	K02-001C								
--	---	-------------------------------------								
	CONTROL ROOM TURN	IOVER CHECKLIST								
REACTOR POWER	100 % RCS: 580	5.5 °F <u>2235</u> PSIG								
ROD CONTROL	AUTO 🗸									
	MANUAL									
Control bank d	229 STEPS									
RCS BORON (C _b)	911 PPM @ D2	ATE/TIME Today / 0430								
EAK RATE (GPM):	IDENTIFIED 0.008 UNIDEN	TIFIED 0.067 @ DATE/TIME Today/0430								
COND. AIR INLEAKAGE IAW STN CH-020)	29.1/ Today	SF								
CANKS AP FILL	ING AN FILLING	BL FILLING BL ON RECIRC								
CONDENSATE DEMINS IN	I SERVICE A B									
PANEL	ESF STATUS PANELS AND REF COMPONENT/TRIP/BLOCK	ACTOR TRIP/BLOCK PANEL REASON								
SA066Y	"B" CCP	PM′s								
SA066Y	"B" EDG	PM's								
) •									
I										

	ONLY

FORTRAMME

APF 21-001-02 Rev. 13 Page 4 of 4

CONTROL ROOM TURNOVER CHECKLIST

ON-COMING CRS/SE/RO/BOP REVIEW (Check Box)

PR	IOR TO	ASSUM	ING WATO	CH	
	CRS	SE	RO	BOP	
					CONTROL ROOM LOGS
					ESSENTIAL READING
					CLEARANCE ORDER LOG
					INSTRUMENT OUT-OF-SERVICE LOG
					EQUIPMENT OUT-OF-SERVICE LOG
					ACTION STATEMENT SUMMARY
					SURVEILLANCE SCHEDULE
		N/A			FIRE PROTECTION PERMITS
		N/A	N/A	N/A	KC008 NOT DISABLED/DISARMED WITHOUT DOCUMENTATION
		N/A	N/A	N/A	DISCHARGE PERMITS
					MCB WALKDOWN WITH OFF-GOING WATCH
AF	TER AS	SUMING	WATCH		
1	CRS	SE	RO	BOD	
		27 / 2	27 / 2	27.12	TEMP MOD LOG
		N/A	N/A	N/A	LOCKED VALVE LOG
		NT / N	NT / 7	NT / 7	COMPUTER ALARM SUMMARY
		N/A	N/A	N/A	CONDUCT SHIFT BRIEF
		NT / 7	N/A	N/A	P-2 SCHEDULE
		N/A	N/A	N/A	OPEN PROCEDURES BOOK [Commitment Step 3.2.18]
ļ				-	OPEN WCGS SUBSTATION WORK AUTHORIZATION FORMS [Commitment Step 3.2.27]
ΑT	TACH AI	NY ADD	ITIONAL	PAGES N	EEDED TO DESCRIBE PLANT CONDITIONS. MARK THE NUMBER OF ADDITIONAL PAGES
		-			
OF	F-GOIN	Ŧ			ON-COMING
	CRS				CRS
	RO				RO
	BOP				вор
	٩F				<u>्</u> म
	10			INITIALS	INITIALS

K02-001C

ALARM WINDOW DESCRIPTION

<u>Window</u>	Name	Reason	WR/WO
00-021F	NB02 Bkr Not Operable	"B" CCP OOS	
00-023E	B EDG OOS	"B" Master Transfer Switch in Local/Manual	

INTERMITTENT ALARMS

· · · · · · · · · · · · · · · · · · ·	

KC008 ALARMS					

APF 21H-001-01 REV 02

		INS	TRUMEN	IT OUT OF SERVIC	E LOG		
005	COMPUTER	DOCUMENT NUMBER	OOS	AFFECTED COMPUTER	REASON	SM/CRS VERIFIED	TAG REMOVAL
SEQUENCE	POINT	(2)	TIME/	PROCESS OR READ-OUT	APPLIED	APPLICABLE TS,	AUTHORIZATION
NUMBER	DESIGNATOR		DATE	DEVICE		TRM AND MODE	(SM/CRS INITIAL
	(1)					RESTRAINT	TIME AND DATE)
			0000 /	NE02 DIESEL FIELD	FAULTY		
96-3		SMP 96-135	3/27/97	AMP METEER	METER		
			0000 /	NE01 DIESEL FIELD	FAULTY		
96-4		SMP 96-135	3/27/97	AMP METEER	METER		
				C.L.			
				3			
			C				
		-FRA					
	FO.	P					

NOTE: 1) FOR INSTRUMENTS OTHER THAN COMPUTER POINTS ENTER N/A.

2) VERIFY OOS SEQUENCE NUMBER IS ON ACTION/WORK REQUEST AND LIST ACTION/WORK REQUEST NUMBER IN THIS COLUMN.

APF 21F-001-01 REV 01

EQUIPMENT OUT OF SERVICE LOG							
EOL DATE/NUMBER	SYSTEM	DECLARED INOPERABLE DATE/TIME/INITIAL	REQUIRED RETURN DATE/TIME/INITIAL	APPLICABLE MODES	MODE RESTRAINT	TECH SPEC TRM	DECLARED OPERABLE DATE/TIME/INITIAL
		(SM/CRS)	(SM/CRS)			ODCM	(SM/CRS)
REMARKS/EQUI	PMENT/AR	/TMO/CO/RETEST					
	Г	1					<u> </u>
01-001	AB	Today/0700/CRS	30 Days/0700/CRS	1,2,3	3	3.7.4 Condition D	
"D" ARV isol	"D" ARV isolated for excessive leakage, repair within 30 days.						
	T	1					-
01-002	BG	Today/0700/CRS	72 Hours/0700/CRS	1,2,3	3	3.5.2 Cond. A TRM 3.1.9 Cond. A	
"B" CCP out	for PM's						
01-003	KJ	Today/1200/CRS	72 Hours/1200/CRS	1,2,3,4	4	3.8.1 Cond. B	
"B" EDG		2	I				
	-						

APF 21-001-10, Rev. 01

		AC	CTION STATEMENT	SUMMARY LOG	
E.O.L.	TECH SPEC #	ENTERED	DEADLINE	REMARKS	RESTORED
YR.		DATE/TIME/SM/CR	DATE/TIME/SM/CR		DATE/TIME/SM/CR
		S	S		S
01-001	3.7.4	Today/0700/	30 days	Restore ARV	
		CRS			
01-002	3.5.2	Today/0700/	72 hours	Restore B CCP	
		CRS			
01-002	TRM 3.1.9	Today/0700/	72 hours	Restore B CCP	
		CRS			
01-003	3.8.1	Today/1200/	72 hours	Restore B EDG	
		CRS			
01-003	3.8.1	Today/1200/	Today/1300/	Perform STS NB-01	Today/1245/
		CRS	CRS		CRS
01-003	3.8.1	Today/1245/	Today/2045/	Perform STS NB-01	
		CRS	CRS		

FORTRAMMEUSEONIN

>SCENARIO #2 >INITIAL CONDITIONS >OVERRIDE ANN 00-23E IMF ANN-E023 0 >"B" CHARGING PUMP TAGGED IRF NBGP05B 1 >"B" EDG TAGGED IMF MDGS02B IRF N1NB211 1 >"D" SG ARV ISOLATED IRF rMSS06 0 >SGFP VIBRATION PROBLEM SET CFC25(2)=1.4 >VCT LEVEL DIVERT IMF MCVL01(2) 0 >OVERRIDE VCT VALVE ANNUNCIATOR IMF ANN-B058(2) 1 >PR N41 FAILURE IMF MNIS03A (3) 120 30 >TRIP BS IMF ANN-B093 (9) 0 IMF BST-JTB411C (9 10) 0 IMF BST-JTB411D (9 13) 0 IMF BST-JTB411G (9 16) 0 IMF BST-JTB411H (9 19) 0 >SG "C" LEVEL CONTROL FAILURE IMF MFWM03C (4) 50 10 >RCS LOOP A LEAK IMF MRCS06A (5) 300 120 >ATWT Event 6 IMF MPCS08A IMF MPCS08B >OPEN TRIP BREAKERS IRF RCRF05 (7) 1 IRF RCRF06 (7 3) 1 >LOSS OF CCW TO RCP'S IOR P19046D (8) 1 IOR P19046C (8) 0 > OVERRIDE ESFAS PANEL LIGHTS - CRVIS TRGSET 1 "JPPLSI(1)" IMF SA066Y_C14W (1) 1 IMF SA066Y C15W (1 35) 1 IMF SA066Y_C16W (1 35) 1 IMF SA066Y G15W (1) 1 >End of File



INITIAL LICENSE EXAM

DECEMBER 2001

DYNAMIC SCENARIO #3

Revision 1, 11/27/2001

/S/	/ 11/30/2001	<u>/S</u> /		/ 11/30/2001
Robert Acree		Howard Bundy		
WCGS Exam Author	DATE	NRC Chief Examiner	DATE	

Scenario Objectives:

- 1. Evaluate the ability to perform normal operations by controlling the unit during a power decrease.
- 2. Abnormal actions and Technical Specifications usage are evaluated by diagnosing and correcting:
 - Failed RCS Temperature Instrument
 - Failed S/G Level Instrument
 - Failed Open S/G Atmospheric Relief Valve
 - Failure of a S/G Feedwater Isolation Valve to close.
- 3. Emergency actions are evaluated for:
 - A Loss of Offsite Power
 - Bus Lockout on one Emergency Bus
 - 4. Contingency actions are evaluated for a failure of the Essential Service Water Pump to automatically start and supply cooling water to the Emergency Diesel Generator.

Scenario Assignments

Crew A

Examiners: <u>BUNDY (E1)</u> JOHNSTON (E3) <u>GAGE (E2)</u> Operators: <u>PENDERGRASS (SO1)</u> <u>PITT (RO2)</u> <u>WILSON (RO1)</u>

Crew B

Examiners: <u>BUNDY (E1)</u> JOHNSTON (E3) <u>GAGE (E2)</u> Operators: <u>BELL (SO2)</u> <u>LAZAROWSKI (RO3)</u> <u>SIMMS (SO3)</u>

GENERAL REFERENCES

NUREG 1021, Rev. 8, Supplement 1, OPERATOR LICENSING EXAMINATION STANDARDS FOR POWER REACTORS OFN SB-008, Rev. 11, "INSTRUMENT MALFUNCTIONS" EMG E-0, Rev. 14, "REACTOR TRIP OR SAFETY INJECTION" EMG ES-02, REV. 12, "REACTOR TRIP RESPONSE" GEN00-004, Rev. 42, "POWER OPERATION" RESET TO IC 173 AND PLACE SIMULATOR IN RUN PRIOR TO LOADING BATCH FILE. Ensure simulator is in run or file will not load properly. You may freeze after file is loaded.

Insert Floppy disk and save the batch file LO01_003 to OPENSIM/BATCH, then open Ph.D. Expert and type "BAT LO01_003.txt"

FREEZE till the Crew assumes the watch.

<u>NOTE:</u> FILE **LO01_003.txt** preloads all LOAs and/or malfunctions required for this scenario. Simulator commands and other functions to be performed by the booth operator are shown in **BOLD**. Trigger commands are used to initiate events and commands.

HANG DNO tag on FC HIS-118 'B' MFP Trip/Reset push-button.

ENSURE 'LOAD DECREASE' circuit on.

ENSURE that a Current, signed copy of GEN 00-004 is available for the SRO.

ENSURE the horns are ON

ENSURE Control Rods are at 160 STEPS on Bank D

ENSURE placard is on the 'A' CCP.

ENSURE both sets of Back up Heaters are ON.

ENSURE Rods are in Auto.

Reset RM-11 alarms from previous Scenarios

Have the above verified by a second person as being correctly performed.

Core age is Middle of Life

Power is 48%. Xenon equilibrium.

Coffey County is in a Severe Thunderstorm Watch.

(
Facility: _	WCGS	<u> </u>	Scenario No.:3 Op-Test No.:				
See Crev	v Assignme	ents. Multip	le Crews will be tested on this Scenario.				
Initial Conditions: <u>Reduction from 100% power in progress. Currently at 48% Power. "B"</u> <u>Main Feed Pump Tagged out for maintenance on control valve linkage. Severe Thunderstorm</u> <u>Watch in effect for Coffey County.</u> Turnover: <u>Continue power reduction to 33% (400MWe) to remove all heater strings. OFN</u> <u>AF-025 is in effect. Presently at step 6.2.11 of GEN00-004,"POWER OPERATION".</u>							
EventMalf.EventNo.No.Type*Description							
1 T+0		R-RO N-BOP N-CRS	Continue Power reduction to 33% at ½ % per minute.				
2 T+7	mRCS 01I	I-RO I-CRS	Loop 1 Thot fails high causing a rod insertion.				
3 T+17	mFWM 02B3	I-BOP I-CRS	"B" SG Level AE LT-529 fails high.				
4 T+23	mEPS 01A and 1B	M-All	Sequential Loss of Offsite Power, Reactor Trips due to low RCS flow. NB01 "A" Emergency Bus has a bus Lock Out.				
5 T+23	P19019 B	C-RO C-CRS	"B" ESW pump fails to Auto start. RO/CRS must get "B" ESW pump started prior to the EDG overheating causing entry into EMG C-0.				
6 T+33	mMSS 07A	C-BOP C-CRS	"A" SG ARV fails open.				
* (N)orma	(N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)aior						

ILC Scenario #3

Time	Simulator	Events and Procedures	Applicant Actions or Behaviors	Notes
(min)	Instructions			
	Malfunction clock starts when the crew has assumed the watch (T=0)	Event #1 T Decrease Power to 33% @ ½ % per minute. P Reactor power & turbine load decrease. A Perform GEN 00-004	Event 1 Crew will review previous steps during pre-brief, crew enters Gen 00-004 at step 6.2.11.	
		 GEN 00-004: steps 6.2.2.2 Reduce turbine Load using Load limit or Load Set <i>Turnover directs use 'Load Set'</i> 6.2.3 Decrease turbine load 6.2.4 Ensure AE HV-38 is closed. 6.2.5 Maintain ΔI & RIL 6.2.10 When Rx power < 48% verify P-8 bistables clear. 6.2.11 When Rx power <40% S/D one Heater drain pump. 6.2.12 When turbine power < 35% for > 6 minutes ensure AMSAC <u>NOT</u> armed. 	 SRO: Direct a power decrease per GEN 00-004 SRO: Conduct a Reactivity Brief. RO/BOP: Coordinate power reduction. BOP: Decrease turbine load RO: Adjust rods & boron as necessary RO: Maintain Tavg/Tref using rods 	

Insert Event 2	Event 2	<u>Event 2</u>
with Trigger 2	 T Loop 1 T_{HOT} Fails to 630°F P Loop 1 Tavg fails high, causing rods to step in ANN 067 thru 069B & D will alarm A Stop Rod Motion 	 RO: Report Inward Rod Motion BOP: Report <u>NO</u> load rejection SRO/RO: Place rods in manual. SRO: Direct RO to place rods in manual OR RO: Place rods in manual and inform SRO. CRITICAL TASK: Take manual control of rods as necessary to prevent reactor trip. STANDARD: This action must be taken in time to prevent a reactor trip.
	OFN SB-008 REV 11 ACTIONS: 1. Check if Sec Sys Inst Channel is malfunctioning. <i>NO</i> 2. Check if RCS Inst Channel is malfunctioning. <i>YES, go to ATT L.</i> ATT L:	SRO: Enter & direct OFN SB-008 Attachment L
	 L1. Check Load Rejection. <i>NONE</i> L2. Switch Rod Control to MAN. L3. Check Stm Dumps. <i>CLOSED</i> L4. Identify Failed Channel. L5. Remove failed channel from ΔT and Tavg. L6. Check temp error W/I 1°F. 	 BOP: Report STM DMPS closed. RO: Identify Loop 1 Temp. Inst. failed. RO: Defeat failed channel. SRO/RO: Restore Tavg. SRO: Conduct Reactivity Brief RO: Withdraw control rods as directed by SRO. (Crew may not restore Tavg and choose to

ILC Scenario #3

		reduce Turbine load instead.	
	 L7. Check rod control in AUTO. L8. Monitor Rod Control for proper response. L9. Check C-7 INTLK not lit. <i>NOT LIT</i> L10. Check Steam Dumps BYP-INTLK switches on. L11. Monitor stm dumps 	RO: Place rods in mode directed by SRO.BOP: Report C-7 not lit & dumps functioning correctly	
	OT Δ T recorders.	RO/BOP: Select Alternate Channel.	
When called as Work Week Manager (WWM) state	L13. Place B/S in the tripped condition. L14. Request INC to repair failed channel. L15. Check C-16 Hold Circuit - CLEAR L16. Monitor T.S. 3.3.1	SRO: Contact WWM for assistance.	
you will get a team together.		SRO: Evaluate & Apply Tech Specs. T.S. 3.3.1, Table 3.3.3, Functions 6 & 7 Trip Bi-stables within 6 hours.	
	L17. Return to procedure and step in effect	SRO: Return to GEN 00-004.	

Insert Event #3 with Trigger 3	Event 3 T 'B' S/G Level Channel Fails High AE LI-529 P Annunciator 110B SG B Level DEV P 'B' FRV Throttle Shut to Maintain Level A Restore 'B' S/G Level OFN SB-008 (Rev. 11)	Event 3 BOP: Report 'B' S/G level problem. SRO/BOP: Take manual control of SG "B" FRV. SRO: Direct BOP to take Manual Control. OR BOP: Take manual control and inform SRO. CRITICAL TASK: Take manual control of "B" FRV or select out failed channel. STANDARD: This action must be taken in time to prevent a reactor trip.	
When called as WWM state you will get a team together.	 Actions: 1. Check if secondary system instrument channel is malfunctioning a. Determine appropriate attachment for malfunctioning channel b. Go to Attachment F F1. Identify failed level channel F2. Check if failed S/G level channel used for feedwater control. F3. Select the alternate S/G level channel. F4. Monitor S/G level response to ensure proper control. F5. Trip bistables F6. Place AMSAC in TRIP condition F7. Request I&C to repair failed channel. 	 SRO: Enter & direct OFN SB-008 RO/BOP: Identify AE LI-529 as failed Instrument. BOP: Select Alternate Instrument. SRO/BOP: Restore 'B' S/G level. SRO: Contact WWM for assistance. SRO: This channel does not require tripping for AMSAC 	

	 F8. Monitor Tech. Specs. 3.3.1 3.3.2 3.3.4, Table 3.3.4-1, Function 8 3.3.3 Table 3.3.3-1, Function 13 F9. Review Att. S F10. Return to procedure and step in effect 	 SRO: Evaluate & Apply Tech Specs. 3.3.1 = 6 hours to trip bi-stables 3.3.2 = 6 hours to trip bi-stables 3.3.4 = N/A 3.3.3 = N/A SRO: Review attachment 'S' & apply 3.3.4, 2of 3 channels required. SRO: Return to GEN 00-004. 	

Insert Event #4 with Trigger 4 NOTE: May have to call as System Ops & inform control room of loss of Benton line.	Event 4 T Sequential Loss of Off-Site Power P Loss of Power from Benton P Lightning Strike in Switchyard P Rx trip due low RCS flow P Bus Lock Out on NB01 A Enter EMG E-0 EMG E-0 STEPS (REV 14) ACTIONS: 1. Verify Rx trip. a. Check all rod bottom lights lit b. Ensure reactor trip breakers and bypass breakers open c. Check neutron flux decreasing d. Transfer NR-45 recorder to intermediate range 2. Verify turbine trip. a. Check the following: * Main stop valves all closed OR * Turbine auto stop bistable lights at least two lit b. Check main generator breakers and exciter breaker open	Event 4 When the crew is made aware of loss of Benton line the SRO may review OFN AF- 025. Maintain gen. load < 995 MWe. (Gross) SRO: Enter and direct EMG E-0 RO/BOP: Perform Immediate Actions RO: Verify Reactor Trip BOP: Verify Turbine Trip.	
--	--	---	--

"B" ESW pump failed to auto start. "A" ESW pump trips.	Event 5T"B" ESW pump fails start to supply cooling water to the "B" EDGPGreen light lit on HandswitchAStart the "B" ESW pump3.Check AC emergency busses at least one energized	Event 5 RO: Recognize NB01 has a Bus Lock Out. Only NB02 bus is energized by the EDG, the RO should check that cooling water is supplied. SRO/RO: Start 'B' ESW pump. CRITICAL TASK: Establish Cooling Water to the Emergency Diesel Generator. STANDARD: Manually start at least one ESW pump in an operating safeguards train before required diesel generator trips or before the end of the scenario.	
	 4. Check if SI is actuated – NO perform RNO RNO – Check if SI is required PZR Pressure < 1830 psig Steam Line Pressure < 615 psig CTMT Pressure > 3.5 psig PZR Level < 6% Subcooling < 30 degrees 	RO/BOP : Check SI Parameters	
	Go to EMG ES-02 EMG ES-02	SRO: Transition Brief for EMG ES-02	
	EMG ES-02 steps: 1. Check RCS cold leg temperatures stable	SRO: Enter & direct EMG ES-02	

ILC Scenario #3

	at 557°F or <557°F 2. Establish SG pressure control	BOP: Stabilize RCS Temperature using ARVs.	
Insert EVENT 7 with TRIGGER 7 at step 3.	 3. Check feedwater status a. Tavg< 564°F b. Check main feedwater pumps tripped c. Check MFIVs closed c. Check total feed flow to SGs > 270,000 lbm/hr 	Event 7 SBO/BOB: Take menual control of 'A' ABV	
	 T "A" SG ARV fails open P RCS temperature decreases P Steam Flow indication increases A Recognize cooldown and close "A" ARV. 	 CRITICAL TASK: Close "A" ARV STANDARD: This action must be taken in time to prevent an unnecessary 'MSLIS'. 	
At Step 4 of EMG ES-02: CALL as System Ops and inform SRO that the estimate is 30 minutes to restore power to the Switchyard.	 4. Verify instrument air to containment a. Check ESW to air compressor valves - open b. Check air compressor breaker reset switches - closed c. Check instrument air pressure > 105 psig d. Check KA HIS-29 open 5. Check charging pumps - at least one running 6. Verify charging system aligned for normal injection 7. Check charging flow established 	Time required to restore power to the switchyard is required to allow the SRO to Classify the event.	
	 8. Check all control rods fully inserted 9. Check PZR level > 17% 	E-Plan Classification: EAL-6 Loss of Electrical Power 6-LEP/AC - 1, 2, 5 - ALERT	

	Terminate Scenario after transition to EMG ES-02 or at discretion of Lead Examiner.	
	>INITIAL SIM EXAM 01-03	
	> >SET-UP RTD FAILURE IMF mRCS01I (2) 650 15	
	> >SET-UP S/G LEVEL FAILURE IME mEW/M02B3 (3) 100 20	
	> >SET-UP LOSS OF POWER	
	IMF mEPS01A (4) IMF mEPS01B (4 60) IMF mEPS06A (4 65)	
	>	
	>SET-UP 'B' ESW PUMP FAILURE TO AUTO START IOR p19019B 0	
	> >SET-UP 'A' ARV FAILURE	
	IMF mMSS07A (7) 100 25 > >End of File	

APF 21-001-02 Rev. 1	3 Page	1 of 4 CONTE	ROL RO	DOM I	URNOVER	CHECKL	IST		K02-001C	
DATE : Today		NIGHT	SHIFT		DAY	SHIFT	1		MODE-	1
TE COINCE (DDINT)	CDC				ON COMTNO			CD C		
F-GOING: (PRINI)	PO				ON-COMING.	(PRINI)		PO		
	RO									
	SE							SE		
	56							5E		
			ON-COM	ING CRS	S/SE/RO/BOP	REVIEW				
EVOLUTIONS IN PROGRES	s:								*	
L) Continue downpower	at ½% p	per minut	te to 33	3%. Ren	ove all he	ater strin	gs fro	m service.		
2) GEN 00-004 complet	e throug	gh step (6.2.13.					J.		
3) Severe Thunderstor	m Watch	issued :	for Coff	Eey Coi	inty					
· ·				1	-					
			1	11						
			7/							
MAINTENANCE IN PROGRE	SS: [Co	ommitment	t Steps	3.2.10), 3.2.12]					
1) "B" Main Feed Pump										
)									
TESTING IN PROGRESS:	[Commit	ment Ste	eps 3.2.	.10, 3.	2.12]					
										-

CONTROL ROOM TURNOVER CHECKLIST COMMENTS:	APF	21-001	-02	Rev.	13	Page	2 of 4			K02-001C
COMPETTS:							CONTROL	ROOM	TURNOVER	CHECKLIST
FOLLOW-UP RUTTONS:	CON									
NORE REQUEST:	CON	ITEN 15.								
NORK REQUEST:										
FOLLOW-UP BUTTORS:										
NORK REQUEST:										4
FOLLCM-UP BUTTONS:										
NORK REQUEST:										
FOLLOW-UP BUTTONS:										
FOTTON-DE BALLONS:										
FOLLOW-UP BUTTONS:										
NORK REQUEST:										
NORK REQUEST:										
NORK REQUEST:										
MORK REQUEST:										
NORK REQUEST:										
WORK REQUEST:										
WORK REQUEST:										
WORK REQUEST: WORK REQUEST:								-		
WORK REQUEST:										
NORK REQUEST:										
NORK REQUEST:							-		•	
WORK REQUEST:										
VORK REQUEST:										
FOLLOW-UP BUTTONS:	WOR	K REQUE	ST:							
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:						2)				
FOLLOW-UP BUTTONS:						-				
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:				1						
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:	EQ-			0110 -						
	FOL	TOM-Ob]	s∩.1.1.	UNS:						

APF 21-001-02 Rev.	13 Page 3 of 4 K02-001C
	CONTROL ROOM TURNOVER CHECKLIST
REACTOR POWER	48 % RCS: 570 °F 2235 PSIG
ROD CONTROL	AUTO 🗸
	MANUAL
CONTROL BANK D	160 STEPS
RCS BORON (C _b)	969 PPM @ DATE/TIME Today / 0430
LEAK RATE (GPM):	IDENTIFIED 0.008 UNIDENTIFIED 0.067 @ DATE/TIME Today/0430
COND. AIR INLEAKAGE IAW STN CH-020)	29.1/ Today
TANKS AP FILL	ING AN FILLING BL FILLING BL ON RECIRC
CONDENSATE DEMINS IN	N SERVICE A B C I D E F
	ESF STATUS PANELS AND REACTOR TRIP/BLOCK PANEL
PANEL	COMPONENT/TRIP/BLOCK REASON

	ONLY

FORTRAMME

APF 21-001-02 Rev. 13 Page 4 of 4

CONTROL ROOM TURNOVER CHECKLIST

ON-COMING CRS/SE/RO/BOP REVIEW (Check Box)

PF	IOR TO	ASSUM	ING WATO	СН								
	CRS	SE	RO	BOP								
					CONTROL ROOM LOGS							
					ESSENTIAL READING							
					CLEARANCE ORDER LOG							
					INSTRUMENT OUT-OF-SERVICE LOG							
					QUIPMENT OUT-OF-SERVICE LOG							
					ACTION STATEMENT SUMMARY							
					SURVEILLANCE SCHEDULE							
		N/A			FIRE PROTECTION PERMITS							
		N/A	N/A	N/A	KC008 NOT DISABLED/DISARMED WITHOUT DOCUMENTATION							
		N/A	N/A	N/A	DISCHARGE PERMITS							
					MCB WALKDOWN WITH OFF-GOING WATCH							
AF	TER AS	SUMING	WATCH									
1	CRS	SE	RO	BOD								
		27 / 2	27 / 2	27.12	TEMP MOD LOG							
		N/A	N/A	N/A	LOCKED VALVE LOG							
		NT / N	NT / 7	NT / 7	COMPUTER ALARM SUMMARY							
		N/A	N/A	N/A	CONDUCT SHIFT BRIEF							
		NT / 7	N/A	N/A	P-2 SCHEDULE							
		N/A	N/A	N/A	OPEN PROCEDURES BOOK [Commitment Step 3.2.18]							
ļ				-	OPEN WCGS SUBSTATION WORK AUTHORIZATION FORMS [Commitment Step 3.2.27]							
ΑT	TACH A	NY ADD	ITIONAL	PAGES N	EEDED TO DESCRIBE PLANT CONDITIONS. MARK THE NUMBER OF ADDITIONAL PAGES							
OF	F-GOIN	r			ON-COMING							
01	1 00110											
	CRS				CRS							
	RO				RO							
	BOP				ВОР							
1	C.L.				C F							
	10			INITIALS	INITIALS							

K02-001C

ALARM WINDOW DESCRIPTION

<u>Window</u>	Name	Reason	WR/WO

INTERMITTENT ALARMS

KC008 ALARMS							

APF 21H-001-01 REV 02

INSTRUMENT OUT OF SERVICE LOG							
005	COMPUTER	DOCUMENT NUMBER	OOS	AFFECTED COMPUTER	REASON	SM/CRS VERIFIED	TAG REMOVAL
SEQUENCE	POINT	(2)	TIME/	PROCESS OR READ-OUT	APPLIED	APPLICABLE TS,	AUTHORIZATION
NUMBER	DESIGNATOR		DATE	DEVICE		TRM AND MODE	(SM/CRS INITIAL
	(1)					RESTRAINT	TIME AND DATE)
			0000 /	NE02 DIESEL FIELD	FAULTY		
96-3		SMP 96-135	3/27/97	AMP METEER	METER		
			0000 /	NE01 DIESEL FIELD	FAULTY		
96-4		SMP 96-135	3/27/97	AMP METEER	METER		
				C.L.			
				3			
			C				
		-FRAN					
	FO.	P					

NOTE: 1) FOR INSTRUMENTS OTHER THAN COMPUTER POINTS ENTER N/A.

2) VERIFY OOS SEQUENCE NUMBER IS ON ACTION/WORK REQUEST AND LIST ACTION/WORK REQUEST NUMBER IN THIS COLUMN.

APF 21F-001-01 REV 01

EQUIPMENT OUT OF SERVICE LOG									
EOL		DECLARED INOPERABLE	REQUIRED RETURN	APPLICABLE	MODE	TECH SPEC	DECLARED OPERABLE		
DATE/NUMBER	SYSTEM	DATE/TIME/INITIAL	DATE/TIME/INITIAL	MODES	RESTRAINT	TRM	DATE/TIME/INITIAL		
		(SM/CRS)	(SM/CRS)			ODCM	(SM/CRS)		
REMARKS/EQUI	PMENT/AR/	TMO/CO/RETEST							
01-001	FC	Today/0700/CRS	N/A	N/A	N/A	N/A			
"B" MFP, For	Tracking	g Only	S						
							I		
		2							
							1		
		· · · · · · · · · · · · · · · · · · ·							
	1	11		I			1		

APF 21-001-10, Rev. 01

ACTION STATEMENT SUMMARY LOG						
E.O.L.	TECH SPEC #	ENTERED	DEADLINE	REMARKS	RESTORED	
YR.		DATE/TIME/SM/CR S	DATE/TIME/SM/CR S		DATE/TIME/SM/CR S	
				04-		
			9*			
	*					

FORTRAMMEUSEONIN

```
>INITIAL SIM EXAM 01-03
>
>SET-UP RTD FAILURE
IMF mRCS01I (2) 650 15
>
>SET-UP S/G LEVEL FAILURE
IMF mFWM02B3 (3) 100 20
>
>SET-UP LOSS OF POWER
IMF mEPS01A (4)
IMF mEPS01B (4 60)
IMF mEPS06A (4 65)
>
>SET-UP 'B' ESW PUMP FAILURE TO AUTO START
IOR p19019B 0
>
>SET-UP 'A' ARV FAILURE
IMF mMSS07A (7) 100 25
>
>End of File
```



INITIAL LICENSE EXAM

DECEMBER 2001

DYNAMIC SCENARIO Spare

Revision 1, 11/27/2001

/S// 11/30/2001/S// 11/30/2001Robert AcreeHoward BundyWCGS Exam AuthorDATENRC Chief ExaminerDATE

1

Scenario Objectives:

- 1. Evaluate the ability to perform normal operations by increasing power from 10^{-8} amps to 1%.
- 2. Abnormal actions and Technical Specifications usage are evaluated by diagnosing and correcting:
 - PZR Pressure Channel failing high
 - SG Level Channel Fails Low
 - Excessive PORV seat leakage requires closure of the associated block valve.
- 3. Emergency actions are evaluated for a Main Steam Line Break, inside of Containment.
- 4. Contingency actions are evaluated for a failure of the MSIV's to automatically close and failure of Containment Isolation Phase A.
GENERAL REFERENCES

NUREG 1021, Rev. 8, Supplement 1, "OPERATOR LICENSING EXAMINATION STANDARDS FOR POWER REACTORS" OFN SB-008, Rev. 11, "INSTRUMENT MALFUNCTIONS" GEN 00-003, Rev. 52, "HOT STANDBY TO MINIMUM LOAD" EMG E-0, Rev. 14, "REACTOR TRIP OR SAFETY INJECTION" EMG E-2, Rev. 9, "FAULTED STEAM GENERATOR ISOLATION" RESET TO IC 176 AND PLACE SIMULATOR IN RUN PRIOR TO LOADING BATCH FILE. Ensure simulator is in run or file will not load properly. You may freeze after file is loaded.

Insert Floppy disk and save the batch file LO01_006 to OPENSIM/BATCH, then open Ph.D. Expert and type "BAT LO01_006.txt"

<u>NOTE:</u> FILE **S LO06_001.txt** preloads all LOAs and/or malfunctions required for this scenario. Simulator commands and other functions to be performed by the booth operator are shown in **BOLD**. Trigger commands are used to initiate events and commands.

ENSURE THE HORNS ARE ON

ENSURE Control Rods are at 98 steps on Control Bank D, 213 steps on Control Bank C and 228 on Control Banks A and B.

ENSURE placard is on the 'A' CCP.

Reset RM-11 alarms from previous Scenarios

Have the above verified by a second person as being correctly performed.

Core age is Middle of Life

Power is 10-8 amps, Critical rod height data is complete. GEN 00-003 is in progress at step 6.25. Provide signed off copy of GEN 00-003.

Facility:	WC	GS	Scenario No.: <u>4(Spare)</u> Op-Test No.:
Examin	ers:		Operators:
Initial C	onditions:	The plant is	at MOL. Unit startup is in progress after a 7 day outage to
resolve	a voltage	e regulator pi	roblem. Reactor power is at $E^{-\delta}$ _Amps, Rod control in manual,
Startup	Feedpun	np in service	, GEN 00-003 is complete through step 6.26.
Turnove	er: <u>All sys</u>	tems norma	l, resume startup at step 6.25 of Gen 00-003.
Event	Malf.	Event	Event Description
No.	No.	Type*	
1 T+0		N (SRO) R (RO)	Increase reactor power to 1%
2	mPRS	I (SRO)	PZR pressure channel BB PT-457 fails high
T+11	01C	I (RO)	
3	mFW	C (SRO)	"B" SG Level Channel AE LT-529 Fails Low
1+25	1VIU2D	C(DOP)	
4	mPRS	C (SRO)	PORV BB PCV-455A excessive seat leakage. Block valve BB
T+35	10A	C (RO)	HV-8000A is isolated.
5	mMSS	M (SRO)	S/G "B" faulted inside containment
1+47	03B	M (RO) M (BOP)	
6	mMSS	C(SRO)	MSIV's Fail to close in Automatic
T+48	02E-H	C (BOP)	
7	mPCS	C (SRO)	Failure of containment isolation phase A
1+53	10A &	C (RO)	
	IUD		

Terminate after stabilization of RCS after Steam Generator blowdown. * (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

ILC Scenario Spare

(min) Instructions Malfunction clock starts when the crew has assumed the watch (T=0) Event #1 T Increase Reactor Power to 1%. SRO: Direct power increase.	
Malfunction clock starts when the crew has assumed the watch (T=0) Event #1 T Increase Reactor Power to 1%. SRO: Direct power increase.	
clock starts when the crew has assumed the watch (T=0) T Increase Reactor Power to 1%. SRO: Direct power increase.	
assumed the watch (T=0) T Increase Reactor Power to 1%. SRO: Direct power increase.	
watch (T=0)	
Let a serie a la contra la contra la contra la contra de la	
A Raise Reactor Power to POAH SRO: Conduct Reactivity Brief.	
Gen 00-003 (rev XX)	
6.24 Stabilize reactor power at 10^{-8} amps	
6.25 Record critical data	
6.26 Complete a Surveillance Procedure	
Credit Cross-Reference and Review Sheet for STS SE001 and route to Surveillance	
Coordinator NA	
6.27 Increase reactor power to .5% RO: Withdraw Control Rods to establish	
6.27.1 Ensure steam dumps or ARVs SUR per CRS directions	
are adjusted to 557°F, ±5°F BOP: Monitor DRPI indications.	
6.27.2 Establish desired SUR (not to	
exceed 1 dpm SS or 1.5 dpm transient)	
0.27.5 Let steam dumps of AK VS	
6.27.4 Reduce or stop blowdown as	
necessary to maintain sufficient feed	
flow.	
6.27.5 Stabilize power between 0.5%	
and 1.0%	
6.27.6 Select highest PR on NR45	
and go to LO-0 speed (1 /m)	

	Event 2	Event 2
Insert Event 2	T BB PT-457 Fails High, PZR Pressure	RO: Report RCS pressure decreasing.
with Trigger 2	 P PZR Spray valves open P PORV 455A opens P PZR Pressure decreases 	SRO/RO: Take Manual Control of Master Pressure Controller and restore RCS pressure.
	A Stop the Pressure Transient	CRITICAL TASK: Place PZR Pressure master controller in manual and close spray valves OR select alternate channel. STANDARD: This action must be taken in time to prevent a reactor trip.
	OFN SB-008 steps: (Rev 11) 2. Check if RCS Inst. failure - YES Go To ATT. K	SRO: Enters and directs OFN SB-008
	 K1. Identify Failed Inst. K2. Check failed inst used for control K3. Check Failed PZR Pressure Channel Failed High 	RO: Identify BB PT-457 has failed high.
When called WWM state you will get a team	 K4. Select Alt. PZR Pressure Channel K5. Stop Pressure Transient K6. Return PZR Pressure Control to AUTO K7. Monitor Pressure K8. Check failed inst. not selected to recorder K9. Check failed inst. not selected to OPΔT/OTΔT recorder K10. Trip bistables K11. Request L&C repair failed inst. 	RO: Select Alternate channel.
together.	 K11. Request tace repair failed first. K12. Monitor T/S: 3.3.1 3.3.2 3.3.4 table 3.3.4-1 function 3 3.3.6 3.3.7 K13. Review attach. S for Post Accident & Remote S/D Inst. 	 SRO: Evaluate and apply T.S. 3.3.1 Trip Bi-stables in 6 hours 3.3.2 Trip Bi-stables in 6 hours 3.3.4 N/A 3.3.6 Verify Ctmt Purge Vlvs shut 3.3.7 CREVS within 7days

	K14. Return to Procedure and Step in effect	SRO: Return to GEN 00-003.	
Insert Event #3	Event 3	Event 3	
with Trigger 3	 P 'B' S/G Level Channel Fails Low AE LI-529 P 'B' Bypass Valve Throttles open to Maintain Level A Restore 'B' S/G Level Perform OFN SB-008 	BOP: Report 'B' S/G level problem. CRITICAL TASK: Take manual control of "B" FRV or select out failed channel. STANDARD: This action must be taken in time to prevent a reactor trip.	
	OFN SB-008 (Rev. 11)	SRO: Enter & direct OFN SB-008	
When called	 Actions: 1. Check if secondary system instrument channel is malfunctioning a. Determine appropriate attachment for malfunctioning channel b. Go to Attachment F F1. Identify failed level channel F2. Check if failed S/G level channel used for feedwater control. F3. Select the alternate S/G level channel. F4. Monitor S/G level response to ensure proper control. 	BOP: Identify AE LI-529 as failed Inst. BOP: Select alternate Inst. BOP: Restore 'B' S/G level.	
WWM state you will get a team together.	 F5. Trip bistables F6. Place AMSAC in TRIP condition F7. Request I&C to repair failed channel. F8. Monitor Tech. Specs. 3.3.1 3.3.2 3.3.4, Table 3.3.4-1, Function 8 3.3.3 Table 3.3.3-1, Function 13 	 SRO: This channel does not require tripping for AMSAC SRO: Evaluate & Apply Tech Specs. 3.3.1 Trip Bi-stables in 6 hours 3.3.2 Trip Bi-stables in 6 hours 3.3.4 N/A 3.3.3 N/A 	
	F9. Review Att. SF10. Return to procedure and step in effect	SRO: Review attachment 'S' & apply SRO: Return to GEN 00-003	

Insert Event #4 with Trigger 4	Event 4TPORV BB PCV-455A Leakage.PPORV Tail pipe temperature increasesPPRT Pressure increasesPPRT Temperature increasesPRCS Pressure decreasesADetermine that PZR PORV has failed to fully seat and is leaking by to the PRT.	Event 4 RO/BOP: Note that PRT parameters have began increasing when they were decreasing RO/BOP: Note that RCS Pressure is decreasing.
	The Crew will have to monitor the plant and determine that whenever the Block valve goes closed RCS pressure recovers to the point the Block valve re-opens causing RCS pressure to decrease again.	 SRO/RO: Close Block valve BB HV8000A to isolate POR V SRO: Determine T.S. applicability. T.S. 3.4.11 PORV's Condition A: Close the Block valve within 1 hour.

Insert Event #5 with Trigger 5	Event 5TS/G "B" faulted in Containment.PRCS Tavg decreasesPPressurizer Pressure will decrease.PMain Steam Line Pressures will decrease.PCTMT Pressures will increase.PCTMT Humidity will increase.ADetermine that a S/G has faulted into CTMT.	Event 5 SRO: Recognize a trip is required and direct the RO to manually trip the reactor. RO: Manually trip the reactor. SRO: Enter and direct E-0.	
	 EMG E-0 STEPS (REV 14) 1. Verify Rx trip. a. Check all rod bottom lights lit b. Ensure reactor trip breakers and bypass breakers open c. Check neutron flux decreasing d. Transfer NR-45 recorder to intermediate range 2. Verify turbine trip. a. Check the following: * Main stop valves all closed <u>OR</u> * Turbine auto stop bistable lights at least two lit b. Check main generator breakers and exciter breaker open 3. Check AC emergency busses at least one 	 RO/BOP: Perform Immediate Actions of E-0, Steps 1 through 4. RO: Verify Reactor Trip. BOP: Verify Turbine Trip. 	
	energized4. Check if SI is actuated5. Check if SI is required:	RO: Verify AC buses energized. RO: Check if SI actuated.	

	<pre>Event 6 MSIV's fail to auto close SG Pressure < 615 psig CTMT Pressure > 17 psig SG Pressures decreasing rapidly A "Fast Close" MSIV's</pre>	Event 6 SRO\BOP: Determine that MSIV's did not close and FAST CLOSE MSIV's. (This action should be done after completion of Immediate Actions.) CRITICAL TASK: Manually actuate main steamline isolation before a severe (orange-path) challenge develops to either the subcriticality or the integrity CSF or before transition to EMG C-21, whichever happens first. STANDARD: All 4 MSIV's Closed. SRO\BOP: Per Fold Out Page of E-0, isolate AFW to the Faulted S/G CRITICAL TASK: Isolate the faulted SG before a severe (orange-path) challenge develops and before the end of the scenario. STANDARD: Both AFW valves to the faulted S/G are closed and verify Main Feed is isolated.	

	 6. Verify automatic actions per Attachment F. ATTACHMENT F F1. Verify feedwater isolation <u>Event 7</u> F2. Verify CISA a. Check ESFAS status panel CISA section all white lights lit F3. Verify AFW pumps running F4. Verify ECCS pumps running F5. Verify CCW alignment F6. Check ESW pumps both running F7. Verify CTMT fan coolers running in slow speed. F8. Verify CPIS a. Check ESFAS status panel CPIS section all white lights lit F9. Verify both trains of CRVIS a. Check ESFAS status panel CRVIS section all white lights lit F10. Verify main steamline isolation not required F11. Verify CTMT spray not required F12. Verify AFW valves - properly aligned. 	BOP/RO: Perform Attachment F. <u>Event 7</u> RO\BOP: Determine that CIS-A did not actuate on either train and inform CRS. (NOTE: Failure of CIS-A will also cause CPIS\CRVIS to fail to actuate.) SRO: Direct actuation of CIS-A. NOTE: CPIS and CRVIS do not actuate either with the failure of CIS-A. Once the operator manually actuates CIS-A the rest will actuate normally.	
	 F14. Verify SI valves - properly aligned. 7. Verify AFW flow > 270,000 lbm/hr. 8. Check RCS cold leg temperature stable. 9. Establish S/G pressure control: a. Check condenser - AVAILABLE - NO RNO - Use SG ARV's 10. Check PZR PORVs - closed 11. Check normal PZR spray valves closed 12. Check PZR safety valves - closed 	BOP: Establish SG Pressure control using SG ARV's.	

 13. Check if RCPs should be stopped. 14. Direct operator to monitor CSFSTs 15. Check if SGs are not faulted. NO - RNO Go To EMG E-2. 	BOP: Determine SG "B" faulted SRO: Transition to EMG E-2.	
EMG E-2 steps: (REV 9)	SRO: Conduct Transition Brief.	
 Check steamline on All SG isolated MSIVs closed MSIV bypasses closed Main steamline low point drain valves closed Check if fault is inside Area 5 Check if any SG is not faulted Identify faulted SG(s) Isolate faulted SG(s) Isolate faulted SG(s) Close AFW flow control valves to faulted SG Locally close steam supply to TD AFW pump Ensure SG ARV on faulted SG is closed Verify feedline isolated on faulted SG Main feed reg valve closed Bypass feed reg valve closed MFIV closed Chemical injection valve closed 	 SRO: Enter and Direct EMG E-2. BOP: Ensure Steam Lines isolated. (Should already be done) BOP: Ensure faulted SG isolated. Dispatch Operator to isolate TDAFW steam supply valve. BOP: Verify feedline isolated. 	
Terminate Scenario after crew isolates the Faulted S/G in EMG E-2 or at discretion of Lead Examiner.	E-PLAN CLASSIFICATION: EAL-4, Main Steam Line Break MSLB 1 –2 –5 –7 –NUE.	

	 >Initial License Exam Spare Scenario #6 >LO01_006 (Spare) 10-8 Amps >GEN00-003 step 6.22 complete >Set up MSIV's Fail to Auto Close IMF mMSS02E IMF mMSS02F IMF mMSS02G IMF mMSS02H >Set up Failure of CISA, Both Trains IMF mPCS10C >PZR Press Channel Failure IMF mPRS01b (2) 2505 5 >SET-UP S/G LEVEL FAILURE IMF mFWM02B3 (3) 0 5 >PORV 455A begins leaking IMF mPRS10A (4) 15 >SG "B" Faults inside CTMT IMF mMSS03B (5) 2.0e+6 180 > End of File 	

APF 21-001-02 Rev. 1	.3 Page	1 of 4			K	02-001C
		CONTROL RO	OM T	URNOVER CHECKLI	IST	
DATE : Today		NIGHT SHIFT	 ✓ 	DAY SHIFT		MODE- 3
				-		
OFF-GOING: (PRINT)	CRS			ON-COMING: (PRINT)	CRS	
	RO				RO	
	BOP				BOP	
	SE				SE	
		ON-COMI	NG CRS	S/SE/RO/BOP REVIEW		
EVOLUTIONS IN PROGRES	ss:					
1)Plant start up in p	progress.	Holding at 10-	8 amps			
		-				
		7 /		~		
MAINTENANCE IN PROGRE	ss: [Co	ommitment Steps	3.2.10	. 3.2.12]		
1)			012120	,		
±).						
C						
TESTING IN PROGRESS:	[Commit	ment Steps 3.2	10, 3.	2.12]		
			.,	-		

CONTROL ROOM TURNOVER CHECKLIST COMMENTS:	APF	21-001	-02	Rev.	13	Page	2 of 4			K02-001C
COMPETTS:							CONTROL	ROOM	TURNOVER	CHECKLIST
FOLLOW-UP RUTTONS:	CON									
NORE REQUEST:	CON	ITEN 15.								
NORK REQUEST:										
FOLLOW-UP BUTTORS:										
NORK REQUEST:										4
FOLLCM-UP BUTTONS:										
NORK REQUEST:										
FOLLOW-UP BUTTONS:										
FOTTON-DE BALLONS:										
FOLLOW-UP BUTTONS:										
NORK REQUEST:										
NORK REQUEST:										
NORK REQUEST:										
MORK REQUEST:										
NORK REQUEST:										
WORK REQUEST:										
WORK REQUEST:										
WORK REQUEST: WORK REQUEST:								-		
WORK REQUEST:										
NORK REQUEST:										
NORK REQUEST:							-		•	
WORK REQUEST:										
VORK REQUEST:										
FOLLOW-UP BUTTONS:	WOR	K REQUE	ST:							
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:						2)				
FOLLOW-UP BUTTONS:						-				
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:				1						
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:										
FOLLOW-UP BUTTONS:	EQ-			0110 -						
	FOL	TOM-Ob]	s∩.1.1.	UNS:						

CONTROL ROOM TURNOVER CHECKLIST REACTOR POWER 0 % RCS: 557 °F 2235 PSIG ROD CONTROL AUTO
REACTOR POWER 0 % RCS: 557 °F 2235 PSIG ROD CONTROL AUTO
ROD CONTROL AUTO MANUAL X CONTROL BANK D 98 STEPS RCS BORON (Cb) PPM @ DATE/TIME Today / 0430 LEAK RATE (GPM): IDENTIFIED 0.008 LIEAK RATE (GPM): IDENTIFIED 0.008 COND. AIR INLEAKAGE 29.1/ Today (IAW STN CH-020)
MANUAL X CONTROL BANK D 98 STEPS RCS BORON (C _b) PPM @ DATE/TIME Today / 0430 LEAK RATE (GPM): IDENTIFIED 0.008 UNIDENTIFIED 0.067 @ DATE/TIME Today/043 COND. AIR INLEAKAGE 29.1/ Today (IAW STN CH-020) TANKS AP FILLING AN FILLING BL FILLING BL ON RECIRC CONDENSATE DEMINS IN SERVICE A B C D E F ESF STATUS PANELS AND REACTOR TRIP/BLOCK PANEL ESF STATUS PANELS AND REACTOR TRIP/BLOCK PANEL A COMPONENT/TRIP/BLOCK REASON
CONTROL BANK D 98 STEPS RCS BORON (C _b) PPM @ DATE/TIME Today / 0430 LEAK RATE (GPM): IDENTIFIED 0.008 UNIDENTIFIED 0.067 @ DATE/TIME Today/043 COND. AIR INLEAKAGE 29.1/ Today (IAW STN CH-020) TANKS AP FILLING AN FILLING BL FILLING BL ON RECIRC CONDENSATE DEMINS IN SERVICE A B C D E F ESF STATUS PANELS AND REACTOR TRIP/BLOCK PANEL PANEL COMPONENT/TRIP/BLOCK REASON
RCS BORON (Cb) PPM @ DATE/TIME Today / 0430 LEAK RATE (GPM): IDENTIFIED 0.008 UNIDENTIFIED 0.067 @ DATE/TIME Today/043 COND. AIR INLEAKAGE 29.1/ Today
LEAK RATE (GPM): IDENTIFIED 0.008 UNIDENTIFIED 0.067 @ DATE/TIME Today/043 COND. AIR INLEAKAGE 29.1/ Today (IAW STN CH-020) INTERDING AN FILLING BL FILLING BL ON RECIRC TANKS AP FILLING AN FILLING BL FILLING D E F CONDENSATE DEMINS IN SERVICE A B C D E F ESF STATUS PANELS AND REACTOR TRIP/BLOCK PANEL PANEL COMPONENT/TRIP/BLOCK REASON
COND. AIR INLEAKAGE 29.1/ Today (IAW STN CH-020) Today FANKS AP FILLING AN FILLING BL FILLING BL ON RECIRC CONDENSATE DEMINS IN SERVICE A B C D E F ESF STATUS PANELS AND REACTOR TRIP/BLOCK PANEL PANEL COMPONENT/TRIP/BLOCK REASON
TAW STN CH-020) TANKS AP FILLING AN FILLING BL FILLING BL ON RECIRC CONDENSATE DEMINS IN SERVICE A B C D E F CONDENSATE DEMINS IN SERVICE A B C D E F ESF STATUS PANELS AND REACTOR TRIP/BLOCK PANEL REASON PANEL COMPONENT/TRIP/BLOCK REASON
FANKS AP FILLING AN FILLING BL FILLING BL ON RECIRC CONDENSATE DEMINS IN SERVICE A B C D E F CONDENSATE DEMINS IN SERVICE A B C D E F ESF STATUS PANELS AND REACTOR TRIP/BLOCK PANEL PANEL COMPONENT/TRIP/BLOCK REASON
CONDENSATE DEMINS IN SERVICE A B C D E F
ESF STATUS PANELS AND REACTOR TRIP/BLOCK PANEL PANEL COMPONENT/TRIP/BLOCK REASON
ESF STATUS PANELS AND REACTOR TRIP/BLOCK PANEL PANEL COMPONENT/TRIP/BLOCK REASON

	ONLY

FORTRAMME

APF 21-001-02 Rev. 13 Page 4 of 4

CONTROL ROOM TURNOVER CHECKLIST

ON-COMING CRS/SE/RO/BOP REVIEW (Check Box)

PR	IOR TO	ASSUM	ING WATO	CH	
	CRS	SE	RO	BOP	
					CONTROL ROOM LOGS
					ESSENTIAL READING
					CLEARANCE ORDER LOG
					INSTRUMENT OUT-OF-SERVICE LOG
					EQUIPMENT OUT-OF-SERVICE LOG
					ACTION STATEMENT SUMMARY
					SURVEILLANCE SCHEDULE
		N/A			FIRE PROTECTION PERMITS
		N/A	N/A	N/A	KC008 NOT DISABLED/DISARMED WITHOUT DOCUMENTATION
		N/A	N/A	N/A	DISCHARGE PERMITS
					MCB WALKDOWN WITH OFF-GOING WATCH
AF	TER AS	SUMING	WATCH		
1	CRS	SE	RO	BOD	
		27 / 2	27 / 2	27.12	TEMP MOD LOG
		N/A	N/A	N/A	LOCKED VALVE LOG
		NT / N	NT / 7	NT / 7	COMPUTER ALARM SUMMARY
		N/A	N/A	N/A	CONDUCT SHIFT BRIEF
		NT / 7	N/A	N/A	P-2 SCHEDULE
		N/A	N/A	N/A	OPEN PROCEDURES BOOK [Commitment Step 3.2.18]
ļ				-	OPEN WCGS SUBSTATION WORK AUTHORIZATION FORMS [Commitment Step 3.2.27]
AT	TACH AI	NY ADD	ITIONAL	PAGES N	EEDED TO DESCRIBE PLANT CONDITIONS. MARK THE NUMBER OF ADDITIONAL PAGES
OF	F-GOIN	Ŧ			ON-COMING
	CRS				CRS
	RO				RO
	BOP				вор
	٩F				<u>्</u> म
	10			INITIALS	INITIALS

K02-001C

ALARM WINDOW DESCRIPTION

<u>Window</u>	Name	Reason	WR/WO

INTERMITTENT ALARMS

KC008 ALARMS						

APF 21H-001-01 REV 02

INSTRUMENT OUT OF SERVICE LOG							
005	COMPUTER	DOCUMENT NUMBER	OOS	AFFECTED COMPUTER	REASON	SM/CRS VERIFIED	TAG REMOVAL
SEQUENCE	POINT	(2)	TIME/	PROCESS OR READ-OUT	APPLIED	APPLICABLE TS,	AUTHORIZATION
NUMBER	DESIGNATOR		DATE	DEVICE		TRM AND MODE	(SM/CRS INITIAL
	(1)					RESTRAINT	TIME AND DATE)
			0000 /	NE02 DIESEL FIELD	FAULTY		
96-3		SMP 96-135	3/27/97	AMP METEER	METER		
			0000 /	NE01 DIESEL FIELD	FAULTY		
96-4		SMP 96-135	3/27/97	AMP METEER	METER		
				C.L.			
				3			
			C				
		-FRAN					
	FO.	P					

NOTE: 1) FOR INSTRUMENTS OTHER THAN COMPUTER POINTS ENTER N/A.

2) VERIFY OOS SEQUENCE NUMBER IS ON ACTION/WORK REQUEST AND LIST ACTION/WORK REQUEST NUMBER IN THIS COLUMN.

APF 21F-001-01 REV 01

		1	EQUIPMENT OUT	OF SERVIC	E LOG				
EOL DATE/NUMBER	SYSTEM	DECLARED INOPERABLE DATE/TIME/INITIAL	REQUIRED RETURN DATE/TIME/INITIAL	APPLICABLE MODES	MODE RESTRAINT	TECH SPEC TRM	DECLARED OPERABLE DATE/TIME/INITIAL		
REMARKS/EQUI	REMARKS/EQUITPMENT/AR/TMO/CO/RETEST								
~									
			S						
	ç0								
	*								
		1							

FORTRAININGUSEONIN

APF 21-001-10, Rev. 01

ACTION STATEMENT SUMMARY LOG							
E.O.L.	TECH SPEC #	ENTERED	DEADLINE	REMARKS	RESTORED		
YR.		DATE/TIME/SM/CR	DATE/TIME/SM/CR		DATE/TIME/SM/CR		
0.1 0.0.1		S	S S		S		
01 - 001	3.5.2 Cond. A	Today/0700/	72 hours/ CRS				
01 002	275 Cond D	CRS	70 hours / ODC				
01-002	3.7.5 Cond. B	CRS	/2 nours/ CRS				
				<u> </u>			
	.06						

FORTRAMMEUSEONIN

```
>Initial License Exam
>LO01_006 (Spare) 10-8 Amps
>GEN00-003 step 6.24 complete
>Set up MSIV's Fail to Auto Close
IMF mMSS02E
IMF mMSS02F
IMF mMSS02G
IMF mMSS02H
>Set up Failure of CISA, Both Trains
IMF mPCS10C
>PZR Press Channel 457 Failure
IMF mPRS01C (2) 2505 5
>SET-UP S/G LEVEL FAILURE
IMF mFWM02B3 (3) 0 5
>PORV 455A begins leaking
IMF mPRS10A (4) 15
>SG "B" Faults inside CTMT
IMF mMSS03B (5) 1.0e+6 180
> OVERRIDE ESFAS PANEL LIGHTS - CRVIS
TRGSET 8 "JPPLSI(1)"
IMF SA066Y C14W (8) 1
IMF SA066Y_C15W (8 35) 1
IMF SA066Y_C16W (8 35) 1
IMF SA066Y_G15W (8) 1
>End of FIle
```

WCGS Initial License Exam Schedule December 2001

Crew Composition and Examiners

Crew A

Crew B

Examiners

U - [E2] SO2 - [E1] E1 Howard Bundy SO1 - [E1] SO3 - [E2] E2 Paul Gage E3 Gary Johnston RO1 - [E2] RO3 - [E3] RO2 - [E3]

Examiner Assignments: E1= SO1, SO2 E2= U, RO1, SO3 E3=RO2, RO3

TUESDAY 12/11/2001

Applicants Arrive 07:00 - Classroom 111, Proctors Arrive 07:00

Simulator (S1,S2, S3, S4) A5 (RO Only)

JPMs C, Plant (P3), and Admin (A4) (E2 will get Whole Body **Count prior to RCA Entry**)

Time	
<u>0730</u>	

Simulator SO1, SO2 [E1] RO2, RO3 [E3] A5 (RO2,RO3) Proctor One

Plant U, RO1, SO3 [E2] (U - P3 and A4 only)E2 Body Count Out when done. Proctor Two

1130-1200 Lunch Provided, Proctor One - Classroom 111, Proctor Two - Simulator Critique Room.

<u>1200</u>

U, RO1, SO3, [E2] (U – S1 and S3 Only) A5 (RO1)

Proctor Two

SO1, SO2 [E1] RO2, RO3 [E3] E1 and E3 Body Count Out when done. Proctor One

Dynamic Exams Category C and Admin 2 days (Wed & Thu), 3 Scenarios, One Back up

WEDNESDAY 12/12/2001

Proctor One 0900 – 1200 Classroom 111 Crew A arrive 0700 Classroom 111 Crew B arrive 1100 Classroom 111

Day 3, Scenarios 1 & 2 Admin A5 for SRO in CRS Position

0730 Crew A (Scenario 1)

CRS: SO1 [E1] RO: RO1 [E2] BOP: RO2 [E3]

<u>0930 Crew A</u> (Scenario 2)

CRS: U [E2] RO: SO1 [E1] BOP: RO2 [E3]

Crew A departs after Scenario #2

1130-1200 Lunch

Exam Team / NRC Examiners

<u>1200 Crew B</u> (Scenario 1)

CRS: SO2 [E1] RO: SO3 [E2] BOP: RO3 [E3]

<u>1400 Crew B</u> (Scenario 2)

CRS: SO3 [E2] RO: SO2 [E1] BOP: RO3 [E3]

Crew B departs after Scenario #2

THURSDAY 12/13/2001

Crew B arrive 0700 Classroom 111 Crew A arrive 0900 Classroom 111 Partridge (U) arrive 1000 Classroom 111

Day 4, Scenario 3

<u>0730 Crew B</u> (Scenario 3)

CRS: SO2 [E1] RO: RO3 [E3] BOP: SO3 [E2]

<u>0930 Crew A</u> (Scenario 3)

CRS: SO1 [E1] RO: RO2 [E3] BOP: RO1 [E2]

1130-1200 Lunch Lunch Provided Classroom 111

1200 JPMs P1, P2, Admins

Crew B (Proctor 1) Admin JPMs A1, A2 and A3 (In simulator – E2)

Crew A (Proctor 2) JPM P1 (E1) JPM P2 (E3)

1400 Crew A (Proctor 2) Admin JPMs A1, A2, and A3 (In simulator – E2)

Crew B (Proctor 1) JPM P1 (E1) JPM P2 (E3)

FRIDAY 12/14/2001

Simulator (S5, S6)

<u>Time</u>	Simulator (Proctor 1)
<u>0730</u>	SO1, SO2 [E1] RO2, RO3 [E3]
<u>0930</u>	RO1, SO3, [E2, E3]

<u>1000</u> EXIT

Exam Team Assignments:

Written12/7/2001 – Proctors: Acree, Murray, Gorman, Wilhelm

Simulator 12/10 – 12/13 Floor: Acree Booth: Gorman, Knapp Extra: Murray