

DCS MS-016

SEP 21 1982

Docket No. 50-335

DISTRIBUTION OPA(Clare Miles)
 ✓ Docket File
 NRC PDR R Ferguson
 Local PDR RDiggs
 ORB#3 Rdg RBallard
 DEisenhut NSIC
 PMKreutzer (3) ASLAB
 MLConner Gray File(4)
 OELD V. Nersus
 SECY
 OI&E (2)
 TBarnhart (4)
 LSchneider (1)
 ACRS (10)

Dr. Robert E. Uhrig
 Vice President
 Advanced Systems & Technology
 Florida Power & Light Company
 P. O. Box 529100
 Miami, Florida 33152

Dear Dr. Uhrig:

The Commission has issued the enclosed Amendment No. 53 to Facility Operating License No. DPR-67 for St. Lucie Plant, Unit No. 1. The amendment consists of changes to the Appendix A Technical Specifications in response to your June 28, 1982 application.

This amendment deletes the current Technical Specification requirements to periodically test the insulation of certain Class 1E electrical underground cables for environmental damage.

Please note that the amendment does not delete the requirement to check the underground cable duct integrity after transit of a heavy load over it. This requirement is retained in the Technical Specifications.

A copy of the Safety Evaluation and the Notice of Issuance are enclosed.

Sincerely,

Eben L. Conner, Project Manager
 Operating Reactors Branch #3
 Division of Licensing

Enclosures:

1. Amendment No. 53 to DPR-67
2. Safety Evaluation
3. Notice of Issuance

cc: See next page

DL:ORB#3
 DWagner
 9/10/82
 WDW

OFFICE	DL:ORB#3	DL:ORB#3	DL:ORB#3	AD:DL	OELD		
SURNAME	PKreutzer	MCann	RAClark	GLainas	N.WRIGHT		
DATE	9/10/82	9/10/82	9/10/82	9/10/82	9/20/82		

Florida Power & Light Company

cc:

Harold F. Reis, Esquire
Lowenstein, Newman, Reis & Alexrad
1025 Connecticut Avenue, N.W.
Washington, D. C. 20036

Mr. Jack Schreve
Office of the Public Counsel
Room 4, Holland Building
Tallahassee, Florida 32304

Norman A. Coll, Esquire
McCarthy, Steel, Hector & Davis
14th Floor, First National Bank Building
Miami Florida 33131

Resident Inspector
c/o U.S.N.R.C.
7900 S. A1A
Jensen Beach, Florida 33457

Indian River Junior College Library
3209 Virginia Avenue
Fort Pierce, Florida 33450

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

State Planning and Development Clearinghouse
Office of Planning and Budgeting
Executive Office of the Governor
The Capitol Building
Tallahassee, Florida 32301

Mr. Weldon B. Lewis
County Administrator
St. Lucie County
2300 Virginia Avenue, Room 104
Fort Pierce, Florida 33450

U.S. Environmental Protection Agency
Region IV Office
ATTN: Regional Radiation
Representative
345 Courtland Street, N.E.
Atlanta, Georgia 30308

Mr. Charles B. Brinkman
Manager - Washington Nuclear Operations
C-E Power Systems
Combustion Engineering, Inc.
4853 Cordell Avenue, Suite A-1
Bethesda, Maryland 20014

Regional Administrator
Nuclear Regulatory Commission, Region II
Office of Executive Director for Operations
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FLORIDA POWER & LIGHT COMPANY

DOCKET NO. 50-335

ST. LUCIE PLANT, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 53
License No. DPR-67

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power and Light Company (the licensee) dated June 28, 1982 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

DESIGNATED ORIGINAL

Certified By _____

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the Attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-67 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 53, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective as of the date of its issuance.

FOR THE U.S. NUCLEAR REGULATORY COMMISSION



Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 21, 1982

ATTACHMENT TO LICENSE AMENDMENT NO. 53

FACILITY OPERATING LICENSE NO. DPR-67

DOCKET NO. 50-335

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Pages

8-4

8-5

8-6

ELECTRICAL POWER SYSTEM

SURVEILLANCE REQUIREMENTS (Continued)

- 4.8.1.1.2 Each diesel generator set shall be demonstrated OPERABLE:
- a. At least once per 31 days on a STAGGERED TEST BASIS by:
 1. Verifying the fuel level in the engine-mounted fuel tank.
 2. Verifying the fuel level in the fuel storage tanks.
 3. Verifying the fuel transfer pump can be started and transfers fuel from the storage system to the engine-mounted tank.
 4. Verifying the diesels start from ambient condition.
 5. Verifying the generator is synchronized, loaded to ≥ 1300 kw, and operates for ≥ 60 minutes.
 6. Verifying the diesel generator set is aligned to provide standby power to the associated emergency busses.
 - b. At least once per 31 days by verifying that a sample of diesel fuel from the fuel storage tank is within the acceptable limits specified in Table 1 of ASTM D975-68 when checked for viscosity, water and sediment.
 - c. At least once per 18 months during shutdown by:
 1. Subjecting the diesels to an inspection in accordance with procedures prepared in conjunction with its manufacturer's recommendations for this class of standby service.
 2. Verifying the generator capability to reject a load of ≥ 600 hp without tripping.
 3. Simulating a loss of offsite power in conjunction with a safety injection actuation signal, and:
 - a) Verifying de-energization of the emergency busses and load shedding from the emergency busses.
 - b) Verifying the diesels start from ambient condition on the auto-start signal, energize the emergency busses with permanently connected loads, energize

THIS PAGE INTENTIONALLY LEFT BLANK



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

SUPPORTING AMENDMENT NO. 53 TO FACILITY OPERATING LICENSE NO. DPR-67

FLORIDA POWER & LIGHT COMPANY

ST. LUCIE PLANT, UNIT NO.1

DOCKET NO. 50-335

Introduction

By application dated June 28, 1982, Florida Power & Light Company (FPL or the licensee) requested an amendment to the Technical Specifications (TS) of Facility Operating License No. DPR-67 for the St. Lucie Plant, Unit No. 1 (St. Lucie-1).

The amendment requested the deletion of periodically testing certain underground Class 1E underground cables at St. Lucie-1 to verify their environmental integrity.

Background

The existing technical specifications for St. Lucie-1 require that at least once every 18 months a sample of the underground cables between (1) the switchgear and the diesel generators, (2) the switchgear and the component cooling water pumps, and (3) between the switchgear and the intake cooling water pumps be electrically tested for insulation degradation. If insulation degradation is found, then additional measures must be taken. The concern which generated this requirement was that, because the underground Class 1E system at St. Lucie is not watertight, the cable insulation might deteriorate over a period of time due to the alternately wet and dry environment.

Discussion and Evaluation

The licensee has been conducting the insulation resistance (megger) and high voltage dc tests required by the technical specifications at St. Lucie since 1978; and he indicates that the cables have tested and worked perfectly. A review of the test data by the licensee however indicated that the leakage of the 5 kV cables over the four year period ranged from 0.0 to 17 microamperes. Subsequently, a circuit that had the 17 microamperes reading was retested and, after careful cleaning of the porcelains, yielded a new net leakage of 0.15 microamperes after 10 minutes. This demonstrates that the leakage was due to dirty connections and not due to deterioration of the electrical insulation.

The licensee has also reviewed the history of the butyl rubber insulated cables installed in the duct and manhole system of Miami beach beginning in the 1940s. The licensee indicates that these cables are subject to environmental conditions more severe than those at St. Lucie. The results of his review indicate there has never been an electrical deterioration failure of any kind on these cables or the splices associated with them.

DESIGNATED ORIGINAL

Certified By _____

8210040046 820921
PDR ADOCK 05000335
P PDR

Additionally, the licensee has provided results from accelerated life tests which compare butyl rubber insulated wire to crosslinked polyethylene insulated wire which is the type of insulation used in the Class 1E underground system at St. Lucie. The results of the tests indicate that the crosslinked polyethylene insulation is superior to the butyl rubber insulation in a wet environment. These results, therefore, when combined with the good operating history of the butyl rubber cables installed in the Miami Beach area, provide good assurance that the crosslinked polyethylene insulated cable installed in the underground system at St. Lucie will function satisfactorily in that environment.

The proposed license amendment to the St. Lucie Technical Specifications which deletes the requirement to periodically test the electrical insulation of the Class 1E underground cable at St. Lucie is therefore acceptable. It is noted that the proposed amendment does not delete the requirement to mechanically check the underground cable duct integrity following movement of a heavy load over it. This requirement correctly should be retained under this amendment.

Environmental Consideration

We have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR §51.5(d)(4), that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

Conclusion

We have concluded, based on the considerations discussed above, that: (1) because the amendment does not involve a significant increase in the probability or consequences of an accident previously evaluated, does not create the possibility of an accident of a type different from any evaluated previously, and does not involve a significant reduction in a margin of safety, the amendment does not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Date: September 21, 1982

Principal Contributors:

J. Lazevnick
Eben Conner
D. Wagner



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

DISTRIBUTION
Docket File
ORB#3 Rdg.
PMKreutzer

Docket No. 50-335

Docketing and Service Section
Office of the Secretary of the Commission

SUBJECT: FLORIDA POWER & LIGHT COMPANY, St. Lucie Plant Unit No. 1

Two signed originals of the Federal Register Notice identified below are enclosed for your transmittal to the Office of the Federal Register for publication. Additional conformed copies (12) of the Notice are enclosed for your use.

- Notice of Receipt of Application for Construction Permit(s) and Operating License(s).
- Notice of Receipt of Partial Application for Construction Permit(s) and Facility License(s): Time for Submission of Views on Antitrust Matters.
- Notice of Availability of Applicant's Environmental Report.
- Notice of Proposed Issuance of Amendment to Facility Operating License.
- Notice of Receipt of Application for Facility License(s); Notice of Availability of Applicant's Environmental Report; and Notice of Consideration of Issuance of Facility License(s) and Notice of Opportunity for Hearing.
- Notice of Availability of NRC Draft/Final Environmental Statement.
- Notice of Limited Work Authorization.
- Notice of Availability of Safety Evaluation Report.
- Notice of Issuance of Construction Permit(s).
- Notice of Issuance of Facility Operating License(s) or Amendment(s).
- Other: Amendment No. 53
Referenced documents have been provided PDR.

Enclosure:
As Stated

Office of Nuclear Reactor Regulation
Division of Licensing

OFFICE →	DL:ORB#3					
SURNAME →	PMKreutzer:dd					
DATE →	9/23/82					