

MAR 14 1983

DCS MS-016

Docket No. 50-335

Dr. Robert E. Uhrig  
Vice President  
Advanced Systems & Technology  
Florida Power & Light Company  
P. O. Box 529100  
Miami, Florida 33152

DISTRIBUTION:

<input checked="" type="checkbox"/> Docket File	OELD (CYR)
NRC PDR	ELJordan
L PDR	JMTaylor
NSIC	TBarnhart-4
ORB#3 Rdg	ACRS-10
DEisenhut	OPA-CMiles
ORAB	SECY
PMKreutzer-3	RDiggs
RAClark	JHeltemes
ELCommer	
DSells	

Dear Dr. Uhrig:

The Commission has issued the enclosed Order confirming your commitments to implement those post-TMI related items set forth in NUREG-0737 for which the staff requested completion on or after July 1, 1981. This Order is based on commitments contained in your letters responding to the NRC's Generic Letters 82-05 and 82-10 dated March 17, 1982 and May 5, 1982, respectively.

The Order references your letters and, in its attachments, contains lists of the applicable NUREG-0737 items with your schedular commitments. As discussed in the Order, several of the items listed in Generic Letter 82-10 will be handled outside of this Order.

The Commission's intention when it issued NUREG-0737 was that items would be completed in accordance with the staff's recommended schedule. However, our evaluation of your proposed schedule exceptions concludes that the proposed delays are acceptable. Among other things, the Order requires implementation of these items in accordance with your proposed schedule.

Some of the items set forth in the attachment to the Order are subject to post implementation review and inspection. Our post implementation review and/or the development of Technical Specifications may identify alterations to your method of implementing and maintaining the requirements. Any identified alterations will be the subject of future correspondence.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

Original signed by  
Robert A. Clark

Robert A. Clark, Chief  
Operating Reactors Branch #3  
Division of Licensing

Enclosure:  
Order

cc w/enclosure:  
See next page

OFFICE	ORB#3:DL	ORB#3:DL	ORB#3:DL	ORAB	AD:OR:DL	OELD	O:DL
SURNAME	PMKreutzer	ELCommer	RAClark	GCvallas	STBURNS	DEisenhut	
DATE	11/23/82	11/24/82	11/24/82	11/17/82	11/17/82	11/14/82	11/14/82



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

DISTRIBUTION:  
Docket File  
ORB#3 Rdg  
PMKreutzer

Docket No. 50-335

Docketing and Service Section  
Office of the Secretary of the Commission

SUBJECT: FLORIDA POWER & LIGHT COMPANY, St. Lucie Plant Unit No. 1

Two signed originals of the Federal Register Notice identified below are enclosed for your transmittal to the Office of the Federal Register for publication. Additional conformed copies (12 ) of the Notice are enclosed for your use.

- Notice of Receipt of Application for Construction Permit(s) and Operating License(s).
- Notice of Receipt of Partial Application for Construction Permit(s) and Facility License(s): Time for Submission of Views on Antitrust Matters.
- Notice of Availability of Applicant's Environmental Report.
- Notice of Proposed Issuance of Amendment to Facility Operating License.
- Notice of Receipt of Application for Facility License(s); Notice of Availability of Applicant's Environmental Report; and Notice of Consideration of Issuance of Facility License(s) and Notice of Opportunity for Hearing.
- Notice of Availability of NRC Draft/Final Environmental Statement.
- Notice of Limited Work Authorization.
- Notice of Availability of Safety Evaluation Report.
- Notice of Issuance of Construction Permit(s).
- Notice of Issuance of Facility Operating License(s) or Amendment(s).

Other: ORDER (NUREG-0737)

Division of Licensing  
Office of Nuclear Reactor Regulation

Enclosure:  
As Stated

OFFICE	ORB#3:SL					
SURNAME	PMKreutzer/ph					
DATE	3/5/83					

Florida Power & Light Company

cc:

Harold F. Reis, Esquire  
Lowenstein, Newman, Reis & Alexrad  
1025 Connecticut Avenue, N.W.  
Washington, D. C. 20036

Mr. Jack Schreve  
Office of the Public Counsel  
Room 4, Holland Building  
Tallahassee, Florida 32304

Norman A. Coll, Esquire  
McCarthy, Steel, Hector & Davis  
14th Floor, First National Bank Building  
Miami Florida 33131

Resident Inspector  
c/o U.S.N.R.C.  
7900 S. A1A  
Jensen Beach, Florida 33457

Indian River Junior College Library  
3209 Virginia Avenue  
Fort Pierce, Florida 33450

Administrator  
Department of Environmental Regulation  
Power Plant Siting Section  
State of Florida  
2600 Blair Stone Road  
Tallahassee, Florida 32301

State Planning and Development Clearinghouse  
Office of Planning and Budgeting  
Executive Office of the Governor  
The Capitol Building  
Tallahassee, Florida 32301

Mr. Weldon B. Lewis  
County Administrator  
St. Lucie County  
2300 Virginia Avenue, Room 104  
Fort Pierce, Florida 33450

U.S. Environmental Protection Agency  
Region IV Office  
ATTN: Regional Radiation  
Representative  
345 Courtland Street, N.E.  
Atlanta, Georgia 30308

Mr. Charles B. Brinkman  
Manager - Washington Nuclear Operations  
C-E Power Systems  
Combustion Engineering, Inc.  
4853 Cordell Avenue, Suite A-1  
Bethesda, Maryland 20014

Regional Administrator  
Nuclear Regulatory Commission, Region II  
Office of Executive Director for Operations  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303



additional protection in the operation of nuclear facilities based on the experience from the accident at TMI-2 and the official studies and investigations of the accident. The staff's proposed requirements and schedule for implementation are set forth in NUREG-0737, "Clarification of TMI Action Plan Requirements." Among these requirements are a number of items, consisting of hardware modifications, administrative procedure implementation and specific information to be submitted by the licensee, scheduled to be completed on or after July 1, 1981. On March 17, 1982, a letter (Generic Letter 82-05) was sent to all licensees of operating power reactors for those items that were scheduled to be implemented from July 1, 1981 through March 1, 1982. Subsequently, on May 5, 1982, a letter (Generic Letter 82-10) was also sent to all licensees of operating power reactors for those items that were scheduled for implementation after March 1, 1982. These letters are hereby incorporated by reference. In these letters each licensee was requested to furnish within 30 days pursuant to 10 CFR 50.54(f) the following information for items which the staff had proposed for completion on or after July 1, 1981:

- (1) For applicable items that have been completed, confirmation of completion and the date of completion,
- (2) For items that have not been completed, a specific schedule for implementation, which the licensee committed to meet, and
- (3) Justification for delay, demonstration of need for the proposed schedule, and a description of the interim compensatory measures being taken.

III.

Florida Power & Light Company responded to Generic Letter 82-05 by letter dated April 19, 1982, and the references stated therein. They also responded to Generic Letter 82-10 by letters dated July 2 and 9, August 13, 1982 and the references stated therein. In these submittals, Florida Power & Light Company confirmed that some of the items identified in the Generic Letters had been completed and made firm commitments to complete the remainder. The attached Tables summarizing the licensee's schedular commitments or status were developed by the staff from the Generic Letters and the licensee-provided information.

Generic Letters 82-05 and 82-10 addressed thirteen and sixteen items, respectively. Of the ten items listed in Generic Letter 82-10 requiring a response, six items are not included in this Order. Item I.A.1.3.2 is part of a separate rulemaking; Items I.C.1, III.A.1.2 (2 items), and III.A.2.2 will be handled separately following Commission actions that would proceed as a result of its consideration of Commission Paper SECY 82-111, as amended; for Items II.K.3.30 and II.K.3.31 (one item), the staff review of the generic models under II.K.3.30 has not been completed, and II.K.3.31 is not required until one year after staff approval of the generic models.

All of the items addressed in this Order are considered by the licensee to be completed or to require no modifications.

In view of the foregoing, I have determined that these modifications and actions are required in the interest of public health and safety and should, therefore, be confirmed by Order.

IV.

Accordingly, pursuant to Sections 103, 161i, and 161o of the Atomic Energy Act of 1954, as amended, and the Commission's regulations in 10 CFR Parts 2 and 50, IT IS HEREBY ORDERED EFFECTIVE IMMEDIATELY THAT THE LICENSEE SHALL:

Implement and maintain the specific items described as complete in the attachments to this Order. Incomplete items shall be completed by no later than the dates shown in the attachments (as described in the licensee's submittals noted in Section III herein) and maintained thereafter.

V.


The licensee may request a hearing on this Order within 20 days of the date of publication of this Order in the Federal Register. A request for a hearing shall be addressed to the Director, Office of Nuclear Reactor Regulation, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555. A copy shall also be sent to the Executive Legal Director at the same address. A REQUEST FOR HEARING SHALL NOT STAY THE IMMEDIATE EFFECTIVENESS OF THIS ORDER.

If a hearing is requested by the licensee, the Commission will issue an Order designating the time and place of any such hearing.

If a hearing is held concerning this Order, the issue to be considered at the hearing shall be whether the licensee should comply with the requirements set forth in Section IV of this Order.

This Order is effective upon issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Purple, Deputy Director  
Division of Licensing  
Office of Nuclear Reactor Regulation

Dated at Bethesda, Maryland  
this 14th day of March,  
1983.

Attachments:

1. Licensee's Commitments on Applicable NUREG-0737 Requirements from Generic Letter 82-05
2. Licensee's Commitments on Applicable NUREG-0737 Requirements from Generic Letter 82-10

LICENSEE COMMITMENTS ON APPLICABLE NUREG-0737 ITEMS  
FROM GENERIC LETTER 82-05

ITEM	TITLE	NUREG-0737 SCHEDULE	REQUIREMENT	LICENSEE'S COMPLETION SCHEDULE (OR STATUS)*
I.A.3.1	Simulator Exams	10/1/81	Include simulator exams in licensing examinations.	Complete
II.B.2	Plant Shielding	1/1/82	Modify facility to provide access to vital areas under accident conditions.	Complete
II.B.3	Post-accident sampling	1/1/82	Install upgrade post-accident sampling capability.	Complete
II.B.4	Training for Mitigating Core Damage	10/1/81	Complete training program.	Complete
II.E.1.2	Aux FW Indication & Flow Indicator	7/1/81	Modify instrumentation to level of safety grade.	Complete
II.E.4.2	Containment Isolation Dependability	7/1/81	Part 5 - lower containment pressure setpoint to level compatible with normal operation.	Complete
II.E.4.2	Containment Isolation Dependability	7/1/81	Part 7 - isolate purge and vent valves on radiation signal.	Complete

\*Where complete date refers to a refueling outage (the estimated date when the outage begins), the item will be completed prior to the restart of the facility.

LICENSEE COMMITMENTS ON APPLICABLE NUREG-0737 ITEMS  
FROM GENERIC LETTER 82-05

ITEM	TITLE	NUREG-0737 SCHEDULE	REQUIREMENT	LICENSEE'S COMPLETION SCHEDULE (OR STATUS)*
II.F.1	Accident Monitoring	1/1/82	(1) Install noble gas effluent monitors.	Complete
		1/1/82	(2) Provide capability for effluent monitoring of iodine.	Complete
		1/1/82	(3) Install in-containment radiation-level monitor.	Complete
		1/1/82	(4) Provide continuous indication of containment pressure.	Complete
		1/1/82	(5) Provide continuous indication of containment water level.	Complete
		1/1/82	(6) Provide continuous indication of hydrogen concentration in containment.	Complete

\*Where completion date refers to a refueling outage (the estimated date when the outage begins), the item will be completed prior to the restart of the facility.

ITEM	TITLE	NUREG-0737 SCHEDULE	REQUIREMENT	LICENSEE'S COMPLETION SCHEDULE (OR STATUS) *
I.A.1.3.1	Limit Overtime	10/1/82 per Gen. Ltr. 82-12 dtd. 6/15/82	Revise administrative procedures to limit overtime in accordance w/NRC Policy Statement issued by Gen. Ltr. No. 82-12, dtd. June 15, 1982.	Complete
I.A.1.3.2	**Minimum Shift Crew	To be superseded by Proposed Rule.	To be addressed in the Final Rule on Licensed Operator Staffing at Nuclear Power Units.	To be addressed when Final Rule is issued.
I.C.1	**Revise Emergency Procedures	Superseded by SECY 82-111	Reference SECY 82-111, Requirements for Emergency Response Capability.	To be determined
II.D.1.2	RV and SV Test Programs	7/1/82	Submit plant specific reports on relief and safety valve program.	Complete
II.D.1.3	Block Valve Test Program	7/1/82	Submit report of results of test program.	Complete
II.K.3.30 & 31	**SBLOCA Analysis	1 yr. after staff approval of model	Submit plant specific analyses.	To be determined following staff approval of model
III.A.1.2	**Staffing Levels for Emergency Situations	Superseded by SECY 82-111	Reference SECY 82-111, Requirements for Emergency Response Capability	To be determined
III.A.1.2	**Upgrade Emergency Support Facilities	""	""	""
III.A.2.2	**Meteorological Data	""	""	""
III.D.3.4	Control Room Habitability	To be determined by licensee	Modify facility as identified by licensee study	Complete

\*Where completion date refers to a refueling outage (the estimated date when the outage begins), the item will be completed prior to the restart of the facility.

\*\*Not Part of Confirmatory Order