



- LEGEND**
- ASME SECTION XI CLASS 1 PIPING
  - - - - ASME SECTION XI CLASS 2 PIPING
  - ..... ASME SECTION XI CLASS 3 PIPING
  - ..... NON-151 NUCLEAR CLASS AND HSC CLASS
  - ..... PRESSURE BOUNDARY EXTENSION
  - - - - REFERENCE & CONTINUITY
  - D-O-H HYAC DUCT
  - A ANCHOR
  - CS CONSTANT SPRING HANGER
  - VS VARIABLE SPRING HANGER
  - HS HYDRAULIC SHUBBER
  - MS MECHANICAL SHUBBER
  - N NON-WELDED SUPPORT ATTACHMENT
  - W WELDED INTEGRAL SUPPORT ATTACHMENT
  - R RIGID SUPPORT
  - T SHAY STRUT
  - SW SHOP WELD
  - FW FIELD WELD
  - LW LONGITUDINAL WELD
  - WOL WELD-O-LET
  - IS1 ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL

- NOTES:**
1. MULTIPLE SHAY STRUTS, SPRING SUPPORTS OR SHUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2HS - TWO HYDRAULIC TYPE SHUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE.)
  2. THE CONTAINMENT SPRAY LINE 8"-HCB-4 WELDS AND SUPPORTS ARE EXEMPT FROM INSERVICE EXAMINATION REQUIREMENTS PER 10CFR 50.55. THE WELDS AND SUPPORTS SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.
  3. PIPING SYSTEMS ON THIS DRAWING WHICH ARE OUTSIDE OF THE 151 BOUNDARY, ARE SHOWN FOR REFERENCE AND CONTINUITY PURPOSES ONLY. THE CONFIGURATION SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.
- GENERAL NOTE:**  
DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

**REFERENCE DRAWINGS:**  
15102-034 EMERGENCY CORE COOLING SYSTEM CONTAINMENT SPRAY AND CORE FLOODING SYSTEMS

	15102-234C-2 PER 15102-234C-1 15102-234C-1 ISSUED FOR SECOND TO YEAR ISI
	INITIALS ON FILE CB EPB LLC HOP ECC
<b>DAVIS-BESSE NUCLEAR POWER STATION</b> <b>UNIT NO. 1</b>	
<b>INSERVICE INSPECTION ISOMETRIC</b> <b>CONTAINMENT SPRAY SYSTEM</b> <b>AUXILIARY BUILDING PUMP 1-1 DISCHARGE</b>	
	<b>ISIM2-234C</b>
	<b>2</b>