

NOV 28 1986

DMB 016

Docket No. 50-335

Mr. C. O. Woody  
Group Vice President  
Nuclear Energy  
Florida Power & Light Company  
P. O. Box 14000  
Juno Beach, Florida 33408

Dear Mr. Woody:

On September 8, 1977, the Commission issued Amendment No. 17 to Facility Operating License No. DPR-67 for the St. Lucie Plant, Unit 1. Page 3/4 9-3 was provided as an unchanged overleaf page, however, the new amendment number was inadvertently added to that page, thus indicating it was a changed page.

Enclosed is a corrected page 3/4 9-3. Please accept our apologies for any inconvenience this administrative error may have caused you.

Sincerely,

Original signed by

E. G. Tourigny, Project Manager  
PWR Project Directorate #8  
Division of PWR Licensing-B

Enclosure:  
TS Page 3/4 9-3

cc w/enclosure:  
See next page

DISTRIBUTION  
Docket File

NRC PDR	BGrimes
L PDR	TBarnhart-4
PBD-8 Rdg	WJones
FMiraglia	EButcher
PKreutzer	ACRS-10
ETourigny	CMiles
OGC-Bethesda	RDiggs
LHarmon	Gray File
EJordan	NThompson
	JPartlow
	RPerfetti

PBD#8  
PPerfetti  
11/26/86

PBD#8  
RPerfetti;cf  
11/26/86

PBD#8  
ETourigny  
11/27/86

PBD#8  
ATHadani  
11/28/86

8612090137 861128  
PDR ADOCK 05000335  
PDR

Mr. C. O. Woody  
Florida Power & Light Company

St. Lucie Plant

cc:

Mr. Jack Shreve  
Office of the Public Counsel  
Room 4, Holland Building  
Tallahassee, Florida 32304

Resident Inspector  
c/o U.S. NRC  
7585 S. Hwy A1A  
Jensen Beach, Florida 33457

State Planning & Development  
Clearinghouse  
Office of Planning & Budget  
Executive Office of the Governor  
The Capitol Building  
Tallahassee, Florida 32301

Harold F. Reis, Esq.  
Newman & Holtzinger  
1615 L Street, N.W.  
Washington, DC 20036

Norman A. Coll, Esq.  
McCarthy, Steel, Hector and Davis  
14th Floor, First National Bank Building  
Miami, Florida 33131

Administrator  
Department of Environmental Regulation  
Power Plant Siting Section  
State of Florida  
2600 Blair Stone Road  
Tallahassee, Florida 32301

Mr. Weldon B. Lewis, County  
Administrator  
St. Lucie County  
2300 Virginia Avenue, Room 104  
Fort Pierce, Florida 33450

Mr. Charles B. Brinkman, Manager  
Washington - Nuclear Operations  
Combustion Engineering, Inc.  
7910 Woodmont Avenue  
Bethesda, Maryland 20814

Mr. Allan Schubert, Manager  
Public Health Physicist  
Department of Health and  
Rehabilitative Services  
1323 Winewood Blvd.  
Tallahassee, Florida 32301

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
Executive Director for Operations  
101 Marietta Street N.W., Suite 2900  
Atlanta, Georgia 30323

REFUELING OPERATIONS

DECAY TIME

LIMITING CONDITION FOR OPERATION

---

3.9.3 The reactor shall be subcritical for a minimum of 72 hours.

APPLICABILITY: During movement of irradiated fuel in the reactor pressure vessel.

ACTION:

With the reactor subcritical for less than 72 hours, suspend all operations involving movement of irradiated fuel in the reactor pressure vessel. The provisions of Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

---

4.9.3 The reactor shall be determined to have been subcritical for at least 72 hours by verification of the date and time of subcriticality prior to movement of irradiated fuel in the reactor pressure vessel.

## REFUELING OPERATIONS

### CONTAINMENT PENETRATIONS

#### LIMITING CONDITION FOR OPERATION

---

3.9.4 The containment penetrations shall be in the following status:

- a. The equipment door closed and held in place by a minimum of four bolts,
- b. A minimum of one door in each airlock is closed, and
- c. Each penetration, except as provided in Table 3.6-2 of Specification 3.6.3.1, providing direct access from the containment atmosphere to the outside atmosphere shall be either:
  1. Closed by an isolation valve, blind flange, or manual valve, or
  2. Be capable of being closed by an OPERABLE automatic containment isolation valve, or
  3. Be capable of being closed by an OPERABLE containment vacuum relief valve.

APPLICABILITY: During CORE ALTERATIONS or movement of irradiated fuel within the containment.

#### ACTION:

With the requirements of the above specification not satisfied, immediately suspend all operations involving CORE ALTERATIONS or movement of irradiated fuel in the containment. The provisions of Specification 3.0.3 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.9.4 Each of the above required containment penetrations shall be determined to be either in its closed/isolated condition or capable of being closed by an OPERABLE automatic containment isolation valve within 72 hours prior to the start of and at least once per 7 days during CORE ALTERATIONS or movement of irradiated fuel in the containment by:

- a. Verifying the penetrations are in their closed/isolated condition, or
- b. Testing the containment isolation valves per the applicable portions of Specifications 4.6.3.1.1 and 4.6.3.1.2.