

March 13, 1986

DUR 016

Docket Nos. 50-335
and 50-389

DISTRIBUTION:

Docket File	LTremper
NRC PDR	LFMB
L PDR	ACRS-10
SECY	WJones
PBD#8 Rdg	TBarnhart-4
FMiraglia	BGrimes
PMKreutzer-3	EJordan
DBOsborne	LJHarmon
OELD	WRegan
Gray File +4	OPA

Mr. C. O. Woody
Group Vice President
Nuclear Energy
Florida Power & Light Company
P. O. Box 14000
Juno Beach, Florida 33408

Dear Mr. Woody:

On December 6, 1985, the Commission issued Amendment Nos. 69 and 13 to Facility Operating License Nos. DPR-67 and NPF-16 for the St. Lucie Plant, Unit Nos. 1 and 2.

Amendment No. 69 contained an error in that two pages were numbered incorrectly, placing two tables out of numerical sequence. Page 1-8 containing Table 1.2 should have been page 1-9. Page 1-9 containing Table 1.1 should have been page 1-8. Those pages have been corrected and are enclosed.

Also in Amendment No. 69, Page 3/4 12-2 contained a typographical error in referencing Specification 5.9.1.10 instead of 6.9.1.10. The correction has been made and the corrected page is enclosed.

The errata sheet for Amendment No. 69 instructed removal of page B 3/4 4-3 but failed to instruct insertion of the replacement page. The page was included in the amendment and was intended to replace the existing page.

Please accept our apologies for any inconvenience this administrative error may have caused you.

Sincerely,

/s/

Donald E. Sells, Project Manager
PWR Project Directorate #8
Division of PWR Licensing-B

Enclosures:
TS pages 1-8, 1-9,
and 3/4 12-2

cc w/enclosures:
See next page

B604080028 B60313
PDR ADDCK 05000335
P PDR

AT

PBD#8:DL
PMKreutzer
3/13/86

PBD#8:DL
DSells;ef
3/13/86

PBD#8:DL
ATHadani
3/13/86

Mr. C. O. Woody
Florida Power & Light Company

St. Lucie Plant

cc:

Mr. Jack Shreve
Office of the Public Counsel
Room 4, Holland Building
Tallahassee, Florida 32304

Resident Inspector
c/o U.S. NRC
7585 S. Hwy A1A
Jensen Beach, Florida 33457

State Planning & Development
Clearinghouse
Office of Planning & Budget
Executive Office of the Governor
The Capitol Building
Tallahassee, Florida 32301

Harold F. Reis, Esq.
Newman & Holtzinger
1615 L Street, N.W.
Washington, DC 20036

Norman A. Coll, Esq.
McCarthy, Steel, Hector and Davis
14th Floor, First National Bank Building
Miami, Florida 33131

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Mr. Weldon B. Lewis, County
Administrator
St. Lucie County
2300 Virginia Avenue, Room 104
Fort Pierce, Florida 33450

Mr. Charles B. Brinkman, Manager
Washington - Nuclear Operations
Combustion Engineering, Inc.
7910 Woodmont Avenue
Bethesda, Maryland 20814

Mr. Allan Schubert, Manager
Public Health Physicist
Department of Health and
Rehabilitative Services
1323 Winewood Blvd.
Tallahassee, Florida 32301

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
Executive Director for Operations
101 Marietta Street N.W., Suite 2900
Atlanta, Georgia 30323

DEFINITIONS

STAGGERED TEST BASIS

- 1.32 A STAGGERED TEST BASIS shall consist of:
- a. A test schedule for n systems, subsystems, trains or other designated components obtained by dividing the specified test interval into n equal subintervals, and
 - b. The testing of one system, subsystem, train or other designated component at the beginning of each subinterval.

THERMAL POWER

1.33 THERMAL POWER shall be the total reactor core heat transfer rate to the reactor coolant.

UNIDENTIFIED LEAKAGE

1.34 UNIDENTIFIED LEAKAGE shall be all leakage which is not IDENTIFIED LEAKAGE or CONTROLLED LEAKAGE.

UNRESTRICTED AREA

1.35 An UNRESTRICTED AREA shall be any area at or beyond the SITE BOUNDARY access to which is not controlled by the licensee for purposes of protection of individuals from exposure to radiation and radioactive materials, or any area within the SITE BOUNDARY used for residential quarters or for industrial, commercial, institutional, and/or recreational purposes.

UNRODDED INTEGRATED RADIAL PEAKING FACTOR - F_r

1.36 The UNRODDED INTEGRATED RADIAL PEAKING FACTOR is the ratio of the peak pin power to the average pin power in an unrodded core, excluding tilt.

UNRODDED PLANAR RADIAL PEAKING FACTOR - F_{xy}

1.37 The UNRODDED PLANAR RADIAL PEAKING FACTOR is the maximum ratio of the peak to average power density of the individual fuel rods in any of the unrodded horizontal planes, excluding tilt.

TABLE 1.1
FREQUENCY NOTATION

<u>NOTATION</u>	<u>FREQUENCY</u>
S	At least once per 12 hours
D	At least once per 24 hours
W	At least once per 7 days
4/M*	At least 4 per month at intervals of no greater than 9 days and a minimum of 48 per year
M	At least once per 31 days
Q	At least once per 92 days
SA	At least once per 184 days
R	At least once per 18 months
S/U	Prior to each reactor startup
p**	Completed prior to each release
N.A.	Not applicable

* For Radioactive Effluent Sampling

** For Radioactive Batch Releases Only

TABLE 1.2
OPERATIONAL MODES

<u>MODE</u>	<u>REACTIVITY CONDITION, K_{eff}</u>	<u>%RATED THERMAL POWER*</u>	<u>AVERAGE COOLANT TEMPERATURE</u>
1. POWER OPERATION	≥ 0.99	$> 5\%$	$\geq 325^{\circ}\text{F}$
2. STARTUP	≥ 0.99	$\leq 5\%$	$\geq 325^{\circ}\text{F}$
3. HOT STANDBY	< 0.99	0	$\geq 325^{\circ}\text{F}$
4. HOT SHUTDOWN	< 0.99	0	$325^{\circ}\text{F} > T_{avg}$ $> 200^{\circ}\text{F}$
5. COLD SHUTDOWN	< 0.99	0	$\leq 200^{\circ}\text{F}$
6. REFUELING**	≤ 0.95	0	$\leq 140^{\circ}\text{F}$

* Excluding decay heat.

** Fuel in the reactor vessel with the vessel head closure bolts less than fully tensioned or with the head removed.

3/4.12 RADIOLOGICAL ENVIRONMENTAL MONITORING

3/4.12.1 MONITORING PROGRAM

LIMITING CONDITION FOR OPERATION

3.12.1 The radiological environmental monitoring program shall be conducted as specified in Table 3.12-1.

APPLICABILITY: At all times.

ACTION:

- a. With the radiological environmental monitoring program not being conducted as specified in Table 3.12-1, prepare and submit to the Commission, in the Annual Radiological Environmental Operating Report required by Specification 6.9.1.11, a description of the reasons for not conducting the program as required and the plans for preventing a recurrence.
- b. With the confirmed* level of radioactivity as the result of plant effluents in an environmental sampling medium at a specified location exceeding the reporting levels of Table 3.12-2 when averaged over any calendar quarter, prepare and submit to the Commission within 30 days, pursuant to Specification 6.9.2, a Special Report that identifies the cause(s) for exceeding the limit(s) and defines the corrective actions to be taken to reduce radioactive effluents so that the potential annual dose to a MEMBER OF THE PUBLIC is less than the calendar year limits of Specifications 3.11.1.2, 3.11.2.2, and 3.11.2.3. When more than one of the radionuclides in Table 3.12-2 are detected in the sampling medium, this report shall be submitted if:

$$\frac{\text{concentration (1)}}{\text{reporting level (1)}} + \frac{\text{concentration (2)}}{\text{reporting level (2)}} + \dots \geq 1.0$$

When radionuclides other than those in Table 3.12-2 are detected and are the result of plant effluents, this report shall be submitted if the potential annual dose to a MEMBER OF THE PUBLIC is equal to or greater than the calendar year limits of Specifications 3.11.1.2, 3.11.2.2 and 3.11.2.3. This report shall include the methodology for calculating the cumulative potential dose contributions for the calendar year from radionuclides detected in environmental samples and can be determined in accordance with the methodology and parameters in the ODCM. This report is not required if the measured level of radioactivity was not the result of plant effluents; however, in such an event, the condition shall be reported and described in the Annual Radiological Environmental Operating Report.

- c. With milk or broadleaf vegetation samples unavailable from one or more of the sample locations required by Table 3.12-1, identify locations

*A confirmatory reanalysis of the original, a duplicate, or a new sample may be desirable, as appropriate. The results of the confirmatory analysis shall be completed at the earliest time consistent with the analysis but in any case within 30 days.

RADIOLOGICAL ENVIRONMENTAL MONITORING

LIMITING CONDITION FOR OPERATION (Continued)

ACTION: (Continued)

for obtaining replacement samples and add them to the radiological environmental monitoring program within 30 days. The specific locations from which samples were unavailable may then be deleted from the monitoring program. Pursuant to Specification 6.9.1.10, identify the cause of the unavailability of samples and identify the new location(s) for obtaining replacement samples in the next Semiannual Radioactive Effluent Release Report and also include in the report a revised figure(s) and table for the ODCM reflecting the new location(s).

- d. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.12.1 The radiological environmental monitoring samples shall be collected pursuant to Table 3.12-1 from the specific locations given in the table and figure(s) in the ODCM, and shall be analyzed pursuant to the requirements of Table 3.12-1 and the detection capabilities required by Table 4.12-1.