

January 10, 2002

Mr. Oliver D. Kingsley, President  
Exelon Nuclear  
Exelon Generation Company, LLC  
200 Exelon Way, KSA 3-E  
Kennett Square, PA 19348

SUBJECT: PEACH BOTTOM ATOMIC POWER STATION, UNITS 2 AND 3 -  
WITHDRAWAL OF AMENDMENT REQUEST RE: OSCILLATION POWER  
RANGE MONITOR REACTOR SCRAM FUNCTION (TAC NOS. MB1165 AND  
MB1166)

Dear Mr. Kingsley:

By letter dated February 8, 2001, Exelon Generation Company, LLC, applied for amendments to Facility Operating License Nos. DPR-44 and DPR-56 for Peach Bottom Atomic Power Station, Units 2 and 3. The proposed change would have modified the facility and the facility Technical Specifications by replacing the interim corrective actions for thermal-hydraulic power oscillations with an automatic reactor scram from the output of the oscillation power range monitor. Subsequently, by letter dated December 13, 2001, Exelon Generation Company withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendments to Facility Operating Licenses with the Office of the Federal Register for publication. The associated TAC Nos. MB1165 and MB1166 are being closed.

Sincerely,

*/RA/*

John P. Boska, Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-277 and 50-278

Enclosure: Notice of Withdrawal

cc w/encl: See next page

Peach Bottom Atomic Power Station  
Units 2 and 3

cc:

Mr. Edward Cullen  
Vice President & General Counsel  
Exelon Generation Company, LLC  
300 Exelon Way  
Kennett Square, PA 19348

Mr. J. Doering  
Site Vice President  
Peach Bottom Atomic Power Station  
1848 Lay Road  
Delta, PA 17314

Mr. G. Johnston  
Plant Manager  
Peach Bottom Atomic Power Station  
1848 Lay Road  
Delta, PA 17314

Mr. A. Winter  
Regulatory Assurance Manager  
Peach Bottom Atomic Power Station  
1848 Lay Road  
Delta, PA 17314

Resident Inspector  
U.S. Nuclear Regulatory Commission  
Peach Bottom Atomic Power Station  
P.O. Box 399  
Delta, PA 17314

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Roland Fletcher  
Department of Environment  
Radiological Health Program  
2400 Broening Highway  
Baltimore, MD 21224

Correspondence Control Desk  
Exelon Generation Company, LLC  
200 Exelon Way, KSA 1-N-1  
Kennett Square, PA 19348

Chief-Division of Nuclear Safety  
PA Dept. of Environmental Protection  
P.O. Box 8469  
Harrisburg, PA 17105-8469

Board of Supervisors  
Peach Bottom Township  
R. D. #1  
Delta, PA 17314

Public Service Commission of Maryland  
Engineering Division  
Chief Engineer  
6 St. Paul Center  
Baltimore, MD 21202-6806

Mr. Richard McLean  
Power Plant and Environmental  
Review Division  
Department of Natural Resources  
B-3, Tawes State Office Building  
Annapolis, MD 21401

Dr. Judith Johnsrud  
National Energy Committee  
Sierra Club  
433 Orlando Avenue  
State College, PA 16803

Manager-Financial Control & Co-Owner  
Affairs  
Public Service Electric and Gas Company  
P.O. Box 236  
Hancocks Bridge, NJ 08038-0236

Mr. Michael P. Gallagher  
Director - Licensing  
Mid-Atlantic Regional Operating Group  
Exelon Generation Company, LLC  
200 Exelon Way, KSA 3-E  
Kennett Square, PA 19348

Peach Bottom Atomic Power Station  
Units 2 and 3

cc:

Mr. Jeffrey A. Benjamin  
Vice President-Licensing  
Exelon Generation Company, LLC  
1400 Opus Place, Suite 900  
Downers Grove, IL 60515

Mr. Joseph Hagan  
Senior Vice President  
Mid-Atlantic Regional Operating Group  
Exelon Generation Company, LLC  
200 Exelon Way, KSA 3-N  
Kennett Square, PA 19348

Mr. John Skolds  
Chief Operating Officer  
Exelon Generation Company, LLC  
1400 Opus Place, Suite 900  
Downers Grove, IL 60515

Mr. William Bohlke  
Senior Vice President, Nuclear Services  
Exelon Generation Company, LLC  
1400 Opus Place, Suite 900  
Downers Grove, IL 60515

Mr. John Cotton  
Senior Vice President, Operations Support  
Exelon Generation Company, LLC  
1400 Opus Place, Suite 900  
Downers Grove, IL 60515

January 10, 2002

Mr. Oliver D. Kingsley, President  
Exelon Nuclear  
Exelon Generation Company, LLC  
200 Exelon Way, KSA 3-E  
Kennett Square, PA 19348

SUBJECT: PEACH BOTTOM ATOMIC POWER STATION, UNITS 2 AND 3 -  
WITHDRAWAL OF AMENDMENT REQUEST RE: OSCILLATION POWER  
RANGE MONITOR REACTOR SCRAM FUNCTION (TAC NOS. MB1165 AND  
MB1166)

Dear Mr. Kingsley:

By letter dated February 8, 2001, Exelon Generation Company, LLC, applied for amendments to Facility Operating License Nos. DPR-44 and DPR-56 for Peach Bottom Atomic Power Station, Units 2 and 3. The proposed change would have modified the facility and the facility Technical Specifications by replacing the interim corrective actions for thermal-hydraulic power oscillations with an automatic reactor scram from the output of the oscillation power range monitor. Subsequently, by letter dated December 13, 2001, Exelon Generation Company withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendments to Facility Operating Licenses with the Office of the Federal Register for publication. The associated TAC Nos. MB1165 and MB1166 are being closed.

Sincerely,

*/RA/*

John P. Boska, Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-277 and 50-278

Enclosure: Notice of Withdrawal

cc w/encls: See next page

DISTRIBUTION:

|                 |                  |           |
|-----------------|------------------|-----------|
| MO'Brien        | PUBLIC           |           |
| JBoska          | ACRS             | PDI-2 r/f |
| OGC             | BPlatchek, RGN-I |           |
| EAdensam (EGA1) | JClifford        |           |

ACCESSION NUMBER: ML013540282

| OFFICE | PM/PD1-2 | LA/PD1-2 | SC/PD1-2              |
|--------|----------|----------|-----------------------|
| NAME   | JBoska   | MO'Brien | REnnis for: JClifford |
| DATE   | 12-21/01 | 1/7/02   | 1/8/02                |

OFFICIAL RECORD COPY

UNITED STATES NUCLEAR REGULATORY COMMISSION

EXELON GENERATION COMPANY, LLC

DOCKET NOS. 50-277 AND 50-278

NOTICE OF WITHDRAWAL OF APPLICATION FOR  
AMENDMENTS TO FACILITY OPERATING LICENSES

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of Exelon Generation Company, LLC, (the licensee) to withdraw its February 8, 2001, application for proposed amendments to Facility Operating License Nos. DPR-44 and DPR-56 for the Peach Bottom Atomic Power Station, Units 2 and 3, located in York County, Pennsylvania.

The proposed amendments would have modified the facility and the facility Technical Specifications by replacing the interim corrective actions for thermal-hydraulic power oscillations with an automatic reactor scram from the output of the oscillation power range monitor.

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on May 30, 2001 (66 FR 29354). However, by letter dated December 13, 2001, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated February 8, 2001, and the licensee's letter dated December 13, 2001, which withdrew the application for license amendment. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site, <http://www.nrc.gov>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in

- 2 -

ADAMS, should contact the NRC Public Document Room (PDR) Reference staff by telephone at 1-800-397-4209, 301-415-4737 or by email to [pdr@nrc.gov](mailto:pdr@nrc.gov).

Dated at Rockville, Maryland, this 10<sup>th</sup> day of January 2002.

FOR THE NUCLEAR REGULATORY COMMISSION

*/RA/*

John P. Boska, Project Manager  
Project Directorate  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation