

April 29, 1987

Docket No. 50-335

DISTRIBUTION

Docket File ACRS (10)
NRC PDR Gray File
Local PDR
PD22 Rdg.
S. Varga
D. Miller
E. Tourigny
OGC-Bethesda
T. Barnhart (4)

Mr. C. O. Woody, Group Vice President
Nuclear Energy Department
Florida Power and Light Company
Post Office Box 14000
Juno Beach, Florida 33408

Dear Mr. Woody:

On March 30, 1987, the Commission issued Amendment No. 78 to Facility Operating License No. DPR-67 for the St. Lucie Plant, Unit No. 1.

Amendment No. 78, Page 3/4 6-16b, did not contain the negative flow rate tolerance for the demineralized water flow rate. The correct value should be 18 plus or minus 1.5 gpm instead of 18 plus 1.5 gpm. The correction has been made and the corrected page is enclosed.

Please accept our apologies for any inconvenience this administrative error may have caused you.

Sincerely,


E. G. Tourigny, Project Manager
Project Directorate II-2
Division of Reactor Projects-I/II

Enclosure:
As stated

cc w/enclosure:
See next page

LA: PD2
D. Miller
4/29/87

PM: PD22
E. G. Tourigny:hc
4/29/87


D: PD22
LRubenstein
4/24/87

Mr. C. O. Woody
Florida Power & Light Company

St. Lucie Plant

cc:

Mr. Jack Shreve
Office of the Public Counsel
Room 4, Holland Building
Tallahassee, Florida 32304

Mr. Allan Schubert, Manager
Public Health Physicist
Department of Health and
Rehabilitative Services
1323 Winewood Blvd.
Tallahassee, Florida 32301

Resident Inspector
c/o U.S. NRC
7585 S. Hwy A1A
Jensen Beach, Florida 33457

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
Executive Director for Operations
101 Marietta Street N.W., Suite 2900
Atlanta, Georgia 30323

State Planning & Development
Clearinghouse
Office of Planning & Budget
Executive Office of the Governor
The Capitol Building
Tallahassee, Florida 32301

Harold F. Reis, Esq.
Newman & Holtzinger
1615 L Street, N.W.
Washington, DC 20036

Norman A. Coll, Esq.
McCarthy, Steel, Hector and Davis
14th Floor, First National Bank Building
Miami, Florida 33131

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Mr. Weldon B. Lewis, County
Administrator
St. Lucie County
2300 Virginia Avenue, Room 104
Fort Pierce, Florida 33450

Mr. Charles B. Brinkman, Manager
Washington - Nuclear Operations
Combustion Engineering, Inc.
7910 Woodmont Avenue
Bethesda, Maryland 20814

CONTAINMENT SYSTEMS

SPRAY ADDITIVE SYSTEM

SURVEILLANCE REQUIREMENTS (Continued)

- d. At least once per 5 years by verifying a minimum sodium hydroxide (NaOH) flow-rate of 10.5 gpm from the spray additive tank to a drain connection immediately downstream of the tank outlet valve, and a demineralized water flow rate of 18 ± 1.5 gpm from that same drain connection to each containment spray pump.