



**LEGEND**

- ASME SECTION XI CLASS 1 PIPING
- ASME SECTION XI CLASS 2 PIPING
- ASME SECTION XI CLASS 3 PIPING
- NON-ISI NUCLEAR CLASS AND HSC CLASS
- PRESSURE BOUNDARY EXTENSION
- REFERENCE & CONTINUITY
- HVAC DUCT
- ANCHOR
- CONSTANT SPRING HANGER
- VARIABLE SPRING HANGER
- HYDRAULIC SNUBBER
- MECHANICAL SNUBBER
- NON-WELDED SUPPORT ATTACHMENT
- WELDED INTEGRAL SUPPORT ATTACHMENT
- RIGID SUPPORT
- SWAY STRUT
- SHOP WELD
- FIELD WELD
- LONGITUDINAL WELD
- WELDOLET
- ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.

**NOTES:**

1. MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2MS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE.)
2. THE COMPONENT COOLING WATER LINE 4-HBB-3, 3-HBB-3, 3-HBB-4 & 3-HBB-4 WELDS AND SUPPORTS ARE EXCEPT FROM INSERVICE EXAMINATION REQUIREMENTS PER 100.1220. THE WELDS AND SUPPORTS SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.

**GENERAL NOTE:**

DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

**REFERENCE DRAWINGS:**

15102-0400 REACTOR COOLENT PUMP & MOTOR

D-119

REV	DATE	BY	CHKD	DESCRIPTION
1	JAN 10 2011	JAN	JAN	ISSUED FOR SECOND 10 YEAR ISI PROGRAM
2	JAN 10 2011	JAN	JAN	ISSUED FOR SECOND 10 YEAR ISI PROGRAM
3	JAN 10 2011	JAN	JAN	ISSUED FOR SECOND 10 YEAR ISI PROGRAM
4	JAN 10 2011	JAN	JAN	ISSUED FOR SECOND 10 YEAR ISI PROGRAM

DAVIS-BESSE NUCLEAR POWER STATION  
 UNIT NO. 1  
 INSERVICE INSPECTION ISOMETRIC  
 COMPONENT COOLING WATER SYSTEM  
 CONTAINMENT BUILDING (P36-4)  
 151M2-236F  
 SHEET 2

I certify that the work shown on this drawing was done in accordance with the design and specifications on the date stated hereon and that it is an accurate reproduction of the work as done and shall be an accurate reproduction of the work as done and shall be an accurate reproduction of the work as done and shall be an accurate reproduction of the work as done.