



**LEGEND**

- ASME SECTION XI CLASS 1 PIPING
- - - ASME SECTION XI CLASS 2 PIPING
- ..... ASME SECTION XI CLASS 3 PIPING
- ..... NON-151 NUCLEAR CLASS AND HSC CLASS
- ..... PRESSURE BOUNDARY EXTENSION
- ..... REFERENCE & CONTINUITY
- D - D HVAC DUCT
- A ANCHOR
- CS CONSTANT SPRING HANGER
- VS VARIABLE SPRING HANGER
- HS HYDRAULIC SNUBBER
- MS MECHANICAL SNUBBER
- N NON-WELDED SUPPORT ATTACHMENT
- W WELDED INTEGRAL SUPPORT ATTACHMENT
- R RIGID SUPPORT
- T SHAY STRUT
- SW SHOP WELD
- FW FIELD WELD
- LW LONGITUDINAL WELD
- WOL WELD-OLETT
- 151 ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.

**NOTES:**

1. MULTIPLE SHAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. EXAMPLE: 2MS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE.
2. THE REACTOR COOLANT DRAIN LINE 38-HSC-23 WELDS AND SUPPORTS ARE EXEMPT FROM INSERVICE EXAMINATION REQUIREMENTS PER 10CFR 50.1220. THE WELDS AND SUPPORTS SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.
3. PIPING SYSTEMS ON THIS DRAWING WHICH ARE OUTSIDE OF THE 151 BOUNDARY, ARE SHOWN FOR REFERENCE AND CONTINUITY PURPOSES ONLY. THE CONFIGURATION SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.

**GENERAL NOTE**

DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

**REFERENCE DRAWINGS:**

- 15102-040A REACTOR COOLANT SYSTEM DETAILS
- W-0386 GASEOUS RADIOACTIVE WASTE SYSTEM

D-130

INC. DCN'S 151M2-240C-1 & 2 FOR DEC 91 2001		ISSUED FOR SECOND 10 YEAR 151 PROGRAM	CB EFB LLC WOP ECC
DATE	REVISED	BY	CHK
151M2-240C-1	151M2-240C-1	151M2-240C-1	151M2-240C-1
DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1			
INSERVICE INSPECTION ISOMETRIC REACTOR COOLANT DRAIN B GASEOUS RADWASTE SYSTEM			
ALUK. BUILDING			
ISIM2-240C			1

I hereby certify that the [unclear] of this drawing was prepared in accordance with the [unclear] of the [unclear] and that it is an accurate representation of the [unclear] as shown on the [unclear] drawings.