



- LEGEND**
- ASME SECTION XI CLASS 1 PIPING
 - ASME SECTION XI CLASS 2 PIPING
 - ASME SECTION XI CLASS 3 PIPING
 - NON-151 NUCLEAR CLASS AND HSC CLASS
 - PRESSURE BOUNDARY EXTENSION
 - REFERENCE & CONTINUITY
 - D-D - HVAC DUCT
 - A - ANCHOR
 - CS - CONSTANT SPRING HANGER
 - VS - VARIABLE SPRING HANGER
 - HS - HYDRAULIC SNUBBER
 - MS - MECHANICAL SNUBBER
 - N - NON-WELDED SUPPORT ATTACHMENT
 - W - WELDED INTEGRAL SUPPORT ATTACHMENT
 - R - RIGID SUPPORT
 - T - SWAY STRUT
 - SW - SHOP WELD
 - FW - FIELD WELD
 - LW - LONGITUDINAL WELD
 - WOL - WELDOLET
 - 151 ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.

- NOTES:**
1. MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2MS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE).
 2. THE 20\"/>

GENERAL NOTE:
 DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

- REFERENCE DRAWINGS:**
- 15102-041A SERVICE WATER PUMPS & SECONDARY SERVICE WATER SYSTEM
 - 15102-041B PRIMARY SERVICE WATER SYSTEM
 - 15102-041C SERVICE WATER SYSTEM FOR CONTAINMENT AIR COOLERS

D-132

1/2"	INC. DCN 151M2-241A-6 PER DCN 01-0001	SW	5/11/98	
1/2"	INC. DCN 151M2-241A-5 PER DCN 01-0001			"INITIALS ON FILE"
1/2"	INC. DCN 151M2-241A-4 PER DCN 01-0001			"INITIALS ON FILE"
1/2"	INC. DCN 151M2-241A-3 FOR HSC 01-0052 SUPP. & B. GEN. UPDATE PER DCN 01-0052 SUPP. & B. GEN. DCN 01-0052-1-4, RELOCATED 1 1/2\"/>			

DAVIS-BESSE NUCLEAR POWER STATION
 UNIT NO. 1
 INSERVICE INSPECTION ISOMETRIC
 SERVICE WATER SYSTEM
 COOLERS & RETURN LINE

151M2-241A 5