



- LEGEND**
- ASME SECTION XI CLASS 1 PIPING
  - - - ASME SECTION XI CLASS 2 PIPING
  - ..... ASME SECTION XI CLASS 3 PIPING
  - ..... NON-151 NUCLEAR CLASS AND HSC CLASS
  - ..... PRESSURE BOUNDARY EXTENSION
  - ..... REFERENCE & CONTINUITY
  - O - D - HVAC DUCT
  - A ANCHOR
  - CS CONSTANT SPRING HANGER
  - VS VARIABLE SPRING HANGER
  - HS HYDRAULIC SHUBBER
  - MS MECHANICAL SHUBBER
  - N NON-WELDED SUPPORT ATTACHMENT
  - W WELDED INTEGRAL SUPPORT ATTACHMENT
  - R RIGID SUPPORT
  - T SWAY STRUT
  - SW SHOP WELD
  - FW FIELD WELD
  - LW LONGITUDINAL WELD
  - WOL WELDOLET
  - ◻ 151 ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.

- NOTES:**
1. MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SHUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2MS - TWO HYDRAULIC TYPE SHUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE).
  2. THE SERVICE WATER LINE 8" HBB-7 WELDS ARE EXEMPT FROM INSERVICE EXAMINATION REQUIREMENTS PER 10C 1220. THE WELDS AND SUPPORTS SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION. THE HBB-7 SUPPORTS ARE ALSO EXEMPT FROM INSERVICE EXAMINATION REQUIREMENTS PER 10C 1220. HOWEVER, THE HBB-7 SUPPORTS HAVE BEEN INCLUDED IN THE TOTAL HANGER POPULATION AND ARE SUBJECT TO EXAMINATION.

**GENERAL NOTE:**  
DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

**REFERENCE DRAWINGS:**  
15102-041C SERVICE WATER SYSTEM FOR CONTAINMENT AIR COOLERS

D-139

▲	INC DCH 151M2-241E-12 FOR	ISS	DATE	BY
▲	151M2-241E-11			
▲	151M2-241E-10			
▲	151M2-241E-9			
▲	151M2-241E-8			
▲	151M2-241E-7			
▲	151M2-241E-6			
▲	151M2-241E-5			
▲	151M2-241E-4			
▲	151M2-241E-3			
▲	151M2-241E-2			
▲	151M2-241E-1			

DAVIS-BESSE NUCLEAR POWER STATION  
UNIT NO. 1  
INSERVICE INSPECTION ISOMETRIC  
SERVICE WATER SYSTEM  
CTMT. AIR COOLER 1-1

151M2-241E 4