

March 5, 1987

DMB 016

Docket No. 50-389

Mr. C. O. Woody
Group Vice President
Nuclear Energy
Florida Power & Light Company
P. O. Box 14000
Juno Beach, Florida 33408

DISTRIBUTION:

LFMB
BGrimes
PBD#8 Rdg
FMiraglia
PMKreutzer-3
ETourigny
JPartlow
LJHarmon
TBarnhart 4
EButcher
LKopp

Docket File

NRC & L PDRs
OPA
ACRS-10
WRegan
WJones
ATHadani
EJordan
OELD
Gray File+2
NThompson

Dear Mr. Williams:

The Commission has issued the enclosed Amendment No.17 to Facility Operating License No. NPF-16 for the St. Lucie Plant, Unit No. 2. This amendment consists of changes to the Technical Specifications in response to your application dated November 7, 1986.

This amendment discontinues the use of nuclear flux peaking augmentation factors.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's next bi-weekly Federal Register notice.

Sincerely,

Original signed by

E. G. Tourigny, Project Manager
PWR Project Directorate #8
Division of PWR Licensing-B

Enclosures:

1. Amendment No. 17 to NPF-16
2. Safety Evaluation

cc w/enclosures:

See next page

PBD#8
PMKreutzer
2/16/87

PBD#8
ETourigny
2/10/86

OGC-Beth
M. Beang
2/12/86

PBD#8
ATHadani
2/12/86

*Make of check state
9527 before
issuance*
AT

Mr. C. O. Woody
Florida Power & Light Company

St. Lucie Plant

cc:

Mr. Jack Shreve
Office of the Public Counsel
Room 4, Holland Building
Tallahassee, Florida 32304

Mr. Allan Schubert, Manager
Public Health Physicist
Department of Health and
Rehabilitative Services
1323 Winewood Blvd.
Tallahassee, Florida 32301

Resident Inspector
c/o U.S. NRC
7585 S. Hwy A1A
Jensen Beach, Florida 33457

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
Executive Director for Operations
101 Marietta Street N.W., Suite 2900
Atlanta, Georgia 30323

State Planning & Development
Clearinghouse
Office of Planning & Budget
Executive Office of the Governor
The Capitol Building
Tallahassee, Florida 32301

Harold F. Reis, Esq.
Newman & Holtzinger
1615 L Street, N.W.
Washington, DC 20036

Norman A. Coll, Esq.
McCarthy, Steel, Hector and Davis
14th Floor, First National Bank Building
Miami, Florida 33131

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Mr. Weldon B. Lewis, County
Administrator
St. Lucie County
2300 Virginia Avenue, Room 104
Fort Pierce, Florida 33450

Mr. Charles B. Brinkman, Manager
Washington - Nuclear Operations
Combustion Engineering, Inc.
7910 Woodmont Avenue
Bethesda, Maryland 20814



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FLORIDA POWER & LIGHT COMPANY

ORLANDO UTILITIES COMMISSION OF

THE CITY OF ORLANDO, FLORIDA

AND

FLORIDA MUNICIPAL POWER AGENCY

DOCKET NO. 50-389

ST. LUCIE PLANT UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 17
License No. NPF-16

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power & Light Company, et al. (the licensee), dated November 7, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8703120391 870305
PDR ADOCK 05000389
P PDR

2. Accordingly, Facility Operating License No. NPF-16 is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and by amending paragraph 2.C.2 to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 17, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Ashok C. Thadani, Director
PWR Project Directorate #8
Division of PWR Licensing-B

Attachment:
Changes to the Technical
Specifications

Date of Issuance: March 5, 1987

ATTACHMENT TO LICENSE AMENDMENT NO. 17

TO FACILITY OPERATING LICENSE NO. NPF-16

DOCKET NO. 50-389

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Remove Pages

3/4 2-2

3/4 2-6

B 3/4 2-1

Insert Pages

3/4 2-2

3/4 2-6

B 3/4 2-1

3/4.2 POWER DISTRIBUTION LIMITS

3/4 2.1 LINEAR HEAT RATE

LIMITING CONDITION FOR OPERATION

3.2.1 The linear heat rate shall not exceed the limits shown on Figure 3.2-1.

APPLICABILITY: MODE 1.

ACTION:

With the linear heat rate exceeding its limits, as indicated by four or more coincident incore channels or by the AXIAL SHAPE INDEX outside of the power dependent control limits of Figure 3.2-2, within 15 minutes initiate corrective action to reduce the linear heat rate to within the limits and either:

- a. Restore the linear heat rate to within its limits within 1 hour, or
- b. Be in at least HOT STANDBY within the next 6 hours.

SURVEILLANCE REQUIREMENTS

4.2.1.1 The provisions of Specification 4.0.4 are not applicable.

4.2.1.2 The linear heat rate shall be determined to be within its limits by continuously monitoring the core power distribution with either the excore detector monitoring system or with the incore detector monitoring system.

4.2.1.3 Excore Detector Monitoring System - The excore detector monitoring system may be used for monitoring the core power distribution by:

- a. Verifying at least once per 12 hours that the full-length CEAs are withdrawn to and maintained at or beyond the Long Term Steady State Insertion Limit of Specification 3.1.3.6.
- b. Verifying at least once per 31 days that the AXIAL SHAPE INDEX alarm setpoints are adjusted to within the limit shown on Figure 3.2-2.

POWER DISTRIBUTION LIMITS

SURVEILLANCE REQUIREMENTS (Continued)

- c. Verifying that the AXIAL SHAPE INDEX is maintained within the allowable limits of Figure 3.2-2, where 100% of maximum allowable power represents the maximum THERMAL POWER allowed by the following expression:

$$M \times N$$

where:

1. M is the maximum allowable THERMAL POWER level for the existing Reactor Coolant Pump combination.
2. N is the maximum allowable fraction of RATED THERMAL POWER as determined by the F_{xy}^T curve of Figure 3.2-3.


4.2.1.4 Incore Detector Monitoring System[#] - The incore detector monitoring system may be used for monitoring the core power distribution by verifying that the incore detector Local Power Density alarms:

- a. Are adjusted to satisfy the requirements of the core power distribution map which shall be updated at least once per 31 days of accumulated operation in MODE 1.
- b. Have their alarm setpoint adjusted to less than or equal to the limits shown on Figure 3.2-1 when the following factors are appropriately included in the setting of these alarms:
 1. A measurement-calculational uncertainty factor of 1.062,
 2. An engineering uncertainty factor of 1.03,
 3. A linear heat rate uncertainty factor of 1.01 due to axial fuel densification and thermal expansion, and
 4. A THERMAL POWER measurement uncertainty factor of 1.02.

[#] If incore system becomes inoperable, reduce power to M x N within 4 hours and monitor linear heat rate in accordance with Specification 4.2.1.3.

FIGURE 3.2-3

ALLOWABLE COMBINATIONS OF THERMAL POWER AND F_r^T, F_{xy}^T



THIS PAGE INTENTIONALLY BLANK

3/4.2 POWER DISTRIBUTION LIMITS

BASES

3/4.2.1 LINEAR HEAT RATE

The limitation on linear heat rate ensures that in the event of a LOCA, the peak temperature of the fuel cladding will not exceed 2200°F.

Either of the two core power distribution monitoring systems, the Excore Detector Monitoring System and the Incore Detector Monitoring System, provides adequate monitoring of the core power distribution and are capable of verifying that the linear heat rate does not exceed its limits. The Excore Detector Monitoring System performs this function by continuously monitoring the AXIAL SHAPE INDEX with the OPERABLE quadrant symmetric excore neutron flux detectors and verifying that the AXIAL SHAPE INDEX is maintained within the allowable limits of Figure 3.2-2. In conjunction with the use of the excore monitoring system and in establishing the AXIAL SHAPE INDEX limits, the following assumptions are made: (1) the CEA insertion limits of Specifications 3.1.3.5 and 3.1.3.6 are satisfied, (2) the AZIMUTHAL POWER TILT restrictions of Specification 3.2.4 are satisfied, and (3) the TOTAL PLANAR RADIAL PEAKING FACTOR does not exceed the limits of Specification 3.2.2.

The Incore Detector Monitoring System continuously provides a direct measure of the peaking factors and the alarms which have been established for the individual incore detector segments ensure that the peak linear heat rates will be maintained within the allowable limits of Figure 3.2-1. The setpoints for these alarms include allowances, set in the conservative directions, for (1) a measurement-calculational uncertainty factor of 1.062, (2) an engineering uncertainty factor of 1.03, (3) an allowance of 1.01 for axial fuel densification and thermal expansion, and (4) a THERMAL POWER measurement uncertainty factor of 1.02.

3/4.2.2, 3/4.2.3 and 3/4.2.4 TOTAL PLANAR AND INTEGRATED RADIAL PEAKING

FACTORS - F_{xy}^T and F_r^T AND AZIMUTHAL POWER TILT - T_q

The limitations on F_{xy}^T and T_q are provided to ensure that the assumptions used in the analysis for establishing the Linear Heat Rate and Local Power Density - High LCOs and LSSS setpoints remain valid during operation at the various allowable CEA group insertion limits. The limitations on F_r^T and T_q are provided to ensure that the assumptions used in the analysis establishing the DNB Margin LCO, the Thermal Margin/Low Pressure LSSS setpoints remain valid during operation at the various allowable CEA group insertion limits. If F_{xy}^T , F_r^T or T_q exceed their basic limitations, operation may continue under the additional restrictions imposed by the ACTION statements since these additional restrictions provide adequate provisions to assure that the

POWER DISTRIBUTION LIMITS

BASES

assumptions used in establishing the Linear Heat Rate, Thermal Margin/Low Pressure and Local Power Density - High LCOs and LSSS setpoints remain valid.

An AZIMUTHAL POWER TILT > 0.10 is not expected and if it should occur, subsequent operation would be restricted to only those operations required to identify the cause of this unexpected tilt.

The requirement that the measured value of T_q be multiplied by the calculated values of F_r and F_{xy} to determine F_r^T and F_{xy}^T is applicable only when F_r and F_{xy} are calculated with a non-full core power distribution analysis code. When monitoring a reactor core power distribution, F_r or F_{xy} with a full core power distribution analysis code the azimuthal tilt is explicitly accounted for as part of the radial power distribution used to calculate F_{xy} and F_r .

The Surveillance Requirements for verifying that F_{xy}^T , F_r^T and T_q are within their limits provide assurance that the actual values of F_{xy} , F_r and T_q do not exceed the assumed values. Verifying F_{xy}^T and F_r^T after each fuel loading prior to exceeding 75% of RATED THERMAL POWER provides additional assurance that the core was properly loaded.

3/4.2.5 DNB PARAMETERS

The limits on the DNB-related parameters assure that each of the parameters are maintained within the normal steady-state envelope of operation assumed in the transient and safety analyses. The limits are consistent with the safety analyses assumptions and have been analytically demonstrated adequate to maintain a minimum DNBR of ≥ 1.28 throughout each analyzed transient.

The 12-hour periodic surveillance of these parameters through instrument readout is sufficient to ensure that the parameters are restored within their limits following load changes and other expected transient operation. The 18-month periodic measurement of the RCS total flow rate is adequate to detect flow degradation and ensure correlation of the flow indication channels with measured flow such that the indicated percent flow will provide sufficient verification of flow rate on a 12-hour basis.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 17

TO FACILITY OPERATING LICENSE NO. NPF-16

FLORIDA POWER & LIGHT COMPANY, ET AL.

ST. LUCIE PLANT, UNIT NO. 2

DOCKET NO. 50-389

INTRODUCTION

By letter dated November 7, 1986, (L-86-444), Florida Power and Light Company (FP&L), the licensee, requested a change to the St. Lucie Unit 2 Technical Specifications to discontinue the use of nuclear flux peaking augmentation factors. These factors were originally developed to provide margin for possible increased flux peaks which could result from the formation of interpellet gaps in the fuel pellet column and the subsequent local creepdown of the fuel cladding. The elimination of these augmentation factors would modify part 4.2.1.4 of the Linear Heat Rate (LHR) Technical Specification and delete Figure 4.2.1, which specifies the value of the augmentation factor versus height in the core.

EVALUATION

A report entitled "Evaluation of Interpellet Gap Formation and Clad Collapse in Modern PWR Fuel Rods", (EPRI NP-3966-CCM), was submitted to the staff during the review of the Calvert Cliffs Unit 1 Cycle 8 license application. The report presented an analysis performed by Combustion Engineering (CE) for Electric Power Research Institute (EPRI) and gave the results of a review of interpellet gap formation, ovality, creepdown and clad collapse data in modern PWR fuel rods (non-densifying fuel in pre-pressurized tubes). The report concluded that since the increased power peaking associated with the small interpellet gaps found in these rods is insignificant compared to other power distribution uncertainties used in the safety analyses, augmentation factors can be removed from the reload of any reactor loaded exclusively with this type of fuel. The staff accepted this conclusion for the Cycle 8 reload review of Calvert Cliffs Unit 1 and the Cycle 3 reload review of San Onofre Unit 2 and agrees that the conclusion is also valid for St. Lucie Unit 2 since the same manufacturing process is used in the Calvert Cliffs, San Onofre and St. Lucie fuel. The densification augmentation factors can, therefore, be eliminated for St. Lucie Unit 2.

8703120396 870305
PDR ADCK 05000389
PDR

The staff has reviewed the FP&L request to remove the nuclear flux peaking augmentation factors from the St. Lucie Unit 2 Technical Specifications. Since the manufacturing process for the fuel rods used in Unit 2 is the same as that which was used in the fuel rods for which CE previously had demonstrated the formation of insignificant interpellet gaps, the request is acceptable. The safety analyses for St. Lucie Unit 2 have been performed in a manner such that the removal of the augmentation factors will not cause any of the results to exceed design acceptance criteria.

ENVIRONMENTAL CONSIDERATION

This amendment involves a change in the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 or a change in surveillance requirements. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously published a proposed finding that the amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR §51.22(c)(9). Pursuant to 10 CFR §51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

CONCLUSION

We have concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Date: March 5, 1987

Principal Contributor:
L. Kopp