

July 30, 1992

Docket No. 50-389

DISTRIBUTION
See Attached List

Mr. J. H. Goldberg
President - Nuclear Division
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

Dear Mr. Goldberg:

SUBJECT: ST. LUCIE UNIT 2 - ISSUANCE OF AMENDMENT RE: SAFETY
INJECTION TANKS (TAC NO. M83245)

The Commission has issued the enclosed Amendment No. 58 to Facility Operating License No. NPF-16 for the St. Lucie Plant, Unit No. 2. This amendment consists of changes to the Technical Specifications in response to your application dated April 21, 1992.

This amendment revises Technical Specifications Section 3.5.1, "Safety Injection Tanks," by reducing the minimum nitrogen cover-pressure from 570 psig to 500 psig.

A copy of the Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

(Original Signed by E. Raghavan for)

Jan A. Norris, Senior Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 58 to NPF-16
2. Safety Evaluation

cc w/enclosures:
See next page

NRC FILE CENTER COPY

OFC	:LA:PDII-2	:PM:PDII-2	:D:PDII-2	:OGC	:	:
NAME	:D. Miller	:J. Norris	:H. Bayliss	:STUR	:	:
DATE	:7/20/92	:7/22/92	:7/22/92	:7/27/92	:	:

DOCUMENT NAME - SL283245.AMD

9208050103 920730
PDR ADOCK 05000389
P PDR

DF01
111

Mr. J. H. Goldberg
Florida Power and Light Company

St. Lucie Plant

cc:

Jack Shreve, Public Counsel
Office of the Public Counsel
c/o The Florida Legislature
111 West Madison Avenue, Room 812
Tallahassee, Florida 32399-1400

Mr. Jacob Daniel Nash
Office of Radiation Control
Department of Health and
Rehabilitative Services
1317 Winewood Blvd.
Tallahassee, Florida 32399-0700

Senior Resident Inspector
St. Lucie Plant
U.S. Nuclear Regulatory Commission
7585 S. Hwy A1A
Jensen Beach, Florida 33457

Regional Administrator, RII
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, Georgia 30323

Mr. Robert G. Nave, Director
Emergency Management
Department of Community Affairs
2740 Centerview Drive
Tallahassee, Florida 32399-2100

Mr. R. E. Grazio
Director, Nuclear Licensing
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

Harold F. Reis, Esq.
Newman & Holtzinger
1615 L Street, N.W.
Washington, DC 20036

John T. Butler, Esq.
Steel, Hector and Davis
4000 Southeast Financial Center
Miami, Florida 33131-2398

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 34982

Mr. James V. Chisolm, County
Administrator
St. Lucie County
2300 Virginia Avenue
Fort Pierce, Florida 34982

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
ABB Combustion Engineering, Nuclear Power
12300 Twinbrook Parkway, Suite 330
Rockville, Maryland 20852



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

FLORIDA POWER & LIGHT COMPANY

ORLANDO UTILITIES COMMISSION OF

THE CITY OF ORLANDO, FLORIDA

AND

FLORIDA MUNICIPAL POWER AGENCY

DOCKET NO. 50-389

ST. LUCIE PLANT UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 58
License No. NPF-16

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power & Light Company, et al. (the licensee), dated April 21, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9208050106 920730
PDR ADOCK 05000389
P PDR

2. Accordingly, Facility Operating License No. NPF-16 is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and by amending paragraph 2.C.2 to read as follows:

2. Technical Specifications

- The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 58 , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 30, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 58
TO FACILITY OPERATING LICENSE NO. NPF-16
DOCKET NO. 50-389

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by amendment number and contains vertical lines indicating the areas of change. The corresponding overleaf page is also provided to maintain document completeness.

Remove Page

3/4 5-1

Insert Page

3/4 5-1

3/4.5 EMERGENCY CORE COOLING SYSTEMS (ECCS)

3/4.5.1 SAFETY INJECTION TANKS

LIMITING CONDITION FOR OPERATION

- 3.5.1 Each Reactor Coolant System safety injection tank shall be OPERABLE with:
- a. The isolation valve open,
 - b. A contained borated water volume of between 1420 and 1556 cubic feet,
 - c. A boron concentration of between 1720 and 2100 ppm of boron, and
 - d. A nitrogen cover-pressure of between 500 and 650 psig.

APPLICABILITY: MODES 1, 2, 3*, and 4*.

ACTION:

- a. With one safety injection tank inoperable, except as a result of a closed isolation valve, restore the inoperable tank to OPERABLE status within 1 hour or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- b. With one safety injection tank inoperable due to the isolation valve being closed, either immediately open the isolation valve or be in at least HOT STANDBY within 1 hour and be in HOT SHUTDOWN within the next 12 hours.

SURVEILLANCE REQUIREMENTS

- 4.5.1.1 Each safety injection tank shall be demonstrated OPERABLE:
- a. At least once per 12 hours by:
 1. Verifying (by the absence of alarms) the contained borated water volume and nitrogen cover-pressure in the tanks, and
 2. Verifying that each safety injection tank isolation valve is open.

*With pressurizer pressure greater than or equal to 1750 psia. When pressurizer pressure is less than 1750 psia, at least three safety injection tanks shall be OPERABLE, each with a minimum pressure of 235 psig and a maximum pressure of 650 psig and a contained water volume of between 1250 and 1556 cubic feet with a boron concentration of between 1720 and 2100 ppm of boron. With all four safety injection tanks OPERABLE, each tank shall have a minimum pressure of 235 psig and a maximum pressure of 650 psig and a contained water volume of between 833 and 1556 cubic feet with a boron concentration of between 1720 and 2100 ppm of boron. In MODE 4 with pressurizer pressure less than 276 psia, the safety injection tanks may be isolated.

EMERGENCY CORE COOLING SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- b. At least once per 31 days and within 6 hours after each solution volume increase of greater than or equal to 1% of tank volume by verifying the boron concentration of the safety injection tank solution.
- c. At least once per 31 days when the RCS pressure is above 700 psia, by verifying that power to the isolation valve operator is disconnected by maintaining the breaker open by administrative controls.
- d. At least once per 18 months by verifying that each safety injection tank isolation valve opens automatically under each of the following conditions:
 - 1. When an actual or simulated RCS pressure signal exceeds 515 psia, and
 - 2. Upon receipt of a safety injection test signal.

4.5.1.2 Each safety injection tank water level and pressure channel shall be demonstrated OPERABLE:

- a. At least once per 31 days by the performance of a CHANNEL FUNCTIONAL TEST.
- b. At least once per 18 months by the performance of a CHANNEL CALIBRATION.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 58

TO FACILITY OPERATING LICENSE NO. NPF-16

FLORIDA POWER & LIGHT COMPANY, ET AL.

ST. LUCIE PLANT, UNIT NO. 2

DOCKET NO. 50-389

1.0 INTRODUCTION

In a submittal dated April 21, 1992, the Florida Power and Light Company (the licensee) proposed a change to the Technical Specifications (TS) for its St. Lucie Unit 2 plant, which would lower the minimum required safety injection tank (SIT) pressure from 570 pounds per square inch-gauge (psig) to 500 psig. In the submittal, the licensee provided a technical report which addresses the impact of this change on licensing basis events.

2.0 EVALUATION

Technical justification for the proposed TS change is contained in technical report OPS-92-0385, which was included in the licensee's submittal. OPS-92-0385 addresses the impact of the proposed TS change on St. Lucie licensing basis events, including Standard Review Plan (SRP) Chapter 15 events. These are discussed in the following sections.

2.1 Small Break LOCA Analyses

To address the impact of the SIT pressure change on the small break loss of coolant accident (LOCA) events, the licensee provided analyses for a spectrum of postulated small break LOCAs ranging in size from 0.0375 square foot, the previously identified worst small break size, to 0.0500 square foot. The new limiting small break size was identified as a 0.045 square foot pump discharge break. The calculated peak cladding temperature for the 0.045 square foot break is 1905 degrees F. This calculated peak cladding temperature (PCT) and the local and core-wide oxidation results calculated for small break LOCAs continue to be bounded by large break LOCA results and are acceptable.

2.2 Large Break LOCA Analyses

The licensee referenced the current large break LOCA analysis of record as being bounding for the proposed reactor configuration with 500 psig SIT pressures. The current analysis of record, performed in 1987 to justify plant operation with 570 psig SIT pressures, assumes the SITs are pressurized to 200 psig. The staff's Safety Evaluation (SE) of November 12, 1987 found this large break LOCA analysis with the 200 psig SIT assumption acceptable for operation with 570 psig SITs. The calculated PCT is 2106 degrees F, the maximum calculated local cladding oxidation is 7.62 percent, and the calculated total core-wide cladding oxidation is less than 0.7 percent. These values, which bound those for the small break LOCA analyses, are within the limits specified in 10 CFR 50.46(b).

Since the present proposal is bounded by the finding made in the 1987 staff SE the staff finds this analysis acceptable. Additionally, the proposed SIT pressure (500 psig) is closer to the analyzed SIT pressure (200 psig) than the existing SIT pressure (570 psig).

2.3 Non-LOCA Design Basis Events

The licensee considered the impact of the lower SIT pressure on non-LOCA design basis event analyses. In its submittal, the licensee reports that its review of St. Lucie Unit 2 non-LOCA design basis event analyses indicates that no credit for SIT injection into the reactor coolant system (RCS) is taken in the analyses and, therefore, the reduction of the SIT minimum pressure setpoint does not impact the non-LOCA safety analyses.

2.4 Station Blackout

The licensee also provided an assessment of the impact of the lower SIT pressure on station blackout events. This assessment amends the current station blackout event analysis which assumes a 570 psig SIT pressure. The current analysis is documented in the St. Lucie 2 Final Safety Analysis Report (FSAR) Section 15.10 (FSAR Amendment 1, April 1986). The objective of the analysis is to assure that natural circulation can be maintained for a 4-hour period following a loss of all alternating current (AC) power (station blackout) at St. Lucie 2, until AC power could be restored to the plant. The current analysis calculated that reactor coolant system (RCS) pressure would reduce to the SIT pressure (570 psig) and the injection rate would exceed the RCS leak rate at about 3.5 hours, and by 3.9 hours the total integrated injection would exceed the total integrated leakage for the event. The analysis concluded that natural circulation would be maintained for the 4-hour period. In a SE dated September 12, 1991 the staff found the 1986 analysis acceptable to address Station Blackout Rule (10 CFR 50.63) requirements.

The new assessment changes the assumed SIT pressure for this event to 500 psia, but changes no other analysis assumptions. At the lower SIT pressure the licensee's analysis indicates that SIT injection would occur at about 3.9 hours, a delay of about 24.3 minutes. In its assessment the licensee adjusted

the RCS inventory from the approved analysis to account for the delay in SIT injection and additional steam mass accumulation during the delay period. The licensee concluded that at least 3373.5 pounds-mass of (liquid) water would remain in the upper head and pressurizer regions at the time of SIT (500 psig) injection, with no voiding introduced into the RCS loops. The licensee concluded that natural circulation continues to be assured on the same basis as for the previous analysis.

In summary, the licensee's assessment concludes that the lowering of SIT pressures to 500 psig does not substantially impact station blackout events. The staff finds this assessment acceptable.

3.0 TECHNICAL FINDINGS

As discussed in Section 2.0, the staff finds the proposed change to the St. Lucie Unit 2 Technical Specifications lowering the SIT minimum pressure setpoint acceptable, based on the justification provided in the licensee's submittal of April 21, 1992.

4.0 STATE CONSULTATION

Based upon the written notice of the proposed amendment, the Florida State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

This amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding (57 FR 19317). Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such

activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: F. Orr

Date: July 30, 1992

DATED: July 30, 1992

AMENDMENT NO. 58 TO FACILITY OPERATING LICENSE NO. NPF-16 - ST. LUCIE, UNIT 2

Docket File
NRC & Local PDRs
PDII-2 Reading
S. Varga, 14/E/4
G. Lainas, 14/H/3
H. Berkow
D. Miller
J. Norris
F. Orr, 8/E/23
OGC
D. Hagan, 3302 MNBB
G. Hill (4) P-137
Wanda Jones, MNBB-7103
C. Grimes, 11/F/23
ACRS (10)
OPA
OC/LFMB
M. Sinkule, R-II