

JUL 17 1975

Docket Nos. 50-259
and 50-260

DISTRIBUTION
Docket Files
NRC PDRs
Local PDRs
ORB#1 Reading
KRGoller
TJCarter
RAPurple
TVWambach
SMSheppard
OELD
OI&E (3)
ACRS (14)

Tennessee Valley Authority
ATTN: Mr. James E. Watson
Manager of Power
818 Power Building
Chattanooga, Tennessee 37201

Gentlemen:

This confirms our telephoned authorization given today (July 17, 1975) for a change in Technical Specifications for the Browns Ferry Nuclear Plant Unit 1 and Unit 2 as requested by your telephone call on July 17, 1975. Facility Operating License Nos. DPR-33 and DPR-52 are amended on this date by making the following technical specification change:

Section 3.3 Specification to read:

"While more than one fuel assembly is in the reactor vessel, the requirements of 3.3.A through 3.3.G shall be met."

Sections 3.10.A.1 and 3.10.A.2, add to the end of each section the phrase:

"while more than one fuel assembly is in the reactor vessel."

Copies of the license amendments, Federal Register Notice, and Safety Evaluation for this technical specification change will be sent to you when completed.

Sincerely,

Original signed by:
Karl R. Goller

Karl R. Goller, Assistant Director
for Operating Reactors
Division of Reactor Licensing

cc: See next page

u

OFFICE >	RL:ORB#1 TVW	RL:ORB#1 RAPurple	RLOR KRG		
SURNAME >	TVWambach:dc	RAPurple	KRGoller		
DATE >	7/17/75	7/17/75	7/17/75		

Tennessee Valley Authority

- 2 -

July 17, 1975

cc: Robert H. Marquis
General Counsel
629 New Sprankle Building
Knoxville, Tennessee 37919

Athens Public Library
South and Forrest
Athens, Alabama 35611

Anthony Z. Roisman, Esquire
Berlin, Roisman & Kessler
1712 N Street, NW
Washington, D.C. 20036