

JUL 17 1975

Docket Nos. 50-259  
and 50-260

DISTRIBUTION  
Docket Files  
NRC PDRs  
Local PDRs  
ORB#1 Reading  
KRGoller  
TJCarter  
RAPurple  
TVWambach  
SMSheppard  
OELD  
OI&E (3)  
ACRS (14)

Tennessee Valley Authority  
ATTN: Mr. James E. Watson  
Manager of Power  
818 Power Building  
Chattanooga, Tennessee 37201

Gentlemen:

This confirms our telephoned authorization given today (July 17, 1975) for a change in Technical Specifications for the Browns Ferry Nuclear Plant Unit 1 and Unit 2 as requested by your telephone call on July 17, 1975. Facility Operating License Nos. DPR-33 and DPR-52 are amended on this date by making the following technical specification change:

Section 3.3 Specification to read:

"While more than one fuel assembly is in the reactor vessel, the requirements of 3.3.A through 3.3.G shall be met."

Sections 3.10.A.1 and 3.10.A.2, add to the end of each section the phrase:

"while more than one fuel assembly is in the reactor vessel."

Copies of the license amendments, Federal Register Notice, and Safety Evaluation for this technical specification change will be sent to you when completed.

Sincerely,

Original signed by:  
Karl R. Goller

Karl R. Goller, Assistant Director  
for Operating Reactors  
Division of Reactor Licensing

cc: See next page

u

OFFICE >	RL:ORB#1 TVW	RL:ORB#1 RAPurple	RLOR KRG		
SURNAME >	TVWambach:dc	RAPurple	KRGoller		
DATE >	7/17/75	7/17/75	7/17/75		

Tennessee Valley Authority

- 2 -

July 17, 1975

cc: Robert H. Marquis  
General Counsel  
629 New Sprankle Building  
Knoxville, Tennessee 37919

Athens Public Library  
South and Forrest  
Athens, Alabama 35611

Anthony Z. Roisman, Esquire  
Berlin, Roisman & Kessler  
1712 N Street, NW  
Washington, D.C. 20036