

Docket Nos. 50-259
 50-260
 and 50-296

Tennessee Valley Authority
 ATTN: Mr. N. B. Hughes
 Manager of Power
 830 Power Building
 Chattanooga, Tennessee 37401

DISTRIBUTION:

- Docket
- NRC PDR
- Local PDR
- ORB#3 Rdg
- VStello
- GLear
- SSheppard
- KRGoller
- RCClark
- OELD
- OI&E (5)
- BJones (2)
- BSchaff (15)
- MJcGough
- DEisenhut
- ACRS (16)
- CMiles
- DRoss
- TBAbernathy
- JRBuchanan
- File
- Xtra Copies

Gentlemen:

On March 29, 1978, we issued Amendments Nos. 37, 34 and 11 to Facility Licenses Nos. DPR-33, DPR-52 and DPR-68. In paragraph 4.9.B.1 of the amended Technical Specifications for Unit No. 1 (page 295), there was a typographical error in line 5. Line 5 should read: "or when the 500kV backfeed to the Unit 2". A copy of the corrected page is enclosed.

Sincerely,
V. Rooney for
 Original signed by

George Lear, Chief
 Operating Reactors Branch #3
 Division of Operating Reactors

Enclosure:
 Page 294/295

cc w/enclosure:
 see next page



OFFICE →	ORB#3	ORB#3	ORB#3			
SURNAME →	<i>SSheppard</i>	<i>RCClark:acr</i>	<i>GLear</i>			
DATE →	3/31/78	3/31/78	3/31/78			

cc: H. S. Sanger, Jr., Esquire
General Counsel
Tennessee Valley Authority
400 Commerce Avenue
E 11B 33 C
Knoxville, Tennessee 37902

Mr. D. McCloud
Tennessee Valley Authority
303 Power Building
Chattanooga, Tennessee 37401

Mr. William E. Garner
Route 4, Box 354
Scottsboro, Alabama 35768

Mr. Charles R. Christopher
Chairman, Limestone County Commission
Post Office Box 188
Athens, Alabama 35611

Ira L. Myers, M.D.
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36104

Mr. C. S. Walker
Tennessee Valley Authority
400 Commerce Avenue
W 9D199 C
Knoxville, Tennessee 37902

Athens Public Library
South and Forrest
Athens, Alabama 35611

Chief, Energy Systems
Analyses Branch (AW-459)
Office of Radiation Programs
U.S. Environmental Protection Agency
Room 645, East Tower
401 M Street, SW
Washington, D.C. 20460

U. S. Environmental Protection
Agency
Region IV Office
ATTN: EIS Coordinator
345 Courtland Street
Atlanta, Georgia 30308

1.9.A Auxiliary Electrical Equipment4.9.A Auxiliary Electrical Equipment

3. Logic Systems

- a. Both divisions of the common accident signal logic system shall be tested every 6 months to demonstrate that it will function on actuation of the core spray system of each reactor to provide an automatic start signal to all 4 units 1 and 2 diesel generators.
- b. Once every 6 months, the condition under which the 480-Volt load shedding logic system is required shall be simulated using pendant test switches and/or pushbutton test switches to demonstrate that the load shedding logic system would initiate load shedding signals on the diesel auxiliary boards, reactor MOV boards, and the 480-Volt shutdown boards.

4. Undervoltage Relays

- a. Once every 6 months, the condition under which the undervoltage relays are required shall be simulated with an undervoltage on start buses 1A and 1B to demonstrate that the diesel generators will start.
- b. Once every 6 months, the conditions under which the undervoltage relays are required shall be simulated with an undervoltage on each shutdown board to demonstrate that the associated diesel generator will start.
- c. The undervoltage relays which start the diesel generators from start buses 1A and 1B and the 4-kV shutdown boards, shall be calibrated annually for trip and reset and the measurements logged.

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.9.B Operation with Inoperable Equipment

Whenever a reactor is in Startup mode or Run mode and not in a cold condition, the availability of electric power shall be as specified in 3.9.A, except as specified herein.

1. From and after the date that one 161-kV line or one common station transformer and its parallel cooling tower transformer or one start bus becomes inoperable, reactor operation is permissible under this condition for seven days.
2. When one of the units 1 and 2 diesel generator is inoperable, continued reactor operation is permissible during the succeeding 7 days, provided that both off-side 161-kV transmission lines and both common station transformers or one common transformer and one cooling tower transformer (not parallel with the energized common transformer) are available, and all of the CS, RHR (LPCI and Containment Cooling) Systems, and the remaining three units 1 and 2 diesel generators are operable. If this requirement cannot be met, an orderly shutdown shall be initiated and both reactors shall be shutdown and in the cold condition within 24 hours.

4.9.B Operation with Inoperable Equipment

1. When one 161-kV line or one common station transformer and its parallel cooling tower transformers or one start bus is found to be inoperable, or when the 500kV backfeed to Unit 2 main or station service transformer is found to be inoperable, all units 1 and 2 diesel generators and associated boards must be demonstrated to be operable immediately and daily thereafter.
2. When one of the Units 1 and 2 diesel generator is found to be inoperable, all of the CS, RHR (LPCI and Containment Cooling) Systems and the remaining diesel generators and associated boards shall be demonstrated to be operable immediately and daily thereafter.