

REGULATORY DOCKET FILE COPY

11/14/79

Docket Nos. 50-259
50-260
and 50-296

Mr. Hugh G. Parris
Manager of Power
Tennessee Valley Authority
500 A Chestnut Street, Tower II
Chattanooga, Tennessee 37401

DISTRIBUTION:

Docket ACRS (16)
NRC PDR CMiles
Local PDR RDiggs
ORB#3 Rdg HDenton
NRR Rdg JRBuchanan
DEisenhut TERA
RVollmer File
WGammill Xtra Copies
LShao
JMiller
BGrimes
SSheppard
RClark
OELD
OI&E (5)
BJones (12)
BScharf (10)
DBrinkman

Dear Mr. Parris:

The Commission has issued the enclosed Amendments Nos. 55, 50 and 27 to Facility Licenses Nos. DPR-33, DPR-52 and DPR-68 for the Browns Ferry Nuclear Plant, Units Nos. 1, 2 and 3. These amendments which are in response to your letter of August 6, 1979 (TVA BFNP TS 128), change the Technical Specifications to allow partial tensioning of the reactor vessel head bolts at 70°F. As discussed with your staff, the other related change which you requested - to adjust curve #3 in the pressure vs. temperature operating NDT limit curves to permit nuclear heat to be utilized above 100°F - is being held in abeyance pending generic resolution of this issue.

Copies of the Safety Evaluation and Notice of Issuance are also enclosed.

Sincerely,

TS

Thomas A. Ippolito, Chief
Operating Reactors Branch #3
Division of Operating Reactors

Enclosures:

1. Amendment No. 55 to DPR-33
2. Amendment No. 50 to DPR-52
3. Amendment No. 27 to DPR-68
4. Safety Evaluation
5. Notice

cc w/enclosures:
see next page

*No local inspection to
be made on amendment
to notice*

CP

CCP

7911290110

OFFICE	ORB#3	ORB#3	OELD	ORB#3	AD/DPR/DOR
SURNAME	SSheppard	RClark:acr	CATCHIN	Tippolito	WGammill
DATE	11/ 8 /79	11/ 08 /79	11/ 13 /79	11/ 8 /79	11/ 4 /79

Mr. Hugh G. Parris
Tennessee Valley Authority

- 2 -

cc:

H. S. Sanger, Jr., Esquire
General Counsel
Tennessee Valley Authority
400 Commerce Avenue
E 11B 33C
Knoxville, Tennessee 37902

Mr. Dennis McCloud
Tennessee Valley Authority
400 Chestnut Street, Tower II
Chattanooga, Tennessee 37401

Mr. Charles R. Christopher
Chairman, Limestone County Commission
P. O. Box 188
Athens, Alabama 35611

Ira L. Myers, M.D.
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36104

Mr. E. G. Beasley
Tennessee Valley Authority
400 Commerce Avenue
W 10C 131C
Knoxville, Tennessee 37902

Athens Public Library
South and Forrest
Athens, Alabama 35611

Director, Office of Urban & Federal
Affairs
108 Parkway Towers
404 James Robertson Way
Nashville, Tennessee 37219

Director, Technical Assessment Division
Office of Radiation Programs (AW-459)
US EPA
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection
Agency
Region IV Office
ATTN: EIS COORDINATOR
345 Courtland Street
Atlanta, Georgia 30308

Mr. Robert F. Sullivan
U. S. Nuclear Regulatory Commission
P. O. Box 1863
Decatur, Alabama 35602



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-259

BROWNS FERRY NUCLEAR PLANT, UNIT NO. 1

AMENDMENT, TO FACILITY OPERATING LICENSE

Amendment No. 55
License No. DPR-33

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated August 6, 1979, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility License No. DPR-33 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 55, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Thomas A. Ippolito, Chief
Operating Reactors Branch #3
Division of Operating Reactors

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 14, 1979

ATTACHMENT TO LICENSE AMENDMENT NO. 55

FACILITY OPERATING LICENSE NO. DPR-33

DOCKET NO. 50-259

Revise Appendix A as follows:

1. Remove the following pages and replace with identically numbered pages:

175/176

216/217

2. The underlined pages are those being changed; the marginal lines on these pages indicate the area being revised. The overleaf pages are provided for convenience.

3.6.A Thermal and Pressurization Limitations

3. During heatup by non-nuclear means, except when the vessel is vented, cooldown following nuclear shutdown on low-level physics tests, the reactor vessel temperatures shall be at or above the temperatures of curve #2 of figure 3.6-1.
4. The reactor vessel shell temperatures during inservice hydrostatic or leak testing shall be at or above the temperatures shown on curve #1 of figure 3.6-1.
5. The reactor vessel head bolting studs may be partially tensioned (four sequences of the seating pass) provided the studs and flange materials are above 70°F. Before loading the flanges any more, the vessel flange and head flange must be greater than 100°F, and must remain above 100°F while under full tension.
6. The pump in an idle recirculation loop shall not be started unless the temperatures of the coolant within the idle and operating recirculation loops are within 50° F of each other.
7. The reactor recirculation pumps shall not be started unless the coolant temperatures between the dome and the bottom head drain are within 145° F.

4.6.A Thermal and Pressurization Limitations

3. Test specimens representing the reactor vessel, base weld, and weld heat affected zone metal shall be installed in the reactor vessel adjacent to the vessel wall at the core midplane level. The number and type of specimens will be in accordance with GE report NEDO-10115. The specimens shall meet the intent of ASTM E 185-70. Samples shall be withdrawn at one-fourth and three-fourths service life.
4. Neutron flux wires shall be installed in the reactor vessel adjacent to the reactor vessel wall at the core midplane level. The wires shall be removed and tested during the first refueling outage to experimentally verify the calculated values of neutron fluence at one-fourth of the beltline shell thickness that are used to determine the NDTT shift from Figure 3.6-2.
5. When the reactor vessel head bolting studs are tensioned and the reactor is in a cold condition, the reactor vessel shell temperature immediately below the head flange shall be permanently recorded.
6. Prior to and during startup of an idle recirculation loop, the temperature of the reactor coolant in the operating and idle loops shall be permanently logged.
7. Prior to starting a recirculation pump, the reactor coolant temperatures in the dome and in the bottom head drain shall be compared and permanently logged.

3.6 PRIMARY SYSTEM BOUNDARYB. Coolant Chemistry

1. Prior to startup and at steaming rates less than 100,000 lb/hr, the following limits shall apply.
 - a. Conductivity, $\mu\text{mho/cm@25}^\circ\text{C}$ 2.0
 - b. Chloride, ppm 0.1

2. At steaming rates greater than 100,000 lb/hr, the following limits shall apply.
 - a. Conductivity, $\mu\text{mho/cm@25}^\circ\text{C}$ 1.0
 - b. Chloride, ppm 0.2

4.6 PRIMARY SYSTEM BOUNDARYB. Coolant Chemistry

1. Reactor coolant shall be continuously monitored for conductivity.
 - a. Whenever the continuous conductivity monitor is inoperable and the condensate demineralizers are bypassed, a sample of reactor coolant shall be analyzed for conductivity every 4 hours. If the condensate demineralizers are in service, a sample of reactor coolant shall be analyzed for conductivity every 8 hours.
 - b. Once a week the continuous monitor shall be checked with an in-line flow cell. This in-line conductivity calibration shall be performed every 24 hours whenever the reactor coolant conductivity is $>1.0 \mu\text{mho/cm}$ at 25°C .

2. During startup prior to pressurizing the reactor above atmospheric pressure, measurements of reactor water quality shall be performed to show conformance with 3.6.B.1. of limiting conditions.

3.6/4.6 BASES

3.6.A/4.6.A

The vessel pressurization temperatures at any time period can be determined from the thermal power output of the plant and its relation to the neutron fluence and from figure 3.6-2. For heatup or cooldown and core operation, see curves #2 & #3 on figure 3.6-1. During the first fuel cycle, only calculated neutron fluence values can be used. At the first refueling, neutron dosimeter wires which are installed adjacent to the vessel wall can be removed to verify the calculated neutron fluence. As more experience is gained in calculating the fluence the need to verify it experimentally will disappear. Because of the many experimental points used to derive figure 3.6-2, there is no need to reverify if for technical reasons, but in case verification is required for other reasons, three sets of mechanical test specimens representing the base metal, weld metal and weld heat affected zone metal have been placed in the vessel. These can be removed and tested as required.

As described in paragraph 4.2.5 of the safety analysis report, detailed stress analyses have been made on the reactor vessel for both steady-state and transient conditions with respect to material fatigue. The results of these analyses are compared to allowable stress limits. Requiring the coolant temperature in an idle recirculation loop to be within 50°F of the operating loop temperature before a recirculation pump is started assures that the changes in coolant temperature at the reactor vessel nozzles and bottom head region are acceptable.

The coolant in the bottom of the vessel is at a lower temperature than that in the upper regions of the vessel when there is no recirculation flow. This colder water is forced up when recirculation pumps are started. This will not result in stresses which exceed ASME Boiler and Pressure Vessel Code, Section III limits when the temperature differential is not greater than 145°F.

The requirements for full tension boltup of the reactor vessel closure are based on the NDT temperature plus 60°F. This is derived from the requirements of the ASME code to which the vessel was built. The NDT temperature of the closure flanges, adjacent head, and shell material is a maximum of 40°F and a maximum of 10°F for the stud material. Therefore, the minimum temperature for full tension boltup is 40°F plus 60°F for a total of 100°F. The partial boltup is restricted to the full loading of eight studs at 70°F, which is stud NDT temperature (10°F) plus 60°F. The neutron radiation fluence at the closure flanges is well below 10^{-17} nvt \geq 1 Mev; therefore, radiation effects will be minor and will not influence this temperature.

3.6.B/4.6.B Coolant Chemistry

Materials in the primary system are primarily 304 stainless steel and the Zircaloy cladding. The reactor water chemistry limits are established to prevent damage to these materials. Limits are placed on conductivity and chloride concentrations. Conductivity is limited because it is continuously measured and gives an indication of abnormal conditions and the presence of unusual materials in the coolant. Chloride limits are specified to prevent stress corrosion cracking of stainless steel.

3.6.B/4.6.B Coolant Chemistry

Zircaloy does not exhibit similar stress corrosion failures. However there are some operating conditions under which the dissolved oxygen content of the reactor coolant water could be higher than .2-.3 ppm, such as reactor startup and hot standby. During these periods, the most restrictive limits for conductivity and chlorides have been established. When steaming rates exceed 100,000 lb/hr, boiling deaerates the reactor water. This reduces dissolved oxygen concentration and assures minimal chloride-oxygen content, which together tend to induce stress corrosion cracking.

When conductivity is in its normal range, pH and chloride and other impurities affecting conductivity must also be within their normal range. When conductivity becomes abnormal, then chloride measurements are made to determine whether or not they are also out of their normal operating values. This would not necessarily be the case. Conductivity could be high due to the presence of a neutral salt which would not have an effect on pH or chloride. In such a case, high conductivity alone is not a cause for shutdown. In some types of water-cooled reactors, conductivities are in fact high due to purposeful addition of additives. In the case of BWR's, however, where no additives are used and where near neutral pH is maintained, conductivity provides a very good measure of the quality of the reactor water. Significant changes therein provide the operator with a warning mechanism so he can investigate and remedy the condition causing the change before limiting conditions, with respect to variables affecting the boundaries of the reactor coolant, are exceeded. Methods available to the operator for correcting the off-standard condition include operation of the reactor cleanup system, reducing the input of impurities and placing the reactor in the cold shutdown condition. The major benefit of cold shutdown is to reduce the temperature dependent corrosion rates and provide time for the cleanup system to reestablish the purity of the reactor coolant.

The conductivity of the reactor coolant is continuously monitored. The samples of the coolant which are taken every 96 hours will serve as a reference for calibration of these monitors and is considered adequate to assure accurate readings of the monitors. If conductivity is within its normal range, chlorides and other impurities will also be within their normal ranges. The reactor coolant samples will also be used to determine the chlorides. Therefore, the sampling frequency is considered adequate to detect long-term changes in the chloride ion content. Daily sampling is performed when increased chloride concentrations are most probable. Reactor coolant sampling is increased to once per shift when the continuous conductivity monitor is unavailable.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-260

BROWNS FERRY NUCLEAR PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 50
License No. DPR-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated August 6, 1979, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility License No. DPR-52 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 50, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Thomas A. Ippolito, Chief
Operating Reactors Branch #3
Division of Operating Reactors

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 14, 1979

ATTACHMENT TO LICENSE AMENDMENT NO. 50

FACILITY OPERATING LICENSE NO. DPR-52

DOCKET NO. 50-260

Revise Appendix A as follows:

1. Remove the following pages and replace with identically numbered pages:

175/176
216/217

2. The underlined pages are those being changed; the marginal lines on these pages indicate the area being revised. The overleaf pages are provided for convenience.

3.6.A Thermal and Pressurization Limitations

3. During heatup by non-nuclear means, except when the vessel is vented, cooldown following nuclear shutdown on low-level physics tests, the reactor vessel temperatures shall be at or above the temperatures of curve #2 of figure 3.6-1.
4. The reactor vessel shell temperatures during inservice hydrostatic or leak testing shall be at or above the temperatures shown on curve #1 of figure 3.6-1.
5. The reactor vessel head bolting studs may be partially tensioned (four sequences of the seating pass) provided the studs and flange materials are above 70°F. Before loading the flanges any more, the vessel flange and head flange must be greater than 100°F, and must remain above 100°F while under full tension.
6. The pump in an idle recirculation loop shall not be started unless the temperatures of the coolant within the idle and operating recirculation loops are within 50° F of each other.
7. The reactor recirculation pumps shall not be started unless the coolant temperatures between the dome and the bottom head drain are within 145° F.

4.6.A Thermal and Pressurization Limitations

3. Test specimens representing the reactor vessel, base weld, and weld heat affected zone metal shall be installed in the reactor vessel adjacent to the vessel wall at the core midplane level. The number and type of specimens will be in accordance with GE report NEDO-10115. The specimens shall meet the intent of ASTM E 185-70. Samples shall be withdrawn at one-fourth and three-fourths service life.
4. Neutron flux wires shall be installed in the reactor vessel adjacent to the reactor vessel wall at the core midplane level. The wires shall be removed and tested during the first refueling outage to experimentally verify the calculated values of neutron fluence at one-fourth of the beltline shell thickness that are used to determine the MDTT shift from Figure 3.6-2.
5. When the reactor vessel head bolting studs are tensioned and the reactor is in a cold condition, the reactor vessel shell temperature immediately below the head flange shall be permanently recorded.
6. Prior to and during startup of an idle recirculation loop, the temperature of the reactor coolant in the operating and idle loops shall be permanently logged.
7. Prior to starting a recirculation pump, the reactor coolant temperatures in the dome and in the bottom head drain shall be compared and permanently logged.

3.6 PRIMARY SYSTEM BOUNDARYB. Coolant Chemistry

1. Prior to startup and at steaming rates less than 100,000 lb/hr, the following limits shall apply.
 - a. Conductivity, $\mu\text{mho/cm@25}^\circ\text{C}$ 2.0
 - b. Chloride, ppm 0.1

2. At steaming rates greater than 100,000 lb/hr, the following limits shall apply.
 - a. Conductivity, $\mu\text{mho/cm@25}^\circ\text{C}$ 1.0
 - b. Chloride, ppm 0.2

4.6 PRIMARY SYSTEM BOUNDARYB. Coolant Chemistry

1. Reactor coolant shall be continuously monitored for conductivity.
 - a. Whenever the continuous conductivity monitor is inoperable and the condensate demineralizers are bypassed, a sample of reactor coolant shall be analyzed for conductivity every 4 hours. If the condensate demineralizers are in service, a sample of reactor coolant shall be analyzed for conductivity every 8 hours.
 - b. Once a week the continuous monitor shall be checked with an in-line flow cell. This in-line conductivity calibration shall be performed every 24 hours whenever the reactor coolant conductivity is $>1.0 \mu\text{mho/cm}$ at 25°C .

2. During startup prior to pressurizing the reactor above atmospheric pressure, measurements of reactor water quality shall be performed to show conformance with 3.6.B.1. of limiting conditions.

3.6/4.6 BASES

3.6.A/4.6.A

The vessel pressurization temperatures at any time period can be determined from the thermal power output of the plant and its relation to the neutron fluence and from figure 3.6-2. For heatup or cooldown and core operation, see curves #2 & #3 on figure 3.6-1. During the first fuel cycle, only calculated neutron fluence values can be used. At the first refueling, neutron dosimeter wires which are installed adjacent to the vessel wall can be removed to verify the calculated neutron fluence. As more experience is gained in calculating the fluence the need to verify it experimentally will disappear. Because of the many experimental points used to derive figure 3.6-2, there is no need to reverify if for technical reasons, but in case verification is required for other reasons, three sets of mechanical test specimens representing the base metal, weld metal and weld heat affected zone metal have been placed in the vessel. These can be removed and tested as required.

As described in paragraph 4.2.5 of the safety analysis report, detailed stress analyses have been made on the reactor vessel for both steady-state and transient conditions with respect to material fatigue. The results of these analyses are compared to allowable stress limits. Requiring the coolant temperature in an idle recirculation loop to be within 50°F of the operating loop temperature before a recirculation pump is started assures that the changes in coolant temperature at the reactor vessel nozzles and bottom head region are acceptable.

The coolant in the bottom of the vessel is at a lower temperature than that in the upper regions of the vessel when there is no recirculation flow. This colder water is forced up when recirculation pumps are started. This will not result in stresses which exceed ASME Boiler and Pressure Vessel Code, Section III limits when the temperature differential is not greater than 145°F.

The requirements for full tension boltup of the reactor vessel closure are based on the NDT temperature plus 60°F. This is derived from the requirements of the ASME code to which the vessel was built. The NDT temperature of the closure flanges, adjacent head, and shell material is a maximum of 40°F and a maximum of 10°F for the stud material. Therefore, the minimum temperature for full tension boltup is 40°F plus 60°F for a total of 100°F. The partial boltup is restricted to the full loading of eight studs at 70°F, which is stud NDT temperature (10°F) plus 60°F. The neutron radiation fluence at the closure flanges is well below 10^{17} nvt \geq 1 Mev; therefore, radiation effects will be minor and will not influence this temperature.

3.6.B/4.6.B Coolant Chemistry

Materials in the primary system are primarily 304 stainless steel and the Zircaloy cladding. The reactor water chemistry limits are established to prevent damage to these materials. Limits are placed on conductivity and chloride concentrations. Conductivity is limited because it is continuously measured and gives an indication of abnormal conditions and the presence of unusual materials in the coolant. Chloride limits are specified to prevent stress corrosion cracking of stainless steel.

3.6.B/4.6.B Coolant Chemistry

Zircaloy does not exhibit similar stress corrosion failures. However there are some operating conditions under which the dissolved oxygen content of the reactor coolant water could be higher than .2-.3 ppm, such as reactor startup and hot standby. During these periods, the most restrictive limits for conductivity and chlorides have been established. When steaming rates exceed 100,000 lb/hr, boiling deaerates the reactor water. This reduces dissolved oxygen concentration and assures minimal chloride-oxygen content, which together tend to induce stress corrosion cracking.

When conductivity is in its normal range, pH and chloride and other impurities affecting conductivity must also be within their normal range. When conductivity becomes abnormal, then chloride measurements are made to determine whether or not they are also out of their normal operating values. This would not necessarily be the case. Conductivity could be high due to the presence of a neutral salt which would not have an effect on pH or chloride. In such a case, high conductivity alone is not a cause for shutdown. In some types of water-cooled reactors, conductivities are in fact high due to purposeful addition of additives. In the case of BWR's, however, where no additives are used and where near neutral pH is maintained, conductivity provides a very good measure of the quality of the reactor water. Significant changes therein provide the operator with a warning mechanism so he can investigate and remedy the condition causing the change before limiting conditions, with respect to variables affecting the boundaries of the reactor coolant, are exceeded. Methods available to the operator for correcting the off-standard condition include operation of the reactor cleanup system, reducing the input of impurities and placing the reactor in the cold shutdown condition. The major benefit of cold shutdown is to reduce the temperature dependent corrosion rates and provide time for the cleanup system to reestablish the purity of the reactor coolant.

The conductivity of the reactor coolant is continuously monitored. The samples of the coolant which are taken every 96 hours will serve as a reference for calibration of these monitors and is considered adequate to assure accurate readings of the monitors. If conductivity is within its normal range, chlorides and other impurities will also be within their normal ranges. The reactor coolant samples will also be used to determine the chlorides. Therefore, the sampling frequency is considered adequate to detect long-term changes in the chloride ion content. Daily sampling is performed when increased chloride concentrations are most probable. Reactor coolant sampling is increased to once per shift when the continuous conductivity monitor is unavailable.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-296

BROWNS FERRY NUCLEAR PLANT, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 27
License No. DPR-68

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated August 6, 1979, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility License No. DPR-68 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 27, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Thomas A. Ippolito, Chief
Operating Reactors Branch #3
Division of Operating Reactors

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 14, 1979

ATTACHMENT TO LICENSE AMENDMENT NO. 27

FACILITY OPERATING LICENSE NO. DPR-68

DOCKET NO. 50-296

Revise Appendix A as follows:

1. Remove the following pages and replace with the identically numbered pages:

186
221

2. The marginal line on each page indicates the area being revised.

3.6 PRIMARY SYSTEM BOUNDARY

4. The reactor vessel shell temperatures during inservice hydrostatic or leak testing shall be at or above the temperatures shown on curve Number 1 of figure 3.6-1:
5. The reactor vessel head bolting studs may be partially tensioned (four sequences of the seating pass) provided the studs and flange materials are above 70°F. Before loading the flanges any more, the vessel flange and head flange must be greater than 100°F, and must remain above 100°F while under full tension.
6. The pump in an idle recirculation loop shall not be started unless the temperatures of the coolant within the idle and operating recirculation loops are within 50°F of each other.
7. The reactor recirculation pumps shall not be started unless the coolant temperatures between the dome and bottom head drain are within 145°F.

4.6 PRIMARY SYSTEM BOUNDARY

4. Neutron flux wires shall be installed in the reactor vessel adjacent to the reactor vessel wall at the core midplane level. The wires shall be removed and tested during the first refueling outage to experimentally verify the calculated values of integrated neutron fluence of one-fourth of the belt line shell thickness that are used to determine the NDTT shift from Figure 3.6-2.
5. When the reactor vessel head bolting studs are tensioned and the reactor is in a Cold Condition, the reactor vessel shell temperature immediately below the head flange shall be permanently recorded.
6. Prior to and during startup of an idle recirculation loop, the temperature of the reactor coolant in the operating and idle loops shall be permanently logged.
7. Prior to starting a recirculation pump, the reactor coolant temperatures in the dome and in the bottom head drain shall be compared and permanently logged.

3.6/4.6 BASES

thermal power output if no great changes in core geometry are made.

The vessel pressurization temperatures at any time period can be determined from the thermal power output of the plant and its relation to the neutron fluence and from figure 3.6-2. For heatup or cooldown and core operation, see curves #2 & #3 on figure 3.6-1. During the first fuel cycle, only calculated neutron fluence values can be used. At the first refueling, neutron dosimeter wires which are installed adjacent to the vessel wall can be removed to verify the calculated neutron fluence. As more experience is gained in calculating the fluence the need to verify it experimentally will disappear. Because of the many experimental points used to derive figure 3.6-2, there is no need to reverify if for technical reasons, but in case verification is required for other reasons, three sets of mechanical test specimens representing the base metal, weld metal and weld heat affected zone metal have been placed in the vessel. These can be removed and tested as required.

As described in paragraph 4.2.5 of the safety analysis report, detailed stress analyses have been made on the reactor vessel for both steady-state and transient conditions with respect to material fatigue. The results of these analyses are compared to allowable stress limits. Requiring the coolant temperature in an idle recirculation loop to be within 50°F of the operating loop temperature before a recirculation pump is started assures that the changes in coolant temperature at the reactor vessel nozzles and bottom head region are acceptable.

The coolant in the bottom of the vessel is at a lower temperature than that in the upper regions of the vessel when there is no recirculation flow. This colder water is forced up when recirculation pumps are started. This will not result in stresses which exceed ASME Boiler and Pressure Vessel Code, Section III limits when the temperature differential is not greater than 145°F.

The requirements for full tension boltup of the reactor vessel closure are based on the NDT temperature plus 60°F. This is derived from the requirements of the ASME code to which the vessel was built. The NDT temperature of the closure flanges, adjacent head, and shell material is a maximum of 40°F and a maximum of 10°F for the stud material. Therefore, the minimum temperature for full tension boltup is 40°F plus 60°F for a total of 100°F. The partial boltup is restricted to the full loading of eight studs at 70°F, which is stud NDT temperature (10°F) plus 60°F. The neutron radiation fluence at the closure flanges is well below 10^{17} nvt \geq 1 Mev; therefore, radiation effects will be minor and will not influence this temperature.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
SUPPORTING AMENDMENT NO. 55 TO FACILITY OPERATING LICENSE NO. DPR-33
AMENDMENT NO. 50 TO FACILITY OPERATING LICENSE NO. DPR-52
AMENDMENT NO. 27 TO FACILITY OPERATING LICENSE NO. DPR-68

TENNESSEE VALLEY AUTHORITY

BROWNS FERRY NUCLEAR PLANT, UNIT NOS. 1, 2 AND 3

DOCKET NOS. 50-259, 50-260 AND 50-296

1.0 Introduction

By letter dated August 6, 1979, the Tennessee Valley Authority (the licensee or TVA) requested changes to the Technical Specifications (Appendix A) appended to Facility Operating Licenses Nos. DPR-33, DPR-52 and DPR-68 for the Browns Ferry Nuclear Plant, Units Nos. 1, 2 and 3. The proposed amendments and revised Technical Specifications would allow partial tensioning of the reactor vessel head bolts at 70°F rather than the 100°F required by the present Technical Specifications. There would be no change in the requirement that the temperature of the pressure vessel head flange be at least 100°F for full tension boltup.

2.0 Discussion

10 CFR Part 50, Appendix G "Fracture Toughness Requirements", requires that pressure-temperature limits be established for reactor coolant system heatup and cooldown operations, inservice leak and hydrostatic tests, and reactor core operation. These limits are required to ensure that the stresses in the reactor vessel remain within acceptable limits. They are intended to provide adequate margins of safety during any condition of normal operation, including anticipated operational occurrences.

The pressure-temperature limits depend upon the metallurgical properties of the reactor vessel materials. The properties of materials in the vessel belt-line region vary over the lifetime of the vessel because of the effects of neutron irradiation. One principle effect of the neutron irradiation is that

it causes the vessel material nil-ductility temperature (RTNDT) to increase with time. The pressure-temperature operating limits must be modified periodically to account for this radiation induced increase in RTNDT by increasing the temperature required for a given pressure. The operating limits for a particular operating period are based on the material properties at the end of the operating period. By periodically revising the pressure-temperature limits to account for radiation damage, the stresses and stress intensities in the reactor vessel are maintained within acceptable limits.

10 CFR Part 50, Appendix G also requires that for nozzles, flanges and shell regions near discontinuities, operating limits provide the same margin of safety as specified in ASME Code, Section III, Appendix G.

ASME Code Appendix G (1977 Edition) states that when the flange and adjacent shell region are stressed by the full intended bolt preload and by pressure not exceeding 20% of the preoperational system hydrostatic test pressure, minimum metal temperature in the stressed region should be at least the initial RTNDT temperature for the material in the stressed regions plus any effects of irradiation at the stressed regions.

3.0 Evaluation

Tennessee Valley Authority proposed that the reactor vessel head bolting studs may be partially tensioned (four sequences of the seating pass) provided the studs and flange materials are above 79°F. Before loading the flanges any more, the vessel flange and head flange must be greater than 100°F, and must remain above 100°F while under full tension. The present Technical Specification requires that studs shall not be under tension unless the temperature of the vessel head flange is greater than 100°F.

The General Electric Company (GE) has determined that the closure flanges may be preloaded by partial bolt tensioning (either eight bolts under full tension or a greater number of bolts under partial tension to give equivalent loading) in order to seat and seal the O-rings at a temperature of 70°F. Because of the sequence of the boltup procedure, the head seating passes will result in loading the bolts and flanges to meet the above restriction.

We have reviewed the proposed change to the operating limits and have performed independent calculations to verify conformance with Appendix G, 10 CFR Part 50. The maximum RTNDT of materials in the reactor vessels of Units 2 and 3 is 40°F. In the Unit 1 vessel the shell to flange weld may be an atypical (off-chemistry) weld metal. The atypical material has an RTNDT of 90°F. The radiation levels in the flange region of the reactor vessels are very low, so no increase in the RTNDT values is anticipated throughout service life. Therefore, we conclude that the proposed boltup limits for Browns Ferry 2 and 3 are acceptable. For Unit 1 partial tensioning will produce maximum stresses in the flange of about 1400 psi, which is less than 10% of the stress at final tensioning. Since the stresses at partial boltup are very low, the proposed boltup limit for Browns Ferry 1 is acceptable.

No changes were proposed for the operating limits during heatup and cooldown, leak testing and for core critical operation. However, these specifications were reviewed and found to be in conformance with Appendix G, 10 CFR Part 50.

4.0 Environmental Consideration

We have determined that these amendments do not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that these amendments involve an action which is insignificant from the standpoint of environmental impact, and pursuant to 10 CFR Section 51.5(d)(4) that an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of these amendments.

5.0 Conclusion

We have concluded that: (1) because the amendments do not involve a significant increase in the probability or consequences of accidents previously considered and do not involve a significant decrease in a safety margin, the amendments do not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Dated: November 14, 1979

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NOS. 50-259, 50-260 AND 50-296TENNESSEE VALLEY AUTHORITYNOTICE OF ISSUANCE OF AMENDMENTS TO FACILITY
OPERATING LICENSES

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 55 to Facility Operating License No. DPR-33, Amendment No. 50 to Facility Operating License No. DPR-52 and Amendment No. 27 to Facility Operating License No. DPR-68 issued to Tennessee Valley Authority (the licensee), for operation of the Browns Ferry Nuclear Plant, Units Nos. 1, 2 and 3, located in Limestone County, Alabama. The amendments are effective as of the date of issuance.

The amendments change the Technical Specifications to allow partial tensioning of the reactor vessel head bolts at 70°F rather than at 100°F as formerly required.

The application for the amendments complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendments. Prior public notice of these amendments was not required since the amendments do not involve a significant hazards consideration.

The Commission has determined that the issuance of these amendments will not result in any significant environmental impact and that pursuant to 10 CFR Section 51.5(d)(4) an environmental impact appraisal need not be prepared in connection with issuance of these amendments.

- 2 -

For further details with respect to this action, see (1) the application for amendments dated August 6, 1979, (2) Amendment No. 55 to License No. DPR-33, Amendment No. 50 to License No. DPR-52, and Amendment No. 27 to License No. DPR-68, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C., and at the Athens Public Library, South and Forrest, Athens, Alabama 35611. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this 14 day of November 1979.

FOR THE NUCLEAR REGULATORY COMMISSION



Thomas A. Ippolito, Chief
Operating Reactors Branch #3
Division of Operating Reactors