

SAFETY EVALUATION PROCESS

- IP-2 TECH SPECS REQUIRED NRC APPROVAL TO RESTART
- INFORMATION REVIEWED BY NRC STAFF DEALT WITH
 - 2000 INSPECTION PROCESS
 - CONDITION MONITORING ASSESSMENT (WERE TUBE INTEGRITY CRITERIA MET, EXCEPT FOR R2C5)
 - OPERATIONAL ASSESSMENT (WOULD TUBE INTEGRITY CRITERIA BE SATISFIED UNTIL THE NEXT INSPECTION)
- SINCE CON ED REPLACING SGs, TS CONDITION REQUIRING RESTART APPROVAL NO LONGER APPLIES
- SE ESSENTIALLY COMPLETE BUT WILL NOT BE ISSUED

7/19/03

INSTEAD, STAFF WILL DEVELOP RIS DISCUSSING MAJOR FINDINGS FROM THE IP-2 SE AND FINDINGS FROM RECENT ANO-2 EXPERIENCE