

September 19, 1984

Docket Nos. 50-259/260/296

Mr. Hugh G. Parris
Manager of Power
Tennessee Valley Authority
500A Chestnut Street, Tower II
Chattanooga, Tennessee 37401

Dear Mr. Parris:

On August 13, 1984, we issued Amendment Nos. 108, 102 and 75 to Facility Operating License Nos. DPR-33, DPR-52 and DPR-68 in response to your application of April 9, 1984 (TVA BFNP TS 197). As you noted in your September 6, 1984 letter from L. M. Mills to H. R. Denton, those amendments contained errors. Please replace the erroneous pages with the enclosed corrected pages.

Sincerely,



Richard J. Clark, Project Manager
Operating Reactors Branch #2
Division of Licensing

Enclosures:
As stated


cc w/enclosures:
See next page

DISTRIBUTION


Docket File
NRC PDR
Local PDR
ORB#2 Reading
DEisenhut
OELD
SNorris
WLong
RClark
Gray File

LJHarmon
ELJordan
JNGrace
TBarnhart (12)
WJones
DBrinkman
ACRS (10)
OPA, CMiles
RDiggs
Extra - 5

DL:ORB#2
SNorris:ajs
09/19/84


DL:ORB#2
WLong
09/19/84

DL:ORB#2
RClark
09/19/84


DL:ORB#2
DVassallo
09/19/84

8410110015 840919
PDR ADOCK 05000259
PDR
P

Mr. Hugh G. Parris
Tennessee Valley Authority
Browns Ferry Nuclear Plant, Units 1, 2 and 3

cc:

H. S. Sanger, Jr., Esquire
General Counsel
Tennessee Valley Authority
400 Commerce Avenue
E 11B 330
Knoxville, Tennessee 37902

Mr. Ron Rogers
Tennessee Valley Authority
400 Chestnut Street, Tower II
Chattanooga, Tennessee 37401

Mr. Charles R. Christopher
Chairman, Limestone County Commission
Post Office Box 188
Athens, Alabama 35611

Ira L. Meyers, M.D.
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36130

Mr. H. N. Culver
249A HBD
400 Commerce Avenue
Tennessee Valley Authority
Knoxville, Tennessee 37902

James P. O'Reilly
Regional Administrator
Region II Office
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

U. S. Environmental Protection
Agency
Region IV Office
Regional Radiation Representative
345 Courtland Street, N. W.
Atlanta, Georgia 30308

Resident Inspector
U. S. Nuclear Regulatory Commission
Route 2, Box 311
Athens, Alabama 35611

Mr. Donald L. Williams, Jr.
Tennessee Valley Authority
400 West Summit Hill Drive, W10B85
Knoxville, Tennessee 37902

George Jones, Manager, BFNP
Tennessee Valley Authority
Post Office Box 2000
Decatur, Alabama 35602

Mr. Oliver Havens
U. S. Nuclear Regulatory Commission
Reactor Training Center
Osborne Office Center, Suite 200
Chattanooga, Tennessee 37411

James A. Coffey
Site Director, BFNP
Tennessee Valley Authority
Post Office Box 2000
Decatur, Alabama 35602

CORRECTION TO LICENSE AMENDMENT NO. 108

FACILITY OPERATING LICENSE NO. DPR-33

DOCKET NO. 50-259

Remove the following page and replace with an identically numbered page.

255

B410110016 B40919
PDR ADDCK 05000259
P PDR

Group 7: The valves in Group 7 are automatically actuated by only the following condition:

1. The respective turbine steam supply valve not fully closed.

Group 8: The valves in Group 8 are automatically actuated by only the following condition:

1. High Drywell pressure
2. Reactor vessel low water level (538")

CORRECTION TO LICENSE AMENDMENT NO. 102

FACILITY OPERATING LICENSE NO. DPR-52

DOCKET NO. 50-260

Remove the following page and replace with an identically numbered page.

255

Group 7: The valves in Group 7 are automatically actuated by only the following condition:

1. The respective turbine steam supply valve not fully closed.

Group 8: The valves in Group 8 are automatically actuated by only the following condition:

1. High Drywell pressure
2. Reactor vessel low water level (538")

CORRECTION TO LICENSE AMENDMENT NO. 75

FACILITY OPERATING LICENSE NO. DPR-68

DOCKET NO. 50-296

Remove the following page and replace with an identically numbered page.

267

only the following condition:

1. The respective turbine steam supply valve not fully closed.

Group 8: The valves in Group 8 are automatically actuated by only the following condition:

1. High Drywell Pressure
2. Reactor vessel low water level (538")