

DATE: 12/20/01
TIME: 12:52:12

AMEREN/UE
DOCUMENT CONTROL SYSTEM
DOCUMENT TRANSMITTAL

PAGE: 62
ARDC8801

TRANSMITTAL NUMBER: 479495
TO CONTROL NUMBER: 338U
TITLE: OTHER
DEPT: NUCLEAR REGULATORY COMM.
LOCATION: USNRC - WASH DC
TRANSMITTAL DATE: 20011220

RETURN ACKNOWLEDGED TRANSMITTAL AND
SUPERSEDED DOCUMENTS (IF APPLICABLE) TO:
ADMINISTRATION RECORDS
AMEREN/UE
CALLAWAY PLANT
P.O. BOX 620
FULTON, MO 65251

TRAN	DOC				RET		ALT	ALT		
CODE	TYPE	DOCUMENT	NUMBER	REV	REV	MED	COPY	MED	COPY	AFFECTED DOCUMENT
A	PROC	01-0508		029		C	1			EIP-ZZ-00101

ACKNOWLEDGED BY:


DATE:

A045

TEMPORARY CHANGE NOTICE REQUEST FORM
(Instructions for Completion Following)

A190.0001/A190.0035

TCN NO. 01-0508



Check the appropriate box below:

- New TCN
- New One-time TCN
- New Superseding TCN
- Extending an existing one-time TCN (use original TCN No.)
- Deleted TCN (use original TCN No.)
- Rejected TCN (use original TCN No.)

Dates: Effective from

TCN No. to be superseded

1. PROCEDURE NUMBER EIP-ZZ-00101 REVISION NO. 029
PROCEDURE TITLE Classification of Emergencies

1.1 Mark one: REFERENCE USE PROCEDURE

1.2 Is this the seventh (7th) TCN against this revision?

YES NO

(If "Yes", generate a CARS action notice to notify the responsible department that a procedure revision is necessary.)

CARS No.

NOTE: If this is the eighth [8th] TCN, the procedure requires formal revision

- *****
- * CONTINUOUS USE PROCEDURE *
- * This procedure must be performed *
- * exactly as written with each step *
- * being read by the user prior to the *
- * performance of that step. *
- * *****

1.3 YES NO Is someone else the owner of this procedure? TCN 01-0380

2. CHANGE SUMMARY

2.1 PAGE NUMBERS AFFECTED BY CHANGE Attachement 2 page 20

2.2 CHANGE SUMMARY:

Add information to the basis for EAL 3.A that specifies that a security threat should be specifically directed at the Callaway Plant for the threat to meet the definition of credible and therefore, an Unusual Event declared. (This is being done to preclude an Unusual Event being declared as a result of an NRC or other federal agency advisory that identifies generic threats and does not identify a specific threat to the Callaway Plant.)

3. THIS TEMPORARY CHANGE REPRESENTS:

3.1.a YES NO A change to a plant procedure that contains information described in the FSAR (as updated) such as how structures, systems, and components are operated and controlled (including assumed operator actions and response times)

• If 3.1.a is checked "Yes", perform a 50.59 Screen (CA2511 from APA-ZZ-00143). Check the "No" box in 3.1.b if the 50.59 Screen (CA2511) shows a 50.59 Evaluation (CA2512) is not required. The completed 2511 is attached.


• If 3.1.a is checked "No", select one of the below bases to substantiate the determination:

Basis 1: The procedure is listed on attachment 5.

Basis 2: An Applicability Determination (CA2510 from APA-ZZ-00143) has been completed and the determination verifies that a 50.59 Screen (CA2511) IS NOT required. The completed CA2510 is attached.

Basis 3: Other (annotate basis in Change Summary, section 2.2 above)

3.1.b NO A change to plant procedures that requires 50.59 Evaluation. A TCN is only allowed if 3.1.b is checked "No".



TEMPORARY CHANGE NOTICE REQUEST FORM

A190.0001/A190.0035

(Instructions for Completion Following)

PROCEDURE NUMBER EIP-ZZ-00101 TCN NO. 01-0508 REVISION NO. 029

3.2 NO **A change to FSAR commitments?**
 A TCN is only allowed if 3.2 is checked "No".
Select one of the below bases to substantiate the "NO" determination:
 Basis 1: FSAR commitments are **not** being modified by the revision of the procedure.
 Basis 2: Other (annotate basis in Change Summary, Section 2.2 above)

- 3.3 NO A change to the Technical Specifications?
- 3.4 NO A change affecting the environment or the NPDES Permit?
- 3.5 YES NO A change to the Offsite Dose Calculation Manual (ODCM) or Process Control Program (PCP)?
- 3.6 YES NO A change which affects the RERP?
- 3.7 YES NO A change which affects the Security Plan?
- 3.8 YES NO A change requiring a new/revision to a Surveillance Task Sheet or EQ PM Task Sheet?
- 3.9 YES NO A change requiring revision to the Acceptance Criteria Instrumentation (ACI) Program?
- 3.10 YES NO A new or change to a computerized Checkoff List?
- 3.11 NO A change to the Technical Specifications or Bases? (A "Yes" answer is a change of intent.)
- 3.12 YES NO A change to hidden text commitments? (Review a hidden text copy of the procedure to ensure you are aware of the impact the change may have on commitments.)
- 3.13 YES NO A change to a Callaway form? (Yes requires completion of a "Request for Forms" (CA0500) in accordance with APA-ZZ-00203.)

Two of the members of plant staff whom who (TCN 01-0380) Prepare, Review, or provide Preliminary Approval of a TCN should be knowledgeable in the area affected by the TCN.

4. WRITTEN BY	<u>Martin Kaulh</u> Signature	Asst. Supt. Security	12/19/01
		Title	Date
5. PREPARED BY	<u>Martin Kaulh</u> Signature	Asst. Supt. Security	12/19/01
		Title	Date
6. QUALIFIED REVIEWER	<u>L.H. Smade</u> Signature	Supt. Protective Services	12-19-01
		Title	Date

For EOP TCNs, the Qualified Reviewer SHOULD be the EOP Coordinator UNLESS that person is the Preparer or Preliminary Approver

The TCN Qualified Reviewer SHALL be different from the Preparer and the Preliminary Approver.

7. PRELIMINARY APPROVAL (Prior to issue CARS 199800102) TCN 01-0380

7.1 SS/OS/SRO	<u>J. Dampf</u> Signature	SS	12/19/01
		Title	Date

TCNs that WILL affect work in progress associated with plant equipment MUST be approved by the on-shift SS/OS before receiving final approval.

The Preliminary Approver SHALL hold a SRO license.

8. FINAL APPROVAL (No greater than 14 days past issue date CARS 199800102)

8.1 APPROVAL AUTHORITY	_____	_____	_____
	Signature	Title	Date

EMERGENCY ACTION LEVEL INDICATORS BASES

Group 3 Hazards Affecting Plant Safety

Initiating Condition

Emergency Classification

- | | | |
|----|--|---------------|
| A. | Confirmed Security Event
Which Indicates a Potential
Degradation in the Level of
Safety of the Plant. | Unusual Event |
|----|--|---------------|

MODES: At All Times

Indicators

Any of the following:

1. Bomb device discovered within the plant Protected Area and outside the following Safe Shutdown Areas:
 - Area 5
 - Containment
 - Aux Feed Pump Rooms
 - Aux Building
 - Diesel Generator Building
 - UHS Cooling Tower
 - ESW Pumphouse
 - Control Building
 - RWST
 - Fuel Building
2. Confirmed report of an attempted entry, sabotage or security threat that cannot be properly compensated for within 10 minutes.

Bases:

The 10 minute criteria to compensate is to allow for normal on site Security actions.

The 10 minute criteria does not apply to a confirmed credible threat from off site authorities, i.e., NRC, FBI, etc. This EAL should be declared immediately.

A Security Threat is any event in which there is a reason to believe that a person or persons has threatened to commit or cause, or attempted to commit or cause any of the following. A confirmed threat is considered credible if notification of the threat has come from the NRC, FBI, or Local Law Enforcement and they consider the threat to be credible or if the threat is deemed credible by the SS/EDO, *AND THE THREAT IS SPECIFICALLY DIRECTED AT THE CAILAWAY PLANT.*

1. A theft or unlawful diversion of nuclear fuel or spent nuclear fuel from the plant site.
2. Significant physical damage to the plant, its equipment, nuclear fuel, spent nuclear fuel or carrier equipment transporting nuclear fuel or spent nuclear fuel.
3. Interruption of the plant's normal operations through the unauthorized use of, or tampering with, the plant's equipment, machinery, components, controls or security system.
4. Any armed attack of the plant's Protected area.
5. Credible bomb or extortion threat.

TCN 01-0508