

October 10, 1984

Docket Nos. 50-259/260/296

Mr. Hugh G. Parris
Manager of Power
Tennessee Valley Authority
500A Chestnut Street, Tower II
Chattanooga, Tennessee 37401

Dear Mr. Parris:

On July 16, 1984, we issued Amendment Nos. 103, 97 and 71 to Facility Operating License Nos. DPR-33, DPR-52 and DPR-68 for the Browns Ferry Nuclear Plant, Units 1, 2 and 3.

On September 25, 1984 your staff brought to our attention the fact that these amendments contained editorial errors. Please replace the erroneous pages with the enclosed corrected pages.

Sincerely,



Richard J. Clark, Project Manager
Operating Reactors Branch #2
Division of Licensing

Enclosures:
As stated

cc w/enclosures:
See next page

DISTRIBUTION

Docket File
NRC PDR
Local PDR
ORB#2 Reading
DEisenhut
OELD
SNorris
WLong
RClark
Gray File

JPartlow
LJHarmon
ELJordan
JNGrace
TBarnhart (12)
WJones
DBrinkman
ACRS (10)
OPA, CMiles
RDiggs
Extra - 5

DL:ORB#2
SNorris:ajs
10/10/84

W Long
DL:ORB#2
WLong
10/10/84

DL:ORB#2
RClark
10/10/84

Mr
DL:ORB#2
DVassallo
10/10/84

8411010125 841010
PDR ADDCK 05000259
PDR

Mr. Hugh G. Parris
Tennessee Valley Authority
Browns Ferry Nuclear Plant, Units 1, 2 and 3

cc:

H. S. Sanger, Jr., Esquire
General Counsel
Tennessee Valley Authority
400 Commerce Avenue
E 11B 330
Knoxville, Tennessee 37902

Mr. Ron Rogers
Tennessee Valley Authority
400 Chestnut Street, Tower II
Chattanooga, Tennessee 37401

Mr. Charles R. Christopher
Chairman, Limestone County Commission
Post Office Box 188
Athens, Alabama 35611

Ira L. Meyers, M.D.
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36130

Mr. H. N. Culver
249A HBD
400 Commerce Avenue
Tennessee Valley Authority
Knoxville, Tennessee 37902

James P. O'Reilly
Regional Administrator
Region II Office
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

U. S. Environmental Protection
Agency
Region IV Office
Regional Radiation Representative
345 Courtland Street, N. W.
Atlanta, Georgia 30308

Resident Inspector
U. S. Nuclear Regulatory Commission
Route 2, Box 311
Athens, Alabama 35611

Mr. Donald L. Williams, Jr.
Tennessee Valley Authority
400 West Summit Hill Drive, W10B85
Knoxville, Tennessee 37902

George Jones, Manager, BFNP
Tennessee Valley Authority
Post Office Box 2000
Decatur, Alabama 35602

Mr. Oliver Havens
U. S. Nuclear Regulatory Commission
Reactor Training Center
Osbornè Office Center, Suite 200
Chattanooga, Tennessee 37411

James A. Coffey
Site Director, BFNP
Tennessee Valley Authority
Post Office Box 2000
Decatur, Alabama 35602

CORRECTION TO LICENSE AMENDMENT NO. 103

FACILITY OPERATING LICENSE NO. DPR-33

DOCKET NO. 50-259

1. Replace page 334 issued July 16, 1984 with attached page. (The page issued July 16, 1984 did not incorporate changes made in Amendment No. 99.)

6.0 ADMINISTRATIVE CONTROLS

- g. All reportable events.
- h. All recognized indications of an unanticipated deficiency in some aspect of design or operation of structures, systems, or components that could affect nuclear safety.
- i. Reports and meeting minutes of the PORC.

6. AUDITS

Audits of unit activities shall be performed under the cognizance of the NSRB. These audits shall encompass.

- a. The conformance of unit operation to provisions contained within the Technical Specifications and applicable license conditions at least once per 12 months.
- b. The performance, training and qualifications of the entire unit staff at least once per 12 months.
- c. The results of actions taken to correct deficiencies occurring in unit equipment, structures, systems or method of operation that affect nuclear safety at least once per 6 months.
- d. The performance of activities required by the Operational Quality Assurance Program to meet the criteria of Appendix "B", 10 CFR 50, at least once per 24 months.
- e. The Site Radiological Emergency Plan and implementing procedures at least once per 12 months.
- f. The Plant Physical Security Plan and implementing procedures at least once per 12 months.
- g. Any other area of unit operation considered appropriate by the NSRB or the Manager of Power.
- h. The Facility Fire Protection Program and implementing procedures at least once per 24 months.
- i. An independent fire protection and loss prevention program inspection and audit shall be performed annually utilizing either qualified offsite licensee personnel or an outside fire protection firm.
- j. An inspection and audit of the fire protection and loss prevention program shall be performed by an outside qualified fire consultant at intervals no greater than 3 years.

CORRECTION TO LICENSE AMENDMENT NO. 97

FACILITY OPERATING LICENSE NO. DPR-52

DOCKET NO. 50-260

1. Replace page 334 issued July 16, 1984 with attached page. (The page issued July 16, 1984 did not incorporate changes made in Amendment No. 93.)

- g. All reportable events.
- h. All recognized indications of an unanticipated deficiency in some aspect of design or operation of structures, systems, or components that could affect nuclear safety.
- i. Reports and meeting minutes of the PORC.

8. AUDITS

Audits of unit activities shall be performed under the cognizance of the NSRB. These audits shall encompass.

- a. The conformance of unit operation to provisions contained within the Technical Specifications and applicable license conditions at least once per 12 months.
- b. The performance, training and qualifications of the entire unit staff at least once per 12 months.
- c. The results of actions taken to correct deficiencies occurring in unit equipment, structures, systems or method of operation that affect nuclear safety at least once per 6 months.
- d. The performance of activities required by the Operational Quality Assurance Program to meet the criteria of Appendix "I", 10 CFR 50, at least once per 24 months.
- e. The Site Radiological Emergency Plan and implementing procedures at least once per 12 months.
- f. The Plant Physical Security Plan and implementing procedures at least once per 12 months.
- g. Any other area of unit operation considered appropriate by the NSRB or the Manager of Power.
- h. The Facility Fire Protection Program and implementing procedures at least once per 24 months.
- i. An independent fire protection and loss prevention program inspection and audit shall be performed annually utilizing either qualified offsite licensee personnel or an outside fire protection firm.
- j. An inspection and audit of the fire protection and loss prevention program shall be performed by an outside qualified fire consultant at intervals no greater than 3 years.

CORRECTION TO LICENSE AMENDMENT NO. 71

FACILITY OPERATING LICENSE NO. DPR-68

DOCKET NO. 50-296

1. Replace page 364 issued July 16, 1984 with attached page. (The page issued July 16, 1984 did not incorporate changes made in Amendment No. 66.)

- g. All reportable events.
- h. All recognized indications of an unanticipated deficiency in some aspect of design or operation of structures, systems, or components that could affect nuclear safety.
- i. Reports and meeting minutes of the PORC.

8. AUDITS

Audits of unit activities shall be performed under the cognizance of the NSRB. These audits shall encompass.

- a. The conformance of unit operation to provisions contained within the Technical Specifications and applicable license conditions at least once per 12 months.
- b. The performance, training and qualifications of the entire unit staff at least once per 12 months.
- c. The results of actions taken to correct deficiencies occurring in unit equipment, structures, systems or method of operation that affect nuclear safety at least once per 6 months.
- d. The performance of activities required by the Operational Quality Assurance Program to meet the criteria of Appendix "B", 10 CFR 50, at least once per 24 months.
- e. The Site Radiological Emergency Plan and implementing procedures at least once per 12 months.
- f. The Plant Physical Security Plan and implementing procedures at least once per 12 months.
- g. Any other area of unit operation considered appropriate by the NSRB or the Manager of Power.
- h. The Facility Fire Protection Program and implementing procedures at least once per 24 months.
- i. An independent fire protection and loss prevention program inspection and audit shall be performed annually utilizing either qualified offsite licensee personnel or an outside fire protection firm.
- j. An inspection and audit of the fire protection and loss prevention program shall be performed by an outside qualified fire consultant at intervals no greater than 3 years.