

October 10, 1984

Docket No. 50-259

Mr. Hugh G. Parris
Manager of Power
Tennessee Valley Authority
500A Chestnut Street, Tower II
Chattanooga, Tennessee 37401

Dear Mr. Parris:

On September 4, 1984, we issued Amendment No. 111 to Facility Operating License No. DPR-33 in response to your application of November 5, 1982 (TVA BFNTP TS 180). That amendment contained errors. (Existing Table 4.2.A notes were not renumbered to reflect addition of the new note added by the Amendment.) Please replace the erroneous pages with the enclosed corrected pages.

Sincerely,



Richard J. Clark, Project Manager
Operating Reactors Branch #2
Division of Licensing

Enclosures:
As stated

cc w/enclosures:
See next page

DISTRIBUTION

Docket File
NRC PDR
Local PDR
ORB#2 Reading
DEisenhut
OELD
SNorris
WLong
RClark
Gray File

JPartlow
LJHarmon
ELJordan
JNGrace
TBarnhart (12)
WJones
DBrinkman
ACRS (10)
OPA, CMiles
RDiggs
Extra - 5

DL:ORB#2
SNorris:ajs
10/10/84

W. Long
DL:ORB#2
WLong
10/10/84

DL:ORB#2
RClark
10/10/84

DP
DL:ORB#2
DVassallo
10/10/84

Mr. Hugh G. Parris
Tennessee Valley Authority
Browns Ferry Nuclear Plant, Units 1, 2 and 3

cc:

H. S. Sanger, Jr., Esquire
General Counsel
Tennessee Valley Authority
400 Commerce Avenue
E 11B 330
Knoxville, Tennessee 37902

Mr. Ron Rogers
Tennessee Valley Authority
400 Chestnut Street, Tower II
Chattanooga, Tennessee 37401

Mr. Charles R. Christopher
Chairman, Limestone County Commission
Post Office Box 188
Athens, Alabama 35611

Ira L. Meyers, M.D.
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36130

Mr. H. N. Culver
249A HBD
400 Commerce Avenue
Tennessee Valley Authority
Knoxville, Tennessee 37902

James P. O'Reilly
Regional Administrator
Region II Office
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

U. S. Environmental Protection
Agency
Region IV Office
Regional Radiation Representative
345 Courtland Street, N. W.
Atlanta, Georgia 30308

Resident Inspector
U. S. Nuclear Regulatory Commission
Route 2, Box 311
Athens, Alabama 35611

Mr. Donald L. Williams, Jr.
Tennessee Valley Authority
400 West Summit Hill Drive, W10B85
Knoxville, Tennessee 37902

George Jones, Manager, BFNP
Tennessee Valley Authority
Post Office Box 2000
Decatur, Alabama 35602

Mr. Oliver Havens
U. S. Nuclear Regulatory Commission
Reactor Training Center
Osbornè Office Center, Suite 200
Chattanooga, Tennessee 37411

James A. Coffey
Site Director, BFNP
Tennessee Valley Authority
Post Office Box 2000
Decatur, Alabama 35602

CORRECTION TO LICENSE AMENDMENT NO. 111

FACILITY OPERATING LICENSE NO. DPR-33

DOCKET NO. 50-259

1. Replace page 85 (September 4, 1984) with the identically number page attached.
2. Disregard the instruction in the September 4, 1984 letter to replace page 110. Page 110 (Amendment No. 102) remains effective.
3. Include attached page 110a as a part of Amendment No. 111.

TABLE 4.2.A
SURVEILLANCE REQUIREMENTS FOR PRIMARY CONTAINMENT AND REACTOR BUILDING ISOLATION INSTRUMENTATION

Function	Functional Test	Calibration Frequency	Instrument Check
Instrument Channel - Reactor Low Water Level (LIS-1-103A-D, SW 2-1)	(1)	(5)	once/day
Instrument Channel - Reactor High Pressure	(1)	once/3 months	none
Instrument Channel - Reactor Low Water Level (LIS-1-36A-D, SW 1)	(1)	once/3 months	once/day
Instrument Channel - High Drywell Pressure (PS-44-36A-D)	(1)	(5)	N/A
Instrument Channel - High Radiation Main Steam Line Tunnel	once/3 months (29)	(5)	once/day
Instrument Channel - Low Pressure Main Steam Line (PPT-1-72, -76, -82, -86)	once/3 months (27) (29)	Once/operating cycle (28)	none
Instrument Channel - High Flow Main Steam Line (dPPT-1-13A-D, -25A-D, -36A-D, -50A-D)	once/3 months (27) (29)	Once/operating cycle (28)	once/day
Instrument Channel - Main Steam Line Tunnel High Temperature	once/3 months (29)	once/operating cycle	none
Instrument Channel - Reactor Building Ventilation High Radiation - Reactor Zone	(1) (14) (22)	once/3 months	once/day (8)

82
UN

NOTES FOR TABLES 4.2.A THROUGH 4.2.H (Continued)

27. Functional test consists of the injection of a simulated signal into the electronic trip circuitry in place of the sensor signal to verify operability of the trip and alarm functions.
28. Calibration consists of the adjustment of the primary sensor and associated components so that they correspond within acceptable range and accuracy to known values of the parameter which the channel monitors, including adjustment of the electronic trip circuitry, so that its output relay changes state at or more conservatively than the analog equivalent of the trip level setting.
29. The functional test frequency decreased to once/3 months to reduce challenges to relief valves per NUREG-0737, Item II.K.3.16.