



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION II  
SAM NUNN ATLANTA FEDERAL CENTER  
61 FORSYTH STREET SW SUITE 23T85  
ATLANTA, GEORGIA 30303-8931

December 20, 2001

MEMORANDUM TO: Loren R. Plisco, Deputy Regional Administrator

FROM: Brian R. Bonser, Chief */RA/*  
Reactor Projects Branch 4  
Division of Reactor Projects

SUBJECT: REPORT ON TRIP TO BRUNSWICK

DATES OF VISIT: December 6, 2001

PURPOSE OF VISIT: Meet with resident inspectors and meet with licensee management

INSPECTORS OBSERVED: Ted Easlick

SENIOR LICENSEE PERSON CONTACTED: Jack Keenan, Brunswick Vice President

OBSERVATIONS NOTED WITH PLANT: Made a comprehensive tour of the plant with Ted Easlick. Overall the plant looked in good condition. Noted in particular that the maintenance to the manholes on site had been successful. This maintenance is still on-going. Several buildings where there had been standing water on the floor due to leakage through the electrical conduits were now water free. This was due the sealing of the conduits in the manholes. Also reviewed completion of the baseline inspection program with the residents. Also discussed with residents the licensees plans to correct the emergency diesel valve seat insert problem.

OTHER COMMENTS: Met with Jack Keenan. Keenan commented on communications between the licensee and the resident staff remains very good. He had no issues with the NRC.

Docket Nos.: 50-325, 50-324  
License Nos.: DPR-71, DPR-62

cc: Regional Administrator  
Technical Division Directors  
Cognizant Senior Resident Inspector  
Cognizant DRP Branch Chief  
Cognizant NRR Project Manager  
Division Secretary

Distribution: (See page 2)

B. Mallett

2

Distribution:  
Docket Files

PUBLIC DOCUMENT (circle one):    YES    NO

OFFICE	DRP/RII						
SIGNATURE	BBonser:vyg						
NAME	bb						
DATE	12/31/2001						
E-MAIL COPY?							

OFFICIAL RECORD COPY

DOCUMENT NAME: C:\Program Files\Adobe\Acrobat 4.0\PDF Output\Tripbru9.wpd