

MAY 21 1984

Docket Nos. 50-259/260/296

Mr. Hugh G. Parris  
Manager of Power  
Tennessee Valley Authority  
500A Chestnut Street, Tower II  
Chattanooga, Tennessee 37401

Dear Mr. Parris:

On April 25, 1984, we issued Amendment Nos. 97, 91 and 64 to Facility Operating License Nos. DPR-33, DPR-52 and DPR-68 in response to your application of April 7, 1983 (TVA BFNP TS 176, Supplement 4). As you noted, there was a typographical error on page 40 of the Unit 2 Technical Specifications in a part of Table 4.1.B that was not changed by Amendment No. 91. A corrected page 40 is enclosed.

Sincerely,

Original signed by/

Richard J. Clark, Project Manager  
Operating Reactors Branch #2  
Division of Licensing

Enclosure:  
As stated

cc w/enclosure:  
See next page

DISTRIBUTION

Docket File  
NRC PDR  
Local PDR  
ORB#2 Reading  
DEisenhut  
SNorris

RClark  
WLong  
OELD  
LJHarmon  
ELJordan  
TBarnhart (12)

WJones  
DBrinkman  
ACRS (10)  
OPA, CMiles  
RDiggs  
Gray File


Extra - 5

DL:ORB#2  
SNorris:ajs  
05/21/84

DL:ORB#2  
RClark  
05/21/84

DL:ORB#2  
WLong  
05/21/84

DL:ORB#2  
DVassallo  
05/21/84



8406040245 840521  
PDR ADOCK 05000260  
PDR

Mr. Hugh G. Parris  
Tennessee Valley Authority  
Browns Ferry Nuclear Plant, Units 1, 2 and 3

cc:

H. S. Sanger, Jr., Esquire  
General Counsel  
Tennessee Valley Authority  
400 Commerce Avenue  
E 11B 330  
Knoxville, Tennessee 37902

Mr. Ron Rogers  
Tennessee Valley Authority  
400 Chestnut Street, Tower II  
Chattanooga, Tennessee 37401

Mr. Charles R. Christopher  
Chairman, Limestone County Commission  
Post Office Box 188  
Athens, Alabama 35611

Ira L. Myers, M. D.  
State Health Officer  
State Department of Public Health  
State Office Building  
Montgomery, Alabama 36130

Mr. H. N. Culver  
249A HBD  
400 Commerce Avenue  
Tennessee Valley Authority  
Knoxville, Tennessee 37902

James P. O'Reilly  
Regional Administrator  
Region II Office  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

U. S. Environmental Protection  
Agency  
Region IV Office  
Regional Radiation Representative  
345 Courtland Street, N. W.  
Atlanta, Georgia 30308

Resident Inspector  
U. S. Nuclear Regulatory Commission  
Route 2, Box 311  
Athens, Alabama 35611

Mr. Donald L. Williams, Jr.  
Tennessee Valley Authority  
400 West Summit Hill Drive, W10B85  
Knoxville, Tennessee 37902

George Jones  
Tennessee Valley Authority  
Post Office Box 2000  
Decatur, Alabama 35602

Mr. Oliver Havens  
U. S. Nuclear Regulatory Commission  
Reactor Training Center  
Osborne Office Center, Suite 200  
Chattanooga, Tennessee 37411

TABLE 4.1.B  
 REACTOR PROTECTION SYSTEM (SCRAM) INSTRUMENT CALIBRATION  
 MINIMUM CALIBRATION FREQUENCIES FOR REACTOR PROTECTION INSTRUMENT CHANNELS

Instrument Channel	Group (1)	Calibration	Minimum Frequency (2)
IRM High Flux	C	Comparison to APRM on Controlled startups (6)	Note (4)
APRM High Flux Output Signal	B	Heat Balance	Once every 7 days
Flow Bias Signal	B	Calibrate Flow Bias Signal (7)	Once/operating cycle
LPRM Signal	B	TIP System Traverse (8)	Every 1000 Effective Full Power Hours
High Reactor Pressure	A	Standard Pressure Source	Every 3 Months
High Drywell Pressure	A	Standard Pressure Source	Every 3 Months
Reactor Low Water Level	A	Pressure Standard	Every 3 Months
High Water Level in Scram Discharge Volume	A	Note (5)	Note (5)
Float Switches	B	Calibrated Water Column	Once/Operating Cycle
Differential Pressure Switches	B		
Turbine Condenser Low Vacuum	A	Standard Vacuum Source	Every 3 Months
Main Steam Line Isolation Valve Closure	A	Note (5)	Note (5)
Main Steam Line High Radiation	B	Standard Current Source (3)	Every 3 Months
Turbine First Stage Pressure Permissive	A	Standard Pressure Source	Every 6 Months
Turbine Stop Valve Closure	A	Note (5)	Note (5)
Turbine Cont. Valve Fast Closure or Turbine Trip	A	Standard Pressure Source	Once/operating cycle

40