

January 19, 1988

Dockets Nos. 50-259/260/296

Mr. S. A. White
Manager of Nuclear Power
Tennessee Valley Authority
6N 38A Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

Dear Mr. White:

SUBJECT: TECHNICAL SPECIFICATION CHANGE TO CLARIFY TRIP LEVEL SETTINGS IN
TABLE 3.2.A FOR THE STANDBY GAS TREATMENT SYSTEM HEATER (TS 232)
(TAC R00031/R00032/R00033)

Re: Browns Ferry Nuclear Plant, Units 1, 2, and 3

The Commission has issued the enclosed Amendments Nos. 140, 136, and 111 to Facility Operating Licenses Nos. DPR-33, DPR-52 and DPR-68 for the Browns Ferry Nuclear Plant, Units 1, 2 and 3, respectively. These amendments are in response to your application dated May 29, 1987. Minor changes were made to the remark column of Technical Specification Table 3.2.A to provide clarification. These changes were discussed with Mr. M. J. May (TVA) on November 18, 1987, and were found acceptable by TVA.

These amendments clarify the trip level setting for the standby gas treatment system relative humidity heater.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Bi-Weekly Federal Register Notice.

Sincerely,

Original signed by:

Gary G. Zech, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

8801260002 880119
PDR ADOCK 05000259
P PDR

Enclosures:

1. Amendment No. 140 to License No. DPR-33
2. Amendment No. 136 to License No. DPR-52
3. Amendment No. 111 to License No. DPR-68
4. Safety Evaluation

cc w/enclosures:
See next page

OFFICIAL RECORD COPY

OSP:DTVA
CJamerson
12/4/87

OSP:DTVA
G. Gray's
12/11/87

OSP:DTVA
JStang:pw
12/11/87

OSP:AD/TP
BDLiaw
12/15/87

OGC-BETH
1/1/88

TVA:AD/TP
GZech
1/11/88

DISTRIBUTION:

Docket File	BDLiaw	JRutberg
NRC PDR	Wanda Jones	KBarr,RII
Local PDR	OGC-BETH	DHagan
SEbnetter	JPartlow	ACRS (10)
JAxelrad	EJordan	Projects Rdg
SRichardson	TBarnhart (12)	BFN File
GZech	GPA/PA	TVA-Bethesda
GGears	LFMB	
JStang (2)	EButcher	
CJamerson (2)	EMiraglia	
AIgnatonis,RII		



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

January 19, 1988

Dockets Nos. 50-259/260/296

Mr. S. A. White
Manager of Nuclear Power
Tennessee Valley Authority
6N 38A Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

Dear Mr. White:

SUBJECT: TECHNICAL SPECIFICATION CHANGE TO CLARIFY TRIP LEVEL SETTINGS IN
TABLE 3.2.A FOR THE STANDBY GAS TREATMENT SYSTEM HEATER (TS 232)
(TAC R00031/R00032/R00033)

Re: Browns Ferry Nuclear Plant, Units 1, 2, and 3

The Commission has issued the enclosed Amendments Nos. 140, 136, and 111 to Facility Operating Licenses Nos. DPR-33, DPR-52 and DPR-68 for the Browns Ferry Nuclear Plant, Units 1, 2 and 3, respectively. These amendments are in response to your application dated May 29, 1987. Minor changes were made to the remark column of Technical Specification Table 3.2.A to provide clarification. These changes were discussed with Mr. M. J. May (TVA) on November 18, 1987, and were found acceptable by TVA.

These amendments clarify the trip level setting for the standby gas treatment system relative humidity heater.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Bi-Weekly Federal Register Notice.

Sincerely,

Gary G. Zech, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Enclosures:

1. Amendment No. 140 to
License No. DPR-33
2. Amendment No. 136 to
License No. DPR-52
3. Amendment No. 111 to
License No. DPR-68
4. Safety Evaluation

cc w/enclosures:
See next page

Mr. S. A. White
Tennessee Valley Authority

Browns Ferry Nuclear Plant
Units 1, 2, and 3

cc:
General Counsel
Tennessee Valley Authority
400 West Summit Hill Drive
E11 B33
Knoxville, Tennessee 37902

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W.
Atlanta, Georgia 30323

Mr. R. L. Gridley
Tennessee Valley Authority
5N 157B Lookout Place
Chattanooga, Tennessee 37402-2801

Resident Inspector/Browns Ferry NP
U.S. Nuclear Regulatory Commission
Route 12, Box 637
Athens, Alabama 35611

Mr. H. P. Pomrehn
Tennessee Valley Authority
Browns Ferry Nuclear Plant
P.O. Box 2000
Decatur, Alabama 35602

Mr. Richard King
c/o U.S. GAO
1111 North Shore Drive
Suite 225, Box 194
Knoxville, Tennessee 37919

Mr. M. J. May
Tennessee Valley Authority
Browns Ferry Nuclear Plant
P.O. Box 2000
Decatur, Alabama 35602

Dr. Henry Myers, Science Advisor
Committee on Interior
and Insular Affairs
U.S. House of Representatives
Washington, D.C. 20515

Mr. D. L. Williams
Tennessee Valley Authority
400 West Summit Hill Drive
W10 B85
Knoxville, Tennessee 37902

Chairman, Limestone County Commission
P.O. Box 188
Athens, Alabama 35611

Claude Earl Fox, M.D.
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36130



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-259

BROWNS FERRY NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 140
License No. DPR-33

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated May 29, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8801260005 880119
PDR ADCK 05000259
P PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-33 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 140, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Gary G. Zech, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: January 19, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 140

FACILITY OPERATING LICENSE NO. DPR-33

DOCKET NO. 50-259

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Overleaf page* is provided to maintain document completeness.

REMOVE

3.2/4.2-9

3.2/4.2-10

INSERT

3.2/4.2-9

3.2/4.2-10*

TABLE 3.2.A (Continued)
PRIMARY CONTAINMENT AND REACTOR BUILDING ISOLATION INSTRUMENTATION

Minimum No. Instrument Channels Operable per Trip Sys(1)(11)	Function	Trip Level Setting	Action (1)	Remarks
1	Instrument Channel - Reactor Building Ventilation High Radiation - Refueling Zone	≤ 100 mr/hr or downscale	F	1. 1 upscale or 2 downscale will a. Initiate SGTS b. Isolate refueling floor c. Close atmosphere control system.
2(7) (8)	Instrument Channel SGTS Flow - Train A R. H. Heaters	≥ 2000 cfm and ≤ 4000 cfm	H and (A or F)	Below 2000 cfm airflow R.H. heaters shall be shut off.
2(7) (8)	Instrument Channel SGTS Flow - Train B R. H. Heaters	≥ 2000 cfm and ≤ 4000 cfm	H and (A or F)	Below 2000 cfm airflow R.H. heaters shall be shut off.
2(7) (8)	Instrument Channel SGTS Flow - Train C R. H. Heaters	≥ 2000 cfm and ≤ 4000 cfm	H and (A or F)	Below 2000 cfm airflow R.H. heaters shall be shut off.
1	Reactor Building Isolation Timer (refueling floor)	$0 \leq t \leq 2$ secs.	H or F	1. Below trip setting prevents spurious trips and system perturbations from initiating isolation.
1	Reactor Building Isolation Timer (reactor zone)	$0 \leq t \leq 2$ secs.	G or A or H	1. Below trip setting prevents spurious trips and system perturbations from initiating isolation.
2(10)	Group 1 (Initiating) Logic	N/A	A	1. Refer to Table 3.7.A for list of valves.

BFN Unit 1

BFN
Unit 1

3.2/4.2-9

Amendment No. 140

TABLE 3.2.A (Continued)
PRIMARY CONTAINMENT AND REACTOR BUILDING ISOLATION INSTRUMENTATION

Minimum No. Instrument Channels Operable per Trip Sys(1)(11)	Function	Trip Level Setting	Action (1)	Remarks
1	Group 1 (Actuation) Logic	N/A	B	1. Refer to Table 3.7.A for list of valves.
2	Group 2 (Initiating) Logic	N/A	A or (B and E)	1. Refer to Table 3.7.A for list valves.
1	Group 2 (RHR Isolation- Actuation) Logic	N/A	D	
1	Group 8 (TIP-Actuation) Logic	N/A	J	
1	Group 2 (Drywell Sump Drains-Actuation) Logic	N/A	K	
1	Group 2 (Reactor Building & Refueling Floor, and Drywell Vent and Purge- Actuation) Logic	N/A	F and G	1. Part of Group 6 Logic
2	Group 3 (Initiating) Logic	N/A	C	1. Refer to Table 3.7.A. for list of valves.
1	Group 3 (Actuation) Logic	N/A	C	
1	Group 6 Logic	N/A	F and G	1. Refer to Table 3.7.A for list of valves.
1	Group 8 (Initiating) Logic	N/A	J	1. Refer to Table 3.7.A for list of valves. 2. Same as Group 2 initiating logic.

BFN
Unit 1

3.2/4.2-10



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY
DOCKET NO. 50-260
BROWNS FERRY NUCLEAR PLANT, UNIT 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 136
License No. DPR-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated May 29, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-52 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 136, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Gary G. Zech, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Attachment:
Charges to the Technical
Specifications

Date of Issuance: January 19, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 136

FACILITY OPERATING LICENSE NO. DPR-52

DOCKET NO. 50-260

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Overleaf page* is provided to maintain document completeness.

REMOVE

3.2/4.2-9

3.2/4.2-10

INSERT

3.2/4.2-9

3.2/4.2-10*

TABLE 3.2.A (Continued)
PRIMARY CONTAINMENT AND REACTOR BUILDING ISOLATION INSTRUMENTATION

Minimum No. Instrument Channels Operable per Trip Sys(1)(11)	Function	Trip Level Setting	Action (1)	Remarks
1	Instrument Channel - Reactor Building Ventilation High Radiation - Refueling Zone	≤ 100 mr/hr or downscale	F	1. 1 upscale or 2 downscale will a. Initiate SGIS b. Isolate refueling floor. c. Close atmosphere control system.
2(7) (8)	Instrument Channel SGTS Flow - Train A R. H. Heaters	≥ 2000 cfm and ≤ 4000 cfm	H and (A or F)	Below 2000 cfm airflow R.H. heaters shall be shut off.
2(7) (8)	Instrument Channel SGTS Flow - Train B R. H. Heaters	≥ 2000 cfm and ≤ 4000 cfm	H and (A or F)	Below 2000 cfm airflow R.H. heaters shall be shut off.
2(7) (8)	Instrument Channel SGTS Flow - Train C R. H. Heaters	≥ 2000 cfm and ≤ 4000 cfm	H and (A or F)	Below 2000 cfm airflow R.H. heaters shall be shut off.
1	Reactor Building Isolation Timer (refueling floor)	$0 \leq t \leq 2$ secs.	H or F	1. Below trip setting prevents spurious trips and system perturbations from initiating isolation.
1	Reactor Building Isolation Timer (reactor zone)	$0 \leq t \leq 2$ secs.	G or A or H	1. Below trip setting prevents spurious trips and system perturbations from initiating isolation.
2(10)	Group 1 (Initiating) Logic	N/A	A	1. Refer to Table 3.7.A for list of valves.

BFN Unit 2

BFN
Unit 2

3.2/4.2-9

Amendment No. 136

TABLE 3.2.A (Continued)
 PRIMARY CONTAINMENT AND REACTOR BUILDING ISOLATION INSTRUMENTATION

Minimum No. Instrument Channels Operable Per Trip Sys(1)(11)	Function	Trip Level Setting	Action (1)	Remarks
1	Group 1 (Actuation) Logic	N/A	B	1. Refer to Table 3.7.A for list of valves.
2	Group 2 (Initiating) Logic	N/A	A or (B and E)	1. Refer to Table 3.7.A for list valves.
1	Group 2 (RIIR Isolation- Actuation) Logic	N/A	D	
1	Group 8 (Tip-Actuation) Logic	N/A	J	
1	Group 2 (Drywell Sump Drains-Actuation) Logic	N/A	K	
1	Group 2 (Reactor Building & Refueling Floor, and Drywell Vent and Purge- Actuation) Logic	N/A	F and G	1. Part of Group 6 Logic
2	Group 3 (Initiating) Logic	N/A	C	1. Refer to Table 3.7.A. for list of valves.
1	Group 3 (Actuation) Logic	N/A	C	
1	Group 6 Logic	N/A	F and G	1. Refer to Table 3.7.A for list of valves.
1	Group 8 (Initiating) Logic	N/A	J	1. Refer to Table 3.7.A for list of valves. 2. Same as Group 2 initiating logic.

BFN
Unit 2

3.2/4.2-10

BFN-Unit 2



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-296

BROWNS FERRY NUCLEAR PLANT, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 111
License No. DPR-68

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated May 29, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-68 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 111, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Gary G. Zech, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: January 19, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 111

FACILITY OPERATING LICENSE NO. DPR-68

DOCKET NO. 50-296

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Overleaf page* is provided to maintain document completeness.

REMOVE

3.2/4.2-9

3.2/4.2-10

INSERT

3.2/4.2-9

3.2/4.2-10*

TABLE 3.2.A (Continued)
PRIMARY CONTAINMENT AND REACTOR BUILDING ISOLATION INSTRUMENTATION

Minimum No. Instrument Channels Operable per Trip Sys(1)(11)	Function	Trip Level Setting	Action (1)	Remarks
1	Instrument Channel - Reactor Building Ventilation High Radiation - Refueling Zone	≤ 100 mr/hr or downscale	F	1. 1 upscale or 2 downscale will a. Initiate SGTS b. Isolate refueling floor. c. Close atmosphere control system.
2(7) (8)	Instrument Channel SGTS Flow - Train A R. H. Heaters	≥ 2000 cfm and ≤ 4000 cfm	H and (A or F)	Below 2000 cfm airflow R.H. heaters shall be shut off.
2(7) (8)	Instrument Channel SGTS Flow - Train B R. H. Heaters	≥ 2000 cfm and ≤ 4000 cfm	H and (A or F)	Below 2000 cfm airflow R.H. heaters shall be shut off.
2(7) (8)	Instrument Channel SGTS Flow - Train C R. H. Heaters	≥ 2000 cfm and ≤ 4000 cfm	H and (A or F)	Below 2000 cfm airflow R.H. heaters shall be shut off.
1	Reactor Building Isolation Timer (refueling floor)	$0 \leq t \leq 2$ secs.	H or F	1. Below trip setting prevents spurious trips and system perturbations from initiating isolation.
1	Reactor Building Isolation Timer (reactor zone)	$0 \leq t \leq 2$ secs.	G or A or H	1. Below trip setting prevents spurious trips and system perturbations from initiating isolation.
2(10)	Group 1 (Initiating) Logic	N/A	A	1. Refer to Table 3.7.A for list of valves.

BFN Unit 3

BFN
Unit 3

3.2/4.2-9

Amendment No. 111

TABLE 3.2.A (Continued)
 PRIMARY CONTAINMENT AND REACTOR BUILDING ISOLATION INSTRUMENTATION

Minimum No. Instrument Channels Operable per Trip Sys(1)(11)	Function	Trip Level Setting	Action (1)	Remarks
1	Group 1 (Actuation) Logic	N/A	B	1. Refer to Table 3.7.A for list of valves.
2	Group 2 (Initiating) Logic	N/A	A or (B and E)	1. Refer to Table 3.7.A for list of valves.
1	Group 2 (RHR Isolation-Actuation) Logic	N/A	D	
1	Group 8 (TIP-Actuation) Logic	N/A	J	
1	Group 2 (Drywell Sump Drains-Actuation) Logic	N/A	K	
1	Group 2 (Reactor Building & Refueling Floor, and Drywell Vent and Purge-Actuation) Logic	N/A	F and G	1. Part of Group 6 Logic
2	Group 3 (Initiating) Logic	N/A	C	1. Refer to Table 3.7.A. for list of valves.
1	Group 3 (Actuation) Logic	N/A	C	
1	Group 6 Logic	N/A	F and G	1. Refer to Table 3.7.A for list of valves.
1	Group 8 (Initiating) Logic	N/A	J	1. Refer to Table 3.7.A for list of valves. 2. Same as Group 2 initiating logic.

BFN-Unit 3

BFN
Unit 3

3.2/4.2-10



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF SPECIAL PROJECTS

SUPPORTING AMENDMENT NO. 140 TO FACILITY OPERATING LICENSE NO. DPR-33

AMENDMENT NO. 136 TO FACILITY OPERATING LICENSE NO. DPR-52

AMENDMENT NO. 111 TO FACILITY OPERATING LICENSE NO. DPR-68

TENNESSEE VALLEY AUTHORITY

BROWNS FERRY NUCLEAR PLANT, UNITS 1, 2 AND 3

DOCKETS NOS. 50-259, 50-260 AND 50-296

1.0 INTRODUCTION

The proposed amendments would clarify the trip level setting for the standby gas treatment system (SGTS) relative humidity (R.H.) heater. The current requirement of "less than or equal to 2000 cfm" is changed to be "greater than or equal to 2000 cfm and less than or equal to 4000 cfm".

2.0 EVALUATION

In the current Technical Specification (TS) a contradiction exists between the trip level setting column and the remarks column of Table 3.2.A for the instrument that trips the SGTS R.H. heater on low flow. The trip level setting column requires the actual trip point to be below 2000 cfm. Since the purpose of the switch is to protect the system from overheating if air flow is lost, the remarks column is correct and the setpoint column must be changed to be consistent with it.

The intent of the TS requirement in Table 3.2.A for the R.H. heater switch is to turn off the heater before a decreasing SGTS flow reaches 2000 cfm. This would prevent damage to the SGTS filter banks by turning off the R.H. heaters. A literal reading of the current TS wording would allow a setpoint of 0 cfm which does not fulfill the intent of the TS. Therefore, the "less than or equal to" requirement should be changed to "greater than or equal to" in order to meet the intent of the TS and achieve agreement with the design basis.

An upper bound of 4000 cfm is imposed on the setpoint to ensure that the flow switches do not prevent the heaters from performing their function during normal blower operation. TS 3.7.B.2.c requires that each train operate within ± 10 percent of design flow (9000 cfm). Therefore, when the system is initiated, the airflow for an operable train would be greater than 4000 cfm and the heaters would perform their function.

8801260009 880119
PDR ADDCK 05000259
PDR

The proposed change makes the TS more consistent with the design basis and the Final Safety Analysis Report and, therefore, will increase the margin of safety.

In further review of the proposed change to the remarks column of the TS Table 3.2.A, the staff found there was not a specific setpoint where the R.H. Heaters were required to be shut off. The current TS have such a setpoint. In discussion with Mr. M. J. May, (TVA) it was agreed upon that clarifications would be made to the proposed wording in the amendments to specify the setpoint of 2000 cfm as the minimum flow rate where R.H. heaters could still operate. The agreed upon clarifications for the wording in the remarks column read as follows:

"Below 2000 cfm airflow R. H. heaters shall be shut off."

Based on the above evaluation and the clarification to TS, the staff finds the proposed change acceptable.

3.0 ENVIRONMENTAL CONSIDERATION

The amendments involve a change to a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that these amendments involve no significant hazards consideration and there has been no public comment on such finding. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement nor environmental assessment need be prepared in connection with the issuance of these amendments.

4.0 CONCLUSION

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of the amendments will not be inimical to the common defense and security nor to the health and safety of the public.

Principal Contributor: John Stang

Dated: January 19, 1988

January 19, 1988

MEMORANDUM FOR: Sholly Coordinator

FROM: Gary G. Zech, Assistant Director
for Projects, OSP

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE - NOTICE
OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

Tennessee Valley Authority, Dockets Nos. 50-259, 50-260 and 50-296, Browns
Ferry Nuclear Plant, Units 1, 2 and 3, Limestone County, Alabama

Date of application for amendments: May 29, 1987 (TS 232)

Brief description of amendments: The amendments clarify the trip level setting
for the standby gas treatment system relative humidity heater. The previous
requirement of "less than or equal to 2000 cfm" has been changed to "greater
than or equal to 2000 cfm and less than or equal to 4000 cfm."

Date of issuance: January 19, 1988

Effective date: January 19, 1988, and shall be implemented within 60 days

Amendments Nos.: 140, 136, 111

Facility Operating Licenses Nos. DPR-33, DPR-52 and DPR-68: Amendments
revised the Technical Specifications.

Date of initial notice in FEDERAL REGISTER: December 16, 1987 (52 FR 47793)

The Commission's related evaluation of the amendments is contained in a Safety
Evaluation dated January 19, 1988.

No significant hazards consideration comments received: No

Local Public Document Room location: Athens Public Library, South Street,
Athens, Alabama 35611.

8801260012 880119
PDR ADDOCK 05000259
P PDR

Original signed by:

Gary G. Zech, Assistant Director
for Projects, OSP

DISTRIBUTION

Docket File Projects Reading GZech CJamerson
OGC-BETH Sholly Coordinator (orig & 1) GGears/JStang

OFFICIAL RECORD COPY

OSP:DTVA
CJamerson
12/4/87

OSP:DTVA
GGears
1/11/88

OSP:DTVA
JStang:pw
12/11/87

OGC-BETH
1/1/87

TVA:ADP
GZech
1/11/88