

February 12, 1987

Dockets Nos. 50-259/260/296

Mr. S. A. White
Manager of Nuclear Power
Tennessee Valley Authority
6N 38A Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

Dear Mr. White:

SUBJECT: TECHNICAL SPECIFICATION CHANGE TO CLARIFY IODINE TESTING AND ANALYSIS
OF CHARCOAL FILTER SAMPLES (TAC 64709/64710/64711) (TS 227)

Re: Browns Ferry Nuclear Plant, Units 1, 2, and 3

The Commission has issued the enclosed Amendments Nos. 143, 139, and 114 to Facility Operating Licenses Nos. DPR-33, DPR-52 and DPR-68 for the Browns Ferry Nuclear Plant, Units 1, 2 and 3, respectively. These amendments are in response to your application dated February 11, 1987. The amendment revises the limiting condition for operation to require that a later standard be used for iodine testing and analysis of charcoal filter samples.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Bi-Weekly Federal Register Notice.

Sincerely,

Original signed by:

Gary G. Zech, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Enclosures:

1. Amendment No. 143 to License No. DPR-33
2. Amendment No. 139 to License No. DPR-52
3. Amendment No. 114 to License No. DPR-68
4. Safety Evaluation

cc w/enclosures:
See next page

DISTRIBUTION:

Docket File	BDLiaw	JRutberg
NRC PDR	Wanda Jones	KBarr, RII
Local PDR	OGC-BETH	DHagan
SEbnetter	JPartlow	ACRS (10)
JAxelrad	EJordan	Projects Rdg
SRichardson	TBarnhart (12)	BFN File
GZech	GPA/PA	TVA-Bethesda
GGears	LFMB	
JStang (2)	EButcher	
CJamerson (2)	FMiraglia	
Aignatonis, RII		

OFFICIAL RECORD COPY

OSP-TVA/LA
CJamerson
2/13/88

OSP-TVA/PM
GGears
2/13/88

OSP-TVA/PM
JKelly:pw
2/14/88

OGC-BETH
2/18/88

TVA:AD/P
GGZech
2/14/88

8802250243 880212
PDR ADOCK 05000259
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

February 12, 1988

Dockets Nos. 50-259/260/296

Mr. S. A. White
Manager of Nuclear Power
Tennessee Valley Authority
6N 38A Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

Dear Mr. White:

SUBJECT: TECHNICAL SPECIFICATION CHANGE TO CLARIFY IODINE TESTING AND ANALYSIS
OF CHARCOAL FILTER SAMPLES (TAC 64709/64710/64711) (TS 227)

Re: Browns Ferry Nuclear Plant, Units 1, 2, and 3

The Commission has issued the enclosed Amendments Nos. 143, 139, and 114 to Facility Operating Licenses Nos. DPR-33, DPR-52 and DPR-68 for the Browns Ferry Nuclear Plant, Units 1, 2 and 3, respectively. These amendments are in response to your application dated February 11, 1987. The amendment revises the limiting condition for operation to require that a later standard be used for iodine testing and analysis of charcoal filter samples.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Bi-Weekly Federal Register Notice.

Sincerely,

A handwritten signature in cursive script, reading "Gary G. Zech".

Gary G. Zech, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Enclosures:

1. Amendment No. 143 to
License No. DPR-33
2. Amendment No. 139 to
License No. DPR-52
3. Amendment No. 114 to
License No. DPR-68
4. Safety Evaluation

cc w/enclosures:
See next page

Mr. S. A. White
Tennessee Valley Authority

Browns Ferry Nuclear Plant
Units 1, 2, and 3

cc:
General Counsel
Tennessee Valley Authority
400 West Summit Hill Drive
E11 B33
Knoxville, Tennessee 37902

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W.
Atlanta, Georgia 30323

Mr. R. L. Gridley
Tennessee Valley Authority
5N 157B Lookout Place
Chattanooga, Tennessee 37402-2801

Resident Inspector/Browns Ferry NP
U.S. Nuclear Regulatory Commission
Route 12, Box 637
Athens, Alabama 35611

Mr. H. P. Pomrehn
Tennessee Valley Authority
Browns Ferry Nuclear Plant
P.O. Box 2000
Decatur, Alabama 35602

Mr. Richard King
c/o U.S. GAO
1111 North Shore Drive
Suite 225, Box 194
Knoxville, Tennessee 37919

Mr. M. J. May
Tennessee Valley Authority
Browns Ferry Nuclear Plant
P.O. Box 2000
Decatur, Alabama 35602

Dr. Henry Myers, Science Advisor
Committee on Interior
and Insular Affairs
U.S. House of Representatives
Washington, D.C. 20515

Mr. D. L. Williams
Tennessee Valley Authority
400 West Summit Hill Drive
W10 B85
Knoxville, Tennessee 37902

Chairman, Limestone County Commission
P.O. Box 188
Athens, Alabama 35611

Claude Earl Fox, M.D.
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36130



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-259

BROWNS FERRY NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 143
License No. DPR-33

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated February 11, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8802250258 880212
PDR ADDOCK 05000259
P PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-33 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 143, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Gary G. Zech, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 12, 1988

ATTACHMENT TO LICENSE AMENDMENT NO.143

FACILITY OPERATING LICENSE NO. DPR-33

DOCKET NO. 50-259

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Overleaf pages* are provided to maintain document completeness.

REMOVE

3.7/4.7-13
3.7/4.7-14
3.7/4.7-19
3.7/4.7-20*
3.7/4.7-21
3.7/4.7-22*
3.7/4.7-47
3.7/4.7-48
3.7/4.7-51
3.7/4.7-52

INSERT

3.7/4.7-13*
3.7/4.7-14
3.7/4.7-19
3.7/4.7-20*
3.7/4.7-21
3.7/4.7-22*
3.7/4.7-47
3.7/4.7-48
3.7/4.7-51
3.7/4.7-52

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

3.7.B. Standby Gas Treatment System

1. Except as specified in Specification 3.7.B.3 below, all three trains of the standby gas treatment system shall be OPERABLE at all times when secondary containment integrity is required.

SURVEILLANCE REQUIREMENTS

4.7.B. Standby Gas Treatment System

1. At least once per year, the following conditions shall be demonstrated.
 - a. Pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 6 inches of water at a flow of 9000 cfm ($\pm 10\%$).
 - b. The inlet heaters on each circuit are tested in accordance with ANSI N510-1975, and are capable of an output of at least 40 kW.
 - c. Air distribution is uniform within 20% across HEPA filters and charcoal adsorbers.

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

3.7.B. Standby Gas Treatment System

2. a. The results of the in-place cold DOP and halogenated hydrocarbon tests at $\geq 10\%$ design flow on HEPA filters and charcoal adsorber banks shall show $\geq 99\%$ DOP removal and $\geq 99\%$ halogenated hydrocarbon removal when tested in accordance with ANSI N510-1975.
- b. The results of laboratory carbon sample analysis shall show $\geq 90\%$ radioactive methyl iodide removal when tested in accordance with ASTM D3803 (130°C, 95% R.H.).
- c. System shall be shown to operate within $\pm 10\%$ design flow.

SURVEILLANCE REQUIREMENTS

4.7.B. Standby Gas Treatment System

2. a. The tests and sample analysis of Specification 3.7.B.2 shall be performed at least once per operating cycle or once every 18 months whichever occurs first for standby service or after every 720 hours of system operation and following significant painting, fire or chemical release in any ventilation zone communicating with the system.
- b. Cold DOP testing shall be performed after each complete or partial replacement of the HEPA filter bank or after any structural maintenance on the system housing.
- c. Halogenated hydrocarbon testing shall be performed after each complete or partial replacement of the charcoal adsorber bank or after any structural maintenance on the system housing.

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

3.7.E. Control Room Emergency Ventilation

1. Except as specified in Specification 3.7.E.3 below, both control room emergency pressurization systems shall be OPERABLE at all times when any reactor vessel contains irradiated fuel.
2. a. The results of the in-place cold DOP and halogenated hydrocarbon tests at design flows on HEPA filters and charcoal adsorber banks shall show $\geq 99\%$ DOP removal and $\geq 99\%$ halogenated hydrocarbon removal when tested in accordance with ANSI N510-1975.

b. The results of laboratory carbon sample analysis shall show $\geq 90\%$ radioactive methyl iodide removal at a velocity when tested in accordance with ASTM D3803 (130°C, 95% R.H.).

c. System flow rate shall be shown to be within $\pm 10\%$ design flow when tested in accordance with ANSI N510-1975.

SURVEILLANCE REQUIREMENTS

4.7.E Control Room Emergency Ventilation

1. At least once per operating cycle, not to exceed 18 months, the pressure drop across the combined HEPA filters and charcoal adsorber banks shall be demonstrated to be less than 6 inches of water at system design flow rate ($\pm 10\%$).
2. a. The tests and sample analysis of Specification 3.7.E.2 shall be performed at least once per operating cycle or once every 18 months, whichever occurs first for standby service or after every 720 hours of system operation and following significant painting, fire, or chemical release in any ventilation zone communicating with the system.

b. Cold DOP testing shall be performed after each complete or partial replacement of the HEPA filter bank or after any structural maintenance on the system housing.

c. Halogenated hydrocarbon testing shall be performed after each complete or partial replacement of the charcoal adsorber bank or after any structural maintenance on the system housing.

d. Each circuit shall be operated at least 10 hours every month.

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

3.7.E. Control Room Emergency Ventilation

3. From and after the date that one of the control room emergency pressurization systems is made or found to be INOPERABLE for any reason, reactor operation or refueling operations is permissible only during the succeeding 7 days unless such circuit is sooner made OPERABLE.
4. If these conditions cannot be met, reactor shutdown shall be initiated and all reactors shall be in Cold Shutdown within 24 hours for reactor operations and refueling operations shall be terminated within 2 hours.

SURVEILLANCE REQUIREMENTS

4.7.E. Control Room Emergency Ventilation

3. At least once per operating cycle not to exceed 18 months, automatic initiation of the control room emergency pressurization system shall be demonstrated.

4. During the simulated automatic actuation test of this system (see Table 4.2.G), it shall be verified that the following dampers operate as indicated:

Close: FCO-150 B, D, E, and F
Open: FCO-151,
FCO-152

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

3.7.F. Primary Containment Purge System

1. The primary containment shall be normally vented and purged through the primary containment purge system. The standby gas treatment system may be used when primary containment purge system is INOPERABLE.
2. a. The results of the in-place cold DOP and halogenated hydrocarbon tests at design flows on HEPA filters and charcoal adsorber banks shall show $\geq 99\%$ DOP removal and $\geq 99\%$ halogenated hydrocarbon removal when tested in accordance with ANSI N510-1975.
- b. The results of laboratory carbon sample analysis shall show $\geq 85\%$ radioactive methyl iodide removal when tested in accordance with ASTM D3803 (130°C 95% R.H.).
- c. System flow rate shall be shown to be within $\pm 10\%$ of design flow when tested in accordance with ANSI N510-1975.

SURVEILLANCE REQUIREMENTS

4.7.F. Primary Containment Purge System

1. At least once per operating cycle, not to exceed 18 months, the pressure drop across the combined HEPA filters and charcoal adsorber banks shall be demonstrated to be less than 8.5 inches of water at system design flow rate ($\pm 10\%$).
2. a. The tests and sample analysis of Specification 3.7.F.2 shall be performed at least once per operating cycle or once every 18 months, whichever occurs first or after 720 hours of system operation and following significant painting, fire, or chemical release in any ventilation zone communicating with the system.
- b. Cold DOP testing shall be performed after each complete or partial replacement of the HEPA filter bank or after any structural maintenance on the system housing.
- c. Halogenated hydrocarbon testing shall be performed after each complete or partial replacement of the charcoal adsorber bank or after any structural maintenance on the system housing.

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

3.7.G. Containment Atmosphere Dilution System (CAD)

1. The Containment Atmosphere Dilution (CAD) System shall be OPERABLE with:
 - a. Two independent systems capable of supplying nitrogen to the drywell and torus.
 - b. A minimum supply of 2,500 gallons of liquid nitrogen per system.
2. The Containment Atmosphere Dilution (CAD) System shall be OPERABLE whenever the reactor mode switch is in the "RUN" position.
3. If one system is INOPERABLE, the reactor may remain in operation for a period of 30 days provided all active components in the other system are OPERABLE.

SURVEILLANCE REQUIREMENTS

4.7.G. Containment Atmosphere Dilution System (CAD)

1. System Operability
 - a. At least once per month cycle each solenoid operated air/nitrogen valve through at least one complete cycle of full travel and verify that each manual valve in the flow path is open.
 - b. Verify that the CAD System contains a minimum supply of 2,500 gallons of liquid nitrogen twice per week.
2. When FCV 84-8B is INOPERABLE, each solenoid operated air/nitrogen valve of System B shall be cycled through at least one complete cycle of full travel and each manual valve in the flow path of System B shall be verified open at least once per week.

The primary containment leak rate test frequency is based on maintaining adequate assurance that the leak rate remains within the specification. The leak rate test frequency is based on the NRC guide for developing leak rate testing and surveillance of reactor containment vessels. Allowing the test intervals to be extended up to 10 months permits some flexibility needed to have the tests coincide with scheduled or unscheduled shutdown periods.

The penetration and air purge piping leakage test frequency, along with the containment leak rate tests, is adequate to allow detection of leakage trends. Whenever a bolted double-gasketed penetration is broken and remade, the space between the gaskets is pressurized to determine that the seals are performing properly. It is expected that the majority of the leakage from valves, penetrations and seals would be into the reactor building. However, it is possible that leakage into other parts of the facility could occur. Such leakage paths that may affect significantly the consequences of accidents are to be minimized.

The primary containment is normally slightly pressurized during period of reactor operation. Nitrogen used for inerting could leak out of the containment but air could not leak in to increase oxygen concentration. Once the containment is filled with nitrogen to the required concentration, determining the oxygen concentration twice a week serves as an added assurance that the oxygen concentration will not exceed 4 percent.

3.7.B/3.7.C Standby Gas Treatment System and Secondary Containment

The secondary containment is designed to minimize any ground level release of radioactive materials which might result from a serious accident. The reactor building provides secondary containment during reactor operation, when the drywell is sealed and in service; the reactor building provides primary containment when the reactor is shutdown and the drywell is open, as during refueling. Because the secondary containment is an integral part of the complete containment system, secondary containment is required at all times that primary containment is required as well as during refueling.

The standby gas treatment system is designed to filter and exhaust the reactor building atmosphere to the stack during secondary containment isolation conditions. All three standby gas treatment system fans are designed to automatically start upon containment isolation and to maintain the reactor building pressure to the design negative pressure so that all leakage should be in-leakage.

High efficiency particulate air (HEPA) filters are installed before and after the charcoal absorbers to minimize potential release of particulates to the environment and to prevent clogging of the iodine absorbers. The charcoal absorbers are installed to reduce the potential release of radioiodine to the environment. The in-place test results should indicate a system leak tightness of less than 1 percent bypass leakage for the charcoal absorbers and a HEPA efficiency of at least 99 percent removal of DOP particulates. The laboratory carbon sample test results should indicate a radioactive methyl iodide removal efficiency of at least 90 percent for expected accident conditions. If the efficiencies of the HEPA filters and charcoal absorbers are as specified, the resulting doses will be less than the 10 CFR 100 guidelines for the accidents analyzed. Operation of the fans significantly different from the design flow will change the removal efficiency of the HEPA filters and charcoal absorbers.

3.7/4.7 BASES (Cont'd)

Only two of the three standby gas treatment systems are needed to clean up the reactor building atmosphere upon containment isolation. If one system is found to be inoperable, there is no immediate threat to the containment system performance and reactor operation or refueling operation may continue while repairs are being made. If more than one train is inoperable, the plant is brought to a condition where the standby gas treatment system is not required.

4.7.B/4.7.C Standby Gas Treatment System and Secondary Containment

Initiating reactor building isolation and operation of the standby gas treatment system to maintain at least a 1/4 inch of water vacuum within the secondary containment provides an adequate test of the operation of the reactor building isolation valves, leak tightness of the reactor building and performance of the standby gas treatment system. Functionally testing the initiating sensors and associated trip logic demonstrates the capability for automatic actuation. Performing these tests prior to refueling will demonstrate secondary containment capability prior to the time the primary containment is opened for refueling. Periodic testing gives sufficient confidence of reactor building integrity and standby gas treatment system performance capability.

The test frequencies are adequate to detect equipment deterioration prior to significant defects, but the tests are not frequent enough to load the filters, thus reducing their reserve capacity too quickly. That the testing frequency is adequate to detect deterioration was demonstrated by the tests which showed no loss of filter efficiency after two years of operation in the rugged shipboard environment on the US Savannah (ORNL 3726). Pressure drop across the combined HEPA filters and charcoal adsorbers of less than six inches of water at the system design flow rate will indicate that the filters and adsorbers are not clogged by excessive amounts of foreign matter. Heater capability, pressure drop and air distribution should be determined at least once per operating cycle to show system performance capability.

The frequency of tests and sample analysis are necessary to show that the HEPA filters and charcoal adsorbers can perform as evaluated. Tests of the charcoal adsorbers with halogenated hydrocarbon refrigerant shall be performed in accordance with USAEC Report DP-1082. Iodine removal efficiency tests shall follow ASTM D3803. The charcoal adsorber efficiency test procedures should allow for the removal of one adsorber tray, emptying of one bed from the tray, mixing the adsorbent thoroughly and obtaining at least two samples. Each sample should be at least two inches in diameter and a length equal to the thickness of the bed. If test results are unacceptable, all adsorbent in the system shall be replaced with an adsorbent qualified according to Table 1 of Regulatory Guide 1.52. The replacement tray for the adsorber tray removed for the test should meet the same adsorbent quality. Tests of the HEPA filters with DOP aerosol shall be performed in accordance to ANSI N510-1975. Any HEPA filters found defective shall be replaced with filters qualified pursuant to Regulatory Position C.3.d of Regulatory Guide 1.52.

All elements of the heater should be demonstrated to be functional and operable during the test of heater capacity. Operation of each filter train for a minimum of 10 hours each month will prevent moisture buildup in the filters and adsorber system.

3.7/4.7 BASES (Cont)

3.7.E/4.7.E Control Room Emergency Ventilation

The control room emergency ventilation system is designed to filter the control room atmosphere for intake air and/or for recirculation during control room isolation conditions. The control room emergency ventilation system is designed to automatically start upon control room isolation and to maintain the control room pressure to the design positive pressure so that all leakage should be out leakage.

High efficiency particulate absolute (HEPA) filters are installed before the charcoal adsorbers to prevent clogging of the iodine adsorbers. The charcoal adsorbers are installed to reduce the potential intake of radioiodine to the control room. The in-place test results should indicate a system leak tightness of less than 1 percent bypass leakage for the charcoal adsorbers and a HEPA efficiency of at least 99 percent removal of DOP particulates. The laboratory carbon sample test results should indicate a radioactive methyl iodide removal efficiency of at least 90 percent for expected accident conditions. If the efficiencies of the HEPA filters and charcoal adsorbers are as specified, the resulting doses will be less than the allowable levels stated in Criterion 19 of the General Design Criteria for Nuclear Power Plants, Appendix A to 10 CFR Part 50. Operation of the fans significantly different from the design flow will change the removal efficiency of the HEPA filters and charcoal adsorbers.

If the system is found to be inoperable, there is no immediate threat to the control room and reactor operation or refueling operation may continue for a limited period of time while repairs are being made. If the system cannot be repaired within seven days, the reactor is shutdown and brought to Cold Shutdown within 24 hours or refueling operations are terminated.

Pressure drop across the combined HEPA filters and charcoal adsorbers of less than six inches of water at the system design flow rate will indicate that the filters and adsorbers are not clogged by excessive amounts of foreign matter. Pressure drop should be determined at least once per operating cycle to show system performance capability.

The frequency of tests and sample analysis are necessary to show that the HEPA filters and charcoal adsorbers can perform as evaluated. Tests of the charcoal adsorbers with halogenated hydrocarbon shall be performed in accordance with USAEC Report-1082. Iodine removal efficiency tests shall follow ASTM D3803. The charcoal adsorber efficiency test procedures should allow for the removal of one adsorber tray, emptying of one bed from the tray, mixing the adsorbent thoroughly and obtaining at least two samples. Each sample should be at least two inches in diameter and a length equal to the thickness of the bed. If test results are unacceptable, all adsorbent in the system shall be replaced with an adsorbent qualified according to Table 1 of Regulatory Guide 1.52. The replacement tray for the adsorber tray removed for the test should meet the same adsorbent quality. Tests of the HEPA filters with DOP aerosol shall be performed in accordance to ANSI N510-1975. Any HEPA filters found defective shall be replaced with filters qualified pursuant to Regulatory Position C.3.d of Regulatory Guide 1.52.

3.7/4.7 BASES (Con. J)

Operation of the system for 10 hours every month will demonstrate operability of the filters and adsorber system and remove excessive moisture built up on the adsorber.

If significant painting, fire or chemical release occurs such that the HEPA filter or charcoal adsorber could become contaminated from the fumes, chemicals or foreign materials, the same tests and sample analysis shall be performed as required for operational use. The determination of significance shall be made by the operator on duty at the time of the incident. Knowledgeable staff members should be consulted prior to making this determination.

Demonstration of the automatic initiation capability is necessary to assure system performance capability.

3.7.F/4.7.F Primary Containment Purge System

The primary containment purge system is designed to provide air to purge and ventilate the primary containment system. The exhaust from the primary containment is first processed by a filter train assembly and then channeled through the reactor building roof exhaust system. During power operation, the primary containment purge and ventilation system is isolated from the primary containment by two isolation valves in series.

HEPA (high efficiency particulate air) filters are installed before the charcoal adsorbers followed by a centrifugal fan. The in-place test results should indicate a leak tightness of the system housing of not less than 99-percent and a HEPA efficiency of at least 99-percent removal of DOP particulates. The laboratory carbon sample test results should indicate a radioactive methyl iodide removal efficiency of at least 85-percent. Operation of the fans significantly different from the design flow will change the removal efficiency of the HEPA filters and charcoal adsorbers.

If the system is found to be inoperable, the Standby Gas Treatment System may be used to purge the containment.

Pressure drop across the combined HEPA filters and charcoal adsorbers of less than 8.5 inches of water at the system design flow rate will indicate that the filters and adsorbers are not clogged by excessive amounts of foreign matter. Pressure drop should be determined at least once per operating cycle to show system performance capability.

The frequency of tests and sample analysis are necessary to show that the HEPA filters and charcoal adsorbers can perform as evaluated. Tests of the charcoal adsorbers with halogenated hydrocarbon shall be performed in accordance with USAEC Report-1082. Iodine removal efficiency tests shall follow ASTM D3803. The charcoal adsorber efficiency test procedures should allow for the removal of one adsorber tray, emptying of one bed from the tray, mixing the adsorbent thoroughly and obtaining at least two samples. Each sample should be at least two inches in diameter and a length equal to the thickness of the bed. If test results are unacceptable, all adsorbent in the system shall be replaced with an adsorbent qualified according to Table 1 of Regulatory Guide 1.52. The replacement tray for the adsorber tray removed



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-260

BROWNS FERRY NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 139
License No. DPR-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated February 11, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-52 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 139, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Gary G. Zech, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 12, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 139

FACILITY OPERATING LICENSE NO. DPR-52

DOCKET NO. 50-260

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Overleaf pages* are provided to maintain document completeness.

REMOVE

3.7/4.7-13
3.7/4.7-14
3.7/4.7-19
3.7/4.7-20*
3.7/4.7-21
3.7/4.7-22*
3.7/4.7-47
3.7/4.7-48
3.7/4.7-51
3.7/4.7-52

INSERT

3.7/4.7-13*
3.7/4.7-14
3.7/4.7-19
3.7/4.7-20*
3.7/4.7-21
3.7/4.7-22*
3.7/4.7-47
3.7/4.7-48
3.7/4.7-51
3.7/4.7-52

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

3.7.B. Standby Gas Treatment System

1. Except as specified in Specification 3.7.B.3 below, all three trains of the standby gas treatment system shall be OPERABLE at all times when secondary containment integrity is required.

SURVEILLANCE REQUIREMENTS

4.7.B. Standby Gas Treatment System

1. At least once per year, the following conditions shall be demonstrated.
 - a. Pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 6 inches of water at a flow of 9000 cfm ($\pm 10\%$).
 - b. The inlet heaters on each circuit are tested in accordance with ANSI N510-1975, and are capable of an output of at least 40 kW.
 - c. Air distribution is uniform within 20% across HEPA filters and charcoal adsorbers.

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

3.7.B. Standby Gas Treatment System

2. a. The results of the in-place cold DOP and halogenated hydrocarbon tests at $\geq 10\%$ design flow on HEPA filters and charcoal adsorber banks shall show $\geq 99\%$ DOP removal and $\geq 99\%$ halogenated hydrocarbon removal when tested in accordance with ANSI N510-1975.
- b. The results of laboratory carbon sample analysis shall show $\geq 90\%$ radioactive methyl iodide removal when tested in accordance with ASTM D3803 (130°C, 95% R.H.).
- c. System shall be shown to operate within $\pm 10\%$ design flow.

SURVEILLANCE REQUIREMENTS

4.7.B. Standby Gas Treatment System

2. a. The tests and sample analysis of Specification 3.7.B.2 shall be performed at least once per operating cycle or once every 18 months whichever occurs first for standby service or after every 720 hours of system operation and following significant painting, fire or chemical release in any ventilation zone communicating with the system.
- b. Cold DOP testing shall be performed after each complete or partial replacement of the HEPA filter bank or after any structural maintenance on the system housing.
- c. Halogenated hydrocarbon testing shall be performed after each complete or partial replacement of the charcoal adsorber bank or after any structural maintenance on the system housing.

LIMITING CONDITIONS FOR OPERATION

3.7.E. Control Room Emergency Ventilation

1. Except as specified in Specification 3.7.E.3 below, both control room emergency pressurization systems shall be OPERABLE at all times when any reactor vessel contains irradiated fuel.
2. a. The results of the in-place cold DOP and halogenated hydrocarbon tests at design flows on HEPA filters and charcoal adsorber banks shall show $\geq 99\%$ DOP removal and $\geq 99\%$ halogenated hydrocarbon removal when tested in accordance with ANSI N510-1975.

b. The results of laboratory carbon sample analysis shall show $\geq 90\%$ radioactive methyl iodide removal at a velocity when tested in accordance with ASTM D3803 (130°C, 95% R.H.).

c. System flow rate shall be shown to be within $\pm 10\%$ design flow when tested in accordance with ANSI N510-1975.

SURVEILLANCE REQUIREMENTS

4.7.E Control Room Emergency Ventilation

1. At least once per operating cycle, not to exceed 18 months, the pressure drop across the combined HEPA filters and charcoal adsorber banks shall be demonstrated to be less than 6 inches of water at system design flow rate ($\pm 10\%$).
2. a. The tests and sample analysis of Specification 3.7.E.2 shall be performed at least once per operating cycle or once every 18 months, whichever occurs first for standby service or after every 720 hours of system operation and following significant painting, fire, or chemical release in any ventilation zone communicating with the system.

b. Cold DOP testing shall be performed after each complete or partial replacement of the HEPA filter bank or after any structural maintenance on the system housing.

c. Halogenated hydrocarbon testing shall be performed after each complete or partial replacement of the charcoal adsorber bank or after any structural maintenance on the system housing.

d. Each circuit shall be operated at least 10 hours every month.

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

3.7.E. Control Room Emergency Ventilation

3. From and after the date that one of the control room emergency pressurization systems is made or found to be INOPERABLE for any reason, reactor operation or refueling operations is permissible only during the succeeding 7 days unless such circuit is sooner made OPERABLE.
4. If these conditions cannot be met, reactor shutdown shall be initiated and all reactors shall be in Cold Shutdown within 24 hours for reactor operations and refueling operations shall be terminated within 2 hours.

SURVEILLANCE REQUIREMENTS

4.7.E. Control Room Emergency Ventilation

3. At least once per operating cycle not to exceed 18 months, automatic initiation of the control room emergency pressurization system shall be demonstrated.
4. During the simulated automatic actuation test of this system (see Table 4.2.G), it shall be verified that the following dampers operate as indicated:

Close: FCO-150 B, D, E, and F
Open: FCO-151
FCO-152

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

3.7.F. Primary Containment Purge System

1. The primary containment shall be normally vented and purged through the primary containment purge system. The standby gas treatment system may be used when primary containment purge system is INOPERABLE.
2. a. The results of the in-place cold DOP and halogenated hydrocarbon tests at design flows on HEPA filters and charcoal adsorber banks shall show $\geq 99\%$ DOP removal and $\geq 99\%$ halogenated hydrocarbon removal when tested in accordance with ANSI N510-1975.
- b. The results of laboratory carbon sample analysis shall show $\geq 85\%$ radioactive methyl iodide removal when tested in accordance with ASTM D3803 (130°C 95% R.H.).
- c. System flow rate shall be shown to be within $\pm 10\%$ of design flow when tested in accordance with ANSI N510-1975.

SURVEILLANCE REQUIREMENTS

4.7.F. Primary Containment Purge System

1. At least once per operating cycle, not to exceed 18 months, the pressure drop across the combined HEPA filters and charcoal adsorber banks shall be demonstrated to be less than 8.5 inches of water at system design flow rate ($\pm 10\%$).
2. a. The tests and sample analysis of Specification 3.7.F.2 shall be performed at least once per operating cycle or once every 18 months, whichever occurs first or after 720 hours of system operation and following significant painting, fire, or chemical release in any ventilation zone communicating with the system.
- b. Cold DOP testing shall be performed after each complete or partial replacement of the HEPA filter bank or after any structural maintenance on the system housing.
- c. Halogenated hydrocarbon testing shall be performed after each complete or partial replacement of the charcoal adsorber bank or after any structural maintenance on the system housing.

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

3.7.G. Containment Atmosphere Dilution System (CAD)

1. The Containment Atmosphere Dilution (CAD) System shall be OPERABLE with:
 - a. Two independent systems capable of supplying nitrogen to the drywell and torus.
 - b. A minimum supply of 2,500 gallons of liquid nitrogen per system.
2. The Containment Atmosphere Dilution (CAD) System shall be OPERABLE whenever the reactor mode switch is in the "RUN" position.
3. If one system is INOPERABLE, the reactor may remain in operation for a period of 30 days provided all active components in the other system are OPERABLE.

SURVEILLANCE REQUIREMENTS

4.7.G. Containment Atmosphere Dilution System (CAD)

1. System Operability
 - a. At least once per month cycle each solenoid operated air/nitrogen valve through at least one complete cycle of full travel and verify that each manual valve in the flow path is open.
 - b. Verify that the CAD System contains a minimum supply of 2,500 gallons of liquid nitrogen twice per week.

The primary containment leak rate test frequency is based on maintaining adequate assurance that the leak rate remains within the specification. The leak rate test frequency is based on the NRC guide for developing leak rate testing and surveillance of reactor containment vessels. Allowing the test intervals to be extended up to 10 months permits some flexibility needed to have the tests coincide with scheduled or unscheduled shutdown periods.

The penetration and air purge piping leakage test frequency, along with the containment leak rate tests, is adequate to allow detection of leakage trends. Whenever a bolted double-gasketed penetration is broken and remade, the space between the gaskets is pressurized to determine that the seals are performing properly. It is expected that the majority of the leakage from valves, penetrations and seals would be into the reactor building. However, it is possible that leakage into other parts of the facility could occur. Such leakage paths that may affect significantly the consequences of accidents are to be minimized.

The primary containment is normally slightly pressurized during period of reactor operation. Nitrogen used for inerting could leak out of the containment but air could not leak in to increase oxygen concentration. Once the containment is filled with nitrogen to the required concentration, determining the oxygen concentration twice a week serves as an added assurance that the oxygen concentration will not exceed 4 percent.

3.7.B/3.7.C Standby Gas Treatment System and Secondary Containment

The secondary containment is designed to minimize any ground level release of radioactive materials which might result from a serious accident. The reactor building provides secondary containment during reactor operation, when the drywell is sealed and in service; the reactor building provides primary containment when the reactor is shutdown and the drywell is open, as during refueling. Because the secondary containment is an integral part of the complete containment system, secondary containment is required at all times that primary containment is required as well as during refueling.

The standby gas treatment system is designed to filter and exhaust the reactor building atmosphere to the stack during secondary containment isolation conditions. All three standby gas treatment system fans are designed to automatically start upon containment isolation and to maintain the reactor building pressure to the design negative pressure so that all leakage should be in-leakage.

High efficiency particulate air (HEPA) filters are installed before and after the charcoal absorbers to minimize potential release of particulates to the environment and to prevent clogging of the iodine absorbers. The charcoal absorbers are installed to reduce the potential release of radioiodine to the environment. The in-place test results should indicate a system leak tightness of less than 1 percent bypass leakage for the charcoal absorbers and a HEPA efficiency of at least 99 percent removal of DOP particulates. The laboratory carbon sample test results should indicate a radioactive methyl iodide removal efficiency of at least 90 percent for expected accident conditions. If the efficiencies of the HEPA filters and charcoal absorbers are as specified, the resulting doses will be less than the 10 CFR 100 guidelines for the accidents analyzed. Operation of the fans significantly different from the design flow will change the removal efficiency of the HEPA filters and charcoal absorbers.

Only two of the three standby gas treatment systems are needed to clean up the reactor building atmosphere upon containment isolation. If one system is found to be inoperable, there is no immediate threat to the containment system performance and reactor operation or refueling operation may continue while repairs are being made. If more than one train is inoperable, the plant is brought to a condition where the standby gas treatment system is not required.

4.7.B/4.7.C Standby Gas Treatment System and Secondary Containment

Initiating reactor building isolation and operation of the standby gas treatment system to maintain at least a 1/4 inch of water vacuum within the secondary containment provides an adequate test of the operation of the reactor building isolation valves, leak tightness of the reactor building and performance of the standby gas treatment system. Functionally testing the initiating sensors and associated trip logic demonstrates the capability for automatic actuation. Performing these tests prior to refueling will demonstrate secondary containment capability prior to the time the primary containment is opened for refueling. Periodic testing gives sufficient confidence of reactor building integrity and standby gas treatment system performance capability.

The test frequencies are adequate to detect equipment deterioration prior to significant defects, but the tests are not frequent enough to load the filters, thus reducing their reserve capacity too quickly. That the testing frequency is adequate to detect deterioration was demonstrated by the tests which showed no loss of filter efficiency after two years of operation in the rugged shipboard environment on the US Savannah (ORNL 3726). Pressure drop across the combined HEPA filters and charcoal adsorbers of less than six inches of water at the system design flow rate will indicate that the filters and adsorbers are not clogged by excessive amounts of foreign matter. Heater capability, pressure drop and air distribution should be determined at least once per operating cycle to show system performance capability.

The frequency of tests and sample analysis are necessary to show that the HEPA filters and charcoal adsorbers can perform as evaluated. Tests of the charcoal adsorbers with halogenated hydrocarbon refrigerant shall be performed in accordance with USAEC Report DP-1082. Iodine removal efficiency tests shall follow ASTM D3803. The charcoal adsorber efficiency test procedures should allow for the removal of one adsorber tray, emptying of one bed from the tray, mixing the adsorbent thoroughly and obtaining at least two samples. Each sample should be at least two inches in diameter and a length equal to the thickness of the bed. If test results are unacceptable, all adsorbent in the system shall be replaced with an adsorbent qualified according to Table 1 of Regulatory Guide 1.52. The replacement tray for the adsorber tray removed for the test should meet the same adsorbent quality. Tests of the HEPA filters with DOP aerosol shall be performed in accordance to ANSI N510-1975. Any HEPA filters found defective shall be replaced with filters qualified pursuant to Regulatory Position C.3.d of Regulatory Guide 1.52.

All elements of the heater should be demonstrated to be functional and operable during the test of heater capacity. Operation of each filter train for a minimum of 10 hours each month will prevent moisture buildup in the filters and adsorber system.

3.7.E/4.7.E Control Room Emergency Ventilation

The control room emergency ventilation system is designed to filter the control room atmosphere for intake air and/or for recirculation during control room isolation conditions. The control room emergency ventilation system is designed to automatically start upon control room isolation and to maintain the control room pressure to the design positive pressure so that all leakage should be out leakage.

High efficiency particulate absolute (HEPA) filters are installed before the charcoal adsorbers to prevent clogging of the iodine adsorbers. The charcoal adsorbers are installed to reduce the potential intake of radioiodine to the control room. The in-place test results should indicate a system leak tightness of less than 1 percent bypass leakage for the charcoal adsorbers and a HEPA efficiency of at least 99 percent removal of DOP particulates. The laboratory carbon sample test results should indicate a radioactive methyl iodide removal efficiency of at least 90 percent for expected accident conditions. If the efficiencies of the HEPA filters and charcoal adsorbers are as specified, the resulting doses will be less than the allowable levels stated in Criterion 19 of the General Design Criteria for Nuclear Power Plants, Appendix A to 10 CFR Part 50. Operation of the fans significantly different from the design flow will change the removal efficiency of the HEPA filters and charcoal adsorbers.

If the system is found to be inoperable, there is no immediate threat to the control room and reactor operation or refueling operation may continue for a limited period of time while repairs are being made. If the system cannot be repaired within seven days, the reactor is shutdown and brought to Cold Shutdown within 24 hours or refueling operations are terminated.

Pressure drop across the combined HEPA filters and charcoal adsorbers of less than six inches of water at the system design flow rate will indicate that the filters and adsorbers are not clogged by excessive amounts of foreign matter. Pressure drop should be determined at least once per operating cycle to show system performance capability.

The frequency of tests and sample analysis are necessary to show that the HEPA filters and charcoal adsorbers can perform as evaluated. Tests of the charcoal adsorbers with halogenated hydrocarbon shall be performed in accordance with USAEC Report-1082. Iodine removal efficiency tests shall follow ASTM D3803. The charcoal adsorber efficiency test procedures should allow for the removal of one adsorber tray, emptying of one bed from the tray, mixing the adsorbent thoroughly and obtaining at least two samples. Each sample should be at least two inches in diameter and a length equal to the thickness of the bed. If test results are unacceptable, all adsorbent in the system shall be replaced with an adsorbent qualified according to Table 1 of Regulatory Guide 1.52. The replacement tray for the adsorber tray removed for the test should meet the same adsorbent quality. Tests of the HEPA filters with DOP aerosol shall be performed in accordance to ANSI N510-1975. Any HEPA filters found defective shall be replaced with filters qualified pursuant to Regulatory Position C.3.d of Regulatory Guide 1.52.

3.7/4.7 BASES (Cont'd)

Operation of the system for 10 hours every month will demonstrate operability of the filters and adsorber system and remove excessive moisture built up on the adsorber.

If significant painting, fire or chemical release occurs such that the HEPA filter or charcoal adsorber could become contaminated from the fumes, chemicals or foreign materials, the same tests and sample analysis shall be performed as required for operational use. The determination of significance shall be made by the operator on duty at the time of the incident. Knowledgeable staff members should be consulted prior to making this determination.

Demonstration of the automatic initiation capability is necessary to assure system performance capability.

3.7.F/4.7.F Primary Containment Purge System

The primary containment purge system is designed to provide air to purge and ventilate the primary containment system. The exhaust from the primary containment is first processed by a filter train assembly and then channeled through the reactor building roof exhaust system. During power operation, the primary containment purge and ventilation system is isolated from the primary containment by two isolation valves in series.

HEPA (high efficiency particulate air) filters are installed before the charcoal adsorbers followed by a centrifugal fan. The in-place test results should indicate a leak tightness of the system housing of not less than 99-percent and a HEPA efficiency of at least 99-percent removal of DOP particulates. The laboratory carbon sample test results should indicate a radioactive methyl iodide removal efficiency of at least 85-percent. Operation of the fans significantly different from the design flow will change the removal efficiency of the HEPA filters and charcoal adsorbers.

If the system is found to be inoperable, the Standby Gas Treatment System may be used to purge the containment.

Pressure drop across the combined HEPA filters and charcoal adsorbers of less than 8.5 inches of water at the system design flow rate will indicate that the filters and adsorbers are not clogged by excessive amounts of foreign matter. Pressure drop should be determined at least once per operating cycle to show system performance capability.

The frequency of tests and sample analysis are necessary to show that the HEPA filters and charcoal adsorbers can perform as evaluated. Tests of the charcoal adsorbers with halogenated hydrocarbon shall be performed in accordance with USAEC Report-1082. Iodine removal efficiency tests shall follow ASTM D3803. The charcoal adsorber efficiency test procedures should allow for the removal of one adsorber tray, emptying of one bed from the tray, mixing the adsorbent thoroughly and obtaining at least two samples. Each sample should be at least two inches in diameter and a length equal to the thickness of the bed. If test results are unacceptable, all adsorbent in the system shall be replaced with an adsorbent qualified according to Table 1 of Regulatory Guide 1.52. The replacement tray for the adsorber tray removed



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-296

BROWNS FERRY NUCLEAR PLANT, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 114
License No. DPR-68

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated February 11, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-68 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 114, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Gary G. Zech, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 12, 1988

ATTACHMENT TO LICENSE AMENDMENT NO.114

FACILITY OPERATING LICENSE NO. DPR-68

DOCKET NO. 50-296

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Overleaf pages* are provided to maintain document completeness.

REMOVE

3.7/4.7-13
3.7/4.7-14
3.7/4.7-19
3.7/4.7-20*
3.7/4.7-21
3.7/4.7-22*
3.7/4.7-45
3.7/4.7-46
3.7/4.7-49
3.7/4.7-50

INSERT

3.7/4.7-13*
3.7/4.7-14
3.7/4.7-19
3.7/4.7-20*
3.7/4.7-21
3.7/4.7-22*
3.7/4.7-45
3.7/4.7-46
3.7/4.7-49
3.7/4.7-50

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

3.7.B. Standby Gas Treatment System

1. Except as specified in Specification 3.7.B.3 below, all three trains of the standby gas treatment system shall be OPERABLE at all times when secondary containment integrity is required.

SURVEILLANCE REQUIREMENTS

4.7.B. Standby Gas Treatment System

1. At least once per year, the following conditions shall be demonstrated.
 - a. Pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 6 inches of water at a flow of 9000 cfm ($\pm 10\%$).
 - b. The inlet heaters on each circuit are tested in accordance with ANSI N510-1975, and are capable of an output of at least 40 kW.
 - c. Air distribution is uniform within 20% across HEPA filters and charcoal adsorbers.

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

3.7.B. Standby Gas Treatment System

2. a. The results of the in-place cold DOP and halogenated hydrocarbon tests at $\geq 10\%$ design flow on HEPA filters and charcoal adsorber banks shall show $\geq 99\%$ DOP removal and $\geq 99\%$ halogenated hydrocarbon removal when tested in accordance with ANSI N510-1975.
- b. The results of laboratory carbon sample analysis shall show $\geq 90\%$ radioactive methyl iodide removal when tested in accordance with ASTM D3803 (130°C, 95% R.H.).
- c. System shall be shown to operate within $\pm 10\%$ design flow.

SURVEILLANCE REQUIREMENTS

4.7.B. Standby Gas Treatment System

2. a. The tests and sample analysis of Specification 3.7.B.2 shall be performed at least once per operating cycle or once every 18 months whichever occurs first for standby service or after every 720 hours of system operation and following significant painting, fire or chemical release in any ventilation zone communicating with the system.
- b. Cold DOP testing shall be performed after each complete or partial replacement of the HEPA filter bank or after any structural maintenance on the system housing.
- c. Halogenated hydrocarbon testing shall be performed after each complete or partial replacement of the charcoal adsorber bank or after any structural maintenance on the system housing.

LIMITING CONDITIONS FOR OPERATION

3.7.E. Control Room Emergency Ventilation

1. Except as specified in Specification 3.7.E.3 below, both control room emergency pressurization systems shall be OPERABLE at all times when any reactor vessel contains irradiated fuel.
2. a. The results of the in-place cold DOP and halogenated hydrocarbon tests at design flows on HEPA filters and charcoal adsorber banks shall show $\geq 99\%$ DOP removal and $\geq 99\%$ halogenated hydrocarbon removal when tested in accordance with ANSI N510-1975.
- b. The results of laboratory carbon sample analysis shall show $\geq 90\%$ radioactive methyl iodide removal at a velocity when tested in accordance with ASTM D3803 (130°C, 95% R.H.).
- c. System flow rate shall be shown to be within $\pm 10\%$ design flow when tested in accordance with ANSI N510-1975.

SURVEILLANCE REQUIREMENTS

4.7.E Control Room Emergency Ventilation

1. At least once per operating cycle, not to exceed 18 months, the pressure drop across the combined HEPA filters and charcoal adsorber banks shall be demonstrated to be less than 6 inches of water at system design flow rate ($\pm 10\%$).
2. a. The tests and sample analysis of Specification 3.7.E.2 shall be performed at least once per operating cycle or once every 18 months, whichever occurs first for standby service or after every 720 hours of system operation and following significant painting, fire, or chemical release in any ventilation zone communicating with the system.
- b. Cold DOP testing shall be performed after each complete or partial replacement of the HEPA filter bank or after any structural maintenance on the system housing.
- c. Halogenated hydrocarbon testing shall be performed after each complete or partial replacement of the charcoal adsorber bank or after any structural maintenance on the system housing.
- d. Each circuit shall be operated at least 10 hours every month.

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

3.7.E. Control Room Emergency Ventilation

3. From and after the date that one of the control room emergency pressurization systems is made or found to be INOPERABLE for any reason, reactor operation or refueling operations is permissible only during the succeeding 7 days unless such circuit is sooner made OPERABLE.
4. If these conditions cannot be met, reactor shutdown shall be initiated and all reactors shall be in Cold Shutdown within 24 hours for reactor operations and refueling operations shall be terminated within 2 hours.

SURVEILLANCE REQUIREMENTS

4.7.E. Control Room Emergency Ventilation

3. At least once per operating cycle not to exceed 18 months, automatic initiation of the control room emergency pressurization system shall be demonstrated.

4. During the simulated automatic actuation test of this system (see Table 4.2.G), it shall be verified that the following dampers operate as indicated:

Close: FCO-150 B, D, E, and F
Open: FCO-151,
FCO-152

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

3.7.F. Primary Containment Purge System

1. The primary containment shall be normally vented and purged through the primary containment purge system. The standby gas treatment system may be used when primary containment purge system is INOPERABLE.
2. a. The results of the in-place cold DOP and halogenated hydrocarbon tests at design flows on HEPA filters and charcoal adsorber banks shall show $\geq 99\%$ DOP removal and $\geq 99\%$ halogenated hydrocarbon removal when tested in accordance with ANSI N510-1975.

b. The results of laboratory carbon sample analysis shall show $\geq 85\%$ radioactive methyl iodide removal when tested in accordance with ASTM D3803 (130°C 95% R.H.).

c. System flow rate shall be shown to be within $\pm 10\%$ of design flow when tested in accordance with ANSI N510-1975.

SURVEILLANCE REQUIREMENTS

4.7.F. Primary Containment Purge System

1. At least once per operating cycle, not to exceed 18 months, the pressure drop across the combined HEPA filters and charcoal adsorber banks shall be demonstrated to be less than 8.5 inches of water at system design flow rate ($\pm 10\%$).
2. a. The tests and sample analysis of Specification 3.7.F.2 shall be performed at least once per operating cycle or once every 18 months, whichever occurs first or after 720 hours of system operation and following significant painting, fire, or chemical release in any ventilation zone communicating with the system.

b. Cold DOP testing shall be performed after each complete or partial replacement of the HEPA filter bank or after any structural maintenance on the system housing.

c. Halogenated hydrocarbon testing shall be performed after each complete or partial replacement of the charcoal adsorber bank or after any structural maintenance on the system housing.

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

3.7.G. Containment Atmosphere Dilution System (CAD)

1. The Containment Atmosphere Dilution (CAD) System shall be OPERABLE with:
 - a. Two independent systems capable of supplying nitrogen to the drywell and torus.
 - b. A minimum supply of 2,500 gallons of liquid nitrogen per system.
2. The Containment Atmosphere Dilution (CAD) System shall be OPERABLE whenever the reactor mode switch is in the "RUN" position.
3. If one system is INOPERABLE, the reactor may remain in operation for a period of 30 days provided all active components in the other system are OPERABLE.
4. If Specifications 3.7.G.1 and 3.7.G.2, or 3.7.G.3 cannot be met, an orderly shutdown shall be initiated and the reactor shall be in the Cold Shutdown condition within 24 hours.
5. Primary containment pressure shall be limited to a maximum of 30 psig during repressurization following a loss of coolant accident.

SURVEILLANCE REQUIREMENTS

4.7.G. Containment Atmosphere Dilution System (CAD)

1. System Operability
 - a. At least once per month cycle each solenoid-operated air/nitrogen valve through at least one complete cycle of full travel and verify that each manual valve in the flow path is open.
 - b. Verify that the CAD System contains a minimum supply of 2,500 gallons of liquid nitrogen twice per week.

3.7/4.7 BASES (Cont'd)

The primary containment leak rate test frequency is based on maintaining adequate assurance that the leak rate remains within the specification. The leak rate test frequency is based on the NRC guide for developing leak rate testing and surveillance of reactor containment vessels. Allowing the test intervals to be extended up to 10 months permits some flexibility needed to have the tests coincide with scheduled or unscheduled shutdown periods.

The penetration and air purge piping leakage test frequency, along with the containment leak rate tests, is adequate to allow detection of leakage trends. Whenever a bolted double-gasketed penetration is broken and remade, the space between the gaskets is pressurized to determine that the seals are performing properly. It is expected that the majority of the leakage from valves, penetrations and seals would be into the reactor building. However, it is possible that leakage into other parts of the facility could occur. Such leakage paths that may affect significantly the consequences of accidents are to be minimized.

The primary containment is normally slightly pressurized during period of reactor operation. Nitrogen used for inerting could leak out of the containment but air could not leak in to increase oxygen concentration. Once the containment is filled with nitrogen to the required concentration, determining the oxygen concentration twice a week serves as an added assurance that the oxygen concentration will not exceed 4 percent.

3.7.B/3.7.C Standby Gas Treatment System and Secondary Containment

The secondary containment is designed to minimize any ground level release of radioactive materials which might result from a serious accident. The reactor building provides secondary containment during reactor operation, when the drywell is sealed and in service; the reactor building provides primary containment when the reactor is shutdown and the drywell is open, as during refueling. Because the secondary containment is an integral part of the complete containment system, secondary containment is required at all times that primary containment is required as well as during refueling.

The standby gas treatment system is designed to filter and exhaust the reactor building atmosphere to the stack during secondary containment isolation conditions. All three standby gas treatment system fans are designed to automatically start upon containment isolation and to maintain the reactor building pressure to the design negative pressure so that all leakage should be in-leakage.

High efficiency particulate air (HEPA) filters are installed before and after the charcoal absorbers to minimize potential release of particulates to the environment and to prevent clogging of the iodine absorbers. The charcoal absorbers are installed to reduce the potential release of radioiodine to the environment. The in-place test results should indicate a system leak tightness of less than 1 percent bypass leakage for the charcoal absorbers and a HEPA efficiency of at least 99 percent removal of DOP particulates. The laboratory carbon sample test results should indicate a radioactive methyl iodide removal efficiency of at least 90 percent for expected accident conditions. If the efficiencies of the HEPA filters and charcoal absorbers are as specified, the resulting doses will be less than the 10 CFR 100 guidelines for the accidents analyzed. Operation of the fans significantly different from the design flow will change the removal efficiency of the HEPA filters and charcoal absorbers.

3.7/4.7 BASES (Cont'd)

Only two of the three standby gas treatment systems are needed to clean up the reactor building atmosphere upon containment isolation. If one system is found to be inoperable, there is no immediate threat to the containment system performance and reactor operation or refueling operation may continue while repairs are being made. If more than one train is inoperable, the plant is brought to a condition where the standby gas treatment system is not required.

4.7.B/4.7.C Standby Gas Treatment System and Secondary Containment

Initiating reactor building isolation and operation of the standby gas treatment system to maintain at least a 1/4 inch of water vacuum within the secondary containment provides an adequate test of the operation of the reactor building isolation valves, leak tightness of the reactor building and performance of the standby gas treatment system. Functionally testing the initiating sensors and associated trip logic demonstrates the capability for automatic actuation. Performing these tests prior to refueling will demonstrate secondary containment capability prior to the time the primary containment is opened for refueling. Periodic testing gives sufficient confidence of reactor building integrity and standby gas treatment system performance capability.

The test frequencies are adequate to detect equipment deterioration prior to significant defects, but the tests are not frequent enough to load the filters, thus reducing their reserve capacity too quickly. That the testing frequency is adequate to detect deterioration was demonstrated by the tests which showed no loss of filter efficiency after two years of operation in the rugged shipboard environment on the US Savannah (ORNL 3726). Pressure drop across the combined HEPA filters and charcoal adsorbers of less than six inches of water at the system design flow rate will indicate that the filters and adsorbers are not clogged by excessive amounts of foreign matter. Heater capability, pressure drop and air distribution should be determined at least once per operating cycle to show system performance capability.

The frequency of tests and sample analysis are necessary to show that the HEPA filters and charcoal adsorbers can perform as evaluated. Tests of the charcoal adsorbers with halogenated hydrocarbon refrigerant shall be performed in accordance with USAEC Report DP-1082. Iodine removal efficiency tests shall follow ASTM D3803. The charcoal adsorber efficiency test procedures should allow for the removal of one adsorber tray, emptying of one bed from the tray, mixing the adsorbent thoroughly and obtaining at least two samples. Each sample should be at least two inches in diameter and a length equal to the thickness of the bed. If test results are unacceptable, all adsorbent in the system shall be replaced with an adsorbent qualified according to Table 1 of Regulatory Guide 1.52. The replacement tray for the adsorber tray removed for the test should meet the same adsorbent quality. Tests of the HEPA filters with DOP aerosol shall be performed in accordance to ANSI N510-1975. Any HEPA filters found defective shall be replaced with filters qualified pursuant to Regulatory Position C.3.d of Regulatory Guide 1.52.

All elements of the heater should be demonstrated to be functional and operable during the test of heater capacity. Operation of each filter train for a minimum of 10 hours each month will prevent moisture buildup in the filters and adsorber system.

3.7/4.7 BASES (Cont'd)

3.7.E/4.7.E Control Room Emergency Ventilation

The control room emergency ventilation system is designed to filter the control room atmosphere for intake air and/or for recirculation during control room isolation conditions. The control room emergency ventilation system is designed to automatically start upon control room isolation and to maintain the control room pressure to the design positive pressure so that all leakage should be out leakage.

High efficiency particulate absolute (HEPA) filters are installed before the charcoal adsorbers to prevent clogging of the iodine adsorbers. The charcoal adsorbers are installed to reduce the potential intake of radioiodine to the control room. The in-place test results should indicate a system leak tightness of less than 1 percent bypass leakage for the charcoal adsorbers and a HEPA efficiency of at least 99 percent removal of DOP particulates. The laboratory carbon sample test results should indicate a radioactive methyl iodide removal efficiency of at least 90 percent for expected accident conditions. If the efficiencies of the HEPA filters and charcoal adsorbers are as specified, the resulting doses will be less than the allowable levels stated in Criterion 19 of the General Design Criteria for Nuclear Power Plants, Appendix A to 10 CFR Part 50. Operation of the fans significantly different from the design flow will change the removal efficiency of the HEPA filters and charcoal adsorbers.

If the system is found to be inoperable, there is no immediate threat to the control room and reactor operation or refueling operation may continue for a limited period of time while repairs are being made. If the system cannot be repaired within seven days, the reactor is shutdown and brought to Cold Shutdown within 24 hours or refueling operations are terminated.

Pressure drop across the combined HEPA filters and charcoal adsorbers of less than six inches of water at the system design flow rate will indicate that the filters and adsorbers are not clogged by excessive amounts of foreign matter. Pressure drop should be determined at least once per operating cycle to show system performance capability.

The frequency of tests and sample analysis are necessary to show that the HEPA filters and charcoal adsorbers can perform as evaluated. Tests of the charcoal adsorbers with halogenated hydrocarbon shall be performed in accordance with USAEC Report-1082. Iodine removal efficiency tests shall follow ASTM D3803. The charcoal adsorber efficiency test procedures should allow for the removal of one adsorber tray, emptying of one bed from the tray, mixing the adsorbent thoroughly and obtaining at least two samples. Each sample should be at least two inches in diameter and a length equal to the thickness of the bed. If test results are unacceptable, all adsorbent in the system shall be replaced with an adsorbent qualified according to Table 1 of Regulatory Guide 1.52. The replacement tray for the adsorber tray removed for the test should meet the same adsorbent quality. Tests of the HEPA filters with DOP aerosol shall be performed in accordance to ANSI N510-1975. Any HEPA filters found defective shall be replaced with filters qualified pursuant to Regulatory Position C.3.d of Regulatory Guide 1.52.

3.7/4.7 BASES (Cont'd)

Operation of the system for 10 hours every month will demonstrate operability of the filters and adsorber system and remove excessive moisture built up on the adsorber.

If significant painting, fire or chemical release occurs such that the HEPA filter or charcoal adsorber could become contaminated from the fumes, chemicals or foreign materials, the same tests and sample analysis shall be performed as required for operational use. The determination of significance shall be made by the operator on duty at the time of the incident. Knowledgeable staff members should be consulted prior to making this determination.

Demonstration of the automatic initiation capability is necessary to assure system performance capability.

3.7.F/4.7.F Primary Containment Purge System

The primary containment purge system is designed to provide air to purge and ventilate the primary containment system. The exhaust from the primary containment is first processed by a filter train assembly and then channeled through the reactor building roof exhaust system. During power operation, the primary containment purge and ventilation system is isolated from the primary containment by two isolation valves in series.

HEPA (high efficiency particulate air) filters are installed before the charcoal adsorbers followed by a centrifugal fan. The in-place test results should indicate a leak tightness of the system housing of not less than 99-percent and a HEPA efficiency of at least 99-percent removal of DOP particulates. The laboratory carbon sample test results should indicate a radioactive methyl iodide removal efficiency of at least 85-percent. Operation of the fans significantly different from the design flow will change the removal efficiency of the HEPA filters and charcoal adsorbers.

If the system is found to be inoperable, the Standby Gas Treatment System may be used to purge the containment.

Pressure drop across the combined HEPA filters and charcoal adsorbers of less than 8.5 inches of water at the system design flow rate will indicate that the filters and adsorbers are not clogged by excessive amounts of foreign matter. Pressure drop should be determined at least once per operating cycle to show system performance capability.

The frequency of tests and sample analysis are necessary to show that the HEPA filters and charcoal adsorbers can perform as evaluated. Tests of the charcoal adsorbers with halogenated hydrocarbon shall be performed in accordance with USAEC Report-1082. Iodine removal efficiency tests shall follow ASTM D3803. The charcoal adsorber efficiency test procedures should allow for the removal of one adsorber tray, emptying of one bed from the tray, mixing the adsorbent thoroughly and obtaining at least two samples. Each sample should be at least two inches in diameter and a length equal to the thickness of the bed. If test results are unacceptable, all adsorbent in the system shall be replaced with an adsorbent qualified according to Table 1 of Regulatory Guide 1.52. The replacement tray for the adsorber tray removed



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF SPECIAL PROJECTS

SUPPORTING AMENDMENT NO. 143 TO FACILITY OPERATING LICENSE NO. DPR-33

AMENDMENT NO. 139 TO FACILITY OPERATING LICENSE NO. DPR-52

AMENDMENT NO. ¹¹⁴ TO FACILITY OPERATING LICENSE NO. DPR-68

TENNESSEE VALLEY AUTHORITY

BROWNS FERRY NUCLEAR PLANT, UNITS 1, 2 AND 3

DOCKETS NOS. 50-259, 50-260 AND 50-296

1.0 INTRODUCTION

The proposed amendment would revise the limiting conditions for operation for the Standby Gas Treatment System, the Control Room Ventilation System and the Primary Containment Purge System. In each case, the proposed change would replace ANSI N510-1975, which is currently referenced in the Technical Specifications for the radioactive methyl iodine removal effectiveness test of charcoal filter samples, with ASTM D3803. ASTM D3803 is referred to in ANSI N510-1980 as the proper test to use for measuring methyl iodine removal effectiveness.

2.0 EVALUATION

Regulatory Guide 1.52, "Design, Testing, and Maintenance Criteria for Post Accident Engineered-Safety-Feature Atmosphere Cleanup System Air Filtration and Adsorption Units of Light-Water-Cooled Nuclear Power Plants," requires that licensees refer to ANSI standard N510-1975 "Testing of Nuclear Air-Cleaning System" for acceptable methods of analyzing carbon samples for iodine removal efficiency. ANSI N510-1975 requires that laboratory testing of samples be performed in accordance with RDT M 16-1T.

During a NRC inspection (November 21 to December 31, 1985), a review of test results indicated that not all the requirements of RDT M 16-1T were being satisfied during the testing. This resulted in a violation of 10 CFR 50, Appendix B, Criterion V (Inspection Report 50-259, 50-260 and 50-245/85-87). This item was also listed as an open item under the topic, Surveillance-Testing-Observation, in that report.

In response to the Inspection Report and Notice of Violation, the licensee has requested a change to the Technical Specifications in regard to the Limiting Condition for Operation (LCO) in Sections 3.7B, Standby Gas Treatment System; 3.7E, Control Room Emergency Ventilation; and 3.7F, Primary Containment Purge System. Specifically the requested change in the LCOs would substitute ASTM D3803 for ANSI N510-1975 in the section on radioactive methyl iodide removal testing.

ANSI N510-1975 was revised in 1980 and the new revision was labeled as ANSI/ASME N510-1980. ANSI/ASME N510-1980 specifically refers to ASTM D3803 as the recommended testing procedure for methyl iodide removal efficiency. ASTM D3803-79 lists detailed procedures for testing which are acceptable to the NRC staff.

Based on the above evaluation, the staff finds the proposed changes to the Technical Specifications acceptable.

3.0 ENVIRONMENTAL CONSIDERATION

The amendments involve a change to a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that these amendments involve no significant hazards consideration and there has been no public comment on such finding. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement nor environmental assessment need be prepared in connection with the issuance of these amendments.

4.0 CONCLUSION

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of the amendments will not be inimical to the common defense and security nor to the health and safety of the public.

Principal Contributor: Rex Wescott

Dated: February 12, 1988