

August 20, 1987

Docket Nos. 50-259/260/296

Mr. S. A. White
Manager of Nuclear Power
Tennessee Valley Authority
6N 38A Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

Dear Mr. White:

SUBJECT: CLARIFICATION OF APPLICABILITY OF TECHNICAL SPECIFICATION DEFINITION
(TAC 64703, 64704, 64705) (TS 225)

Re: Browns Ferry Nuclear Plant, Units 1, 2 and 3

The Commission has issued the enclosed Amendments Nos. 135, 131, and 106 to Facility Operating Licenses Nos. DPR-33, DPR-52 and DPR-68 for the Browns Ferry Nuclear Plant, Units 1, 2 and 3. These amendments are in response to your application dated February 6, 1987.

The amendments change the Technical Specifications to clarify the applicability of definition 1.0.C.2 so that the definition will not be erroneously applied while in Cold Shutdown condition or Refueling mode.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Bi-Weekly Federal Register Notice.

Sincerely,

Original signed by:

John A. Zwolinski, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Enclosures:

1. Amendment No. 135 to License No. DPR-33
2. Amendment No. 131 to License No. DPR-52
3. Amendment No. 106 to License No. DPR-68
4. Safety Evaluation

cc w/enclosures:
See next page

DISTRIBUTION:

Docket File	FMiraglia
NRC PDR	JPartlow
Local PDR	DHagan
JAxelrad	EButcher
SEbnetter	EJordan
SRichardson	RDiggs
JZwolinski	TBarnhart (12)
BDLiaw	Wanda Jones
GZech	GPA/PA
SRConnelly	OGC-BETH
TVA-Bethesda	ACRS (10)
JStang	BF File
GGears	Projects Rdg
CJamerson	AIgnatonis,RII

8708270365 870820
PDR ADOCK 05000259
P PDR

OSP:DTVA
CJamerson
6/19/87

OSP:DTVA
JStang
6/29/87

OSP:DTVA
GGears
6/28/87

OSP:AD/TP
BDLiaw
7/19/87

OGC-BETH
Barnhart
7/15/87

DTVA:AD/P
JZwolinski
7/20/87



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

August 20, 1987

Docket Nos. 50-259/260/296

Mr. S. A. White
Manager of Nuclear Power
Tennessee Valley Authority
6N 38A Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

Dear Mr. White:

SUBJECT: CLARIFICATION OF APPLICABILITY OF TECHNICAL SPECIFICATION DEFINITION
(TAC 64703, 64704, 64705) TS 225

Re: Browns Ferry Nuclear Plant, Units 1, 2 and 3

The Commission has issued the enclosed Amendments Nos. 135, 131, and 106 to Facility Operating Licenses Nos. DPR-33, DPR-52 and DPR-68 for the Browns Ferry Nuclear Plant, Units 1, 2 and 3. These amendments are in response to your application dated February 6, 1987.

The amendments change the Technical Specifications to clarify the applicability of definition 1.0.C.2 so that the definition will not be erroneously applied while in Cold Shutdown condition or Refueling mode.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Bi-Weekly Federal Register Notice.

Sincerely,

John A. Zwolinski, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Enclosures:

1. Amendment No. 135 to License No. DPR-33
2. Amendment No. 131 to License No. DPR-52
3. Amendment No. 106 to License No. DPR-68
4. Safety Evaluation

cc w/enclosures:
See next page

Mr. S. A. White
Tennessee Valley Authority

Browns Ferry Nuclear Plant
Units 1, 2, and 3

cc:
General Counsel
Tennessee Valley Authority
400 West Summit Hill Drive
E11 B33
Knoxville, Tennessee 37902

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W.
Atlanta, Georgia 30323

Mr. R. L. Gridley
Tennessee Valley Authority
5N 157B Lookout Place
Chattanooga, Tennessee 37402-2801

Resident Inspector/Browns Ferry NP
U.S. Nuclear Regulatory Commission
Route 12, Box 637
Athens, Alabama 35611

Mr. H. P. Pomrehn
Tennessee Valley Authority
Browns Ferry Nuclear Plant
P.O. Box 2000
Decatur, Alabama 35602

Mr. Richard King
c/o U.S. GAO
1111 North Shore Drive
Suite 225, Box 194
Knoxville, Tennessee 37919

Mr. M. J. May
Tennessee Valley Authority
Browns Ferry Nuclear Plant
P.O. Box 2000
Decatur, Alabama 35602

Mr. D. L. Williams
Tennessee Valley Authority
400 West Summit Hill Drive
W10 B85
Knoxville, Tennessee 37902

Chairman, Limestone County Commission
P.O. Box 188
Athens, Alabama 35611

Claude Earl Fox, M.D.
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36130



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-259

BROWNS FERRY NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 135
License No. DPR-33

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated February 6, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-33 is hereby amended to read as follows:

8708270378 870820
PDR ADOCK 05000259
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 135, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance and shall be implemented within 60 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John A. Zwolinski, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 20, 1987

ATTACHMENT TO LICENSE AMENDMENT NO. 135

FACILITY OPERATING LICENSE NO. DPR-33

DOCKET NO. 50-259

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain vertical lines indicating the areas of change. Overleaf page provided to maintain document completeness.*

REMOVE

1.0-1
1.0-2

INSERT

1.0-1*
1.0-2

1.0 DEFINITIONS

The succeeding frequently used terms are explicitly defined so that a uniform interpretation of the specifications may be achieved.

- A. Safety Limit - The safety limits are limits below which the reasonable maintenance of the cladding and primary systems are assured. Exceeding such a limit requires unit shutdown and review by the Atomic Energy Commission before resumption of unit operation. Operation beyond such a limit may not in itself result in serious consequences but it indicates an operational deficiency subject to regulatory review.
- B. Limiting Safety System Settings (LSSS) - The limiting safety system settings are settings on instrumentation which initiate the automatic protective action at a level such that the safety limits will not be exceeded. The region between the safety limit and these settings represents margin with normal operation lying below these settings. The margin has been established so that with proper operation of the instrumentation the safety limits will never be exceeded.
- C. Limiting Conditions for Operation (LCO) - The limiting conditions for operation specify the minimum acceptable levels of system performance necessary to assure safe startup and operation of the facility. When these conditions are met, the plant can be operated safely and abnormal situations can be safely controlled.
 - 1. In the event a Limiting Condition for Operation and/or associated requirements cannot be satisfied because of circumstances in excess of those addressed in the specification, the unit shall be placed in at least Hot Standby within 6 hours and in Cold Shutdown within the following 30 hours unless corrective measures are completed that permit operation under the permissible discovery or until the reactor is placed in an operational condition in which the specification is not applicable. Exceptions to these requirements shall be stated in the individual specifications. This provides actions to be taken for circumstances not directly provided for in the specifications and where occurrence would violate the intent of the specification. For example, if a specification calls for two systems (or subsystems) to be operable and provides for explicit requirements if one system (or subsystem) is inoperable, then if both systems (or subsystems) are inoperable the unit is to be in at least Hot Standby in 6 hours and in Cold Shutdown within the following 30 hours if the inoperable condition is not corrected.

1.0 DEFINITIONS (Cont'd)

2. When a system, subsystem, train, component, or device is determined to be inoperable solely because its onsite power source is inoperable, or solely because its offsite power source is inoperable, it may be considered operable for the purpose of satisfying the requirements of its applicable Limiting Condition For Operation, provided:

(1) its corresponding offsite or diesel power source is operable; and (2) all of its redundant system(s), subsystem(s), train(s), component(s), and device(s) are operable, or likewise satisfy these requirements. Unless both conditions (1) and (2) are satisfied, the unit shall be placed in at least Hot Standby within 6 hours, and in at least Cold Shutdown within the following 30 hours. This definition is not applicable in Cold Shutdown or Refueling. This provision describes what additional conditions must be satisfied to permit operation to continue consistent with the specifications for power sources, when an offsite or onsite power source is not operable. It specifically prohibits operation when one division is inoperable because its offsite or diesel power source is inoperable and a system, subsystem, train, component, or device in another division is inoperable for another reason. This provision permits the requirements associated with individual systems, subsystems, trains, components, or devices to be consistent with the requirements of the associated electrical power source. It allows operation to be governed by the time limit of the requirements associated with the Limiting Condition For Operation for the offsite or diesel power source, not the individual requirements for each system, subsystem, train, component, or device that is determined to be inoperable solely because of the inoperability of its offsite or diesel power source.

D. Deleted

E. Operable - Operability - A system, subsystem, train, component, or device shall be operable or have operability when it is capable of performing its specified function(s). Implicit in this definition shall be the assumption that all necessary attendant instrumentation, controls, normal and emergency electrical power sources, cooling or seal water, lubrication or other auxiliary equipment that are required for the system, subsystem, train, component, or device to perform its function(s) are also capable of performing their related support function(s).

F. Operating - Operating means that a system or component is performing its intended functions in its required manner.

G. Immediate - Immediate means that the required action will be initiated as soon as practicable considering the safe operation of the unit and the importance of the required action.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-260

BROWNS FERRY NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 131
License No. DPR-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated February 6, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-52 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 131, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance and shall be implemented within 60 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John A. Zwolinski, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 20, 1987

ATTACHMENT TO LICENSE AMENDMENT NO. 131

FACILITY OPERATING LICENSE NO. DPR-52

DOCKET NO. 50-260

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain vertical lines indicating the areas of change. Overleaf page provided to maintain document completeness.*

REMOVE

1.0-1
1.0-2

INSERT

1.0-1*
1.0-2

1.0 DEFINITIONS

The succeeding frequently used terms are explicitly defined so that a uniform interpretation of the specifications may be achieved.

- A. Safety Limit - The safety limits are limits below which the reasonable maintenance of the cladding and primary systems are assured. Exceeding such a limit requires unit shutdown and review by the Atomic Energy Commission before resumption of unit operation. Operation beyond such a limit may not in itself result in serious consequences but it indicates an operational deficiency subject to regulatory review.
- B. Limiting Safety System Settings (LSSS) - The limiting safety system settings are settings on instrumentation which initiate the automatic protective action at a level such that the safety limits will not be exceeded. The region between the safety limit and these settings represents margin with normal operation lying below these settings. The margin has been established so that with proper operation of the instrumentation the safety limits will never be exceeded.
- C. Limiting Conditions for Operation (LCO) - The limiting conditions for operation specify the minimum acceptable levels of system performance necessary to assure safe startup and operation of the facility. When these conditions are met, the plant can be operated safely and abnormal situations can be safely controlled.
 - 1. In the event a Limiting Condition for Operation and/or associated requirements cannot be satisfied because of circumstances in excess of those addressed in the specification, the unit shall be placed in at least Hot Standby within 6 hours and in Cold Shutdown within the following 30 hours unless corrective measures are completed that permit operation under the permissible discovery or until the reactor is placed in an operational condition in which the specification is not applicable. Exceptions to these requirements shall be stated in the individual specifications. This provides actions to be taken for circumstances not directly provided for in the specifications and where occurrence would violate the intent of the specification. For example, if a specification calls for two systems (or subsystems) to be operable and provides for explicit requirements if one system (or subsystem) is inoperable, then if both systems (or subsystems) are inoperable the unit is to be in at least Hot Standby in 6 hours and in Cold Shutdown within the following 30 hours if the inoperable condition is not corrected.

1.0 DEFINITIONS (Cont'd)

2. When a system, subsystem, train, component, or device is determined to be inoperable solely because its onsite power source is inoperable, or solely because its offsite power source is inoperable, it may be considered operable for the purpose of satisfying the requirements of its applicable Limiting Condition For Operation, provided:

(1) its corresponding offsite or diesel power source is operable; and (2) all of its redundant system(s), subsystem(s), train(s), component(s), and device(s) are operable, or likewise satisfy these requirements. Unless both conditions (1) and (2) are satisfied, the unit shall be placed in at least Hot Standby within 6 hours, and in at least Cold Shutdown within the following 30 hours. This definition is not applicable in Cold Shutdown or Refueling. This provision describes what additional conditions must be satisfied to permit operation to continue consistent with the specifications for power sources, when an offsite or onsite power source is not operable. It specifically prohibits operation when one division is inoperable because its offsite or diesel power source is inoperable and a system, subsystem, train, component, or device in another division is inoperable for another reason. This provision permits the requirements associated with individual systems, subsystems, trains, components, or devices to be consistent with the requirements of the associated electrical power source. It allows operation to be governed by the time limit of the requirements associated with the Limiting Condition For Operation for the offsite or diesel power source, not the individual requirements for each system, subsystem, train, component, or device that is determined to be inoperable solely because of the inoperability of its offsite or diesel power source.

- D. Deleted
- E. Operable - Operability - A system, subsystem, train, component, or device shall be operable or have operability when it is capable of performing its specified function(s). Implicit in this definition shall be the assumption that all necessary attendant instrumentation, controls, normal and emergency electrical power sources, cooling or seal water, lubrication or other auxiliary equipment that are required for the system, subsystem, train, component, or device to perform its function(s) are also capable of performing their related support function(s).
- F. Operating - Operating means that a system or component is performing its intended functions in its required manner.
- G. Immediate - Immediate means that the required action will be initiated as soon as practicable considering the safe operation of the unit and the importance of the required action.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-296

BROWNS FERRY NUCLEAR PLANT, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 106
License No. DPR-68


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated February 6, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-68 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 106, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance and shall be implemented within 60 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John A. Zwolinski, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 20, 1987

ATTACHMENT TO LICENSE AMENDMENT NO.106

FACILITY OPERATING LICENSE NO. DPR-68

DOCKET NO. 50-296

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain vertical lines indicating the areas of change. Overleaf page provided to maintain document completeness.*

REMOVE

1.0-1
1.0-2

INSERT

1.0-1*
1.0-2

1.0 DEFINITIONS

The succeeding frequently used terms are explicitly defined so that a uniform interpretation of the specifications may be achieved.

- A. Safety Limit - The safety limits are limits below which the reasonable maintenance of the cladding and primary systems are assured. Exceeding such a limit requires unit shutdown and review by the Nuclear Regulatory Commission before resumption of unit operation. Operation beyond such a limit may not in itself result in serious consequences but it indicates an operational deficiency subject to regulatory review.

- B. Limiting Safety System Setting (LSSS) - The limiting safety system settings are settings on instrumentation which initiate the automatic protective action at a level such that the safety limits will not be exceeded. The region between the safety limit and these settings represents margin with normal operation lying below these settings. The margin has been established so that with proper operation of the instrumentation the safety limits will never be exceeded.

- C. Limiting Conditions for Operation (LCO) - The limiting conditions for operation specify the minimum acceptable levels of system performance necessary to assure safe startup and operation of the facility. When these conditions are met, the plant can be operated safely and abnormal situations can be safely controlled.
 - 1. In the event a Limiting Condition and/or associated requirements cannot be satisfied because of circumstances in excess of those addressed in the specification, the unit shall be placed in at least Hot Standby within 6 hours and in Cold Shutdown within the following 30 hours unless corrective measures are completed that permit operation under the permissible discovery or until the reactor is placed in an operational condition in which the specification is not applicable. Exceptions to these requirements shall be stated in the individual specifications. This provides action to be taken for circumstances not directly provided for in the specifications and where occurrence would violate the intent of the specification. For example, if a specification calls for two systems (or subsystems) to be operable and provides for explicit requirements if one system (or subsystem) is inoperable, then if both systems (or subsystems) are inoperable the unit is to be in at least Hot Standby in 6 hours and in Cold Shutdown within the following 30 hours if the inoperable condition is not corrected.

1.0 DEFINITIONS (Cont'd)

2. When a system, subsystem, train, component, or device is determined to be inoperable solely because its onsite power source is inoperable, or solely because its offsite power source is inoperable, it may be considered operable for the purpose of satisfying the requirements of its applicable Limiting Condition For Operation, provided:

(1) its corresponding offsite or diesel power source is operable; and (2) all of its redundant system(s), subsystem(s), train(s), component(s), and device(s) are operable, or likewise satisfy these requirements. Unless both conditions (1) and (2) are satisfied, the unit shall be placed in at least Hot Standby within 6 hours, and in at least Cold Shutdown within the following 30 hours. This definition is not applicable in Cold Shutdown or Refueling. This provision describes what additional conditions must be satisfied to permit operation to continue consistent with the specifications for power sources, when an offsite or onsite power source is not operable. It specifically prohibits operation when one division is inoperable because its offsite or diesel power source is inoperable and a system, subsystem, train, component, or device in another division is inoperable for another reason. This provision permits the requirements associated with individual systems, subsystems, trains, components, or devices to be consistent with the requirements of the associated electrical power source. It allows operation to be governed by the time limit of the requirements associated with the Limiting Condition For Operation for the offsite or diesel power source, not the individual requirements for each system, subsystem, train, component, or device that is determined to be inoperable solely because of the inoperability of its offsite or diesel power source.

D. Deleted

- E. Operable - Operability - A system, subsystem, train, component, or device shall be operable or have operability when it is capable of performing its specified function(s). Implicit in this definition shall be the assumption that all necessary attendant instrumentation, controls, normal and emergency electrical power sources, cooling or seal water, lubrication or other auxiliary equipment that are required for the system, subsystem, train, component, or device to perform its function(s) are also capable of performing their related support function(s).
- F. Operating - Operating means that a system or component is performing its intended functions in its required manner.
- G. Immediate - Immediate means that the required action will be initiated as soon as practicable considering the safe operation of the unit and the importance of the required action.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF SPECIAL PROJECTS

SUPPORTING AMENDMENT NO. 135 TO FACILITY OPERATING LICENSE NO. DPR-33

AMENDMENT NO. 131 TO FACILITY OPERATING LICENSE NO. DPR-52

AMENDMENT NO. 106 TO FACILITY OPERATING LICENSE NO. DPR-68

TENNESSEE VALLEY AUTHORITY

BROWNS FERRY NUCLEAR PLANT, UNITS 1, 2 AND 3

DOCKETS NOS. 50-259, 50-260 AND 50-296

1.0 INTRODUCTION

By letter dated February 6, 1987, Tennessee Valley Authority (TVA, the licensee) requested amendments to definition 1.0.C.2 of the Technical Specifications (TS) for Browns Ferry Nuclear Plant (BFNP). The proposed TS change will clarify the applicability of definition 1.0.C.2 so that the definition will not be erroneously applied while in Cold Shutdown condition or Refuel mode.

Definition 1.0.C.2 for units 1, 2 and 3 is changed by adding the word "definition" and by deleting the phrase "if the unit is already" so that the sentence beginning on the thirteenth line of BFNP definition 1.0.C.2 reads, "This definition is not applicable in Cold Shutdown or Refueling."

2.0 EVALUATION

By letter dated April 10, 1980 the NRC sent letters to all Power Reactor Licensees, requesting that the provisions of certain model TS be added to each licensee's TS. Among these was model Boiling Water Reactor Limiting Condition for Operation (LCO) 3.0.5. TS Section 3.0.5 deals with the operability of systems when normal or emergency power supplies are lost. Model TS 3.0.5 contains the sentence, "This Specification is not applicable in OPERATIONAL CONDITIONS 4 or 5."

Two minor mistakes were made in adopting this sentence of model LCO 3.0.5 to be BFNP technical specification definition 1.0.C.2. These mistakes resulted in confusion about when definition 1.0.C.2 may be applied.

First, the word "specification" in the model LCO should have been changed to "definition" to adapt from an LCO to a definition format. Instead, the word "specification" was deleted without being replaced by the word "definition."

Second, the phrase "if the unit is already" was incorporated into the TS from an early GE-STs (BWR/4) LCO 3.0.5. In a later edition GE-STs (BWR/4), LCO 3.0.5 was deleted and replaced by a combination of a revised definition of Operable-Operability and a new action (c) in LCO 3.8.11.

This change to GE-STS (BWR/4) made the old concept represented by the early GE-STS (BWR/4) LCO 3.0.5 only applicable in Operational Conditions 1, 2 and 3 (Power Operation, Startup, and Hot Shutdown). The sentence in model LCO 3.0.5 reflected this restriction of applicability.

The changes to the TS will clarify the applicability of the definition and since the revised wording will be more restrictive than the current definition, the staff concludes that the margin of safety will not be reduced, and therefore, the proposed changes are acceptable.

3.0 ENVIRONMENTAL CONSIDERATIONS

The amendments change a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration and there has been no public comment on such finding. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement nor environmental assessment need be prepared in connection with the issuance of the amendments.

4.0 CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: John Stang

Dated: August 20, 1987



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

August 20, 1987

MEMORANDUM FOR: Sholly Coordinator

FROM: John A. Zwolinski, Assistant Director
for Projects
TVA Projects Division, OSP

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE - NOTICE
OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

Tennessee Valley Authority, Dockets Nos. 50-259, 50-260 and 50-296, Browns
Ferry Nuclear Plant, Units 1, 2 and 3, Limestone County, Alabama

Date of application for amendments: February 6, 1987 (TS 225)

Brief description of amendments: The amendments clarify the applicability of definition 1.0.C.2 so that the definition will not be erroneously applied while in Cold Shutdown condition or Refuel mode. Definition 1.0.C.2 for Units 1, 2 and 3 is changed by adding the word "definition" and by deleting the phrase "if the unit is already" so that the sentence beginning on the thirteenth line of the Browns Ferry Technical Specifications definition 1.0.C.2 reads, "This definition is not applicable in Cold Shutdown or Refueling."

Date of issuance: August 20, 1987

Effective date: August 20, 1987, and shall be implemented within 60 days.

Amendments Nos.: 134⁵, 131, 106

Facility Operating Licenses Nos. DPR-33, DPR-52 and DPR-68: Amendments revised the Technical Specifications.

Date of initial notice in FEDERAL REGISTER: April 22, 1987 (52 FR 13350)

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated

No significant hazards consideration comments received: No

8708270392 870820
PDR ADDCK 05000259
P PDR

August 20, 1987

Local Public Document Room location: Athens Public Library, South Street,
Athens, Alabama 35611.


Original signed by:

John A. Zwolinski, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

DISTRIBUTION:

Docket File
Projects Reading
CJamerson
GGears
JStang
JZwolinski
OGC-BETH

OSP:DTVA
CJamerson
6/19/87



DTVA:BF
GGears/pn
6/23/87

SE for
DTVA:BF
JStang
6/23/87

OGC-BETH
Bordenick
7/11/87

OSP:DTVA
JAZwolinski
7/20/87

