

**Dave Morey**  
Vice President  
Farley Project

**Southern Nuclear  
Operating Company, Inc.**  
Post Office Box 1295  
Birmingham, Alabama 35201  
Tel 205.992.5131



October 22, 2001

Docket No. 50-348

NEL-01-0256

U. S. Nuclear Regulatory Commission  
ATTN.: Document Control Desk  
Washington, DC 20555-0001

**Joseph M. Farley Nuclear Plant – Unit 1  
Steam Generator Plugging 15-Day Report**

Ladies and Gentlemen:

In accordance with Technical Specification reporting requirement 5.6.10.a, the number of tubes plugged in each Steam Generator (S/G) shall be reported to the NRC within 15 days of the completion of the inspection or plugging effort. The inspection effort was completed on October 18, 2001. This letter provides the plugging results of the S/G inservice inspection performed during the Farley Unit 1 17<sup>th</sup> Refueling Outage.

Tube Category	S/G A	S/G B	S/G C
Tubes Removed from Service by Plugging	0	0	0

There are no NRC commitments associated with this letter.

If there are any questions, please advise.

Respectfully submitted,

A handwritten signature in cursive script that reads "Dave Morey".

Dave Morey

WAS/kaw:sgplugging.doc

A001

Page 2

U. S. Nuclear Regulatory Commission

cc: Southern Nuclear Operating Company  
Mr. L. M. Stinson, General Manager – Farley

U. S. Nuclear Regulatory Commission, Washington, D. C.  
Mr. F. Rinaldi, Licensing Project Manager – Farley

U. S. Nuclear Regulatory Commission, Region II  
Mr. L. A. Reyes, Regional Administrator  
Mr. T. P. Johnson, Senior Resident Inspector – Farley