

July 15, 1980

Docket Nos. 50-259  
50-260  
and 50-296

Distribution:

- ✓ Docket OELD
- NRC PDR OI&E (5)
- Local PDR BJones (12)
- ORB Reading BScharf (10)
- NRR Reading JWetmore
- DEisnehut ACRS (16)
- RPurple OPA (Clare Miles)
- TNovak RDiggs
- RTedesco HDenton
- GLainas JHeltemes, AEOD
- JDishinski NSIC
- SNorris TERA
- RJClark Chairman, ASLAB

Mr. Hugh G. Parris  
Manager of Power  
Tennessee Valley Authority  
500A Chestnut Street Tower II  
Chattanooga, Tennessee 37401

Dear Mr. Parris:

The Commission has issued the enclosed Amendment Nos. 61, 56, and 33 to Facility License Nos. DPR-33, DPR-52, and DPR-68 for the Browns Ferry Nuclear Plant, Unit Nos. 1, 2, and 3. These amendments are in response to your letter of July 14, 1980.

These amendments change the Technical Specifications pertaining to thermal discharge limits. The limitations on both maximum plant-induced temperature rise and maximum water temperature measured downstream of the plant discharge in Wheeler Reservoir are revised to be consistent with the provisions of NPDES Permit No. AL0022080, issued by the Environmental Protection Agency (EPA).

In the Final Environmental Statement - Browns Ferry Nuclear Plant Units 1, 2, and 3, the NRC staff evaluated the environmental impact for temperature criteria of 10°F thermal rise above ambient water temperature with a maximum water temperature not to exceed 93°F after reasonable mixing. These limitations were applicable for initial operation of the plants. These limitations, however, were less restrictive than those imposed by the EPA and the Technical Specifications were written to reflect the more restrictive EPA limits. Subsequently, the NRC staff was informed that EPA will relax the subject limits. You requested the Technical Specifications be changed to incorporate by reference the EPA limitations, providing these limitations were consistent with the staff's Final Environmental Statement.

We have evaluated the potential for environmental impact of plant operation in accordance with the enclosed amendments. The amendments are administrative in nature since changes effected by these amendments have been previously evaluated and found acceptable in the Final Environmental Statement. This results in no impact over those conclusions in the FES issued in connection with the Operating License. Thus, this action results in no impact not previously evaluated. We have determined that the amendments do not authorize a change in effluent types or total amounts nor an increase in

8007240225

OFFICE ▶	.....	.....	.....	.....	.....	.....
SURNAME ▶	.....	.....	.....	.....	.....	.....
DATE ▶	.....	.....	.....	.....	.....	.....

Letter to Hugh G. Parris

- 2 -

power level, and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendments involve an action which is insignificant from the standpoint of environmental impact and pursuant to 10 CFR §51.5(d)(4) that an environmental impact statement, negative declaration or environmental impact appraisal need not be prepared in connection with the issuance of these amendments.

Since the amendments apply only to thermal discharge limits, they do not involve significant new safety information of a type not considered by a previous Commission safety review of the facility. They do not involve a significant increase in the probability or consequences of an accident, do not involve a significant decrease in a safety margin, and therefore, do not involve a significant hazards consideration. We have also concluded that there is reasonable assurance that the health and safety of the public will not be endangered by this action.

A copy of the Notice of Issuance is also enclosed.

Sincerely,

Thomas A. Ippolito, Chief  
Operating Reactors Branch #2  
Division of Licensing

Enclosures:

- 1. Amendment No. 61 to DPR-33
- 2. Amendment No. 56 to DPR-52
- 3. Amendment No. 33 to DPR-68
- 4. Notice

cc w/enclosures:

See next page

OFFICE ▶	ORB #2	ORB #2	AD:DL	OELD	ORB #2
SURNAME ▶	SNorris	*RJClark:kk	*TMNovak	*Cutchin	TAIppolito
DATE ▶	7/15/80	7/15/80	7/15/80	7/15/80	7/15/80

Distribution:

Docket	OELD
NRC PDR	OI&E (5)
Local PDR	BJones (12)
ORB Reading	BScharf (10)
NRR Reading	JWetmore
DEisenhut	ACRS (16)
RPurple	OPA (Clare Miles)
TNovak	RDiggs
RTedesco	HDenton
GLainas	JHeltemes, AEOD
JOlshinski	NSIC
SNorris	TERA
RJClark	Chairman, ASLAB

Docket Nos. 50-259  
50-260  
and 50-296

Mr. Hugh G. Parris  
Manager of Power  
Tennessee Valley Authority  
500A Chestnut Street Tower II  
Chattanooga, Tennessee 37401

Dear Mr. Parris:

The Commission has issued the enclosed Amendment Nos.                    and  
to Facility License Nos. DPR-33, DPR-52, and DPR-68 for the Browns Ferry  
Nuclear Plant, Unit Nos. 1, 2, and 3. These amendments are in response  
to your letter of July 14, 1980.

These amendments change the Technical Specifications pertaining to  
thermal discharge limits. The limitations on both maximum plant-induced  
temperature rise and maximum water temperature measured downstream of the  
plant discharge in Wheeler Reservoir are revised to be consistent with  
the provisions of NPDES Permit No. AL0022080, issued by the Environmental  
Protection Agency.(EPA).

In the Final Environmental Statement - Browns Ferry Nuclear Plant Units 1,  
2, and 3, the NRC staff evaluated the environmental impact for temperature  
criteria of 10°F thermal rise above ambient water temperature with a  
maximum water temperature not to exceed 93°F after reasonable mixing. These  
limitations were applicable for initial operation of the plants. These  
limitations, however, were less restrictive than those imposed by the EPA  
and the Technical Specifications were written to reflect the more restrictive  
EPA limits. Subsequently, the NRC staff was informed that EPA will some-  
what relax the subject limits. You requested the Technical Specifications  
be changed to incorporate by reference the EPA limitations, providing these  
limitations were consistent with the staff's Final Environmental Statement.

We have evaluated the potential for environmental impact of plant operation  
in accordance with the enclosed amendment. The amendment is administrative  
in nature since changes effected by this amendment have been previously  
evaluated and found acceptable in the Final Environmental Statement. We  
have determined that the amendment does not authorize a change in effluent  
types or total amounts nor an increase in power level, and will not result  
in any significant environmental impact. Having made this determination,  
we have further concluded that the amendment involves an action which is  
insignificant from the standpoint of environmental impact and pursuant to

OFFICE ▶	.....	.....	.....	.....	.....	.....
SURNAME ▶	.....	.....	.....	.....	.....	.....
DATE ▶	.....	.....	.....	.....	.....	.....

Letter to Hugh G. Parris

- 2 -

10 CFR §51.5(d)(4) that an environmental impact statement, negative declaration or environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

Since the amendment applies only to thermal discharge limits, it does not involve significant new safety information of a type not considered by a previous Commission safety review of the facility. It does not involve a significant increase in the probability or consequences of an accident, does not involve a significant decrease in a safety margin, and therefore, does not involve a significant hazards consideration. We have also concluded that there is reasonable assurance that the health and safety of the public will not be endangered by this action.

A copy of the Notice of Issuance is also enclosed.

Sincerely,

Thomas A. Ippolito, Chief  
Operating Reactors Branch #2  
Division of Licensing

Enclosures:

- 1. Amendment No. to DPR-33
- 2. Amendment No. to DPR-52
- 3. Amendment No. to DPR-68
- 4. Notice

cc w/enclosures:  
See next page

*No. High of factors  
to favor of TS  
for amendment*

*7/15/80*

*7/15/80*

*7/15/80*

*7/15/80*

OFFICE	ORB #2	ORB #2	AD:DL	OELD	ORB #2
SURNAME	SNorris	RClark:kk	TNovak	<i>WICHIN</i>	TAIppolito
DATE	1 / 80	7/15/80	7/15/80	7/15/80	7/15/80



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20545

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-259

BROWNS FERRY NUCLEAR PLANT, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 61  
License No. DPR-33

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Tennessee Valley Authority (the licensee) dated July 14, 1980, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility License No. DPR-33 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 61, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Thomas A. Ippolito, Chief  
Operating Reactors Branch #2  
Division of Operating Reactors

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: July 15, 1980

ATTACHMENT TO LICENSE AMENDMENT NO. 61

FACILITY OPERATING LICENSE NO. DPR-33

DOCKET NO. 50-259

Revise Appendix B as follows:

1. Remove the following pages and replace with identically numbered pages:

1/2

2. The underlined pages are those being changed; marginal lines on these pages indicate the revised area. The overleaf pages are provided for convenience.

## 1.0 DEFINITIONS

The following terms are defined for uniform interpretation of these specifications.

### Administrative Terminology

Environmental limiting condition for operation--any limiting condition for plant operation as stated in Section 2 of the Browns Ferry Nuclear Plant Environmental Technical Specifications.

Unusual event with the potential for a significant environmental impact--an event that results in noncompliance with an environmental technical specification, or an event that results in uncontrolled or unplanned releases of chemical, radioactive, thermal, or other discharges from the Browns Ferry Nuclear Plant in excess of applicable Federal, state, and local regulations.

### Thermal Properties

Thermal limits--limits defined for temperatures, spatial changes in temperature, and temporal changes in temperature within Wheeler Reservoir that are attributable to thermal discharges from Browns Ferry Nuclear Plant.

Intake temperature--the average temperature at a given time within the intake system at a point beyond the intake pumps.

Discharge temperature--the average temperature at a given time in the cooling water return channel or at the condenser outlet butterfly valves.

Delta T ( $\Delta T$ )--the difference in temperatures of the river at the control monitors attributable to thermal discharges from Browns Ferry Nuclear Plant.

### Instrumentation Properties

Accuracy--a measure of the difference between the true and measured values of a given parameter, hence a measure of error.

Minimum detectable level--that level below which a specific detector, instrument, or analysis is unable to detect the presence of a given constituent.

Sensitivity--the minimum change in the variable detected by a given sensor.

## 2.0 LIMITING CONDITIONS FOR OPERATION

### 2.1 THERMAL DISCHARGE LIMITS

#### Objective

The purpose of this specification is to limit the thermal stress on Aquatic life in Wheeler Reservoir by operating Browns Ferry Nuclear Plant so as to meet the applicable water quality temperature standards of the State of Alabama.

#### Specification

The maximum plant-induced temperature rise and the maximum water temperature measured downstream of the plant discharge in Wheeler Reservoir caused by the discharge of condenser cooling water shall not exceed the more restrictive of the applicable maximum limits as specified by NPDES Permit No. AL0022080, which has been issued by the Environmental Protection Agency, or a 10°F thermal use above ambient water temperature with a maximum temperature not to exceed 93°F after reasonable mixing.\*

If these limiting conditions are predicted, the plant operator shall initiate control measures. The control measures shall be (1) to reduce the waste heat discharged to the reservoir and/or (2) to request modifications in the releases from TVA's Guntersville and/or Wheeler Dams to increase the streamflow by the Browns Ferry plant.

\*The NRC Final Environmental Statement has previously evaluated temperature criteria of 10°F thermal rise above ambient water temperature with a maximum temperature not to exceed 93°F after reasonable mixing. The NRC cost benefit analysis regarding reservoir temperature must be reevaluated before these limits are exceeded by TVA.

Reservoir water temperatures used to help show compliance with applicable standards will be measured at the one-meter and two-meter depths and averaged to give a temperature applicable to the five-foot depth, which is the point of application of the current Alabama temperature standards. Three thermal monitors spaced across the reservoir in the vicinity of river mile 293.5 shall be used to measure downstream mixed water temperatures. The system is designed so that the downstream monitors serve as backup for one another. The accuracy of the monitoring equipment and the sensitivity of the thermistor sensors are designed to be  $\pm 0.3F$  and  $0.01F$ , respectively. The locations of temperature monitors are displayed in Figure 2.1-1.

The plant-induced temperature rise shall be computed using a computer model for the mixing of the plant discharge. This model requires measured plant data as well as downstream reservoir temperatures as input and will be updated as necessary to reflect current understanding of discharge mixing predictions.

All necessary plant and reservoir data is transmitted to the Browns Ferry meteorological station. The meteorological station will receive the data and record the readings once hourly. All data are automatically recorded and maintained for record keeping purposes. Calculations necessary to compute parameters for showing compliance with applicable thermal standards will automatically be completed by a computer situated in the meteorological station. All measured and computed data which are used to help prevent exceeding the limiting conditions will be transmitted to the control room and will be visually displayed for monitoring purposes.

In the event the system described is out of service, an alternate method will be employed three times a day (once each shift) to measure the temperature rise and the maximum river temperature below the plant. When such a method would result in an imminent and substantial endangerment to the safety of personnel, this paragraph shall not apply.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-260

BROWNS FERRY NUCLEAR PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 56  
License No. DPR-52


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Tennessee Valley Authority (the licensee) dated July 14, 1980, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility License No. DPR-52 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 56, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Thomas A. Ippolito, Chief  
Operating Reactors Branch #2  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: July 15, 1980

ATTACHMENT TO LICENSE AMENDMENT NO. 56

FACILITY OPERATING LICENSE NO. DPR-52

DOCKET NO. 50-260

Revise Appendix B as follows:

1. Remove the following pages and replace with identically numbered pages:

1/2

2. The underlined pages are those being changed; marginal lines on these pages indicate the revised area. The overleaf pages are provided for convenience.

## 1.0 DEFINITIONS

The following terms are defined for uniform interpretation of these specifications.

### Administrative Terminology

Environmental limiting condition for operation--any limiting condition for plant operation as stated in Section 2 of the Browns Ferry Nuclear Plant Environmental Technical Specifications.

Unusual event with the potential for a significant environmental impact--an event that results in noncompliance with an environmental technical specification, or an event that results in uncontrolled or unplanned releases of chemical, radioactive, thermal, or other discharges from the Browns Ferry Nuclear Plant in excess of applicable Federal, state, and local regulations.

### Thermal Properties

Thermal limits--limits defined for temperatures, spatial changes in temperature, and temporal changes in temperature within Wheeler Reservoir that are attributable to thermal discharges from Browns Ferry Nuclear Plant.

Intake temperature--the average temperature at a given time within the intake system at a point beyond the intake pumps.

Discharge temperature--the average temperature at a given time in the cooling water return channel or at the condenser outlet butterfly valves.

Delta T ( $\Delta T$ )--the difference in temperatures of the river at the control monitors attributable to thermal discharges from Browns Ferry Nuclear Plant.

### Instrumentation Properties

Accuracy--a measure of the difference between the true and measured values of a given parameter, hence a measure of error.

Minimum detectable level--that level below which a specific detector, instrument, or analysis is unable to detect the presence of a given constituent.

Sensitivity--the minimum change in the variable detected by a given sensor.

Monitoring Requirement

2.0 LIMITING CONDITIONS FOR OPERATION

2.1 THERMAL DISCHARGE LIMITS

Objective

The purpose of this specification is to limit the thermal stress on Aquatic life in Wheeler Reservoir by operating Browns Ferry Nuclear Plant so as to meet the applicable water quality temperature standards of the State of Alabama.

Specification

The maximum plant-induced temperature rise and the maximum water temperature measured downstream of the plant discharge in Wheeler Reservoir caused by the discharge of condenser cooling water shall not exceed the more restrictive of the applicable maximum limits as specified by NPDES Permit No. ALO022080, which has been issued by the Environmental Protection Agency, or a 10°F thermal use above ambient water temperature with a maximum temperature not to exceed 93°F after reasonable mixing.\*

If these limiting conditions are predicted, the plant operator shall initiate control measures. The control measures shall be (1) to reduce the waste heat discharged to the reservoir and/or (2) to request modifications in the releases from TVA's Guntersville and/or Wheeler Dams to increase the streamflow by the Browns Ferry plant.

\*The NRC Final Environmental Statement has previously evaluated temperature criteria of 10°F thermal rise above ambient water temperature with a maximum temperature not to exceed 93°F after reasonable mixing. The NRC cost benefit analysis regarding reservoir temperature must be reevaluated before these limits are exceeded by TVA.

Reservoir water temperatures used to help show compliance with applicable standards will be measured at the one-meter and two-meter depths and averaged to give a temperature applicable to the five-foot depth, which is the point of application of the current Alabama temperature standards. Three thermal monitors spaced across the reservoir in the vicinity of river mile 293.5 shall be used to measure downstream mixed water temperatures. The system is designed so that the downstream monitors serve as backup for one another. The accuracy of the monitoring equipment and the sensitivity of the thermistor sensors are designed to be  $\pm 0.3F$  and  $0.01F$ , respectively. The locations of temperature monitors are displayed in Figure 2.1-1.

The plant-induced temperature rise shall be computed using a computer model for the mixing of the plant discharge. This model requires measured plant data as well as downstream reservoir temperatures as input and will be updated as necessary to reflect current understanding of discharge mixing predictions.

All necessary plant and reservoir data is transmitted to the Browns Ferry meteorological station. The meteorological station will receive the data and record the readings once hourly. All data are automatically recorded and maintained for record keeping purposes. Calculations necessary to compute parameters for showing compliance with applicable thermal standards will automatically be completed by a computer situated in the meteorological station. All measured and computed data which are used to help prevent exceeding the limiting conditions will be transmitted to the control room and will be visually displayed for monitoring purposes.

In the event the system described is out of service, an alternate method will be employed three times a day (once each shift) to measure the temperature rise and the maximum river temperature below the plant. When such a method would result in an imminent and substantial endangerment to the safety of personnel, this paragraph shall not apply.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-296

BROWNS FERRY NUCLEAR PLANT, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 33  
License No. DPR-68


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Tennessee Valley Authority (the licensee) dated July 14, 1980, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility License No. DPR-68 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 33, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Thomas A. Ippolito, Chief  
Operating Reactors Branch #2  
Division of Operating Reactors

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: July 15, 1980

Monitoring Requirement

2.0 LIMITING CONDITIONS FOR OPERATION

2.1 THERMAL DISCHARGE LIMITS

Objective

The purpose of this specification is to limit the thermal stress on Aquatic life in Wheeler Reservoir by operating Browns Ferry Nuclear Plant so as to meet the applicable water quality temperature standards of the State of Alabama.

Specification

The maximum plant-induced temperature rise and the maximum water temperature measured downstream of the plant discharge in Wheeler Reservoir caused by the discharge of condenser cooling water shall not exceed the more restrictive of the applicable maximum limits as specified by NPDES Permit No. AL0022080, which has been issued by the Environmental Protection Agency, or a 10°F thermal use above ambient water temperature with a maximum temperature not to exceed 93°F after reasonable mixing.\*

If these limiting conditions are predicted, the plant operator shall initiate control measures. The control measures shall be (1) to reduce the waste heat discharged to the reservoir and/or (2) to request modifications in the releases from TVA's Guntersville and/or Wheeler Dams to increase the streamflow by the Browns Ferry plant.

\*The NRC Final Environmental Statement has previously evaluated temperature criteria of 10°F thermal rise above ambient water temperature with a maximum temperature not to exceed 93°F after reasonable mixing. The NRC cost benefit analysis regarding reservoir temperature must be reevaluated before these limits are exceeded by TVA.

Amendment No. 24, 33

Reservoir water temperatures used to help show compliance with applicable standards will be measured at the one-meter and two-meter depths and averaged to give a temperature applicable to the five-foot depth, which is the point of application of the current Alabama temperature standards. Three thermal monitors spaced across the reservoir in the vicinity of river mile 293.5 shall be used to measure downstream mixed water temperatures. The system is designed so that the downstream monitors serve as backup for one another. The accuracy of the monitoring equipment and the sensitivity of the thermistor sensors are designed to be  $\pm 0.3F$  and  $0.01F$ , respectively. The locations of temperature monitors are displayed in Figure 2.1-1.

The plant-induced temperature rise shall be computed using a computer model for the mixing of the plant discharge. This model requires measured plant data as well as downstream reservoir temperatures as input and will be updated as necessary to reflect current understanding of discharge mixing predictions.

All necessary plant and reservoir data is transmitted to the Browns Ferry meteorological station. The meteorological station will receive the data and record the readings once hourly. All data are automatically recorded and maintained for record keeping purposes. Calculations necessary to compute parameters for showing compliance with applicable thermal standards will automatically be completed by a computer situated in the meteorological station. All measured and computed data which are used to help prevent exceeding the limiting conditions will be transmitted to the control room and will be visually displayed for monitoring purposes.

In the event the system described is out of service, an alternate method will be employed three times a day (once each shift) to measure the temperature rise and the maximum river temperature below the plant. When such a method would result in an imminent and substantial endangerment to the safety of personnel, this paragraph shall not apply.

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NOS. 50-259, 59-260 AND 50-296

TENNESSEE VALLEY AUTHORITY

NOTICE OF ISSUANCE OF AMENDMENTS TO FACILITY  
OPERATING LICENSES

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 61 to Facility Operating License No. DPR-33, Amendment No. 56 to Facility Operating License No. DPR-52, and Amendment No. 33 to Facility Operating License No. DPR-68 issued to Tennessee Valley Authority (the licensee), which revised Technical Specifications for operation of the Browns Ferry Nuclear Plant, Unit Nos. 1, 2, and 3, located in Limestone County, Alabama. The amendments are effective as of the date of issuance.

These amendments change the Technical Specifications pertaining to thermal discharge limits to be consistent with the more restrictive of the limitations imposed by the Environmental Protection Agency, or a 10°F thermal use above ambient water temperature with a maximum temperature not to exceed 93°F after reasonable mixing.

The application for the amendments complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendments. Prior public notice of these amendments was not required since the amendments do not involve a significant hazards consideration.


The Commission has determined that the issuance of these amendments will not result in any significant environmental impact and that pursuant to 10 CFR

§51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of these amendments.

For further details with respect to this action, see (1) the application for amendments dated July 14, 1980, (2) Amendment No. 61 to License No. DPR-33, Amendment No. 56 to License No. DPR-52, and Amendment No. 33 to License No. DPR-68, and (3) the Commission's letter to the licensee dated July 15, 1980. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C., and at the Athens Public Library, South and Forrest, Athens, Alabama, 34611. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland this 15th day of July, 1980.

FOR THE NUCLEAR REGULATORY COMMISSION



Thomas A. Ippolito, Chief  
Operating Reactors Branch #2  
Division of Licensing