



LICENSE AUTHORITY FILE COPY
UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DO NOT REMOVE

July 16, 1984

Docket Nos. 50-259/260/296

Mr. Hugh G. Parris
Manager of Power
Tennessee Valley Authority
500A Chestnut Street, Tower II
Chattanooga, Tennessee 37401

Posted
Amat. 97
to DPR-52
(See Correction
letter of 10-10-84)

Dear Mr. Parris:

The Commission has issued the enclosed Amendment Nos. 103, 97 and 71 to Facility Operating License Nos. DPR-33, DPR-52 and DPR-68 for the Browns Ferry Nuclear Plant, Units 1, 2 and 3. These amendments are in response to your applications dated November 5, 1982 (TVA BFNP TS 176-S1) and December 17, 1982.

The amendments change the Technical Specifications to correct errors in the list of isolation valves, revise the Physical Security Plan audit cycle, and eliminate Plant Operations Review Committee review of the Quality Assurance Program.

A copy of the Safety Evaluation is also enclosed.

Sincerely,

Richard J. Clark, Project Manager
Operating Reactors Branch #2
Division of Licensing

Enclosures:

1. Amendment No. 103 to
License No. DPR-33
2. Amendment No. 97 to
License No. DPR-52
3. Amendment No. 71 to
License No. DPR-68
4. Safety Evaluation

cc w/enclosures:
See next page

Mr. Hugh G. Parris
Tennessee Valley Authority
Browns Ferry Nuclear Plant, Units 1, 2 and 3

cc:

H. S. Sanger, Jr., Esquire
General Counsel
Tennessee Valley Authority
400 Commerce Avenue
E 11B 330
Knoxville, Tennessee 37902

Mr. Ron Rogers
Tennessee Valley Authority
400 Chestnut Street, Tower II
Chattanooga, Tennessee 37401

Mr. Charles R. Christopher
Chairman, Limestone County Commission
Post Office Box 188
Athens, Alabama 35611

Ira L. Myers, M. D.
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36130

Mr. H. N. Culver
249A HBD
400 Commerce Avenue
Tennessee Valley Authority
Knoxville, Tennessee 37902

James P. O'Reilly
Regional Administrator
Region II Office
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

U. S. Environmental Protection
Agency
Region IV Office
Regional Radiation Representative
345 Courtland Street, N. W.
Atlanta, Georgia 30308

Resident Inspector
U. S. Nuclear Regulatory Commission
Route 2, Box 311
Athens, Alabama 35611

Mr. Donald L. Williams, Jr.
Tennessee Valley Authority
400 West Summit Hill Drive, W10885
Knoxville, Tennessee 37902

George Jones
Tennessee Valley Authority
Post Office Box 2000
Decatur, Alabama 35602

Mr. Oliver Havens
U. S. Nuclear Regulatory Commission
Reactor Training Center
Osborne Office Center, Suite 200
Chattanooga, Tennessee 37411



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-259

BROWNS FERRY NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 103
License No. DPR-33

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The applications for amendment by Tennessee Valley Authority (the licensee) dated November 5, 1982 and December 17, 1982, comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility Operating License No. DPR-33 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 103, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 16, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 103

FACILITY OPERATING LICENSE NO. DPR-33

DOCKET NO. 50-259

Revise Appendix A as follows:

1. Remove the following pages and replace with identically numbered pages.

250

252

334

336

2. The marginal lines on these pages denote the area being changed.

TABLE 3.7.A
PRIMARY CONTAINMENT ISOLATION VALVES

Group	Valve Identification	Number of Power Operated Valves		Maximum Operating Time (sec.)	Normal Position	Action on Initiating Signal
		Inboard	Outboard			
1	Main steamline isolation valves (PCV-1-14, 26, 37, 65; 1-15, 27, 38, & 52)	4	4	3 < T < 5	0	GC
1	Main steamline drain isolation valves PCV-1-55 & 1-56	1	1	15	0	GC
1 *	Reactor Water sample line isolation valves	1	1	5	C	SC
2	RHRS shutdown cooling supply isolation valves FCV-74-48 & 47	1	1	40	C	SC
2	RHRS - LPCI to reactor FCV-74-53, 67		2	30	C	SC
2	Reactor vessel head spray isolation valves FCV-74-77, 78	1	1	30	C	SC
2	RHRS flush and drain vent to suppression chamber FCV-74-102, 103, 119, & 120		4	20	C	SC
2	Suppression Chamber Drain FCV 74-57, -58		2	15	C	SC
2	Drywell equipment drain discharge isolation valves PCV-77-15A, & 15B		2	15	0	GC
2	Drywell floor drain discharge isolation valves PCV-77-2A & 2B		2	15	0	GC

*These valves isolate only on reactor vessel low low water level (470") and main steam line high radiation of Group 1 isolations.

TABLE 3.7.A (Continued)

Group	Valve Identification	Number of Power Operated Valves		Maximum Operating Time (sec.)	Normal Position	Action on Initiating Signal
		Inboard	Outboard			
6	Suppression Chamber purge Inlet (FCV-64-19)		1	2.5	C	SC
6	Drywell/Suppression Chamber nitrogen purge Inlet (FCV-76-17)		1	5	C	SC
6	Drywell Exhaust Valve Bypass to Standby Gas Treatment System (FCV-64-31)		1	5	O	GC
6	Suppression Chamber Exhaust Valve Bypass to Standby Gas Treatment System (FCV-64-34)		1	5	O	GC
6	Drywell/Suppression Chamber Nitrogen Purge Inlet (FCV-76-24)		1	5	C	SC
6	System Suction Isolation Valves to Air Compressors "A" and "B" (FCV-32-62, 63)		2	15	O	GC
7	RCIC Steamline Drain (FCV-71-6A, 6B)		2	5	O	GC
7	RCIC Condensate Pump Drain (FCV-71-7A, 7B)		2	5	C	SC
7	HPCI Hotwell pump discharge isolation valves (FCV-73-17A, 17B)		2	5	C	SC
7	HPCI steamline drain (FCV 73-6A, -6B)		2	5	O	GC
8	TIP Guide Tubes (5)		1 per guide tube	NA	C	GC

6.0 ADMINISTRATIVE CONTROLS

- g. All reportable events.
- h. All recognized indications of an unanticipated deficiency in some aspect of design or operation of structures, systems, or components that could affect nuclear safety.
- i. Reports and meeting minutes of the PORC.

6. AUDITS

Audits of unit activities shall be performed under the cognizance of the NSRB. These audits shall encompass.

- a. The conformance of unit operation to provisions contained within the Technical Specifications and applicable license conditions at least once per 12 months.
- b. The performance, training and qualifications of the entire unit staff at least once per 12 months.
- c. The results of actions taken to correct deficiencies occurring in unit equipment, structures, systems or method of operation that affect nuclear safety at least once per 6 months.
- d. The performance of activities required by the Operational Quality Assurance Program to meet the criteria of Appendix "B", 10 CFR 50, at least once per 24 months.
- e. The Site Radiological Emergency Plan and implementing procedures at least once per 12 months.
- f. The Plant Physical Security Plan and implementing procedures at least once per 12 months.
- g. Any other area of unit operation considered appropriate by the NSRB or the Manager of Power.
- h. The Facility Fire Protection Program and implementing procedures at least once per 24 months.
- i. An independent fire protection and loss prevention program inspection and audit shall be performed annually utilizing either qualified offsite licensee personnel or an outside fire protection firm.
- j. An inspection and audit of the fire protection and loss prevention program shall be performed by an outside qualified fire consultant at intervals no greater than 3 years.

4. Duties and Responsibilities

The PORC serves in an advisory capacity to the plant superintendent and as an investigating and reporting body to the Nuclear Safety Review Board in matters related to safety in plant operations. The plant superintendent has the final responsibility in determining the matters that should be referred to the Nuclear Safety Review Board.

The responsibility of the committee will include:

- a. Review all standard and emergency operating and maintenance instructions and any proposed revisions thereto, with principal attention to provisions for safe operation.
- b. Review proposed changes to the Technical Specifications.
- c. Review proposed changes to equipment or systems having safety significance, or which may constitute "an unreviewed safety question," pursuant to 10 CFR 50.59.
- d. Investigate reported or suspected incidents involving safety questions, violations of the Technical Specifications, and violations of plant instructions pertinent to nuclear safety.
- e. Review reportable events, unusual events, operating anomalies and abnormal performance of plant equipment.
- f. Maintain a general surveillance of plant activities to identify possible safety hazards.
- g. Review plans for special fuel handling, plant maintenance, operations, and tests or experiments which may involve special safety considerations, and the results thereof, where applicable.
- h. (deleted)
- i. Review implementing procedures of the Radiological Emergency Plan and the Industrial Security Program on an annual basis.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-260

BROWNS FERRY NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 97
License No. DPR-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The applications for amendment by Tennessee Valley Authority (the licensee) dated November 5, 1982 and December 17, 1982, comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility Operating License No. DPR-52 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 97, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

[Signature]
Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 16, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 97

FACILITY OPERATING LICENSE NO. DPR-52

DOCKET NO. 50-260

Revise Appendix A as follows:

1. Remove the following pages and replace with identically numbered pages.

334

336

2. The marginal lines on these pages denote the area being changed.

- 5. All reportable events.
- b. All recognized indications of an unanticipated deficiency in some aspect of design or operation of structures, systems, or components that could affect nuclear safety.
- i. Reports and meeting minutes of the PORC.

8. AUDITS

Audits of unit activities shall be performed under the cognizance of the NSRB. These audits shall encompass.

- a. The conformance of unit operation to provisions contained within the Technical Specifications and applicable license conditions at least once per 12 months.
- b. The performance, training and qualifications of the entire unit staff at least once per 12 months.
- c. The results of actions taken to correct deficiencies occurring in unit equipment, structures, systems or method of operation that affect nuclear safety at least once per 6 months.
- d. The performance of activities required by the Operational Quality Assurance Program to meet the criteria of Appendix "B", 10 CFR 50, at least once per 24 months.
- e. The Site Radiological Emergency Plan and implementing procedures at least once per 12 months.
- f. The Plant Physical Security Plan and implementing procedures at least once per 12 months.
- g. Any other area of unit operation considered appropriate by the NSRB or the Manager of Power.
- h. The Facility Fire Protection Program and implementing procedures at least once per 24 months.
- i. An independent fire protection and loss prevention program inspection and audit shall be performed annually utilizing either qualified offsite licensee personnel or an outside fire protection firm.
- j. An inspection and audit of the fire protection and loss prevention program shall be performed by an outside qualified fire consultant at intervals no greater than 3 years.

4. Duties and Responsibilities

The PORC serves in an advisory capacity to the plant superintendent and as an investigating and reporting body to the Nuclear Safety Review Board in matters related to safety in plant operations. The plant superintendent has the final responsibility in determining the matters that should be referred to the Nuclear Safety Review Board.

The responsibility of the committee will include:

- a. Review all standard and emergency operating and maintenance instructions and any proposed revisions thereto, with principal attention to provisions for safe operation.
- b. Review proposed changes to the Technical Specifications.
- c. Review proposed changes to equipment or systems having safety significance, or which may constitute "an unreviewed safety question," pursuant to 10 CFR 50.59.
- d. Investigate reported or suspected incidents involving safety questions, violations of the Technical Specifications, and violations of plant instructions pertinent to nuclear safety.
- e. Review reportable events, unusual events, operating anomalies and abnormal performance of plant equipment.
- f. Maintain a general surveillance of plant activities to identify possible safety hazards.
- g. Review plans for special fuel handling, plant maintenance, operations, and tests or experiments which may involve special safety considerations, and the results thereof, where applicable.
- h. (deleted)
- i. Review implementing procedures of the Radiological Emergency Plan and the Industrial Security Program on an annual basis.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-296

BROWNS FERRY NUCLEAR PLANT, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 71
License No. DPR-68

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The applications for amendment by Tennessee Valley Authority (the licensee) dated November 5, 1982 and December 17, 1982, comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility Operating License No. DPR-68 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 71, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

[Handwritten signature]
Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 16, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 71

FACILITY OPERATING LICENSE NO. DPR-68

DOCKET NO. 50-296

Revise Appendix A as follows:

1. Remove the following pages and replace with identically numbered pages.

262

264

364

366

2. The marginal lines on these pages denote the area being changed.

TABLE 3.7.A
PRIMARY CONTAINMENT ISOLATION VALVES

Group	Valve Identification	Number of Power Operated Valves		Maximum Operating Time (sec.)	Normal Position	Action on Initiating Signal
		Inboard	Outboard			
1	Main steamline isolation valves (PCV-1-14, 26, 37, & 51; 1-15, 27, 38 & 52)	4	4	3 < T < 5	0	GC
1	Main steamline drain isolation valves (PCV-1-55 & 1-56)	1	1	15	0	GC
1 *	Reactor Water sample line isolation valves	1	1	5	C	SC
2	RHRS shutdown cooling supply isolation valves (PCV-74-48 & 47)	1	1	40	C	SC
2	RHRS - LPCI to reactor (PCV-74-53 & 67)		2	30	C	SC
2	Reactor vessel head spray isolation valves (PCV-74-77 & 78)	1	1	30	C	SC
2	RHRS flush and drain vent to suppression chamber (PCV-74-102, 103, 119, & 120)		4	20	C	SC
2	Suppression Chamber Drain (PCV-75-57 & 58)		2	15	C	SC
2	Drywell equipment drain discharge isolation valves (PCV-77-15A & 15B)		2	15	0	GC
2	Drywell floor drain discharge isolation valves (PCV-77-2A & 2B)		2	15	0	GC

*These valves isolate only on reactor vessel low low water level (470") and main steam line high radiation of Group 1 isolations.

LE 3.7.A (Continued)

Group	Valve Identification	Number of Power Operated Valves		Maximum Operating Time (Sec.)	Normal Position	Action on Initiating Signal
		Inboard	Outboard			
6	Suppression Chamber purge inlet (FCV-64-19)		1	2.5	C	SC
6	Drywell/Suppression Chamber nitrogen purge inlet (FCV-76-17)		1	5	C	SC
6	Drywell Exhaust Valve Bypass to Standby Gas Treatment System (FCV-64-31)		1	5	0	GC
6	Suppression Chamber Exhaust Valve Bypass to Standby Gas Treatment System (FCV-64-34)		1	5	0	GC
6	System Suction Isolation Valves to Air Compressors "A" and "B" (FCV-32-62, 63)		2	15	0	GC
6	Drywell/Suppression Chamber Nitrogen Purge Inlet (FCV-76-24)		1	5	C	SC
6	Torus Hydrogen Sample Line Valves Analyzer A (FSV-76-55, 56)		2	NA	Note 1	SC
6	Torus Oxygen Sample Line Valves Analyzer A (FSV-76-53, 54)		2	NA	Note 1	SC
6	Drywell Hydrogen Sample Line Valves Analyzer A (FSV-76-49, 50)	1	1	NA	Note 1	SC
6	Drywell Oxygen Sample Line Valves Analyzer A (FSV-76-51, 52)	1	1	NA	Note 1	SC
6	Sample Return Valves - Analyzer A (FSV-76-57, 58)		2	NA	0	GC
6	Torus Hydrogen Sample Line Valves Analyzer B (FSV-76-65, 66)		2	NA	Note 1	SC

Amendment No. 71

- g. All reportable events.
- h. All recognized indications of an unanticipated deficiency in some aspect of design or operation of structures, systems, or components that could affect nuclear safety.
- i. Reports and meeting minutes of the PORC.

8. AUDITS

Audits of unit activities shall be performed under the cognizance of the NSRB. These audits shall encompass.

- a. The conformance of unit operation to provisions contained within the Technical Specifications and applicable license conditions at least once per 12 months.
- b. The performance, training and qualifications of the entire unit staff at least once per 12 months.
- c. The results of actions taken to correct deficiencies occurring in unit equipment, structures, systems or method of operation that affect nuclear safety at least once per 6 months.
- d. The performance of activities required by the Operational Quality Assurance Program to meet the criteria of Appendix "B", 10 CFR 50, at least once per 24 months.
- e. The Site Radiological Emergency Plan and implementing procedures at least once per 12 months.
- f. The Plant Physical Security Plan and implementing procedures at least once per 12 months.
- g. Any other area of unit operation considered appropriate by the NSRB or the Manager of Power.
- h. The Facility Fire Protection Program and implementing procedures at least once per 24 months.
- i. An independent fire protection and loss prevention program inspection and audit shall be performed annually utilizing either qualified offsite licensee personnel or an outside fire protection firm.
- j. An inspection and audit of the fire protection and loss prevention program shall be performed by an outside qualified fire consultant at intervals no greater than 3 years.

4. Duties and Responsibilities

The PORC serves in an advisory capacity to the plant superintendent and as an investigating and reporting body to the Nuclear Safety Review Board in matters related to safety in plant operations. The plant superintendent has the final responsibility in determining the matters that should be referred to the Nuclear Safety Review Board.

The responsibility of the committee will include:

- a. Review all standard and emergency operating and maintenance instructions and any proposed revisions thereto, with principal attention to provisions for safe operation.
- b. Review proposed changes to the Technical Specifications.
- c. Review proposed changes to equipment or systems having safety significance, or which may constitute "an unreviewed safety question," pursuant to 10 CFR 50.59.
- d. Investigate reported or suspected incidents involving safety questions, violations of the Technical Specifications, and violations of plant instructions pertinent to nuclear safety.
- e. Review reportable events, unusual events, operating anomalies and abnormal performance of plant equipment.
- f. Maintain a general surveillance of plant activities to identify possible safety hazards.
- g. Review plans for special fuel handling, plant maintenance, operations, and tests or experiments which may involve special safety considerations, and the results thereof, where applicable.
- h. (deleted)
- i. Review implementing procedures of the Radiological Emergency Plan and the Industrial Security Program on an annual basis.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
SUPPORTING AMENDMENT NO. 103 TO FACILITY OPERATING LICENSE NO. DPR-33

AMENDMENT NO. 97 TO FACILITY OPERATING LICENSE NO. DPR-52

AMENDMENT NO. 71 TO FACILITY OPERATING LICENSE NO. DPR-68

TENNESSEE VALLEY AUTHORITY

BROWNS FERRY NUCLEAR PLANT, UNIT NOS. 1, 2 AND 3

DOCKET NOS. 50-259, 50-260 AND 50-296

1.0 Introduction

By letters dated November 5, 1982, (TVA BFNP TS 176-S1) and December 17, 1982, the Tennessee Valley Authority (the licensee or TVA) requested amendments to Facility Operating License Nos. DPR-33, DPR-52 and DPR-68 for the Browns Ferry Nuclear Plant, Unit Nos. 1, 2 and 3. The requested changes would make corrections and clarifications to the Table of Primary Containment Isolation Valves, change the frequency for Physical Security Plan audits, and delete the requirement for the Plant Operations Review Committee (PORC) to review the Quality Assurance (QA) program.

2.0 Evaluations

Table of Primary Containment Isolation Valves (applicable to Units 1 and 3, Unit 2 changes were part of Amendment #85)

Technical Specifications (Table 3.7.A) for Units 1 and 3 would be changed to add a footnote for clarification of initiating conditions for reactor water sample line isolation. The table presently indicates that the sample line isolation valves are closed by any one of the five following conditions 1) reactor low water level, 2) main steamline high radiation, 3) main steamline high flow 4) main steamline high temperature or, 5) main steamline low pressure. However, installed instrumentation is such that only reactor water low-low level or main steamline high radiation initiate sample line isolation. These events are sufficiently diverse to ensure reliable isolation capability consistent with Standard Review Plan Section 6.2.4 criteria. This change is therefore acceptable.

Table 3.7.A would be changed to indicate that the drywell exhaust valve bypass to standby gas treatment (SBGT) system (FCV 64-31), and the suppression chamber exhaust valve bypass to SBGT system (FCV 64-34) are normally open instead of normally closed. These valves were originally

"normally closed". However the piping in which they are installed is now, as a result of a modification, common to the drywell-to-suppression chamber differential pressure control system. These valves must now be "normally open" to allow differential pressure control. This change is therefore acceptable.

Plant Physical Security Plan Audit Intervals Units 1, 2, & 3.

Technical Specifications for all units would be changed to specify a 12-month, instead of 24-month, audit cycle for the Physical Security Plan. This change is necessary for consistency with 10 CFR 73.55(g) and is therefore acceptable.

Quality Assurance Program Overview (Units 1, 2, & 3)

Technical Specification 6.2.B.4.h for all units would be changed to delete a requirement that the Plant Operations Review Committee (PORC) periodically review the Quality Assurance Program. The QA program is presently required to be reviewed by both the PORC and the Nuclear Safety Review Board (NSRB). However, Regulatory Guide 1.33 (by endorsing ANS 3.2 "Administrative Controls and Quality Assurance for the Operational Phase of Nuclear Power Plants") prescribes QA program review by an independent offsite organization. This position is met by the NSRB review and PORC review is therefore unnecessary. This change is therefore acceptable.

3.0 Environmental Considerations

The amendments involve a change in the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. We have determined that the amendments involve no significant increase in the amounts and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupation radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration and there has been no public comment on such finding. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

4.0 Conclusion

We have concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations,

and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: W. Long

Dated: July 16, 1984