

DO NOT REMOVE

Dockets Nos. 50-259/260/296

August 26, 1987

*Posted
AMOLT 133
to DPR-52*

Mr. S. A. White
Manager of Nuclear Power
Tennessee Valley Authority
6N 38A Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

Dear Mr. White:

SUBJECT: TECHNICAL SPECIFICATION (TS 222) RELATED TO REACTOR COOLANT LEAKAGE (TAC 64372, 64373, 64374)

Re: Browns Ferry Nuclear Plant, Units 1, 2, and 3

The Commission has issued the enclosed Amendments Nos. 137, 133, and 108 to Facility Operating Licenses Nos. DPR-33, DPR-52 and DPR-68 for the Browns Ferry Nuclear Plant, Units 1, 2 and 3, respectively. These amendments are in response to your application dated December 15, 1986.

The amendments change the Technical Specifications to add dry well leakage measurement and recording requirements in response to NRC Generic Letter 84-11.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Bi-Weekly Federal Register Notice.

Sincerely,

Original Signed By
John A. Zwolinski, Assistant Director
for Projects

TVA Projects Division
Office of Special Projects
DISTRIBUTION:

Enclosures:

1. Amendment No. 137 to License No. DPR-33
2. Amendment No. 133 to License No. DPR-52
3. Amendment No. 108 to License No. DPR-68
4. Safety Evaluation

cc w/enclosures:
See next page

Docket File	BDLiaw	SRConnelly, OIA
NRC PDR	Wanda Jones	GZech, RII
Local PDR	OGC-BETH	DHagan
JAxelrad	JPartlow	ACRS (10)
SEbnetter	EJordan	Projects Rdg
SRichardson	TBarnhart (12)	BFN File
JZwolinski	GPA/PA	TVA-Bethesda
GGears	LFMB	Aignatonis, RII
JStang	EButcher	
CJamerson (2)	FMiraglia	

OFFICIAL RECORD COPY

OSP:DTVA
CJamerson
8/25/87

OSP:DTVA
GGears:as
7/23/87

OSP:DTVA
JStang
8/26/87

OSP:AD/TP
BDLiaw
7/23/87

OGC-BETH
7/23/87

OSP:AD/P
JAZwolinski
8/26/87



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

August 26, 1987

Dockets Nos. 50-259/260/296

Mr. S. A. White
Manager of Nuclear Power
Tennessee Valley Authority
6N 38A Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

Dear Mr. White:

SUBJECT: TECHNICAL SPECIFICATION (TS 222) RELATED TO REACTOR COOLANT
LEAKAGE (TAC 64372, 64373, 64374)

Re: Browns Ferry Nuclear Plant, Units 1, 2, and 3

The Commission has issued the enclosed Amendments Nos. 137, 133, and 108 to Facility Operating Licenses Nos. DPR-33, DPR-52 and DPR-68 for the Browns Ferry Nuclear Plant, Units 1, 2 and 3, respectively. These amendments are in response to your application dated December 15, 1986.

The amendments change the Technical Specifications to add dry well leakage measurement and recording requirements in response to NRC Generic Letter 84-11.

A copy of the Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Bi-Weekly Federal Register Notice.

Sincerely,

A handwritten signature in black ink, appearing to read "John A. Zwolinski".

John A. Zwolinski, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Enclosures:

1. Amendment No. 137 to License No. DPR-33
2. Amendment No. 133 to License No. DPR-52
3. Amendment No. 108 to License No. DPR-68
4. Safety Evaluation

cc w/enclosures:
See next page

Mr. S. A. White
Tennessee Valley Authority

Browns Ferry Nuclear Plant
Units 1, 2, and 3

CC:
General Counsel
Tennessee Valley Authority
400 West Summit Hill Drive
E11 B33
Knoxville, Tennessee 37902

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W.
Atlanta, Georgia 30323

Mr. R. L. Gridley
Tennessee Valley Authority
5N 157B Lookout Place
Chattanooga, Tennessee 37402-2801

Resident Inspector/Browns Ferry NP
U.S. Nuclear Regulatory Commission
Route 12, Box 637
Athens, Alabama 35611

Mr. H. P. Pomrehn
Tennessee Valley Authority
Browns Ferry Nuclear Plant
P.O. Box 2000
Decatur, Alabama 35602

Mr. Richard King
c/o U.S. GAO
1111 North Shore Drive
Suite 225, Box 194
Knoxville, Tennessee 37919

Mr. M. J. May
Tennessee Valley Authority
Browns Ferry Nuclear Plant
P.O. Box 2000
Decatur, Alabama 35602

Mr. D. L. Williams
Tennessee Valley Authority
400 West Summit Hill Drive
W10 B85
Knoxville, Tennessee 37902

Chairman, Limestone County Commission
P.O. Box 188
Athens, Alabama 35611

Claude Earl Fox, M.D.
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36130

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-259

BROWNS FERRY NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 137
License No. DPR-33

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated December 15, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-33 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 137, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John A. Zwolinski, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 26, 1987

ATTACHMENT TO LICENSE AMENDMENT NO. 137

FACILITY OPERATING LICENSE NO. DPR-33

DOCKET NO. 50-259

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

3.6/4.6-9
3.6/4.6-10

INSERT

3.6/4.6-9
3.6/4.6-10

3.6/4.6 PRIMARY SYSTEM BOUNDARY

LIMITING CONDITIONS FOR OPERATION

3.6.C. Coolant Leakage

1. a. Any time irradiated fuel is in the reactor vessel and reactor coolant temperature is above 212°F, reactor coolant leakage into the primary containment from unidentified sources shall not exceed 5 gpm. In addition, the total reactor coolant system leakage into the primary containment shall not exceed 25 gpm.
- b. Anytime the reactor is in RUN mode, reactor coolant leakage into the primary containment from unidentified sources shall not increase by more than 2 gpm averaged over any 24-hour period in which the reactor is in the RUN mode except as defined in 3.6.C.1.c below.
- c. During the first 24 hours in the RUN mode following STARTUP, an increase in reactor coolant leakage into the primary containment of >2 gpm is acceptable as long as the requirements of 3.6.C.1.a are met.

SURVEILLANCE REQUIREMENTS

4.6.C. Coolant Leakage

1. Reactor coolant system leakage shall be checked by the sump and air sampling system and recorded at least once per 4 hours.

3.6/4.6 PRIMARY SYSTEM BOUNDARY

LIMITING CONDITIONS FOR OPERATION

3.6.C Coolant Leakage

2. Both the sump and air sampling systems shall be OPERABLE during reactor power operation. From and after the date that one of these systems is made or found to be INOPERABLE for any reason, reactor power operation is permissible only during the succeeding 24 hours for the sump system or 72 hours for the air sampling system.

The air sampling system may be removed from service for a period of 4 hours for calibration, function testing, and maintenance without providing a temporary monitor.

3. If the condition in 1 or 2 above cannot be met, an orderly shutdown shall be initiated and the reactor shall be shutdown in the Cold Condition within 24 hours.

3.6.D. Relief Valves

1. When more than one relief valves are known to be failed, an orderly shutdown shall be initiated and the reactor depressurized to less than 105 psig within 24 hours.

SURVEILLANCE REQUIREMENTS

4.6.C Coolant Leakage

2. With the air sampling system INOPERABLE, grab samples shall be obtained and analyzed at least once every 24 hours.

4.6.D. Relief Valves

1. Approximately one-half of all relief valves shall be bench-checked or replaced with a bench-checked valve each operating cycle. All 13 valves will have been checked or replaced upon the completion of every second cycle.
2. Once during each operating cycle, each relief valve shall be manually opened until thermocouples and acoustic monitors downstream of the valve indicate steam is flowing from the valve.

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555



TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-260

BROWNS FERRY NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 133
License No. DPR-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated December 15, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-52 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 133, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John A. Zwolinski, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 26, 1987

ATTACHMENT TO LICENSE AMENDMENT NO. 133

FACILITY OPERATING LICENSE NO. DPR-52

DOCKET NO. 50-260

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

3.6/4.6-9
3.6/4.6-10

INSERT

3.6/4.6-9
3.6/4.6-10

3.6/4.6 PRIMARY SYSTEM BOUNDARY

LIMITING CONDITIONS FOR OPERATION

3.6.C. Coolant Leakage

1. a. Any time irradiated fuel is in the reactor vessel and reactor coolant temperature is above 212°F, reactor coolant leakage into the primary containment from unidentified sources shall not exceed 5 gpm. In addition, the total reactor coolant system leakage into the primary containment shall not exceed 25 gpm.
- b. Anytime the reactor is in RUN mode, reactor coolant leakage into the primary containment from unidentified sources shall not increase by more than 2 gpm averaged over any 24-hour period in which the reactor is in the RUN mode except as defined in 3.6.C.1.c below.
- c. During the first 24 hours in the RUN mode following STARTUP, an increase in reactor coolant leakage into the primary containment of >2 gpm is acceptable as long as the requirements of 3.6.C.1.a are met.

SURVEILLANCE REQUIREMENTS

4.6.C. Coolant Leakage

1. Reactor coolant system leakage shall be checked by the sump and air sampling system and recorded at least once per 4 hours.

3.6/4.6 PRIMARY SYSTEM BOUNDARY

LIMITING CONDITIONS FOR OPERATION

3.6.C Coolant Leakage

2. Both the sump and air sampling systems shall be OPERABLE during reactor power operation. From and after the date that one of these systems is made or found to be INOPERABLE for any reason, reactor power operation is permissible only during the succeeding 24 hours for the sump system or 72 hours for the air sampling system.

The air sampling system may be removed from service for a period of 4 hours for calibration, function testing, and maintenance without providing a temporary monitor.

3. If the condition in 1 or 2 above cannot be met, an orderly shutdown shall be initiated and the reactor shall be shutdown in the Cold Condition within 24 hours.

3.6.D. Relief Valves

1. When more than one relief valves are known to be failed, an orderly shutdown shall be initiated and the reactor depressurized to less than 105 psig within 24 hours.

SURVEILLANCE REQUIREMENTS

4.6.C Coolant Leakage

2. With the air sampling system INOPERABLE, grab samples shall be obtained and analyzed at least once every 24 hours.

4.6.D. Relief Valves

1. Approximately one-half of all relief valves shall be bench-checked or replaced with a bench-checked valve each operating cycle. All 13 valves will have been checked or replaced upon the completion of every second cycle.
2. Once during each operating cycle, each relief valve shall be manually opened until thermocouples and acoustic monitors downstream of the valve indicate steam is flowing from the valve.

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-296

BROWNS FERRY NUCLEAR PLANT, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 108
License No. DPR-68

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated December 15, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-68 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No.108, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John A. Zwolinski, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 26, 1987

ATTACHMENT TO LICENSE AMENDMENT NO. 108

FACILITY OPERATING LICENSE NO. DPR-68

DOCKET NO. 50-296

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

3.6/4.6-9
3.6/4.6-10

INSERT

3.6/4.6-9
3.6/4.6-10

3.6/4.6 PRIMARY SYSTEM BOUNDARY

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.6.C. Coolant Leakage

1. a. Any time irradiated fuel is in the reactor vessel and reactor coolant temperature is above 212°F, reactor coolant leakage into the primary containment from unidentified sources shall not exceed 5 gpm. In addition, the total reactor coolant system leakage into the primary containment shall not exceed 25 gpm.
- b. Anytime the reactor is in RUN mode, reactor coolant leakage into the primary containment from unidentified sources shall not increase by more than 2 gpm averaged over any 24-hour period in which the reactor is in the RUN mode except as defined in 3.6.C.1.c below.
- c. During the first 24 hours in the RUN mode following STARTUP, an increase in reactor coolant leakage into the primary containment of >2 gpm is acceptable as long as the requirements of 3.6.C.1.a are met.

4.6.C. Coolant Leakage

1. Reactor coolant system leakage shall be checked by the sump and air sampling system and recorded at least once per 4 hours.

3.6/4.6 PRIMARY SYSTEM BOUNDARY

LIMITING CONDITIONS FOR OPERATION

3.6.C Coolant Leakage

2. Both the sump and air sampling systems shall be OPERABLE during reactor power operation. From and after the date that one of these systems is made or found to be INOPERABLE for any reason, reactor power operation is permissible only during the succeeding 24 hours for the sump system or 72 hours for the air sampling system.

The air sampling system may be removed from service for a period of 4 hours for calibration, function testing, and maintenance without providing a temporary monitor.

3. If the condition in 1 or 2 above cannot be met, an orderly shutdown shall be initiated and the reactor shall be shutdown in the Cold Condition within 24 hours.

3.6.D. Relief Valves

1. When more than one relief valves are known to be failed, an orderly shutdown shall be initiated and the reactor depressurized to less than 105 psig within 24 hours.

SURVEILLANCE REQUIREMENTS

4.6.C Coolant Leakage

2. With the air sampling system INOPERABLE, grab samples shall be obtained and analyzed at least once every 24 hours.

4.6.D. Relief Valves

1. Approximately one-half of all relief valves shall be bench-checked or replaced with a bench-checked valve each operating cycle. All 13 valves will have been checked or replaced upon the completion of every second cycle.
2. Once during each operating cycle, each relief valve shall be manually opened until thermocouples and acoustic monitors downstream of the valve indicate steam is flowing from the valve.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF SPECIAL PROJECTS

SUPPORTING AMENDMENT NO. 137 TO FACILITY OPERATING LICENSE NO. DPR-33

AMENDMENT NO. 133 TO FACILITY OPERATING LICENSE NO. DPR-52

AMENDMENT NO. 108 TO FACILITY OPERATING LICENSE NO. DPR-68

TENNESSEE VALLEY AUTHORITY

BROWNS FERRY NUCLEAR PLANT, UNITS 1, 2 AND 3

DOCKETS NOS. 50-259, 50-260 AND 50-296

1.0 INTRODUCTION

By letter dated December 15, 1986, the Tennessee Valley Authority (TVA or the licensee) proposed to change the Technical Specifications (TS) for the Browns Ferry Nuclear Plant, Units 1, 2, and 3. The specifications to be changed are concerned with coolant leakage monitoring requirements.

In NRC Generic Letter 84-11, "Stainless Steel Piping Reinspection" dated April 19, 1984, the NRC specified the need for more restrictive leakage monitoring limits. The proposed changes address this request.

2.0 EVALUATION

The proposed changes would affect the following:

Section 4.6.C.1, "Coolant Leakage," would be changed to require reactor coolant leakage to be checked by the sump and air sampling system and recorded at least once every 4 hours. The current TS require sampling and recording once every 8 hours. In addition, the corresponding Limiting Condition for Operation (LCO) 3.6.C.1.b is being changed to delete the last sentence which is actually a Surveillance Requirement (SR) and redundant to SR 4.6.G.1.

LCO 3.6.C.2, "Coolant Leakage," would be changed to restrict reactor power operation to continue only during the succeeding 24 hours whenever the drywell sump system is found to be inoperable. The current TS allow 72 hours of continued operation once the drywell sump system is declared inoperable.

These proposed changes are in accordance with the guidance provided in GL 84-11 as well as Section IV.B.1.a.2 of NUREG-0313 (Technical Report on Material Selection and Processing Guidelines for BWR Coolant Pressure Boundary Piping, July 1980). Both changes are more restrictive than the current TS requirement.

Based on the above considerations, we conclude that the proposed changes enhance the overall margin of safety, and are consistent with the intent of all regulatory guidance.

3.0 ENVIRONMENTAL CONSIDERATION

The amendments involve a change to a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes to the surveillance requirements. The staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that these amendments involve no significant hazards consideration and there has been no public comment on such finding. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement nor environmental assessment need be prepared in connection with the issuance of these amendments.

4.0 CONCLUSION

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of the amendments will not be inimical to the common defense and security nor to the health and safety of the public.

Principal Contributor: G. Gears

Dated: August 26, 1987