

April 1, 1988

*Posted
Collection to*

Amdt. 142 to DPR-52

Docket Nos. 50-259/260/296

Mr. S. A. White
Manager of Nuclear Power
Tennessee Valley Authority
6N 38A Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

Distribution

Docket File	BDLiaw	DMoran
NRC PDR	KBarr	GGears
Local PDR	JRutberg	OGC-Rockville
Projects Rdg.	EJordan	TBarnhart(12)
SEbneter	JPartlow	CJamerson(2)
JAxelrad	DHagan	LFMB
SRichardson	GPA/PA	BFN File
GZech	ACRS(10)	JKelly
FMiraglia	EButcher	
TVA-Rockville	Aignatonis	

Dear Mr. White:

SUBJECT: TECHNICAL SPECIFICATION PAGE CORRECTIONS (TS 229) (TAC 00176, 00177 AND 00178)

Re: Browns Ferry Nuclear Plant, Units 1, 2, and 3

On March 1, 1988, the Commission issued Amendment Nos. 146, 142, and 117 to Facility Operating License Nos. DPR-33, DPR-52 and, DPR-68 for the Browns Ferry Nuclear Plant, Units 1, 2 and 3, respectively. The previously effective amendment numbers were inadvertently omitted from the issued Technical Specifications pages. In order to maintain document integrity, we have corrected these pages. Please discard the previously issued TS pages for Amendment Nos. 146, 142, and 117 for Browns Ferry Nuclear Plant, Units 1, 2 and 3, respectively, and replace them with the enclosed pages.

Sincerely,

Original Signed by Rajender Auluck
Gary G. Zech, Assistant Director
for Projects
TVA Projects Division
Office of Special Projects

Enclosures:

1. TS pages to Amendment No. 146
2. TS pages to Amendment No. 142
3. TS pages to Amendment No. 117

cc w/enclosures:
See next page

OSP:TVA/LA
CJamerson:as
3/31/88

[Signature]
OSP:TVA/PM
JKelly
3/31/88

OSP:TVA/PM
GGears
4/1/88

TVA:AD/P
GZech
4/1/88

[Signature]

Mr. S. A. White
Tennessee Valley Authority

Browns Ferry Nuclear Plant
Units 1, 2, and 3

cc:

General Counsel
Tennessee Valley Authority
400 West Summit Hill Drive
E11 B33
Knoxville, Tennessee 37902

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W.
Atlanta, Georgia 30323

Mr. R. L. Gridley
Tennessee Valley Authority
5N 157B Lookout Place
Chattanooga, Tennessee 37402-2801

Resident Inspector/Browns Ferry NP
U.S. Nuclear Regulatory Commission
Route 12, Box 637
Athens, Alabama 35611

Mr. H. P. Pomrehn
Tennessee Valley Authority
Browns Ferry Nuclear Plant
P.O. Box 2000
Decatur, Alabama 35602

Mr. Richard King
c/o U.S. GAO
1111 North Shore Drive
Suite 225, Box 194
Knoxville, Tennessee 37919

Mr. M. J. May
Tennessee Valley Authority
Browns Ferry Nuclear Plant
P.O. Box 2000
Decatur, Alabama 35602

Dr. Henry Myers, Science Advisor
Committee on Interior
and Insular Affairs
U.S. House of Representatives
Washington, D.C. 20515

Mr. D. L. Williams
Tennessee Valley Authority
400 West Summit Hill Drive
W10 B85
Knoxville, Tennessee 37902

Chairman, Limestone County Commission
P.O. Box 188
Athens, Alabama 35611

Claude Earl Fox, M.D.
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36130

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.7.C. Secondary Containment

4. If refueling zone secondary containment cannot be maintained the following conditions shall be met:
 - a. Handling of spent fuel and all operations over spent fuel pools and open reactor wells containing fuel shall be prohibited.
 - b. The standby gas treatment system suction to the refueling zone will be blocked except for a controlled leakage area sized to assure the achieving of a vacuum of at least 1/4-inch of water and not over 3 inches of water in all three reactor zones.

D. Primary Containment Isolation Valves

1. When Primary Containment Integrity is required, all isolation valves listed in Table 3.7.A and all reactor coolant system instrument line flow check valves shall be OPERABLE except as specified in 3.7.D.2.

D. Primary Containment Isolation Valves

1. The primary containment isolation valves surveillance shall be performed as follows:
 - a. At least once per operating cycle the OPERABLE isolation valves that are power operated and automatically initiated shall be tested for simulated automatic initiation and closure times.
 - b. At least once per quarter:
 - (1) All normally open power-operated isolation valves (except for the main steam line power-operated isolation valves) shall be fully closed and reopened.

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.7.D. Primary Containment Isolation Valves

4.7.D. Primary Containment Isolation Valves

4.7.D.1.b (Cont'd)

(2) With the reactor power less than 75%, trip main steam isolation valves individually and verify closure time.

c. (Deleted)

d. At least once per operating cycle, the operability of the reactor coolant system instrument line flow check valves shall be verified.

2. In the event any isolation valve specified in Table 3.7.A becomes INOPERABLE, reactor power operation may continue provided at least one valve in each line having an INOPERABLE valve, is OPERABLE and within 4 hours either:

a. The INOPERABLE valve is restored to OPERABLE status, or

b. Each affected line is isolated by use of at least one deactivated containment isolation valve secured in the isolated position.

3. If Specification 3.7.D.1 and 3.7.D.2 cannot be met, an orderly shutdown shall be initiated and the reactor shall be in the Cold Shutdown condition within 24 hours.

2. Whenever an isolation valve listed in Table 3.7.A is INOPERABLE, the position of at least one other valve in each line having an INOPERABLE valve shall be recorded daily.

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.7.C. Secondary Containment

4. If refueling zone secondary containment cannot be maintained the following conditions shall be met:
 - a. Handling of spent fuel and all operations over spent fuel pools and open reactor wells containing fuel shall be prohibited.
 - b. The standby gas treatment system suction to the refueling zone will be blocked except for a controlled leakage area sized to assure the achieving of a vacuum of at least 1/4-inch of water and not over 3 inches of water in all three reactor zones.

D. Primary Containment Isolation Valves

1. When Primary Containment Integrity is required, all isolation valves listed in Table 3.7.A and all reactor coolant system instrument line flow check valves shall be OPERABLE except as specified in 3.7.D.2.

D. Primary Containment Isolation Valves

1. The primary containment isolation valves surveillance shall be performed as follows:
 - a. At least once per operating cycle the OPERABLE isolation valves that are power operated and automatically initiated shall be tested for simulated automatic initiation and closure times.
 - b. At least once per quarter:
 - (1) All normally open power-operated isolation valves (except for the main steam line power-operated isolation valves) shall be fully closed and reopened.

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.7.D. Primary Containment Isolation Valves

4.7.D. Primary Containment Isolation Valves

4.7.D.1.b (Cont'd)

(2) With the reactor power less than 75%, trip main steam isolation valves individually and verify closure time.

c. (Deleted)

d. At least once per operating cycle, the operability of the reactor coolant system instrument line flow check valves shall be verified.

2. In the event any isolation valve specified in Table 3.7.A becomes INOPERABLE, reactor power operation may continue provided at least one valve in each line having an INOPERABLE valve, is OPERABLE and within 4 hours either:

- a. The INOPERABLE valve is restored to OPERABLE status, or
- b. Each affected line is isolated by use of at least one deactivated containment isolation valve secured in the isolated position.

3. If Specification 3.7.D.1 and 3.7.D.2 cannot be met, an orderly shutdown shall be initiated and the reactor shall be in the Cold Shutdown condition within 24 hours.

2. Whenever an isolation valve listed in Table 3.7.A is INOPERABLE, the position of at least one other valve in each line having an INOPERABLE valve shall be recorded daily.

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.7.C. Secondary Containment

4. If refueling zone secondary containment cannot be maintained the following conditions shall be met:
 - a. Handling of spent fuel and all operations over spent fuel pools and open reactor wells containing fuel shall be prohibited.
 - b. The standby gas treatment system suction to the refueling zone will be blocked except for a controlled leakage area sized to assure the achieving of a vacuum of at least 1/4-inch of water and not over 3 inches of water in all three reactor zones.

D. Primary Containment Isolation Valves

1. When Primary Containment Integrity is required, all isolation valves listed in Table 3.7.A and all reactor coolant system instrument line flow check valves shall be OPERABLE except as specified in 3.7.D.2.

D. Primary Containment Isolation Valves

1. The primary containment isolation valves surveillance shall be performed as follows:
 - a. At least once per operating cycle the OPERABLE isolation valves that are power operated and automatically initiated shall be tested for simulated automatic initiation and closure times.
 - b. At least once per quarter:
 - (1) All normally open power-operated isolation valves (except for the main steam line power-operated isolation valves) shall be fully closed and reopened.

3.7/4.7 CONTAINMENT SYSTEMS

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.7.D. Primary Containment Isolation Valves

4.7.D. Primary Containment Isolation Valves

4.7.D.1.b (Cont'd)

(2) With the reactor power less than 75%, trip main steam isolation valves individually and verify closure time.

c. (Deleted)

d. At least once per operating cycle, the operability of the reactor coolant system instrument line flow check valves shall be verified.

2. Whenever an isolation valve listed in Table 3.7.A is INOPERABLE, the position of at least one other valve in each line having an INOPERABLE valve shall be recorded daily.

2. In the event any isolation valve specified in Table 3.7.A becomes INOPERABLE, reactor power operation may continue provided at least one valve in each line having an INOPERABLE valve, is OPERABLE and within 4 hours either:

a. The INOPERABLE valve is restored to OPERABLE status, or

b. Each affected line is isolated by use of at least one deactivated containment isolation valve secured in the isolated position.

3. If Specification 3.7.D.1 and 3.7.D.2 cannot be met, an orderly shutdown shall be initiated and the reactor shall be in the Cold Shutdown condition within 24 hours.