



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379-2000

November 9, 2001

State of Tennessee  
Department of Environment and Conservation  
Division of Water Pollution Control  
401 Church Street, 6th Floor Annex  
Nashville, Tennessee 37243-1534

Attention: Ms. Evelyn Haskin, Enforcement & Compliance

Dear Ms. Haskin:

TENNESSEE VALLEY AUTHORITY - DISCHARGE MONITORING REPORT FOR  
SEQUOYAH NUCLEAR PLANT (SQN)

Please find enclosed the Discharge Monitoring Report (DMR) of October 2001 for SQN.  
Please contact me at (423) 843-6700 if you have any questions or comments.

Sincerely,

Diedre B. Nida  
Environmental Supervisor  
Signatory Authority  
for Richard T. Purcell  
Vice President  
Sequoyah Nuclear Plant

Enclosures: 2 (original & copy)

cc (Enclosure):

Chattanooga Environmental Assistance Center  
Division of Water Pollution Control  
State Office Building, Suite 550  
540 McCallie Avenue  
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

IE25

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name TVA - SEQUOYAH NUCLEAR PLANT  
 Address BOX 2000  
(INTEROFFICE SB-2A)  
SODDY - DAISY TN 37384  
 Facility TVA - SEQUOYAH NUCLEAR PLANT  
 Location HAMILTON COUNTY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
 DISCHARGE MONITORING REPORT (DMR) (17-19)

**TNO026450** **101 G**  
 PERMIT NUMBER DISCHARGE NUMBER

MAJOR (SUBR 01)  
 F - FINAL  
 DIFFUSER DISCHARGE  
 EFFLUENT

Form Approved.  
 OMB No. 2040-0004  
 Approval expires 05-31-98

MONITORING PERIOD  
 From **01 10 01** To **01 10 31**  
 (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form.

ATTN: Diedre B. Nida

PARAMETER (32-37)	SAMPLE MEASUREMENT	3 Card Only QUANTITY OR LOADING (46-53) (54-61)			4 Card Only QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
TEMPERATURE, WATER DEG. CENTIGRADE 00010 Z 0 0 INSTREAM MONITORING	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	24.3	(04)	0	31 / 31	MODEL
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.5 DAILY MX	DEG. C.		SEE PERMIT	CK REQ
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	37.1	(04)	0	31 / 31	RCORDR
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	REPORT DAILY MX	DEG. C.		SEE PERMIT	CK REQ
PH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	7.6	*****	7.8	(12)	0	10 / 31	GRAB
	PERMIT REQUIREMENT	*****	*****	****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		WEEKLY	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	5	6	(19)	0	5 / 31	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	30 MO AVG	100 DAILY MX	MG/L		WEEKLY	GRAB
OIL AND GREASE 00556 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	<5	<5	(19)	0	5 / 31	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	15 MO AVG	20 DAILY MX	MG/L		WEEKLY	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	1661	(03)	*****	*****	*****	**	0	31 / 31	RCORDR
	PERMIT REQUIREMENT	*****	REPORT DAILY MX	MGD	*****	*****	*****	****		CONTINUOUS	RCORDR
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	**	*****	<0.011	<0.055	(19)	0	43 / 31	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.036	0.058 INST MAX	MG/L		WEEK-DAYS	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §1001 AND 33 U.S.C. §1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)	TELEPHONE		DATE		
Richard T. Purcell Site Vice President		423	843-6700	01	11	13
TYPED OR PRINTED		AREA CODE	NUMBER	YEAR	MO	DAY

*Diedre B. Nida*  
 Environmental Supervisor

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
 No closed mode operation. The following injections occurred: 1. PCL-222 (max. calc. conc. was 0.060 mg/L--limit 0.100mg/L) 2. CL-363 (max. calc. conc. was 0.012 mg/L--limit 0.100mg/L) 3. PCL-222/PCL-401 (max. calc. conc. was 0.025 mg/L--limit 0.100mg/L) 4. H-130M (max. calc. conc. was 0.022 mg/L--limit 0.050mg/L)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name TVA - SEQUOYAH NUCLEAR PLANT  
 Address BOX 2000  
 (INTEROFFICE SB-2A)  
SODDY - DAISY TN 37384  
 Facility TVA - SEQUOYAH NUCLEAR PLANT  
 Location HAMILTON COUNTY

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
 DISCHARGE MONITORING REPORT (DMR)  
 (2-16) (17-19)

**TN0026450** **101 G**  
 PERMIT NUMBER DISCHARGE NUMBER

MAJOR (SUBR 01)

F - FINAL  
 DIFFUSER DISCHARGE  
 EFFLUENT

Form Approved.  
 OMB No. 2040-0004  
 Approval expires 05-31-98

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
01	10	01	01	10	31

From (20-21) (22-23) (24-25) To (26-27) (28-29) (30-31)

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form.

ATTN: Dledre B. Nida

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING (46-53) (54-61)			(4 Card Only) QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
TEMPERATURE - C, RATE OF CHANGE 82234 1 0 0	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	0.2	(04)	0	31 / 31	CALCTD
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	2.0	DEG. C.			CALCTD
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C 00016 1 0 0	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	2.7	(04)	0	31 / 31	CALCTD
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	3.0	DEG. C.			CALCTD
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
BORON, TOTAL 01022 1 0 0	SAMPLE MEASUREMENT	*****	*****	**	<0.2	<0.2	<0.2	(19)	0	1 / 31	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	REPORT	REPORT	REPORT	MG/L			GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Richard T. Purcell Site Vice President TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §1001 AND 33 U.S.C. §1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)	<i>Diedre B Nida</i> Environmental Supervisor SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			423	843-6700	01	11	13
			AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
 CCW data for July 2001 to October 2001 attached.

---

**CCW CHANNEL**

---

<b>DATE</b>	<b>DIESEL RANGE ORGANICS (mg/L)</b>	<b>TOTAL PETROLEUM HYDROCARBONS (mg/L)</b>	<b>COMMENTS</b>
07/04/01	< 0.1	< 1	
07/18/01	< 0.1	< 1	
08/01/01	< 0.1	< 1	
08/15/01	< 0.1	< 1	
08/29/01	< 0.1	< 1	
09/12/01	< 0.1	< 1	
09/26/01	< 0.1	< 1	
10/10/01	< 0.1	< 1	
10/24/01	< 0.1	< 1	

---

---

**TRENCH DISCHARGE**

---

<b>DATE</b>	<b>DIESEL RANGE ORGANICS (mg/L)</b>	<b>TOTAL PETROLEUM HYDROCARBONS (mg/L)</b>	<b>COMMENTS</b>
07/04/01	0.27	< 1	
07/18/01	< 0.1	< 1	
08/01/01	0.34	< 1	
08/15/01	0.45	< 1	
08/29/01	0.8	< 1	
09/12/01	0.4	< 1	
09/26/01	0.4	< 1	
10/10/01	0.33	< 1	
10/24/01	0.4	< 1	

---

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**  
 Address **BOX 2000**  
 (INTEROFFICE SB-2A)  
**SODDY - DAISY TN 37384**  
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**  
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
 DISCHARGE MONITORING REPORT (DMR)  
 (17-19)

**TN0026450** **103 G**  
 PERMIT NUMBER DISCHARGE NUMBER

MAJOR

(SUBR 01)

F - FINAL

LOW VOL. WASTE TREATMENT POND

EFFLUENT

Form Approved.

OMB No. 2040-0004

Approval expires 05-31-98

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
01	10	01	01	10	31

From **01 10 01** To **01 10 31**  
 (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form.

ATTN: Diedre B. Nida

PARAMETER (32-37)	SAMPLE MEASUREMENT	3 Card Only QUANTITY OR LOADING (46-53) (54-61)			4 Card Only QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)			UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				
PH	SAMPLE MEASUREMENT	*****	*****	**	7.0	*****	8.8	(12)	0	15 / 31	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	**	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		THREE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	72	161	(26)	*****	10	18	(19)	0	7 / 31	GRAB
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	380 MO AVG	1250 DAILY MX	LBS/DY	*****	30 MO AVG	100 DAILY MX	MG/L		WEEKLY	GRAB
OIL AND GREASE	SAMPLE MEASUREMENT	<35	<52	(26)	*****	<5	<5	(19)	0	7 / 31	GRAB
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	190 MO AVG	250 DAILY MX	LBS/DY	*****	15 MO AVG	20 DAILY MX	MG/L		WEEKLY	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.925	1.977	(03)	*****	*****	*****	**	0	31 / 31	TOTAL
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	**		DAILY	TOTAL
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  Richard T. Purcell  Site Vice President  TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §1001 AND 33 U.S.C. §1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)	TELEPHONE		DATE		
		423	843-6700	01	11	13
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

*Diedre B. Nida*  
 Environmental Supervisor

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
 Turbine Building Sump was aligned to the Yard Pond on 10/28/01 @ 1115 until 10/30/01 @ 0810 and 10/31/01 @ 1717 until 11/03/01 @ 1022.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**  
 Address **BOX 2000**  
 (INTEROFFICE SB-2A)  
**SODDY - DAISY TN 37384**  
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**  
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) (17-19)

**TN0026450** **107 G**  
 PERMIT NUMBER DISCHARGE NUMBER

MAJOR

(SUBR 01)

F - FINAL

METAL CLEANING WASTE POND

EFFLUENT

Form Approved.

OMB No. 2040-0004

Approval expires 05-31-98

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
01	10	01	01	10	31

From


To

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form.

ATTN: Diedre B. Nida

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only (46-53) (54-61))			QUALITY OR CONCENTRATION (4 Card Only (38-45) (46-53) (54-61))			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
PH	SAMPLE MEASUREMENT	*****	*****	**				(12)		
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU	DAILY	GRAB
PHOSPHORUS, TOTAL (AS P)	SAMPLE MEASUREMENT	*****	*****	**				(19)		
00665 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	MG/L	DAILY	COMP-8
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**				(19)		
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30 DAILY MX	MG/L	DAILY	COMP-8
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**				(19)		
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	15 DAILY MX	MG/L	DAILY	GRAB
COPPER, TOTAL (AS CU)	SAMPLE MEASUREMENT	*****	*****	**				(19)		
01042 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	MG/L	DAILY	COMP-8
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	*****	*****	**				(19)		
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1.0 DAILY MX	MG/L	DAILY	COMP-8
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT			(03)				**		
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	****	DAILY	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §1001 AND 33 U.S.C. §1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)	 Environmental Supervisor		TELEPHONE		DATE		
Richard T. Purcell				423	843-6700	01	11	13
Site Vice President		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No phosphate bearing chemicals were employed. No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**  
 Address **BOX 2000**  
 (INTEROFFICE SB-2A)  
**SODDY - DAISY TN 37384**  
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**  
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
 DISCHARGE MONITORING REPORT (DMR)  
 (2-16) (17-19)

**TN0026450** **110 G**  
 PERMIT NUMBER DISCHARGE NUMBER

MAJOR (SUBR 01)

F - FINAL  
 RECYCLED COOLING WATER  
 EFFLUENT

Form Approved.  
 OMB No. 2040-0004  
 Approval expires 05-31-98

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
01	10	01	01	10	31

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form.

ATTN: Diedre B. Nida

PARAMETER (32-37)	SAMPLE MEASUREMENT	QUANTITY OR LOADING (3 Card Only (46-53) (54-61))			QUALITY OR CONCENTRATION (4 Card Only (38-45) (46-53) (54-61))			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
PH	SAMPLE MEASUREMENT	*****	*****	**				(12)		
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	<b>6.0 MINIMUM</b>		<b>9.0 MAXIMUM</b>	SU	DAILY	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**				(19)		
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***			<b>30 DAILY MX</b>	MG/L	DAILY	GRAB
OIL AND GREASE	SAMPLE MEASUREMENT	*****	*****	**				(19)		
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***			<b>15 DAILY MX</b>	MG/L	DAILY	GRAB
COPPER, TOTAL (AS CU)	SAMPLE MEASUREMENT	*****	*****	**				(19)		
01042 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***			<b>1.0 DAILY MX</b>	MG/L	DAILY	GRAB
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	*****	*****	**				(19)		
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***			<b>1.0 DAILY MX</b>	MG/L	DAILY	GRAB
PHOSPHORUS, TOTAL (AS P)	SAMPLE MEASUREMENT	*****	*****	**				(19)		
00665 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***			<b>1.0 DAILY MX</b>	MG/L	DAILY	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT			(03)				**		
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	<b>REPORT MO AVG</b>	<b>REPORT DAILY MX</b>	MGD				***	DAILY	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §1001 AND 33 U.S.C. §1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)	TELEPHONE		DATE			
Richard T. Purcell		567 Environmental Supervisor	423	843-6700	01	11	13
Site Vice President			AREA CODE	NUMBER	YEAR	MO	DAY
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
 No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**  
 Address **BOX 2000**  
 (INTEROFFICE SB-2A)  
**SODDY - DAISY TN 37384**  
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**  
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
 DISCHARGE MONITORING REPORT (DMR)  
 (2-16) (17-19)

**TN0026450** **118 G**  
 PERMIT NUMBER DISCHARGE NUMBER

MAJOR (SUBR 01)

F - FINAL  
 WASTEWATER & STORM WATER  
 EFFLUENT

Form Approved.  
 OMB No. 2040-0004  
 Approval expires 05-31-98

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
01	10	01	01	10	31

From (20-21) (22-23) (24-25) To (26-27) (28-29) (30-31)

\*\*\* NO DISCHARGE  \*\*\*

NOTE: Read instructions before completing this form.

ATTN: Diedre B. Nida

PARAMETER (32-37)	SAMPLE MEASUREMENT	(3 Card Only) QUANTITY OR LOADING			(4 Card Only) QUALITY OR CONCENTRATION			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS	MINIMUM (38-45)	AVERAGE (46-53)	MAXIMUM (54-61)			
OXYGEN, DISSOLVED (DO) 00300 1 0 0	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	(19)		
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	2.0 DAILY MN	*****	*****	MG/L	TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		(19)		
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	*****	*****	100 DAILY MX	MG/L	TWICE/ WEEK	GRAB
SOLIDS, SETTLEABLE 00545 1 0 0	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		(25)		
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	***	*****	*****	1.0 DAILY MX	ML/L	ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT			(03)	*****	*****	*****	**		
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	*	ONCE/ BATCH	CALCTD
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Richard T. Purcell Site Vice President TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §1001 AND 33 U.S.C. §1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)	<i>Diedre B Nida</i> Environmental Supervisor	TELEPHONE		DATE		
			423	843-6700	01	11	13
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
 During this reporting period, there has been no flow from the Dredge Pond other than that resulting from rainfall. No Discharge this Period