

Docket No. 50-296

May 25, 1977

DISTRIBUTION

Docket	ACRS(16)
NRC PDR	OPA(CMiles)
Local PDR	DRose
ORB#1 Reading	TBAbernathy
VStello	JRBuchanan
KRGoller	
SMSheppard	
ASchwencer	
TWambach	
OELD	
OI&E(5)	
BJones(4)	
BScharf(10)	
JMcGough	
BHarless	
DEisenhut	

Tennessee Valley Authority
 ATTN: Mr. Godwin Williams, Jr.
 Manager of Power
 818 Power Building
 Chattanooga, Tennessee 37201

Gentlemen:

By letter dated February 15, 1977, we transmitted to you Amendment No. 3 to Browns Ferry Nuclear Plant, Unit No. 3. Page 198 of the Technical Specifications attached to Amendment No. 3 contained a typographical error ("124 months" should have read "124 days"). Enclosed is a corrected page 198.

Sincerely,

Original signed by

A. Schwencer, Chief
 Operating Reactors Branch #1
 Division of Operating Reactors

Enclosure:
 Corrected Page 198

cc w/enclosure:
 See next page

OFFICE➤ x27433:tsb	ORB#1	ORB#1	ORB#1			
SURNAME➤	SMSheppard	TVWambach	ASchwencer			
DATE➤	5/25/77	5/25/77	5/25/77			

Tennessee Valley Authority

- 2 -

May 25, 1977

cc: H. S. Sanger, Jr., Esquire
General Counsel
Tennessee Valley Authority
400 Commerce Avenue
E 11B 33 C
Knoxville, Tennessee 37902

U. S. Environmental Protection Agency
Region IV Office
ATTN: EIS COORDINATOR
345 Courtland Street
Atlanta, Georgia 30308

Mr. D. McCloud
Tennessee Valley Authority
303 Power Building
Chattanooga, Tennessee 37401

Mr. William E. Garner
Route 4, Box 354
Scottsboro, Alabama 35768

Athens Public Library
South and Forrest
Athens, Alabama 35611

Mr. Charles R. Christopher
Chairman, Limestone County Commission
Post Office Box 188
Athens, Alabama 35611

Ira L. Myers, M.D.
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36104

Mr. C. S. Walker
Tennessee Valley Authority
400 Commerce Avenue
W 9D199 C
Knoxville, Tennessee 37902

Chief, Energy Systems
Analyses Branch (AW-459)
Office of Radiation Programs
U. S. Environmental Protection Agency
Room 645, East Tower
401 M Street, SW
Washington, D. C. 20460

3.6 PRIMARY SYSTEM BOUNDARY

H. Shock Suppressors (Snubbers)

1. During all modes of operation except Cold Shutdown and Refuel, all safety-related snubbers shall be operable except as noted in 3.6.H.2 through 3.6.H.5 below.

4.6 PRIMARY SYSTEM BOUNDARY

H. Shock Suppressors (Snubbers)

The following surveillance requirements apply to all hydraulic snubbers listed in 3.6.H.2.

1. All hydraulic snubbers whose seal material has been demonstrated by operating experience, lab testing or analysis to be compatible with the operating environment shall be visually inspected. This inspection shall include, but not necessarily be limited to, inspection of the hydraulic fluid reservoir, fluid connections, and linkage connections to the piping and anchor to verify their operability in accordance with the following schedule:

Number of Snubbers Found Inoperable During Inspection or During Inspection Interval	Next Required Inspection Interval
---	-----------------------------------

0	Operating Cycle	+25%
1	12 months	+25%
2	6 months	+25%
3,4	124 days	+25%
5,6,7	62 days	+25%
≥8	31 days	+25%

The required inspection interval shall not be lengthened more than one step at a time.