

Dockets Nos. 50-259/260 & 295

FEB 7 1977

DISTRIBUTION
Dockets (3) ACRS(16)
NRC PDR (3)
Local PDR
ORB#1 Reading
VStello
KRGoller
TJCarter
JMcGough
Branch Chief(ASchwencer)
TVWambach
SMSheppard
DEisenhut
OI&E(3)
OELD
BJones
TBAbernathy

Tennessee Valley Authority
ATTN: Mr. Godwin Williams, Jr.
Manager of Power
818 Power Building
Chattanooga, Tennessee 37201

Gentlemen:

This confirms our telephoned authorization given today, February 7, 1977, for a change in Technical Specifications for the Browns Ferry Units 1, 2 and 3, as requested by your application dated January 26, 1977 as supplemented February 7, 1977. Facility Operating Licenses Nos. DPR-33, DPR-52 and DPR-68 are amended on this date, February 7, 1977, by making the following technical specification change:

Change 850 psig to 825 psig in the following places:

Specification 2.1.H and the bases therefor.

Table 3.2.A p. 55 Units 1 & 2; p. 57 Unit 3.
Trip Level Setting for "Instrument Channel - Low Pressure Main Steam Line" and the bases therefor.

Copies of the license amendment, our evaluation and Federal Register Notice for this technical specification change will be sent to you when completed.

Sincerely,

Original Signed By

Karl R. Goller, Assistant Director
for Operating Reactors
Division of Operating Reactors

OFFICE >	ORB#1	ORB#1	AD:OR			
x27433:tsb NAME >	TVWambach	ASchwencer	KRGoller			
DATE >	2/7/77	2/ /77	2/ /77			

Tennessee Valley Authority

- 2 -

February 7, 1977

cc: H. S. Sanger, Jr., Esquire
General Counsel
Tennessee Valley Authority
400 Commerce Avenue
E 11B 33 C
Knoxville, Tennessee 37902

U. S. Environmental Protection Agency
Region IV Office
ATTN: EIS COORDINATOR
345 Courtland Street
Atlanta, Georgia 30308

Mr. D. McCloud
Tennessee Valley Authority
303 Power Building
Chattanooga, Tennessee 37401

Mr. William E. Garner
Route 4, Box 354
Scottsboro, Alabama 35768

Athens Public Library
South and Forrest
Athens, Alabama 35611

Mr. Charles R. Christopher
Chairman, Limestone County Commission
Post Office Box 188
Athens, Alabama 35611

Ira L. Myers, M.D.
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36104

Mr. C. S. Walker
Tennessee Valley Authority
400 Commerce Avenue
W 9D199 C
Knoxville, Tennessee 37902

Chief, Energy Systems
Analyses Branch (AW-459)
Office of Radiation Programs
U.S. Environmental Protection Agency
Room 645, East Tower
401 M Street, SW
Washington, D.C. 20460