

DISTRIBUTION CONTROL LIST

Document Name: EMER PLAN

CC_NAME NAME	DEPT	LOCATION
0 ELLMERS J (TRANS. ONLY)	APPRAISAL & COMPLIANCE	WPO/14A
1 MONTANARELLO M	ADMINISTRATION	45-3-B
2 TRAINING MANAGER	TRAINING	#48
3 RES DEPARTMENT MANAGER	RES DEPARTMENT	45-4-A
4 REFERENCE LIBRARY	RECORDS (TRNG BLDG)	#48
8 PUBLIC RELATIONS MANAGER	PUB. REL. (AP-ONLY)	46-2-C
9 JOINT NEWS CENTER	EMERGENCY PLANNING	EOF
10 SHIFT MGR. (LUB-001-GEN)	OPERATIONS	IP3
11 CONTROL ROOM & MASTER	OPS (3PT-D001-D006 ONLY)	IP3
12 COMPUTER SERVICES MANAGER	COMPUTER SERVICES	45-2-E
13 I&C MANAGER	I&C	45-2-A
14 EOF	E-PLAN	EOF
15 EOF	E-PLAN	EOF
16 AEOF/A.GROSJEAN	E-PLAN (EOP'S ONLY)	WPO-12D
17 AEOF/A.GROSJEAN	E-PLAN (EOP'S ONLY)	WPO-12D
19 NUC ENGINEERING LIBRARY	WPO DOCUMENT CONTROL	WPO/7A
22 RESIDENT INSPECTOR	US NRC	45-2-B
23 MCNAMARA N	NRC	OFFSITE
24 MCNAMARA N	NRC	OFFSITE
25 DOCUMENT CONTROL DESK	NRC	OFFSITE
28 AVRAKOTOS N	J A FITZPATRICK	OFFSITE
29 E-PLAN ENGINEER	E-PLAN	EOF
30 E-PLAN COORDINATOR	E-PLAN	EOF
31 BARANSKI J	ST. EMERG. MGMT. OFFICE	OFFSITE
32 MURPHY L - VOLUME #1 ONLY	DISASTER & EMERGENCY	WESTCHESTR
33 LONGO, N. - VOLUME #1 ONLY	EMERGENCY SERVICES	ROCKLAND
34 GREENE D - VOLUME #1 ONLY	DISASTER & CIVIL DEFENSE	ORANGE
35 RAMPOLLA M - VOLUME #1 ONLY	OFFICE OF EMERG MANAGE	PUTNAM
37 HP WATCH OFFICE	LAURA EAGENS	45-4-A
38 SECURITY COMMAND POST	SECURITY	#44A
39 SECONDARY ALARM (SAS)	SECURITY	44A
40 SECURITY MANAGER	SECURITY	44-A
41 SIMULATOR	TRAINING	48-2-A
42 CONTROL ROOM & MASTER	OPS (3PT-D001-D006 ONLY)	IP3
106 SIMULATOR INSTRUCT AREA	TRG/3PT-D001-D006 ONLY)	#48
107 QA MANAGER	QA	TRL #2A
128 O.R.G. DEPT. MANAGER	O.R.G. DEPARTMENT	46-2-B
158 SYSTEM ENGINEERING MGR.	SYSTEM ENGINEERING	45-3-H
211 D&A MANAGER	DESIGN ENGINEERING	TRL-#31-A
308 HUGHES J IP-1011 ONLY	E-PLAN	CON ED
309 HUGHES J IP-1011 ONLY	E-PLAN	CON ED
319 C.STELLATO	NRQ-OPS / TRAINING	#48
354 L.GRANT	LRQ-OPS / TRAINING	#48
357 TRAINING - OPS OFFICE	TRAINING - D. PITT	#48
376 EOF	E-PLAN	EOF
424 OPS-INSTR (LL'S 1 COPY)	J. CHIUSANO/TRAINING	#48

A1045



AP-18.2
 Revision 10

Attachment 1
 Page 1 of 1

		CONTROLLED DOCUMENT TRANSMITTAL FORM	
TO: DISTRIBUTION		DATE October 18, 2001	TRANSMITTAL NO: 22232
FROM: IP3 DOCUMENT CONTROL GROUP		EXTENSION: 2038	
<p>The Document(s) identified below are forwarded for use. In accordance with AP-18.2, please review to verify receipt, incorporate the document(s) into your controlled document file, properly disposition superseded, void, or inactive document(s). Sign and return the receipt acknowledgement below within fifteen (15) working days.</p>			
AFFECTED DOCUMENT: EMERGENCY PLAN PROCEDURE			
DOC #	REV #	TITLE	INSTRUCTIONS
<p>***** SEE ATTACHED FOR INSTRUCTIONS *****</p> <p><u>*PLEASE NOTE EFFECTIVE DATES*</u></p>			
<p>RECEIPT OF THE ABOVE LISTED DOCUMENT(S) IS HEREBY ACKNOWLEDGED. I CERTIFY THAT ALL SUPERSEDED, VOID, OR INACTIVE COPIES OF THE ABOVE LISTED DOCUMENT(S) IN MY POSSESSION HAVE BEEN REMOVED FROM USE AND ALL UPDATES HAVE BEEN PERFORMED IN ACCORDANCE WITH EFFECTIVE DATE(S) (IF APPLICABLE) AS SHOWN ON THE DOCUMENT(S).</p>			
_____ NAME (PRINT)	_____ SIGNATURE	_____ DATE	_____ CC# 25



Entergy Nuclear Northeast
 Entergy Nuclear Operations, Inc.
 Indian Point 3 NPP
 P.O. Box 308
 Buchanan, NY 10511
 Tel 914 736 8000

TO: NRC Doc. Control Desk
 FROM: EMERGENCY PLANNING
 SUBJECT: Emergency Planning Implementing Procedures

CONTROL COPY NO.: 25
 DATE: 10/16/01

The enclosed revisions are for your controlled copy of the IP-3 Emergency Plan. Please discard old sheets, insert new sheets, initial/date this transmittal and return it to the IP-DOCUMENTS DEPARTMENT. If you have any questions regarding these changes, call Emergency Planning (x8404/x8318).

Thank you.

Volume III - Emergency Plan Implementing Procedures

<u>OLD</u>		<u>NEW</u>	
Table of Contents	09/01	Table of Contents	10/01
IP-1057	Rev. 7	IP-1057	Rev. 8

I acknowledge the receipt of these revisions to the IP-3 Emergency Plan.

 (Signature)

 (Date)

ENTERGY
 INDIAN POINT NO. 3 NUCLEAR POWER PLANT
 EMERGENCY PLAN - VOLUME III
IMPLEMENTING PROCEDURES

TABLE OF CONTENTS

<u>PROCEDURE #</u>	<u>PROCEDURE TITLE</u>	<u>REV.</u>	<u>DATE</u>
<u>Dose Assessment</u>			
IP-1001	Determining the Magnitude of Release	17	03/00
IP-1002	Post-Accident Monitoring of Noble Gas Concentration in Plant Vent	4	02/99
IP-1003	Obtaining Meteorological Data	18	03/00
IP-1004	Midas Computer System	16	03/00
<u>Environmental Monitoring</u>			
IP-1011	Offsite Monitoring/Site Perimeter Surveys	24	05/99
IP-1012	Emergency Airborne Activity Determination	4	02/99
IP-1015	Post-Accident Environmental Sampling and Counting	7	12/98
<u>Protective Actions</u>			
IP-1017	Protective Action Recommendations for the Offsite Population	13	12/98
IP-1019	Emergency Use of Potassium Iodide (KI)	9	11/97
<u>Personnel Injury</u>			
IP-1021	Radiological Medical Emergency	25	06/98
IP-1023	Use and Set Up of the IP3 Personnel Decon Suite	VOID	N/A
<u>Damage Assessment</u>			
IP-1025	Repair and Corrective Action Teams	12	12/98
IP-1027	Emergency Personnel Exposure	12	12/97
IP-1028	Core Damage Assessment	9	06/98
<u>Notification and Communication</u>			
IP-1038	Offsite Emergency Notifications	26	09/01
IP-1039	Emergency Response Data System (ERDS) Activation and Testing	4	02/01

ENTERGY
INDIAN POINT NO. 3 NUCLEAR POWER PLANT
EMERGENCY PLAN - VOLUME III
IMPLEMENTING PROCEDURES

TABLE OF CONTENTS

<u>PROCEDURE #</u>	<u>PROCEDURE TITLE</u>	<u>REV.</u>	<u>DATE</u>
<u>Emergency Response Facilities</u>			
IP-1040	Habitability of the Emergency Response Facilities and Assembly Areas	16	11/97
IP-1041	Personnel Monitoring for EOF, TSC, OSC and Control Room Personnel	VOID	N/A
<u>Accountability and Evacuation</u>			
IP-1050	Accountability	25	12/00
IP-1053	Evacuation of Site	12	10/99
IP-1054	Search and Rescue Teams	10	12/97
<u>Non-Radiological Emergencies</u>			
IP-1052	Hazardous Waste Emergency	7	07/97
IP-1055	Fire Emergency Response	14	03/00
IP-1056	Directing Fire Fighting Personnel in Controlled Area	VOID	N/A
IP-1057	Natural Phenomena Emergency	8	10/01
IP-1058	Earthquake Emergency	VOID	N/A
IP-1059	Air Raid Alert	7	05/01
<u>H.P. Release Surveys and Decontamination</u>			
IP-1060	Personnel Radiological Check and Decontamination	11	02/98
IP-1063	Vehicle/Equipment Radiological Check and Decontamination	11	11/97
<u>Emergency Equipment and Maintenance</u>			
IP-1070	Periodic Inventory of Emergency Plan Equipment	31	02/01
IP-1076	Roster Notification Methods	25	08/01
IP-1080	Conduct of Emergency Exercises and Drills	VOID	N/A
IP-1085	Maintenance of Emergency Preparedness at IP-3	VOID	N/A



CONTROLLED COPY #: 25

EMERGENCY PLAN PROCEDURES

PROCEDURE NO. IP-1057 REV. 8

TITLE: NATURAL PHENOMENA EMERGENCY

"This procedure has been extensively revised"

THIS PROCEDURE IS TSR

THIS PROCEDURE IS NOT TSR

WRITTEN BY: Dana Weaver 10/17/01
SIGNATURE/DATE

REVIEWED BY: Rebecca A Martin 10/17/01
SIGNATURE/DATE

APPROVED BY: MaryAnn Wilson 10/17/01
SIGNATURE/DATE

EFFECTIVE DATE: 10/18/01

PROCEDURE USE IS
REFERENCE

IP-1057

NATURAL PHENOMENA EMERGENCY

TABLE OF CONTENTS

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
1.0	Purpose	1
2.0	Responsibilities	1
3.0	References	1
4.0	Procedure	2
5.0	Attachments	
	5.1 Instructions in the use of Backup Communication Methods	

IP-1057

NATURAL PHENOMENA EMERGENCY

1.0 PURPOSE

This procedure specifies actions to be taken for any severe weather disturbance (i.e., earthquake, hurricane, tornado) which makes an emergency declaration necessary.

NOTE

It is not the intent of this procedure to substitute for radiological emergency procedures if the consequences of an earthquake, tornado, or hurricane create a radiological hazard rather, applicable procedures for that type of radiological emergency should be followed in addition to this procedure.

2.0 RESPONSIBILITIES

- 2.1 The Control Room (CR) Operators are responsible for making initial notifications to plant personnel and IP2 CR when severe weather conditions exist at IP3.
- 2.2 The CR Operators are responsible for making the appropriate emergency classification as per IC/EAL's, "Initiating Conditions and Emergency Action Levels" found in Volume II of the Emergency Plan.

3.0 REFERENCES

- 3.1 Volume II, IC/EAL's, "Initiating Conditions and Emergency Action Levels"
- 3.2 ONOP-S-1, "Seismic Monitoring Equipment Actuation"
- 3.3 OD-8, "Guidelines for Severe Weather"
- 3.4 Volume II, IP-2001, Emergency Director (ED), Plant Operations Manager (POM), Shift manager (SM) Procedure
- 3.5 IP-1003, "Obtaining Meteorological Data"
- 3.6 IP-1038, "Offsite Emergency Notifications"
- 3.7 IP-2602, "Development of a Recovery Action Plan"

4.0 PROCEDURE

NOTE

The steps in this procedure are not required to be performed in sequence.

4.1 RECEIVE severe weather warnings from any of the following sources:

- CR meteorological or seismic monitoring equipment;
- IP2 CR;
- Tone Alert Weather Radio;
- National Weather Service (Refer to IP-1003, "Obtaining Meteorological Data" for additional information and Volume II, Appendix B, "Emergency Offsite Telephone List".)

NOTE

The IP3 CR is equipped with alarm panels and recording devices associated with two SMA-2 Strong Motion Accelerographs located on the 46' and 99' elevations of the Vapor Containment Building (VC), three peak shock recorders located on the 46' elevation, and peak recording accelerographs installed on a Reactor Coolant Pump (RCP), a Steam Generator (SG), and the Pressurizer.

- 4.2 DECLARE an emergency classification when severe weather conditions meet the criteria listed in IC/EAL's, "Initiating Conditions and Emergency Action Levels" found in Volume II of the Emergency Plan.
- 4.3 INITIATE Emergency Plan as required by IP-2001, "Emergency Director (ED), Plant Operations Manager (POM), Shift manager (SM) Procedure" in Volume II of the Emergency Plan.
- 4.4 USE Attachment 5.1, "Instructions in the Use of Backup Communication Methods" when regular telephones are inoperable.
- 4.5 Request assistance for Entergy employees and/or their families, as necessary as referenced in IP-2602, "Development of a Recovery Action Plan".

5.0 ATTACHMENTS

- 5.1 Instructions in the Use of Backup Communication Methods

END OF TEXT

ATTACHMENT 5.1

INSTRUCTIONS IN THE USE OF BACKUP COMMUNICATION METHODS

1. CELLULAR TELEPHONES

The Emergency Plan vehicles (EP-1 and EP-2) have cellular telephone capability. These vehicles are used by the Offsite Monitoring/Site Perimeter Survey Teams during an emergency. The cellular phone handsets are stored in the OSC H.P. Locker#2. Keys to the vehicles and the H.P. Locker are located in the OSC Key Locker. The OSC Key Locker key can also be found in the CR Key Locker.

Some IP3 managers have cellular capability that can be used as needed.

2. MICROWAVE TELEPHONE LINKS

Microwave telephone links exist between the Indian Point site and New York City which are available for use any time. The microwave link is the (212) area code numbers available on the telephone consoles in the CR and the Emergency Operation Facility (EOF).

3. TELEPHONE LINKS

Telephone links exist between the IP3 CR and the Energy Control Center (ECC) in Marcy, New York (north of Utica). The ECC has telephone lines and radio capabilities to other facilities and sites. The ECC also maintains cellular telephones.

4. LOCAL GOVERNMENT RADIO (LGR)

The LGR can be used to contact offsite agencies if necessary. Pickup the push-to-talk handset, turn on the unit, adjust volume. Press the bar inside the handset to transmit. This radio is available in the CR, EOF, and the AEOF. Refer to IP-1038, "Offsite Emergency Notifications" for more information regarding the LGR.

5. IP2 RADIO FREQUENCY #1

The IP2 Radio Frequency #1 permits radio communication between the EOF, AEOF, Indian Point 2 and 3 Control Rooms, Offsite Monitoring Vehicles, TSC, OSC and Security.

6. SECURITY PLECTRON DEVICE

The Security radio frequency provides direct communication with the New York State Police so that information can get off site if other communications are lost.