November 7, 1990

Docket No. 50-296

Mr. Oliver D. Kingsley, Jr. Senior Vice President, Nuclear Power Tennessee Valley Authority EN 38A Lookout Place 1101 Market Street Chattanogga, Tennessee 37402-2801

Dear Mr. Kingsley:

SUBJECT: TECHNICAL SPECIFICATION PAGE CORRECTION - BROWNS FERRY, UNIT 3

Amendments 132, 128 and 103 of the Operating Licenses (OL) for Units 1, 2, and 3 were issued February 5, 1987 to incorporate the Radiological Effluent Technical Specifications (RETS). These amendments, along with other changes, replaced the original TS definition for Dose Equivalent Iodine (DE I-131) contained as a footnote on Page 3.6/4.6-8, with a new definition in Section I.0, "Definitions". Subsequently, Amendments 158, 154 and 129 were issued on November 18, 1988. These amendments involved TS changes to the definitions for modes of operation, core alterations and reactor conditions. However, page 3.6/4.6-8 for Unit 3, re-issued as part of Amendment 129, inadvertantly reinstated the DE I-131 note which had been deleted by amendment no. 103. Consequently, the NRC is hereby reissuing Page 3.6/4.6-8 for the Unit 3 TS in order to correct this administrative error and bring the TS into conformance with Amendment 103.

Sincerely,

Original signed by

Thierry M. Ross, Project Manager Project Directorate II-4 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Enclosures: 1. Effective page list 2. Unit 3 T.S. page 3.6/4.6-7 3. Unit 3 T.S. page 3.6/4.6-8

cc w/enclosures:
See next page

9011130092 901107 PDR ADOCK 050002

	9					
OFC	:PDII-4/LA	PDII-	:PDI1-4/PM	:PDII-4/DD	:PDII-4/D	
NAME	MKrebsMK	:DMokap	TROSS R	SBlack	:FHebdon	
DATE	11/6 /90	: \\ / \\ /90	: 11/7 /90	:11/7/90	11/7 /90	
OFF1C Docum	IAL RECORD COPY ent Name: BFN CO	RRECTION			DFOI	C A.A.
					111	°(i))*

Mr. Oliver D. Kingsley, Jr.

-2-

cc:

Mr. Marvin Runyon, Chairman Tennessee Valley Authority ET 12A 7A 400 West Summit Hill Drive Knoxville, Tennessee 37902

Mr. Edward G. Wallace Manager, Nuclear Licensing and Regulatory Affairs Tennessee Valley Authority 5N 157B Lookout Place Chattanooga, Tennessee 37402-2801

Mr. John B. Waters, Director Tennessee Valley Authority ET 12A 9A 400 West Summit Hill Drive Knoxville, Tennessee 37902

Mr. W. F. Willis Chief Operating Officer ET 12B 16B 400 West Summit Hill Drive Knoxville, Tennessee 37902

General Counsel Tennessee Valley Authority 400 West Summit Hill Drive ET 11B 33H Knoxville, Tennessee 37902

Mr. Dwight Nunn Vice President, Nuclear Projects Tennessee Valley Authority 6N 38A Lockout Place 1101 Market Street Chattanooga, Tennessee 37402-2801

Dr. Mark O. Medford Vice President, Nuclear Assurance, Licensing and Fuels Tennessee Valley Authority 6N 38A Lookout Place Chattanooga, Tennessee 37402-2801 Mr. O. J. Zeringue, Site Director Browns Ferry Nuclear Plant Tennessee Valley Authority P. O. Box 2000 Decatur, Alabama 35602

Mr. P. Carier, Site Licensing Manager Prowns Ferry Nuclear Plant Tennessee Valley Authority P. C. Box 2000 Decatur, Alabama 35602

Mr. L. W. Myers, Plant Manager Browns Ferry Nuclear Plant Tennessee Valley Authority P. O. Box 2000 Decatur, Alabama 35602

Chairman, Limestone County Commission P. O. Box 188 Athens, Alabama 35611

Claude Earl Fox, M.D. State Health Officer State Department of Public Health State Office Building Montgomery, Alabama 36130

Regional Administrator, Region II U.S. Nuclear Regulatory Commission 101 Marietta Street, N.W. Atlanta, Georgia 30323

Mr. Charles Patterson Senior Resident Inspector Browns Ferry Nuclear Plant U.S. Nuclear Regulatory Commission Route 12, Box 637 Athens, Alabama 35611

Tennessee Valley Authority Rockville Office 11921 Rockville Pike Suite 402 Rockville, Maryland 20852 UNIT 3 EFFECTIVE PAGE LIST

REMOVE

•

INSERT

3.6/4.6-7	3.6/4.6-7*
3.6/4.6-8	3.6/4.6-8

*Denotes overleaf or spillover page.

3.6/4.6 PRIMARY SYSTEM BOUNDARY

LIMITING CONDITIONS FOR OPERATION

3.6.B. <u>Coolant Chemistry</u>

SURVEILLANCE REQUIREMENTS

4.6.B. <u>Coolant Chemistry</u>

The additional coolant liquid samples shall be taken at 4-hour intervals for 48 hours, or until a stable iodine concentration below the limiting value $(3.2 \ \mu ci/gm)$ is established. However, at least 3 consecutive samples shall be taken in all cases. An isotopic analysis shall be performed for each sample, and quantitative measurements made to determine the dose equivalent I-131 concentration. If the total iodine activity of the sample is below 0.032 µci/gm, an isotopic analysis to determine equivalent I-131 is not required.

- 4. When the reactor is not pressurized, except during the STARTUP CONDITION, the reactor water shall be maintained within the following limits.
 - a. Conductivity -10 µmho/cm at 25°C
 - b. Chloride 0.5 ppm

AMENDMENT NO. 128

3.6/4.6 PRIMARY SYS BOUNDARY

LIMITING CONDITIONS FOR OPERATION

3.6.B. <u>Coolant Chemistry</u>

F

5. Whenever the reactor is critical, the limits on activity concentrations in the reactor coolant shall not exceed the equilibrium value of $3.2 \mu c/gm$ of dose equivalent I-131.

> This limit may be exceeded following power transients for a maximum of 48 hours. During this activity transient the iodine concentrations shall not exceed the equilibrium values by a factor of more than 10 whenever the reactor is critical. The reactor shall not be operated more than 5 percent of its yearly power operation under this exception for the equilibrium activity limits. If the iodine concentration in the coolant exceeds the equilibrium limit by a factor of ten, the reactor shall be shut down, and the steam line isolation valves shall be closed immediately.

SURVEILLANCE REQUIREMENTS

4.6.B. Coolant Chemistry

Distribution

۰.

Docket File NRC PDR Local PDR BFN Reading File S. Varga G. Lainas F. Hebdon S. Black M. Krebs D. Moran T. Ross	14-E-4 14-H-3
UGC R Wilcon	Pogion II
E Jordan	MNRR_2202
G Hill	P1_37
P. Kellogg	Region II
C. Patterson	Region II
Wanda Jones	MNBB-7103
J. Calvo	11-F-22
W. Jones	MNBB-7103
ACRS(10)	
GPA/PA	2-G-5
OC/LFMB	MNBB-9112