

Robert G. Byram
Senior Vice President and
Chief Nuclear Officer

PPL Susquehanna, LLC
Two North Ninth Street
Allentown, PA 18101-1179
Tel. 610.774.7502 Fax 610.774.6092
rgbyram@pplweb.com



OCT 26 2001

U. S. Nuclear Regulatory Commission
Attn.: Document Control Desk
Mail Stop OP1-17
Washington, DC 20555

**SUSQUEHANNA STEAM ELECTRIC STATION
SUPPLEMENTAL INFORMATION RELATED TO
PROPOSED AMENDMENT NO. 242 TO OPERATING
LICENSE NPF-14 TO REVISE THE UNIT 1 REACTOR
PRESSURE VESSEL (RPV) MATERIAL
SURVEILLANCE PROGRAM
PLA-5386**

Docket No. 50-387

- References:*
1. PLA-5366, R. G. Byram (PPL) to USNRC Document Control Desk, "Proposed Amendment No. 242 to Operating License NPF-14 to Revise the Unit 1 Reactor Pressure Vessel (RPV) Material Surveillance Program", dated September 19, 2001.
 2. Letter, W. R. Butler (USNRC) to Harold W. Keiser (PPL), "Technical Specification Changes Reflecting Revision to Material Surveillance Schedule and, Lead Factor Ratio (TAC No. 68664)", dated October 31, 1988.

In accordance with the provisions of 10CFR50.90, PPL Susquehanna, LLC (PPL) submitted a request (Reference 1) for an amendment to Susquehanna SES Unit 1 operating license NPF-14. Approval of the proposed amendment would revise the Unit 1 RPV material surveillance program to defer the withdrawal of the second surveillance capsule for one operating cycle to coincide with the Unit 1 Cycle 13 refueling outage planned for the Spring of 2004.

Reference 1 identified that the current surveillance capsule withdrawal schedule is in accordance with ASTM-E-185-73. The purpose of this letter is to identify that the current surveillance capsule withdrawal schedule is in accordance with ASTM-E-185-82, not ASTM-E-185-73. Reference 2, which approved a change to the SSES Unit 1 Technical Specifications, specifically identifies that the PPL surveillance capsule withdrawal schedule is in accordance with ASTM-E-185-82. The No Significant Hazards Consideration Determination provided in Reference 1 is unaffected by this correction.


A047

OCT 26 2001

In accordance with 10 CFR 50.91(b)(1), PPL is sending a copy of this letter to the Pennsylvania Department of Environmental Protection.

Should you have any questions, please contact Mr. Michael H. Crowthers at (610) 774-7766.

Sincerely,



R. G. Byram
Attachment

copy: NRC Region I
Mr. S. L. Hansell, NRC Sr. Resident Inspector
Mr. R. G. Schaaf, NRC Project Manager
Mr. David J. Allard, PA DEP

**BEFORE THE
UNITED STATES NUCLEAR REGULATORY COMMISSION**

In the Matter of

:

PPL Susquehanna, LLC:

Docket No. 50-387


**SUPPLEMENT TO PROPOSED AMENDMENT NO. 242 TO LICENSE NPF-14:
REVISION TO THE REACTOR PRESSURE VESSEL
MATERIAL SURVEILLANCE PROGRAM
UNIT NO. 1**


Licensee, PPL Susquehanna, LLC, hereby files Proposed Amendment No. 242 in support of a revision to its Facility Operating License No. NPF-14 dated July 17, 1982.

This amendment involves a revision to the Susquehanna SES Final Safety Analysis Report.

PPL Susquehanna, LLC

By:






R. G. Byram

Sr. Vice-President and Chief Nuclear Officer

Sworn to and subscribed before me
this 26th day of October, 2001.


Notary Public

Notarial Seal
Nancy J. Lannen, Notary Public
Allentown, Lehigh County
My Commission Expires June 14, 2004