

MAR 21 1975

Docket No. 50-324
DPR-62

Carolina Power & Light Company
ATTN: J. A. Jones
Executive Vice President
336 Fayetteville Street
Raleigh, North Carolina 27602

Dear Mr. Jones:

We have reviewed the emergency request received by telephone from your Mr. Black on March 21, 1975, regarding a change in Appendix B to Facility Operating License No. DPR-62 Section 2.5.2g. We find that the enclosed change to Section 2.5.2g provides clarification of the intent of this technical specification. We intend to include this technical specification change with other requested changes included in your letter dated March 11, 1975.

This letter confirms the oral authorization for the technical specification change as defined in the enclosed copy of Technical Specification 2.5.2g, page 2-13 of Appendix B to Operating License No. DPR-62.

Sincerely,

Original signed by
Walter Butler

for
R. C. DeYoung, Assistant Director
for Light Water Reactors Group 1
Division of Reactor Licensing

Enclosure:
Revised Technical Specification
2.5.2g

cc: Richard E. Jones, Esq.
Carolina Power & Light Company
336 Fayetteville Street
Raleigh, North Carolina 27602

Distribution

NRC PDR
Local PDR
Docket File
LWR 1-2 File
V. Moore
R. DeYoung
F. Schroeder
A. Kenneke
R. Klecker
M. Williams
ELD
IE (3)
R. Powell
M. Maigret (w/extra cys)
V. Benaroya
G. Dicker
H. Thornburg, OI&E

LWR 1 BC's
ACRS (14)

bcc: J.R. Buchanan,
ORNL
T.B. Abernathy,
DTIE

OFFICE	L:LWR 1-2	L:LWR 1-2	AD/LWR 1		
SURNAME	RPowell/red	WButler	RCDeYoung		
DATE	7791 3/2/75	3/2/75	3/2/75		

MAR 21 1975

cc: George F. Trowbridge, Esq.
Shaw, Pittman, Potts & Trowbridge
910 17th Street, N. W.
Washington, D. C. 20006

John J. Burney, Jr., Esq.
Burney, Burney, Sperry & Barefoot
110 North Fifth Avenue
P. O. Box 1741
Wilmington, North Carolina 28401

Ms. Janet Godwin, President
Project Environment
202 Bedford Road East
Wilmington, North Carolina 28401

OFFICE ➤						
SURNAME ➤						
DATE ➤						

ENCLOSURE

REVISED TECHNICAL SPECIFICATION 2.5.2g
March 21, 1975

- 2.5.2g The drywell shall be purged through the standby gas treatment system, or released to the environment at a rate in conformance with Specifications 2.5.2.c(2) and (3) based on a containment sample analysis as defined in Table 3.5-2.