

MAR 19 1976

DISTRIBUTION

Docket File
NRC PR
Local PDR
KRGoller/TJCarter
RAPurple
SMSheppard
CMTrammell
Attorney, OELD
OI&E (2)
BJones (4)
ACRS (16)
BScharf (12)
CMiles, OPA
DEisehnut
VStello

Docket No. 50-324

Carolina Power & Light Company
ATTN: Mr. J. A. Jones
Executive Vice President
336 Fayetteville Street
Raleigh, North Carolina 27602

Gentlemen:

The Commission has requested the Federal Register to publish the enclosed Notice of Proposed Issuance of Amendment to Facility License No. DPR-62 for the Brunswick Steam Electric Plant, Unit No. 2. This notice relates to your request of December 19, 1975, to operate the Brunswick Steam Electric Plant, Unit No. 2, by lowering the main steam line low pressure isolation setpoint from 850 psig to 825 psig.

Sincerely,
Original signed by

C.M. Trammell

for | Robert A. Purple, Chief
Operating Reactors Branch #1
Division of Operating Reactors

Enclosure:
Federal Register Notice

cc w/enclosure:
See next page

bcc: T. B. Abernathy, DTIE
J. R. Buchanan, NSIC

OFFICE >	ORB#1 <i>CM Trammell</i>	OELD <i>AWM</i>	ORB#1 <i>CM Trammell</i>			
SURNAME >	CMTrammell:lb		RAPurple			
DATE >	<i>2/25/76</i>	<i>3/18/76</i>	<i>3/19/76</i>			

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-324

CAROLINA POWER & LIGHT COMPANY

NOTICE OF PROPOSED ISSUANCE OF AMENDMENT
TO FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. DPR-62 issued to Carolina Power & Light Company (the licensee) for operation of the Brunswick Steam Electric Plant, Unit No. 2 (the facility), located in Brunswick County, North Carolina.

The amendment would lower the main steam line low pressure isolation setpoint from 850 psig to 825 psig, in accordance with the licensee's application for Amendment dated December 19, 1975.

Prior to issuance of the proposed license amendment, the Commission will have made the findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations.

By _____ the licensee may file a request for a hearing and any person whose interest may be affected by this proceeding may file a request for a hearing in the form of a petition for leave to intervene with respect to the issuance of this amendment to the subject facility operating license. Petitions for leave to intervene must be filed under oath or affirmation in accordance with the provisions of Section 2.714 of 10 CFR Part 2 of the Commission's regulations. A petition for leave to intervene must set forth the interest of the petitioner in the proceeding,

OFFICE ➤						
SURNAME ➤						
DATE ➤						

how that interest may be affected by the results of the proceeding, and the petitioner's contentions with respect to the proposed licensing action. Such petitions must be filed in accordance with the provisions of this FEDERAL REGISTER Notice and Section 2.714, and must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Docketing and Service Section, by the above date. A copy of the petition and/or request for a hearing should be sent to the Executive Legal Director, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555 and to Richard E. Jones, Esquire, Carolina Power & Light Company, 336 Fayetteville Street, Raleigh, North Carolina 27602, attorney for the licensee.

A petition for leave to intervene must be accompanied by a supporting affidavit which identifies the specific aspect or aspects of the proceeding as to which intervention is desired and specifies with particularity the facts on which the petitioner relies as to both his interest and his contentions with regard to each aspect on which intervention is requested. Petitions stating contentions relating only to matters outside the Commission's jurisdiction will be denied.

All petitions will be acted upon by the Commission or licensing board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel. Timely petitions will be considered to determine whether a hearing should be noticed or another appropriate order issued regarding the disposition of the petitions.

OFFICE >						
SURNAME >						
DATE >						

In the event that a hearing is held and a person is permitted to intervene, he becomes a party to the proceeding and has a right to participate fully in the conduct of the hearing. For example, he may present evidence and examine and cross-examine witnesses.

For further details with respect to this action, see the application for amendment dated December 19, 1975, which is available for public inspection at the Commission's Public Document Room, 1717 H Street, NW., Washington, D.C. and at the Southport-Brunswick County Library, 109 W. Moore Street, Southport, North Carolina 28461. The license amendment and Safety Evaluation, when issued, may be inspected at the above locations and a copy may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this 19th day of March 1976.

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by

Charles M. Trammell, Acting Chief
Operating Reactors Branch #1
Division of Operating Reactors

OFFICE >	ORB#1	OELD	ORB#1		
SURNAME >	C. Trammell		RAPurple		
DATE >	2/23/76	2/ /76	2/ /76		