

July 6, 1982

Docket Nos. 50-325
and 50-324

Mr. J. A. Jones
Senior Executive Vice President
Carolina Power & Light Company
P. O. Box 1551
Raleigh, North Carolina 27602

Dear Mr. Jones:

Re: Brunswick Steam Electric Plant, Units 1 and 2

This confirms our telephone authorization given July 3, 1982 for the addition of license conditions for the Brunswick Steam Electric Plant, Units 1 and 2 licenses as requested by telecopy on July 3, 1982. Facility Operating License Nos. DPR-71 and DPR-62 are amended as of July 3, 1982 by adding the enclosed clauses to the respective licenses.

Copies of the final license amendments, our evaluation, and the Federal Register Notice for this change will be sent to you when completed.

Sincerely,

ORIGINAL SIGNED BY

Thomas M. Novak, Assistant Director
for Operating Reactors
Division of Licensing

Enclosure:
As stated

cc w/encl:
See Next Page

DISTRIBUTION:	Docket Files	NRC PDR	LPDR	ORB#2 Rdg	D. Eisenhut
	J. Heltemes	S. Norris	J. Van Vliet	OELD	I&E-1
	NSIC	Gray	ACRS-10		

8208030072 820706
PDR ADOCK 05000324
P PDR

OFFICE	DL:ORB#2 SNorris	DL:ORB#2 JVanVliet	DL:ORB#2 DVassat	DL:ORB#2 TNovak		
SURNAME	7/6/82	7/6/82	7/6/82	7/6/82		
DATE						

Mr. J. A. Jones

cc:

Richard E. Jones, Esquire
Carolina Power & Light Company
336 Fayetteville Street
Raleigh, North Carolina 27602

George F. Trowbridge, Esquire
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 1057
Southport, North Carolina 28461

Southport - Brunswick County Library
109 W. Moore Street
Southport, North Carolina 28461

Mr. Charles R. Dietz
Plant Manager
P. O. Box 458
Southport, North Carolina 28461

James P. O'Reilly
Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 1
DPR-71 OPERATING LICENSE CONDITION

Operating License Paragraph 2.C.(2)(b)

Effective July 1, 1982, through July 8, 1982, Action statement "a" of Technical Specification 3.8.1.1 shall read as follows:

ACTION:

- a. With either one offsite circuit or one diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirements 4.8.1.1.1.a and 4.8.1.1.2.a.4 within two hours and at least once per 12 hours thereafter; restore at least two offsite circuits and four diesel generators to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 2
DPR-62 OPERATING LICENSE CONDITION

Operating License Paragraph 2.c.(2)(c)

Effective July 1, 1982, through July 8, 1982, Action statement "a" of Technical Specification 3.8.1.1 shall read as follows:

ACTION:

- a. With either one offsite circuit or one diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirements 4.8.1.1.1.a and 4.8.1.1.2.a.4 within two hours and at least once per 12 hours thereafter; restore at least two offsite circuits and four diesel generators to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.