

December 10, 2001  
NG-01-1367

Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station 0-P1-17  
Washington, D.C. 20555-0001


Subject: Duane Arnold Energy Center  
Docket No: 50-331  
Op. License No: DPR-49  
Cancellation of Licensee Event Report #2001-002-00  
Reference: Licensee Event Report #2001-002-00  
File: A-120

Dear Sirs:

On July 20, 2001, Nuclear Management Company, LLC (NMC) submitted the referenced Licensee Event Report (LER) pursuant to 10CFR50.73(a)(2)(v)(D). LER 2001-002-00 reported an event involving the High Pressure Coolant Injection (HPCI) system. The HPCI system was declared inoperable when the flow-indicating controller was found reading an erroneous value due to air entrapment in the instrument line. Subsequent to the submittal of the LER, a calculation was completed that concluded the HPCI system was operable in its as-found condition. Therefore, NMC is formally withdrawing LER 331/2001-002-00.

Should you have any questions regarding this cancellation, please contact John Karrick at 319-851-7901. There are no new commitments being made in this letter.

Sincerely,



Rob Anderson,  
Plant Manager - Nuclear

cc: Mr. James Dyer  
Regional Administrator, Region III  
U. S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, IL 60532

NRC Resident Inspector - DAEC

DOCU

IE22