

NOV 15 2001



LRN-01-0380

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT  
SALEM GENERATING STATION UNIT 1  
DOCKET NO. 50-272**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 1 Technical Specifications, the operating statistics for **October 2001** are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "D. F. Garchow", written over the typed name.

D. F. Garchow  
Vice President - Operations

RAR  
Attachments

C Distribution

JE24

**INDEX**

<b><u>SECTION</u></b>	<b><u>NUMBER OF PAGES</u></b>
Operating Data Report .....	1
Monthly Operating Summary .....	1

DOCKET NO.: 50-272  
 UNIT: Salem 1  
 DATE: 11/09/01  
 COMPLETED BY: F. Todd  
 TELEPHONE: (856) 339-1316

Reporting Period October 2001

**OPERATING DATA REPORT**

**Design Electrical Rating (MWe-Net)**  
**Maximum Dependable Capacity (MWe-Net)**  
  
**No. of hours reactor was critical**  
**No. of hours generator was on line (service hours)**  
**Unit reserve shutdown hours**  
**Net Electrical Energy (MWH)**

<b>1130</b>		
<b>1096</b>		
<b>Month</b>	<b>Year-to-date</b>	<b>Cumulative</b>
<b>390</b>	<b>5755</b>	<b>132764</b>
<b>374</b>	<b>5652</b>	<b>128231</b>
<b>0</b>	<b>0</b>	<b>0</b>
<b>403169</b>	<b>6095184</b>	<b>129669159</b>

**UNIT SHUTDOWNS**

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT
3	10/1/01 - 10/16/01	F	371 hrs.	A	4	Loss of #2 Station Power Transformer

**(1) Reason**

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

DOCKET NO.: 50-272  
UNIT: Salem 1  
DATE: 11/09/01  
COMPLETED BY: R. Ritzman  
TELEPHONE: (856) 339-1445

### **Summary Of Monthly Operating Experience**

- Salem 1 began the month in a forced shutdown.
- Salem 1 went online on October 16 and returned to 100% power on October 17.
- At the end of the month, Salem 1 completed 15 days of consecutive on-line operation.