www.exeloncorp.com

Exelon Generation 4300 Winfield Road Warrenville, IL 60555

RS-01-291

December 17, 2001

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555 - 0001

> Quad Cities Nuclear Power Station, Units 1 and 2 Facility Operating License Nos. DPR-29 and DPR-30 NRC Docket Nos. 50-254 and 50-265

- Subject: Supplemental Information Supporting Technical Specification changes to Reactor Protection System Instrumentation Scram Discharge Volume Water Level - High
- Reference: Letter from Timothy J.Tulon, Exelon Generation Company (EGC), LLC, to U. S. NRC, "Request for Technical Specifications Change Reactor Protection System Instrumentation Scram Discharge Volume Water Level High," dated June 22, 2001

In the above reference, Exelon Generation Company (EGC), LLC, submitted a Technical Specification Amendment request for the Quad Cities Nuclear Power Station (QCNPS), Units 1 and 2. The proposed change supports a planned upgrade to the scram discharge volume level instrumentation from Fluid Components International thermal switches to Magnetrol float switches.

In a telephone conference call on November 29, 2001, Mr. A. R. Haeger (EGC) and Mr. S. N. Bailey (U.S. NRC) discussed a request for additional information regarding the process used to determine the allowable value for the scram discharge volume. The attachment to this letter provides the requested information.

Exelon

Nuclear

Rec'd Instan

December 17, 2001 U. S. Nuclear Regulatory Commission Page 2

If you have any questions concerning this letter, please contact D. L. Cecchett at (630) 657-2826.

Respectfully,

ich R. Jury

K. R. Jury Director - Licensing Midwest Regional Operating Group

- Attachment: Supplemental Information Supporting Technical Specification change for Reactor Protection System Instrumentation Scram Discharge Volume Water Level – High
- cc: Regional Administrator NRC Region III NRC Senior Resident Inspector – Quad Cities Nuclear Power Station Office of Nuclear Facility Safety – Illinois Department of Nuclear Safety

STATE OF ILLINOIS)	
COUNTY OF DUPAGE)	
IN THE MATTER OF)	
EXELON GENERATION COMPANY, LLC)	Docket Numbers
QUAD CITIES NUCLEAR POWER STATION, UNITS 1 AND 2)	50-254 AND 50-265

SUBJECT: Additional Information Supporting Technical Specification Changes to Reactor Pressure Vessel Level Instrumentation Surveillance Frequencies and Allowable Values Requirements

AFFIDAVIT

÷

I affirm that the content of this transmittal is true and correct to the best of my knowledge, information and belief.

K. R. Jury Director - Licensing Midwest Regional Operating Group

Subscribed and sworn to before me, a Notary Public in and

for the State above named, this ____/ // ___ day of

December , 2001.

Amuse R. Brighy



Attachment

Additional Information Supporting Technical Specification Changes to Reactor Pressure Vessel Level Instrumentation Surveillance Frequencies and Allowable Values Requirements

Question:

Justify the applicability of Electric Power Research Institute (EPRI) TR-103335, "Guidelines for Instrument Calibration Extension / Reduction Programs," to the reactor vessel level Instrumentation for which the surveillance interval is being extended.

Response:

This modification provides a safety-related analog trip configuration that will perform the current function of the installed six Yarway reactor water level switches. The safety-related analog trip configurations which will take the place of these Yarway switches consist of Rosemount transmitters and Rosemount Model 710DU trip units. To be consistent with other Rosemount brand Reactor Protection System (RPS) trip units already installed at Quad Cities Nuclear Power Station (QCNPS) a 92-day calibration frequency has been selected for the trip units.

As part of the QCNPS Allowed Outage Time/Surveillance Test Interval (AOT/STI) Technical Specification upgrade, an evaluation of the instrument drift for Rosemount Model 710DU trip units was performed. This evaluation is consistent with EPRI TR-103335, "Guidelines for Instrument Calibration Extension / Reduction Programs." Since the new trip units are the same model as previously evaluated and the calibration methods will remain unchanged, the results of those evaluations are directly applicable to the new installations.