

Operated by Nuclear Management Company, LLC



December 14, 2001

10 CFR 50, Appendix E Section V

US Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT Docket No. 50-263 License No. DPR-22

Emergency Plan Implementing Procedures

Furnished with this letter is a revision to the Monticello Nuclear Generating Plant Emergency Plan Implementing Procedures. The following procedure is revised:

Procedure

Procedure Title

Revision 4

A.2-419

Containment Atmosphere Sample Obtained From Reactor Sample Station

Please post changes in your copy of the Monticello Nuclear Generating Plant Emergency Plan Implementing Procedures. Superseded procedures should be destroyed. This revision does not reduce the effectiveness of the Monticello Nuclear Generating Plant Emergency Plan.

Please contact Douglas A. Neve, Project Manager – Licensing (Interim), at 763-295-1353 if you require further information.

Jeffery S. Forbes Site Vice President Monticello Nuclear Generating Plant

c: Regional Administrator – III, NRC (w/ two copies of enclosure) NRR Project Manager, NRC (w/o enclosure) Sr Resident Inspector, NRC (w/o enclosure, EPIP dist. by Monticello Document Control) Minnesota Dept. of Commerce (w/o enclosure) J. E. Silberg (w/o enclosure) T. LaPlant (w/o enclosure) G. Holthaus (w/o enclosure) Document Control (w/o enclosure) File (w/o enclosure)

2045

2807 West County Road 75 • Monticello, Minnesota 55362-9637 Telephone: 763.295.5151 • Fax: 763.295.1454

	North Monticel Document	ern Stat lo Nucle Control	es Power Comp ar Generating Distribution	bany g Plant n System			26-Nov-2001 Page 1
	Docum Contr	ent Dist olled Do	ribution Man: cuments - Cu	fest rrent			
Name: US NRC Title: ATTN: DOCUMENT CON Company: MONTI LICENSING Location: ATTN:DOUG NEVE MNGP-SAB/2ND FLOOR 11 COPIES OF USAR	ROL DESK	Mani Distri Hc	fest Number: bution Type: lder Number: ID Number:	2001-871 I 195 YYYY09	Date	e Mailed:	
Distribution Type: OPERATIONS	MANUALS						
Document Type	Document Number		Revision	Title			
NOTE: The documents listed belo	w are new or revised	l 					
1060 A.2-419		4	CONTAINMENT	ATMOSPHERE	SAMPLE OBTAINED	FROM	

CONTAINMENT ATMOSPHERE SAMPLE OBTAINED FROM REACTOR SAMPLE STATION

ι

 (\cdot)

1

MONTICELLO NUCLEAR GENERATING PLANT TITLE: CONTAINMENT ATMOSPHERE SAMPLE OBTAINED FROM REACTOR SAMPLE Revision 4 STATION Daga

A.2-419

Page 1 of 6

EMERGENCY PLAN IMPLEMENTING PROCEDURE - TABLE OF CONTENTS

tSECTIO	<u>N</u>	PAGE
1.0	PURPOSE	2
2.0	APPLICABILITY	2
3.0	ORGANIZATION AND RESPONSIBILITIES	2
4.0	DISCUSSION	3
5.0	PRECAUTIONS	3
6.0	INSTRUCTIONS	4
	6.1 Pre-Sample Preparations	4
	6.2 Obtain Sample	5
	6.3 Sample Transport and Analysis	5
7.0	FIGURES	6

Prepared By: Stimutian,	Reviewed By:	some
ALARA Coord Review By:	Sumiles	
OC Review Req'd: YES	OC Meeting Number: 339	3 = Date: 1/15/01
Approved By:	septon .	Date: ////v,
FO This revision incorporates Volume F Mem	DR ADMINISTRATIVE USE ONLY	
3087 (DOCUMENT CHANGE, HOLD, AN	ID COMMENT FORM) incorporated:	01-4255
Resp Supv: GTRNG ARMS: A.2-419 Doc Ty	Assoc Ref: A.2 /pe: 1060 Admin Initials:	SR: N Freq: 1) yrs/

.____

MONTICE	ELLO NUCLEAR GENERATING PLANT	A 2 410	1
TITLE:	CONTAINMENT ATMOSPHERE SAMPLE	A.2-4 9	ł
	OBTAINED FROM REACTOR SAMPLE	Revision 4	
,	STATION		I
		Page 2 of 6	

1.0 PURPOSE

The purpose of this procedure is to provide instructions and precautions for collection and handling of containment atmosphere gas samples during and following an emergency.

2.0 <u>APPLICABILITY</u>

- 2.1 An emergency (Alert or higher classification) has been declared at Monticello Nuclear Generating Plant which involves abnormal or elevated radiological conditions which preclude use of normal sampling methods.
- 2.2 The REC/CSL has requested analysis of containment gas samples.
- 2.3 The PASS (Post Accident Sampling System) is inoperable. OR Exposure Rates do not limit sampling from this location.

3.0 ORGANIZATION AND RESPONSIBILITIES

- 3.1 The <u>Radiological Emergency Coordinator (REC)</u> is responsible for:
 - 3.1.1 Overall direction of the Radiation Protection and Chemistry Group activities.
- 3.2 The <u>Chemistry Section Leader (CSL)</u> is responsible for:
 - 3.2.1 Overall coordination for PASS sampling and analysis.
 - 3.2.2 Overall coordination of Chemistry Group activities.
- 3.3 The <u>Chemistry Coordinator</u> is responsible for:
 - 3.3.1 Coordination of Chemistry Group activities in the Chemistry Lab.
- 3.4 The <u>Radiation Protection Specialist (Chem)</u> are responsible for:
 - 3.4.1 Implementation of this procedure.
 - 3.4.2 Performing post-accident sampling using the PASS system.

MONTICE	ELLO NUCLEAR GENERATING PLANT	A.2-419
TITLE:	CONTAINMENT ATMOSPHERE SAMPLE	2
	OBTAINED FROM REACTOR SAMPLE	Revision 4
	STATION	
	р	Page 3 of 6

行

4.0 DISCUSSION

The containment atmosphere sample station is located near the Drywell personnel access hatch on the 935 elevation of the Reactor Building. Sample valves and equipment are located behind the 02 monitoring control Panel C-250. In the event of a Reactor accident, access to this area may be restricted to very specific travel routes due to very high radiation dose rates. Consult with Radiation Protection personnel to determine the safest route.

4.1 CEquipment and Reagents for side to the second se 이상 밤에서는 것같 것 같아. 주관

north and the

5 - 15cc off-gas vials with septums 4.1.1

4.1.2 1'- 0-1 cc gas syringe with needle

neo nor reol^o el cer 4.1.3 1 = 1 ft length of surgical tubing

the set the country of the 1 - shielded sample holder 4.1.4

公司的代码,在1998年,1

5.0 PRECAUTIONS

- Kolo segneti se el cuito Exposures of sampling and analysis personnel SHALL be in accordance with 5.1A.2-401 (EMERGENCY EXPOSURE CONTROL).
- 5.2 Exposures to all personnel due to sampling and analysis operations should be maintained AS LOW AS REASONABLY ACHIEVABLE STechniques such as temporary shielding, remote handling, and sample dilution prior to analysis should be considered to reduce exposure to personnel-Play and a grade
- 5.3 When actual or potential radiation levels so warrant, high range portable survey instruments, and self-reading dosimeters (ALNOR) SHALL be provided to sampling and analysis personnel. THE MELTINE MELTING 1584

Appropriate extremity dosimeters should be provided and worn when handling 5.4 samples which themselves represent high level radiation sources.

5.5 Two person teams should be used to obtain samples from the 935 Reactor Sample Station when possible.

Local Leak Rate Test (LLRT) for the containment atmosphere sample station is 5.6 conducted at a maximum pressure of 2 psig. The use of the containment atmosphere sample station at any pressure higher than 2 psig SHALL be evaluated by Plant Engineering, Chemistry and Plant Management.

MONTICE	ELLO NUCLEAR GENERATING PLANT	
TITLE:	CONTAINMENT ATMOSPHERE SAMPLE	A.2-419
	OBTAINED FROM REACTOR SAMPLE	Revision 4
	STATION	Page 4 of 6

6.0 **INSTRUCTIONS**

6.1 Pre-Sample Preparations

6.1.1 Obtain next sequential sample number from Form 5790-408-01 (EMERGENCY CHEMISTRY SAMPLE LOG) IAW A.2-408 (SAMPLE COORDINATION DURING EMERGENCIES).

CAUTION

The following steps *SHALL* only be performed when specified by the Emergency Director or Emergency Manager.

- 6.1.2 Inform the Control Room of your intentions to collect a Containment Atmosphere sample from the Drywell on the 935 elevation in the Reactor Building.
- 6.1.3 <u>IF</u> a Group 2 isolation signal exists and cannot be reset, <u>THEN</u> have operations perform the following actions to open sample isolation valves CV-3307 and CV-3308 and sample return isolation valves CV-3313 and CV-3314.
 - A. Place the handswitches at Panel C-26 for the following valves to close:
 - 1. CV-3307 CV-3311 CV-3313 SV-4081

2.	CV-3308	CV-3312	CV-3314	SV-4082
----	---------	---------	---------	---------

- B. Isolate the Drywell CAM by closing DWV-33, DWV-34 and DWV-38.
- C. At Panel C-26, lift and tape the external wires at the following terminals:
 - 1. Q530/1
 - 2. Q528/1
- D. At Panel C-26, jumper the following terminals:

1. Q530/X1 - Q530/1

- 2. Q528/X1 Q528/1
 - E. Open sample isolation valves CV-3307, CV-3308 and sample return valves CV-3313 and CV-3314 by placing the handswitches to AUTO/OPEN.

MONTICE	LLO NU	CLEAR GENERATING PLANT	A.2-419
TITLE:	CON OB	TAINMENT ATMOSPHERE SAMPLE	Revision 4
		STATION	Page 5 of 6
·	6.1.4	Evacuate a 15 cc off-gas vial and label as Vi	al No. 1
	6.1.5	Proceed to the containment atmosphere san the Chemistry Coordinator.	ple area as directed by
6.2	Obțai	n Sample	
	6.2.1	Connect the surgical tubing to TSV-1 and TS	V-3.
. . .	6.2.2	Open valves DWV-18-2 and DWV-18-5.	
i i i i i i i i i i i i i i i i i i i	6.2.3	Open TSV-1 and TSV-3.	
	6.2.4	Check open TSV-2.	· · ·
	6.2.5	Start the sample pump P-89 and adjust samp on flow indicator FIC-3410.	ble flow to 2 cfm as read
	6.2.6	Adjust sample flow to 30 SCFH by throttling 1	rsv-2.
<u>IOTE</u> : Pul iso	rge samp lated pric	ble line adequately. This is especially import or to sampling.	ant if the line has been
	v ≆6.2.7 ÷	Insert the syringe needle into the surgical tub gas.	ing and withdraw 1 cc of
	6.2.8	Inject the gas into the evacuated 15 cc off-gat the sample.	s vial. Note the time of
	6.2.9	Stop pump P-89.	
	6.2.10	Fully open TSV-2 then close TSV-1 and TSV-	3.
	6.2.11	Shut DWV-18-2 and DWV-18-5.	
6.3	Sampl	e Transport and Analysis	
	6.3.1	Place the 15 cc off-gas vial in the shielded sar to the Chemistry Hot Lab.	mple holder and proceed
	6.3.2	Perform analysis as required IAW Operations (CONTAINMENT ATMOSPHERE RADIOCHE	Manual A.2-420 MICAL ANALYSIS).
	6.3.3	Place the shielded sample holder in the shield rear of the lab after analysis.	ed storage area at the

6.3.4 <u>IF</u> sample is to be sent off-site for analysis, <u>THEN</u> notify the REC for instructions.

l/plr

MONTICE	ELLO NUCLEAR GENERATING PLANT	A 2-419
TITLE:	CONTAINMENT ATMOSPHERE SAMPLE OBTAINED FROM REACTOR SAMPLE	Revision 4
	STATION	Page 6 of 6

7.0 <u>FIGURES</u>

None